



Jack Long, Director
Southeast District Office

Florida Department of Environmental Protection

Southeast District Office
400 N. Congress Avenue, Suite 200
West Palm Beach, FL 33401
(561) 681-6600

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Mimi A. Drew
Secretary

December 10, 2010

ELECTRONIC CORRESPONDENCE

In the Matter of an
Application for Permit by:

Mr. John F. Hayford, P.E. Executive Director
Okeechobee Utility Authority
100 Southwest 5th Avenue
Okeechobee, FL 34974-4221
Email: jhayford@ouafl.com

Permit Number FLA013884
PA File Number FLA013884-005-DW3P
Okeechobee County
Everglades Elementary School WWTF/Permit Renewal

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number FLA013884 to operate the Everglades Elementary School Wastewater Treatment Facility, issued under Chapter 403, Florida Statutes.

Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the Permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, Florida Statutes, within fourteen days of receipt of notice. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request an extension of the time for filing a petition for an administrative hearing. The request must be filed (received by the Clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first. Section 120.60(3), Florida Statutes, however, also allows that any person who has asked the Department for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for an extension of time within fourteen days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

Mr. John F. Hayford, P.E.
Okeechobee Utility Authority
Permit Number FLA013884

A petition that disputes the material facts on which the Department's action is based must contain the following information, as indicated in Rule 28-106.201, Florida Administrative Code:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, and telephone number of the petitioner; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the determination;
- (c) A statement of when and how the petitioner received notice of the Department's decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the Department's proposed action;
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the Department's proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's proposed action.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This permit action is final and effective on the date filed with the Clerk of the Department unless a petition (or request for an extension of time) is filed in accordance with the above. Upon the timely filing of a petition (or request for an extension of time), this permit will not be effective until further order of the Department.

Any party to this permit has the right to seek judicial review of the permit action under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when this permit action is filed with the Clerk of the Department.

Executed in West Palm Beach, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Linda A Brien, P.G.
Water Facilities Administrator
Southeast District

LAB/MWB/brk


CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that this NOTICE OF PERMIT and all copies were electronically sent before the close of business on **December 10, 2010** to the listed persons.

Mr. John F. Hayford, P.E.
Okeechobee Utility Authority
Permit Number FLA013884

FILING AND ACKNOWLEDGMENT

FILED, on this date, under section 120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

  12/10/10
[Clerk] [Date]

Electronic Copies furnished to:

Susan G. Martelli, P.E., Metzger & Willard, Inc., smartelli@metzgerwillard.com
Jamie Gamotea, Okeechobee Utility Authority, jgamotea@ouafl.com
William Thiel, DEP, PSL, William.Thiel@dep.state.fl.us
Jeffery Christian, DEP, PSL, Jeff.Christian@dep.state.fl.us



Jack Long, Director
Southeast District Office

Florida Department of Environmental Protection

Southeast District Office
400 N. Congress Avenue, Suite 200
West Palm Beach, FL 33401 Southeast District Office
(561) 681-6600

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Mimi A. Drew
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:

Okeechobee Utility Authority

RESPONSIBLE OFFICIAL:

Mr. John F Hayford, Director
Okeechobee Utility Authority
100 SW 5th Avenue
Okeechobee, Florida 34974-4221
(863) 763-9460

PERMIT NUMBER:

FLA013884-005

FILE NUMBER:

FLA013884-005-DW3P

ISSUANCE DATE:

December 10, 2010

EXPIRATION DATE:

December 9, 2015

FACILITY:

Everglades Elementary School WWTF
560 SE 40th Ave.
Okeechobee, FL 34974
Okeechobee County
Latitude: 27°14' 16.12" N Longitude: 80°47' 17.19" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. The above named Permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

WASTEWATER TREATMENT:

The treatment facility consists of a package treatment unit, manufactured by Davco (now U.S. Filter), including the following: Duplex Lift Station; Aerated 5000-gallons Surge Tank with flow splitter box; Three Aeration Basins - 5000 gallons each; Two blowers for aeration, approximately 79 cfm each; One 3000-gallons clarifier; One 2347-gallons Aerobic Digester; One 887-gallons Chlorine Contact Tank; and Two Dual-Media Gravity Filters with Backwash Holding Tank. REUSE: Land Application: Treated effluent, meeting the effluent limitations set forth in this permit, is released to an existing 0.015 mgd three month average daily flow (TMADF) permitted capacity absorption field system (R-001), consisting of 3 sections with a combined area of 23,328S.F. The WWTF is located approximately at latitude 27° 14' 15.85" N, longitude 80° 47' 17.18" W.

REUSE OR DISPOSAL:

Land Application R-001: An existing .015 million gallons per day (mgd) annual average daily flow (AADF) permitted capacity absorption field system. R-001 is a reuse system which consists of Absorption Fields having a capacity of .015 mgd located approximately at latitude 27°14' 17" N, longitude 80°47' 17" W.

IN ACCORDANCE WITH: The limitations, monitoring requirements, and other conditions set forth in this cover sheet and Part I through Part IX on pages 1 through 17 of this permit.

PERMITTEE: Okeechobee Utility Authority
 FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Reuse and Land Application Systems

- During the period beginning on the issuance date and lasting through the expiration date of this permit, the Permittee is authorized to direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the Permittee as specified below and reported in accordance with condition I.**Error! Reference source not found.. 7.-9.**

			Reclaimed Water Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Monitoring Frequency	Sample Type	Monitoring Site Number	Notes
Flow (When magnetic flow meter used)	mgd	Max Max	0.015 Report	Annual Average Monthly Average	5 Days/Week	Meter	FLW-01	See I. Error! Reference source not found..3
Flow (When elapse time meter used)	mgd	Max Max	0.015 Report	Annual Average Monthly Average	5 Days/Week	Meter	FLW-02	See I. Error! Reference source not found..3
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Monthly	Grab	EFF-01	See I. Error! Reference source not found..5.
Solids, Total Suspended	mg/L	Max	10.0	Single Sample	Monthly	Grab	EFF-01	See I. Error! Reference source not found..5.
Coliform, Fecal	#/100mL	Max Max Max	200 200 800	Annual Average Monthly Geometric Mean Single Sample	Monthly	Grab	EFF-01	See I. Error! Reference source not found..5. and 6.

PERMITTEE: Okeechobee Utility Authority
 FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

			Reclaimed Water Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Monitoring Frequency	Sample Type	Monitoring Site Number	Notes
pH	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	5 Days/Week	Grab	EFF-01	See I. Error! Reference source not found..5.
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	5 Days/Week	Grab	EFF-01	See I. Error! Reference source not found..4. and 5.
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	Monthly	Grab	EFF-01	See I. Error! Reference source not found..5.
Phosphorus, Total (as P)	mg/L	Max	Report	Single Sample	Monthly	Grab	EFF-01	See I. Error! Reference source not found..5.
Nitrogen, Total	mg/L	Max	Report	Single Sample	Monthly	Grab	EFF-01	See I. Error! Reference source not found..5.

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I.**Error! Reference source not found..Error! Reference source not found..** and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-01	Magnetic flow meter on the influent force main to the equalization tank
FLW-02	The lift station pump elapsed run time on the influent pump station to the equalization tank
EFF-01	Chlorine Contact Tank effluent

3. A magnetic meter shall be utilized to measure flow and shall be calibrated at least once every 12 months. When the magnetic meter is not operating properly, the Permittee may use the lift station pump elapsed run time counter and the pumping rate shall be calibrated at least once every 12 months. *[62-601.200(17) and .500(6)] [62-4.070(1) and (3)]*
4. Total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. *[62-610.525(5) and 62-600.440(5)(b)]*
5. Grab samples are to be collected during peak hydraulic conditions. *[62-4.070(1) and (3)]*
6. The effluent limitation for the monthly geometric mean for fecal coliform is only applicable if 10 or more values are reported. If fewer than 10 values are reported, the monthly geometric mean shall be calculated and reported on the Discharge Monitoring Report. *[62-600.440(4)(c)]*

PERMITTEE: Okeechobee Utility Authority
 FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

B. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the Permittee as specified below and reported in accordance with condition I.B.7.-9.:

			Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow (When magnetic flow meter used)	mgd	Max Max	0.015 Report	Annual Average Monthly Average	5 Days/Week	Meter	FLW-01	See I. B.3., 4 and 10.
Flow (When elapse time meter used)	mgd	Max Max	0.015 Report	Annual Average Monthly Average	5 Days/Week	Meter	FLW-02	See I. B.3., 4 and 10.
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	Monthly	Calculated	OTH-01	
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	Monthly	Grab	INF-01	See I. B. 3. and 5.
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	Monthly	Grab	INF-01	See I. B. 3. and 5.

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I.B 1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-01	Magnetic flow meter on the influent force main to the equalization tank
FLW-02	The lift station pump elapsed run time on the influent pump station to the equalization tank
OTH-01	Calculated Percent Capacity (TMADF/Permitted Capacity x 100)
INF-01	Aerobic Surge Tank Influent

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
4. A magnetic meter shall be utilized to measure flow and shall be calibrated at least once every 12 months. When the magnetic meter is not operating properly, the Permittee may use the lift station pump elapsed run time counter and the pumping rate shall be calibrated at least once every 12 months. [62-601.200(17) and .500(6)] [62-4.070(1) and (3)]
5. The sample collection, analytical test methods and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate. The list of Department established analytical methods, and corresponding MDLs (method detection limits) and PQLs (practical quantitation limits), which is titled "FAC 62-4 MDL/PQL Table (April 26, 2006)" is available at <http://www.dep.state.fl.us/labs/library/index.htm>. The MDLs and PQLs as described in this list shall constitute the minimum acceptable MDL/PQL values and the Department shall not accept results for which the laboratory's MDLs or PQLs are greater than those described above unless alternate MDLs and/or PQLs have been specifically approved by the Department for this permit. Any method included in the list may be used for reporting as long as it meets the following requirements:
- The laboratory's reported MDL and PQL values for the particular method must be equal or less than the corresponding method values specified in the Department's approved MDL and PQL list;
 - The laboratory reported MDL for the specific parameter is less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Parameters that are listed as "report only" in the permit shall use methods that provide an MDL, which is equal to or less than the applicable water quality criteria stated in 62-302, F.A.C.; and
 - If the MDLs for all methods available in the approved list are above the stated permit limit or applicable water quality criteria for that parameter, then the method with the lowest stated MDL shall be used.

When the analytical results are below method detection or practical quantitation limits, the Permittee shall report the actual laboratory MDL and/or PQL values for the analyses that were performed following the instructions on the applicable discharge monitoring report.

Where necessary, the Permittee may request approval of alternate methods or for alternative MDLs or PQLs for any approved analytical method. Approval of alternate laboratory MDLs or PQLs are not necessary if the laboratory reported MDLs and PQLs are less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Approval of an analytical method not included in the above-referenced list is not necessary if the analytical method is approved in accordance with 40 CFR 136 or deemed acceptable by the Department. [62-4.246, 62-160]

6. The Permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
7. Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the Permittee shall continue to monitor and report in accordance with previously

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

effective permit requirements, if any. During the period of operation authorized by this permit, the Permittee shall complete and submit to the Department Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type on DMR	Monitoring Period	Due Date
Monthly or Toxicity	first day of month - last day of month	28 th day of following month
Quarterly	January 1 - March 31 April 1 - June 30 July 1 - September 30 October 1 - December 31	April 28 July 28 October 28 January 28
Semiannual	January 1 - June 30 July 1 - December 30	July 28 January 28
Annual	January 1 - December 31	January 28

DMRs shall be submitted for each required monitoring period including months of no discharge. The Permittee shall make copies of the attached DMR form(s) and shall submit the completed DMR form(s) to the Department's Southeast District Office at the address specified in Permit Condition I. **Error! Reference source not found. Error! Reference source not found.** by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18)][62-601.300(1),(2), and (3)]

8. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's Southeast District Office at the address specified below:

Florida Department of Environmental Protection
Southeast District/Port St. Lucie Office
1801 East Hillmoor Drive, Suite C-204
Port St. Lucie, Florida 34952
Phone Number: (772) 398 – 2806
FAX Number: (772) 398 – 2815
(All FAX copies and e-mails shall be followed by original copies.)
[62-620.305]

9. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. [62-620.305]
10. No additional or expanded flows from existing or new customers will be allowed without the written approval by the Department.

II. RESIDUALS MANAGEMENT REQUIREMENTS

1. The method of residuals use or disposal by this facility is transport to Okeechobee Utility Authority WWTF or disposal in a solid waste landfill. Transportation of the residuals to an alternative residuals management facility does not require a permit modification. However, use of an alternative residuals management facility requires the submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the residuals. [62-620,320(6),62-640.880(1)]
2. The Permittee shall be responsible for proper treatment, management, use, and land application or disposal of its residuals. [62-640.300(5)]
3. The Permittee shall not be held responsible for treatment, management, use, or land application violations that occur after its residuals have been accepted by a permitted residuals management facility with which the source

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

facility has an agreement in accordance with Rule 62-640.880(1)(c), F.A.C., for further treatment, management, use or land application. [62-640.300(5)]

4. Disposal of residuals, septage, and other solids in a solid waste disposal facility, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with the requirements of Chapter 62-701, F.A.C. [62-640.100(6)(k)3&4]
5. The Permittee shall be responsible for proper treatment, management, use, and land application of residuals accepted from source facilities. [62-640.880(1)(a)]
6. The Permittee shall enter into a written agreement with each source facility that it intends to receive residuals from. The agreement shall address the quality and quantity of the residuals accepted by the Permittee. The agreement shall include a statement, signed by the Permittee, as to the availability of sufficient permitted capacity to receive the residuals from the source facility, and indicating that the Permittee will continue to operate in compliance with the requirements of its permit. The agreement shall also address responsibility during transport of residuals between the facilities. The Permittee shall submit a copy of this agreement to the Department's Southeast District Office at least 30 days before transporting residuals from the source facility to the Permittee. [62-640.880(1)(c)]
7. The Permittee shall keep hauling records to track the transport of residuals between facilities. The hauling records shall contain the following information:

Source Facility	Residuals Management Facility or Treatment Facility
1. Date and Time Shipped	1. Date and Time Received
2. Amount of Residuals Shipped	2. Amount of Residuals Received
3. Degree of Treatment (if applicable)	3. Name and ID Number of Source Facility
4. Name and ID Number of Residuals	4. Signature of Hauler
Management Facility or Treatment Facility	5. Signature of Responsible Party at Residuals Management Facility or Treatment Facility
5. Signature of Responsible Party at Source Facility	
6. Signature of Hauler and Name of Hauling Firm	

These records shall be kept for five years and shall be made available for inspection upon request by the Department. A copy of the hauling records information maintained by the source facility shall be provided upon delivery of the residuals to the residuals management facility or treatment facility. The Permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of residuals leaving the source facility and arriving at the residuals management facility or treatment facility.

[62-640.880(4)]

8. Storage of residuals or other solids at the permitted facility shall require prior written notification to the Department. [62-640.300(4)]

III. GROUND WATER REQUIREMENTS

1. The Permittee shall give at least 72-hours notice to the Department's Southeast District Office, prior to the installation of any monitoring wells. [62-620.320(6)]
2. Prior to construction of ground water monitoring wells, a soil boring shall be made at each monitoring well location in order to properly determine the well depth and screen interval. [62-520.900(3)]
3. Within 30 days after installation of a monitoring well, the Permittee shall submit to the Department's Southeast District Office detailed information on the well's location and construction on the attached DEP Form(s) 62-520.900(3), Monitoring Well Completion Report. [62-532.410 and 62-520.900(3)]

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

4. All piezometers and monitoring wells not part of the approved ground water monitoring plan are to be plugged and abandoned in accordance with Rule 62-532.500(4), F.A.C., unless future use is intended. [62-532.500(4)]
5. For the Part IV land application system(s), all ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge for Land Application Site R-001 shall extend horizontally to the facility's property line and vertically to the base of the surficial aquifer. [62-520.200(27)] [62-520.200(10), and 62-520.465]
6. During the period of operation authorized by this permit, the Permittee shall continue to sample ground water at the monitoring wells identified in Permit Conditions III.7. and III.9., below in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-520.600, F.A.C. [62-520.600] [62-610.510]
7. The following monitoring well shall be sampled for Reuse System R-001.

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Latitude			Longitude			Depth (Feet)	Aquifer Monitored	New or Existing
		°	'	"	°	'	"			
MWC-1	COMPLIANCE/NW corner of the absorption field system, formerly MWC-1N	27	14	17	80	47	18	n/a	Surficial	Existing
MWC-2	COMPLIANCE/SE corner of the absorption field system, formerly MWC-1S	27	14	16	80	47	16	n/a	Surficial	Existing

MWC = Compliance; MWP = Piezometer

[62-520.600] [62-610.510]

PERMITTEE: Okeechobee Utility Authority
 FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

8. The following parameters shall be analyzed for each monitoring well identified in Permit Condition III.9:

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Water Level Relative to NGVD	Report	ft	In Situ	Semi-Annually; twice per year
Nitrogen, Nitrate, Total (as N)	10	mg/L	Grab	Semi-Annually; twice per year
Solids, Total Dissolved (TDS)	500	mg/L	Grab	Semi-Annually; twice per year
Coliform, Fecal	4	#/100mL	Grab	Semi-Annually; twice per year
pH	6.5-8.5	s.u.	In Situ	Semi-Annually; twice per year
Phosphorus, Total (as P)	Report	mg/L	Grab	Semi-Annually; twice per year
Nitrogen, Total	Report	mg/L	Grab	Semi-Annually; twice per year
Specific Conductance	Report	umhos/cm	Grab	Semi-Annually; twice per year

[62-520.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-601.300(6)] [62-520.310(5)]

9. The following parameters shall be analyzed monthly for a minimum of 12 months from the issue date of this permit in each monitoring well identified in Permit Condition III.7.:

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Nitrogen, Nitrate, Total (as N)	10	mg/L	Grab	Monthly
Water Level Relative to NGVD	Report	ft	In Situ	Monthly

The Okeechobee Utility Authority will produce a Report of the findings of this monitoring following 12 months. There will be an evaluation of the results to determine whether additional monthly monitoring is stopped or addition testing is required. A permit revision may be required by the Department to modify the permit to implement the recommendation of the report after the Department's acceptance. *[62-520.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-601.300(6)] [62-520.310(5)]*

10. Water levels shall be recorded before evacuating each well for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NAVD allowable) at a precision of plus or minus 0.01 foot. *[62-520.600(11)(c)] [62-610.510(3)(b)]*
11. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples. *[62-160.210] [62-601.700(5)]*

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

12. Analyses shall be conducted on unfiltered samples, unless filtered samples have been approved by the Department's Southeast District Office as being more representative of ground water conditions. [62-520.310(5)]
13. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10) in accordance with Permit Condition I. **Error! Reference source not found. Error! Reference source not found.** [62-520.600(11)(b)] [62-601.300(3), 62.601.700, and Figure 3 of 62-601] [62-620.610(18)]
14. If any monitoring well becomes damaged or inoperable, the Permittee shall notify the Department's Southeast District Office immediately and a detailed written report shall follow within seven days. The written report shall detail what problem has occurred and remedial measures that have been taken to prevent recurrence. All monitoring well design and replacement shall be approved by the Department's Southeast District Office prior to installation. [62-520.600] [62-620.320(6)]

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

A. Part IV Absorption Field System(s)

1. Advisory signs shall be posted around the site boundaries to designate the nature of the project area. [62-610.518]
2. The Permittee may allow public access to the absorption field sites. [62-610.518]
3. The absorption field shall be operated to preclude saturated conditions from developing at the ground surface. [62-610.500(2)]
4. The maximum annual average loading rate to the Absorption Fields shall be limited to 1 inch per day (as applied to the entire bottom area of the absorption field trenches or spreading areas). [62-610.523(3)]
5. The reuse system has three subsurface absorption fields which have a total square foot area of 23,328. The loading is light and significantly below 1 inch per day. This permit will initiate priority for which absorption fields to be used. The northernmost field is allowed to be used only when the other absorption fields are overloaded. The remaining two absorption fields (southernmost) will typically be loaded and rested in 7 day cycles. [62-610.523(4)]
6. Overflows from absorption fields or from emergency discharge facilities on storage ponds shall be reported as abnormal events in accordance with Permit Condition IX.20. [62-610.800(9)]

V. OPERATION AND MAINTENANCE REQUIREMENTS

A. Staffing Requirements

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of a(n) operator(s) certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class D facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class D or higher operator for 3 visits/week on nonconsecutive days for a total of 1 1/2 hours/week. The lead/chief operator must be a Class D operator, or higher.

2. An operator meeting the lead/chief operator class for the treatment plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. Daily checks of the plant shall be performed by the Permittee or his representative or agent 5 days per week. [62-699.311(1) and (2)]

B. Capacity Analysis Report and Operation and Maintenance Performance Report Requirements

1. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(5)]
2. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1)]

C. Recordkeeping Requirements

1. The Permittee shall maintain the following records and make them available for inspection on the site of the permitted facility.
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current permit;
 - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
 - g. A copy of any required record drawings;
 - h. Copies of the licenses of the current certified operators; and
 - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and license number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities, including any preventive maintenance or repairs made or requested; results of tests performed and samples taken, unless documented on a laboratory sheet; and notation of any notification or reporting completed in accordance with Rule 62-602.650(3), F.A.C. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed.

[62-620.350, 62-602.650]

VI. SCHEDULES

1. Okeechobee Utility Authority at Everglades Elementary School WWTF shall obtain a collection systems permit for connection to a regional WWTF no later than 90 days of availability. The connection shall be completed within 180 days following permit issuance. A connection shall be deemed "available" if the regional utility has adequate treatment/disposal capacity and is located within one-fourth mile of the WWTF as measured and accessed via existing easements or rights-of-way.
2. If the Permittee wishes to continue operation of this wastewater facility after the expiration date of this permit, the Permittee shall submit an application for renewal no later than one-hundred and eighty days (180) prior to the expiration date of this permit. Application shall be made using the appropriate forms listed in Rule 62-620.910, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C. [62-620.335(1) and (2)]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

1. This facility is not required to have a pretreatment program at this time. *[62-625.500]*

VIII. OTHER SPECIFIC CONDITIONS

1. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the Permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. *[62-600.410(8) and 62-640.400(6)]*
2. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. *[62-604.130(3)]*
3. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. *[62-604.550] [62-620.610(20)]*
4. The operating authority of a collection/transmission system and the Permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health and safety problems.

[62-604.130(5)]

5. The treatment facility, storage ponds for Part II systems, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. *[62-610.518(1) and 62-600.400(2)(b)]*
6. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. *[62-701.300(1)(a)]*
7. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. *[62-620.310(4)]*
8. The Permittee shall provide verbal notice to the Department's Southeast District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, wastewater residuals (sludge), or reclaimed water. The Permittee shall immediately implement measures

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

appropriate to control the entry of contaminants, and shall detail these measures to the Department's Southeast District Office in a written report within 7 days of the sinkhole discovery. [62-620.320(6)]

9. The Permittee shall provide adequate notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2)]

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications, or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
5. This permit does not relieve the Permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the Permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The Permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5)]
6. If the Permittee wishes to continue an activity regulated by this permit after its expiration date, the Permittee shall apply for and obtain a new permit. [62-620.610(6)]
7. The Permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the Permittee to achieve compliance with the

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7)]

8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8)]
9. The Permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the Permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

10. In accepting this permit, the Permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. [62-620.610(10)]
11. When requested by the Department, the Permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The Permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the Permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. [62-620.610(11)]
12. Unless specifically stated otherwise in Department rules, the Permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the Permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. [62-620.610(12)]
13. The Permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. [62-620.610(13)]
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The Permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. [62-620.610(14)]
15. The Permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. [62-620.610(15)]

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

16. The Permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16)]
17. The Permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The Permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.[62-620.610(17)]
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-601, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the Permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
 - e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
 - f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.[62-620.610(18)]
19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(19)]
20. The Permittee shall report to the Department's Southeast District Branch Office any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the Permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

- a. The following shall be included as information which must be reported within 24 hours under this condition:
 - (1) Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - (4) Any unauthorized discharge to surface or ground waters.
- b. Oral reports as required by this subsection shall be provided as follows:
 - (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4. that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the Permittee becomes aware of the discharge. The Permittee, to the extent known, shall provide the following information to the State Warning Point:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of Permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.
 - (2) Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department's Southeast District Branch Office within 24 hours from the time the Permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department's Southeast District Branch Office shall waive the written report.

[62-620.610(20)]

21. The Permittee shall report all instances of noncompliance not reported under Permit Conditions IX.17., IX.18., or IX.19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20. of this permit. [62-620.610(21)]

22. Bypass Provisions.

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
- b. Bypass is prohibited, and the Department may take enforcement action against a Permittee for bypass, unless the Permittee affirmatively demonstrates that:
 - (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (3) The Permittee submitted notices as required under Permit Condition IX.22.b. of this permit.
- c. If the Permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The Permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX.20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass,

PERMITTEE: Okeechobee Utility Authority
FACILITY: Everglades Elementary School

PERMIT NUMBER: FLA013884

including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.

- d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the Permittee demonstrates that it will meet the three conditions listed in Permit Condition IX.22.a.1. through 3. of this permit.
- e. A Permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX.22.a. through c. of this permit.

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the Permittee.
 - (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
 - (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the Permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The Permittee submitted notice of the upset as required in Permit Condition IX.20. of this permit; and
 - (4) The Permittee complied with any remedial measures required under Permit Condition IX.5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the Permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

Executed in West Palm Beach, Florida.

STATE OF FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION



Linda A. Brien, P.G.
Water Facilities Administrator
Southeast District

LAB/MWB/brk

Attachment(s):
Discharge Monitoring Report

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Florida Department of Environmental Protection Southeast District / Port St. Lucie Office / 1801 South East Hillmoor Drive, Suite C-204 Port St. Lucie, Florida 34952

PERMITTEE NAME:	Okeechobee Utility Authority	PERMIT NUMBER:	FLA013884-005-DW3P	REPORT FREQUENCY:	Monthly
MAILING ADDRESS:	100 SW 5th Avenue Okeechobee, Florida 34974-4221	LIMIT:	Final	PROGRAM:	Domestic
		CLASS SIZE:	N/A		
FACILITY:	Everglades Elementary School WWTF	MONITORING GROUP NUMBER:	R-001		
LOCATION:	560 SE 40 th Ave. Okeechobee, FL 34974	MONITORING GROUP DESCRIPTION	Reuse land application with influent		
COUNTY:	Okeechobee	RE-SUBMITTED DMR: ☐	NO DISCHARGE FROM SITE: ☐		
OFFICE:	Southeast District Branch	MONITORING PERIOD	From: _____ To: _____		

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow (When magnetic flow meter used)	Sample Measurement										
PARM Code 50050 1 Mon. Site No. FLW-01	Permit Requirement	0.015 (An. Avg.)		mgd						5 Days/Week	Meter
Flow (When magnetic flow meter used)	Sample Measurement										
PARM Code 50050 P Mon. Site No. FLW-01	Permit Requirement	Report (Mo. Avg.)		mgd						5 Days/Week	Meter
Flow (When elapse time meter used)	Sample Measurement										
PARM Code 50050 Q Mon. Site No. FLW-01	Permit Requirement	0.015 (An. Avg.)		mgd						5 Days/Week	Meter
Flow (When elapse time meter used)	Sample Measurement										
PARM Code 50050 R Mon. Site No. FLW-01	Permit Requirement	Report (Mo. Avg.)		mgd						5 Days/Week	Meter
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon. Site No. EFF-01	Permit Requirement				20.0 (An. Avg.)		mg/L			Monthly	Grab
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 1 Mon. Site No. EFF-01	Permit Requirement					60.0 (Max.)	mg/L			Monthly	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-01	Permit Requirement					10.0 (Max.)	mg/L			Monthly	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Everglades Elementary School WWTF

MONITORING GROUP NUMBER: R-001

PERMIT NUMBER: FLA013884-005-DW3P

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Coliform, Fecal	Sample Measurement										
PARM Code 74055 Y Mon. Site No. EFF-01	Permit Requirement				200 (An. Avg.)			#/100mL		Monthly	Grab
Coliform, Fecal	Sample Measurement										
PARM Code 74055 1 Mon. Site No. EFF-01	Permit Requirement					800 (Max.)		#/100mL		Monthly	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-01	Permit Requirement				6.5 (Min.)	8.5 (Max.)		s.u.		5 Days/Week	Grab
Chlorine, Total Residual(For Disinfection)	Sample Measurement										
PARM Code 50060 1 Mon. Site No. EFF-01	Permit Requirement				0.5 (Min.)			mg/L		5 Days/Week	Grab
Nitrogen, Nitrate, Total (as N)	Sample Measurement										
PARM Code 00620 1 Mon. Site No. EFF-01	Permit Requirement					12.0 (Max.)		mg/L		Monthly	Grab
Phosphorus, Total (as P)	Sample Measurement										
PARM Code 00665 1 Mon. Site No. EFF-01	Permit Requirement					Report (Max.)		mg/L		Monthly	Grab
Nitrogen, Total	Sample Measurement										
PARM Code 00600 1 Mon. Site No. EFF-01	Permit Requirement					Report (Max.)		mg/L		Monthly	Grab
Flow (When magnetic flow meter used)	Sample Measurement										
PARM Code 50050 S Mon. Site No. FLW-01	Permit Requirement		0.015 (3-Mo. Avg.)	mgd						5 Days/Week	Meter
Flow (When elapse time meter used)	Sample Measurement										
PARM Code 50050 T Mon. Site No. FLW-02	Permit Requirement		0.015 (3-Mo. Avg.)	mgd						5 Days/Week	Meter
Percent Capacity, (TMADF/ Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 Q Mon. Site No. OTH-01	Permit Requirement					Report (Mo. Avg.)		percent		Monthly	Calculated
BOD, Carbonaceous 5 day, 20C(Influent)	Sample Measurement										
PARM Code 80082 G Mon. Site No. INF-01	Permit Requirement					Report (Max.)		mg/L		Monthly	Grab
Solids, Total Suspended(Influent)	Sample Measurement										
PARM Code 00530 G Mon. Site No. INF-01	Permit Requirement					Report (Max.)		mg/L		Monthly	Grab

DAILY SAMPLE RESULTS - PART B

Permit Number: FLA013884-005-DW3P

Facility: Everglades Elementary School WWTF

Monitoring Period From: _____ To: _____

	BOD, Carbonaceous 5 day, 20C mg/L	Chlorine, Total Residual (For Disinfection) mg/L	Coliform, Fecal #/100mL	Nitrogen, Nitrate, Total (as N) mg/L	Nitrogen, Total mg/L	Phosphorus, Total (as P) mg/L
Code	80082	50060	74055	00620	00600	00665
Mon. Site	EFF-01	EFF-01	EFF-01	EFF-01	EFF-01	EFF-01
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
Total						
Mo. Avg.						

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

DAILY SAMPLE RESULTS - PART B

Permit Number: FLA013884-005-DW3P

Facility: Everglades Elementary School WWTF

Monitoring Period From: _____ To: _____

	Solids, Total Suspended mg/L	pH s.u.	Flow (When magnetic flow meter used) mgd	Flow (When elapse time meter used) mgd	BOD, Carbonaceous 5 day, 20C (Influent) mg/L	Solids, Total Suspended (Influent) mg/L
Code	00530	00400	50050	50050	80082	00530
Mon. Site	EFF-01	EFF-01	FLW-01	FLW-02	INF-01	INF-01
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
Total						
Mo. Avg.						

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Everglades Elementary School WWTF
Permit Number: FLA013884-005-DW3P
County: Okeechobee

Monitoring Well ID:	MWC-1		
Well Type:	Compliance	Report Frequency:	Monthly
Description:	COMPLIANCE/NW corner of the absorption field system, formerly MWC-1N	Program:	Domestic
Re-submitted DMR:	☐		

Office: Southeast District Branch

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____
Time Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

[illegible]

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED	TELEPHONE NO	DATE

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Everglades Elementary School WWTF
 Permit Number: FLA013884-005-DW3P
 County: Okeechobee

Monitoring Well ID: MWC-2
 Well Type: Compliance
 Description: COMPLIANCE/SE
 corner of the
 absorption field
 system, formerly
 MWC-1S
 Re-submitted DMR: ☐

Report Frequency: Monthly
 Program: Domestic

Office: Southeast District Branch

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____
 Time Sample Obtained: _____

Was the well purged before sampling? ____ Yes ____ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Monthly				
Water Level Relative to NGVD	82545		Report	ft	In Situ	Monthly				

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Everglades Elementary School WWTF
 Permit Number: FLA013884-005-DW3P
 County: Okeechobee

Monitoring Well ID: MWC-1
 Well Type: Compliance
 Description: COMPLIANCE/NW
 corner of the
 absorption field
 system, formerly
 MWC-1N

Report Frequency: Semi-annually
 Program: Domestic

Office: Southeast District Branch

Re-submitted DMR: ☐

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Semi-annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Semi-annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Semi-annually				
Coliform, Fecal	74055		4	#/100mL	Grab	Semi-annually				
pH	00400		6.5-8.5	s.u.	In Situ	Semi-annually				
Phosphorus, Total (as P)	00665		Report	mg/L	Grab	Semi-annually				
Nitrogen, Total	00600		Report	mg/L	Grab	Semi-annually				
Specific Conductance	00095		Report	umhos/cm	Grab	Semi-annually				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Everglades Elementary School WWTF
 Permit Number: FLA013884-005-DW3P
 County: Okeechobee

Monitoring Well ID: MWC-2
 Well Type: Compliance
 Description: COMPLIANCE/SE
 corner of the
 absorption field
 system, formerly
 MWC-1S

Report Frequency: Semi-annually
 Program: Domestic

Office: Southeast District Branch

Re-submitted DMR: ☐

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Semi-annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Semi-annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Semi-annually				
Coliform, Fecal	74055		4	#/100mL	Grab	Semi-annually				
pH	00400		6.5-8.5	s.u.	In Situ	Semi-annually				
Phosphorus, Total (as P)	00665		Report	mg/L	Grab	Semi-annually				
Nitrogen, Total	00600		Report	mg/L	Grab	Semi-annually				
Specific Conductance	00095		Report	umhos/cm	Grab	Semi-annually				

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g. highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (mgd).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

**FACT SHEET
FOR
STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT**

December 9, 2010

PERMIT NUMBER: FLA013884

FACILITY NAME: Everglades Elementary School Wastewater Treatment Facility

FACILITY LOCATION: 560 SE 40th Ave., Okeechobee, FL 34974
Okeechobee County

NAME OF PERMITTEE: Okeechobee Utility Authority

PERMIT WRITER: Bruce Kay

1. SUMMARY OF APPLICATION

a. Chronology of Application

Application Number: FLA013884-005-DW3P

Application Submittal Date: April 13, 2010

b. Type of Facility

Domestic Wastewater Treatment Plant

Ownership Type: Public

SIC Code: 4952

c. Facility Capacity

Existing Permitted Capacity: 0.015 mgd Three Month Average Daily Flow

Proposed Increase in Permitted Capacity: 0.00 mgd Three Month Average Daily Flow

Proposed Total Permitted Capacity: 0.015 mgd Three Month Average Daily Flow

d. Description of Wastewater Treatment

The treatment facility consists of a package treatment unit, manufactured by Davco (now U.S. Filter), including the following: Duplex Lift Station; Aerated 5000-gallon Surge Tank with flow splitter box; Three Aeration Basins - 5000 gallons each; Two blowers for aeration, approximately 79 cfm each; One 3000-gallon clarifier; One 2347-gallon Aerobic Digester; One 887-gallon Chlorine Contact Tank; and Two Dual-Media Gravity Filters with Backwash Holding Tank.

e. Description of Effluent Disposal and Land Application Sites (as reported by applicant)

Land Application: Treated effluent meeting the effluent limitations set forth in this permit is released to an existing 0.015 mgd three month average daily flow (TMADF) permitted capacity absorption field system (R-001), consisting of three (3) sections with the combined area of 23,328 sq. ft. In the past, the effluent was directed to one of the three sections on a 7-day rotation cycle while the remaining section(s) is/are rested. The system is located approximately at latitude 27°14' 16" N, longitude 80° 47' 17" W.

The permit writer found elevated Nitrate values. The site has some private water wells north of the percolation ponds. The loading is light and significantly below 1 inch per day. This permit will initiate priority use in the southern absorption fields by only using the northernmost field when the other absorption fields are overloaded. The remaining two absorption fields (southernmost) will typically be loaded and rested in 7 day cycles.

2. BASIS FOR PERMIT LIMITATIONS AND MONITORING REQUIREMENTS

This facility is authorized to direct reclaimed water to Reuse System R-001, an Absorption Field system, based on the following:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow (When magnetic flow meter used)	mgd	Max	0.015	Annual Average	62-600.400(3)(b) & 62-610.810(5) FAC
		Max	Report	Monthly Average	62-600.400(3)(b) & 62-610.810(5) FAC
Flow (When elapse time meter used)	mgd	Max	0.015	Annual Average	62-600.400(3)(b) & 62-610.810(5) FAC
		Max	Report	Monthly Average	62-600.400(3)(b) & 62-610.810(5) FAC
BOD, Carbonaceous 5 day, 20C	mg/L	Max	20.0	Annual Average	62-610.525(5) & 62-600.740(1)(b)1.a. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
Solids, Total Suspended	mg/L	Max	10.0	Single Sample	62-610.525(5) & 62-600.440(5)(f)3. FAC
Coliform, Fecal	#/100mL	Max	200	Annual Average	62-610.510 & 62-600.440(4)(c)1 FAC
		Max	800	Single Sample	62-600.440(4)(c)4 FAC
pH	s.u.	Min	6.0	Single Sample	62-610.525(8)(a) & 62-550.320 FAC
		Max	8.5	Single Sample	62-610.525(8)(a) & 62-550.320 FAC
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	62-610.525(5) & 62-600.440(5)(b) FAC
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	62-600.740(1)(b)2.d. FAC
Phosphorus, Total (as P)	mg/L	Max	Report	Single Sample	62-4.070 FAC (BPJ)
Nitrogen, Total	mg/L	Max	Report	Single Sample	62-4.070 FAC (BPJ)

The former permit had flow limitations to R-001 of 0.015 mgd three-month average flow. The absorption beds actually are sized to handle more than the wastewater treatment plant permitted capacity. Therefore, the permit writer determined that 0.015 annual average daily flow (AADF) is more appropriate than the former flow limit of 0.015 mgd three month average daily flow to R-001. The flow limit to the wastewater treatment plant is the limiting flow value.

Other Limitations and Monitoring Requirements:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow (When magnetic flow meter used)	mgd	Max	0.015	Three Month Average	62-600.400(3)(b) FAC
Flow (When elapse time meter used)	mgd	Max	0.015	Three Month Average	62-600.400(3)(b) FAC
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	62-600.405(4) FAC
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	62-601.300(1) FAC
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	62-601.300(1) FAC
Monitoring Frequencies and Sample Types	-	-	-	All Parameters	62-601 FAC & 62-699 FAC and/or BPJ of permit writer
Sampling Locations	-	-	-	All Parameters	62-601, 62-610.412, 62-610.463(1), 62-610.568, 62-610.613 FAC and/or BPJ of permit writer

The Influent for Everglades Elementary WWTF comes from two sources. One is the New Everglades Elementary School located at 3725 SE 8th Street, Okeechobee, FL. This flow is considered seasonal and adds very little when school is out. The second influent addition is from the Okeechobee Argi-Civic Center located at 4601 Highway 710 E, Okeechobee, FL. The Agri-Civic Center flow is sporadic with various weekend events being its addition to the influent. No additional or expanded flows from existing or new customers will be allowed without the written approval by the Department.

3. DISCUSSION OF CHANGES TO PERMIT LIMITATIONS

The current wastewater permit for this facility FLA013884 expired on October 2, 2010. There are no changes to the current limits of this facility except as mentioned above.

4. RESIDUALS MANAGEMENT

The method of residuals use or disposal by this facility is transport to Okeechobee Utility Authority WWTF or disposal in a solid waste landfill.

5. GROUND WATER MONITORING REQUIREMENTS

Ground water monitoring requirements have been established in accordance with Chapters 62-520, 532, 601, 610, and 620, F.A.C. Additional Monthly Groundwater monitoring is being undertaken for 12 months to study process optimization which influences Nitrate concentration.

6. PERMIT SCHEDULES

Okeechobee Utility Authority at Everglades Elementary School WWTF shall obtain a collection system permit for connection to a regional WWTF no later than 90 days of availability. The connection shall be completed within 180 days following permit issuance. A connection shall be deemed "available" if the regional utility has adequate treatment/disposal capacity and is located within one-fourth mile of the WWTF as measured and accessed via existing easements or rights-of-way.

7. INDUSTRIAL PRETREATMENT REQUIREMENTS

At this time, the facility is not required to develop an approved industrial pretreatment program. However, the Department reserves the right to require an approved program if future conditions warrant.

8. REQUESTED VARIANCES OR ALTERNATIVES TO REQUIRED STANDARDS

No variances were requested for this facility.

9. THE ADMINISTRATIVE RECORD

The administrative record including application, permit, fact sheet, additional information is available for public inspection during normal business hours at the location specified in item 11. Copies will be provided at a minimal charge per page.

10. PROPOSED SCHEDULE FOR PERMIT ISSUANCE

Notice of Permit Issuance: December 9, 2010

11. DEP CONTACT

Additional information concerning the permit and proposed schedule for permit issuance may be obtained during normal business hours from:

Bruce Kay
Engineer II
Southeast District Office
400 N Congress Ave Suite 200
West Palm Beach, FL 33401-2913
Email: bruce.kay@dep.state.fl.us
Telephone No.: (561) 681-6695
Fax No.: (561) 681-6760