

## APPENDIX H. ORANGE CREEK BASIN ONSITE WASTEWATER TREATMENT SYSTEM NUTRIENT LOADING ANALYSIS

---

MARCH 13, 2006

*Jennifer Gihring, Florida Department of Environmental Protection*

### **Background**

The Total Maximum Daily Load (TMDL) documents prepared for the four impaired lakes in the Orange Creek Basin (Newnans, Orange, Lochloosa, and Wauberg) <sup>1</sup> identified onsite wastewater systems (septic tanks and package plants) as sources of nutrient loading. However, loading values from onsite wastewater systems were calculated differently among the four lakes. The Newnans and Orange Lake TMDLs estimated loading from failing septic tanks only. The Lake Wauberg TMDL estimated loading from all septic tanks, with a reduction factor applied to account for nutrient retention in the soil. Septic tank loading was not quantified in the Lake Lochloosa TMDL.

This analysis provides a consistent method for estimating nutrient loading from properly functioning and failing onsite wastewater treatment systems that contribute loading to lakes in this Basin. This information is provided to the Orange Creek Basin Basin Management Plan (BMAP) Working Group for their use in developing and prioritizing management actions. Various sources contribute nutrients to the four impaired lakes, and knowledge of the relative magnitude of these sources will help the Working Group make informed decisions regarding the type of corrective actions to be implemented.

The results of this analysis are expressed in terms of the Total Nitrogen (TN) loading per year that reaches the four impaired lakes through direct surface runoff and/or near-shore groundwater flow.

### **Approach**

The approach for this study is similar to the 2005 Marion County wastewater study<sup>2</sup>. Calculation of loading from onsite systems required determination of: 1) the total number and locations of septic tank and package plant systems in the basin; and 2) nutrient loads to lakes associated with each system.

### **Number and Location of Systems**

Land parcels with activities that require onsite wastewater treatment were identified through a GIS analysis. These included residential, commercial, and public use facilities. For unincorporated Alachua County, map layers derived from the County Property Appraiser's GIS database were used to identify such parcels. Information provided by Gainesville Regional Utilities and Marion County was used to identify parcels with septic tanks within their service areas. Information from Gainesville Regional Utilities (GRU) was applicable to the Newnans Lake Subbasin, while the Marion County information was applicable to Orange Lake.

---

<sup>1</sup> Baniukiewicz, A. 2004. Total Maximum Daily Loads for Lake Lochloosa; Wu, T.S. 2003. Nutrient Total Maximum Daily Load for Lake Wauberg Outlet; Gao, X. 2003. Nutrient Total Maximum Daily Load for Orange Lake; Gao, X. 2003. Draft Nutrient Total Maximum Daily Load for Newnans Lake.

<sup>2</sup> Kuphal, T. 2005. Quantification of Domestic Wastewater Discharge and Associated Nitrate Loading in Marion County, Florida. Marion County, FL, Planning Department.

Consistent with the 1995 St. Johns River Water Management District (SJRWMD) Nutrient Budget Report<sup>3</sup>, only those systems within 200 meters (m) of the lake shore or the lake's tributaries (e.g. connected wetland, stream, or canal system) were considered to contribute nutrients to the lake. Aerial photos (2005) were used to confirm the presence of structures associated with onsite wastewater systems in the 200m surface water drainage area.

At any given time, a portion of these systems are “failing” septic tanks. Although there are multiple ways in which a septic system can physically fail, for the purposes of this study failed septic tanks were considered to contribute 100 percent of their loading directly to a surface water, without soil retention. The TMDL documents consistently estimate the rate of septic tank failure at 5 percent. As such, the total number of septic tanks was split into “functioning” and “failing” at the rate of 95 percent and 5 percent, respectively. All calculated loading values applied a soil retention factor for the 95 percent of functioning systems and did not apply the soil retention factor for the 5 percent of failing systems.

Two package plants were identified inside the 200m drainage area: Brittany Estates (Newnans Lake subbasin) and Sportsmans Cove (Orange Lake subbasin). Table 1 contains the estimated total number of onsite systems in each subbasin.

**TABLE 1. NUMBER OF SEPTIC SYSTEMS WITHIN 200M DRAINAGE AREA OF EACH LAKE**

| Lake           | Total # Septic Systems | Estimated # Failing Systems (5 percent) | Package Plants   |
|----------------|------------------------|-----------------------------------------|------------------|
| Lake Lochloosa | 127                    | 6                                       | 0                |
| Newnans Lake   | 397                    | 20                                      | Brittany Estates |
| Orange Lake    | 204                    | 10                                      | Sportsmans Cove  |
| Lake Wauberg   | 26                     | 1                                       | 0                |
| <b>TOTAL</b>   | <b>754</b>             | <b>37</b>                               | <b>2</b>         |

### **Total Nitrogen Loading to Lakes**

The Total Nitrogen load from septic tanks was calculated with the following formula:

$$A \times 0.065 \times N \times 8.337 \times (1-S)$$

- A = Number of septic tank systems (including Homestead reduction as noted above)
- 0.065 = Average annual discharge in million gallons (65,000 gallons per system per year/1,000,000 gallons)
- N = Total Nitrogen (TN) concentration of septic tank effluent in milligrams per liter
- 8.337 = Conversion factor (milligrams per liter to pounds per million gallons)
- S = percentage of TN loading from the septic tank effluent retained in the soil

This calculation is similar to that used in the 2005 Marion County wastewater study, with two exceptions. First, TN loading was calculated using 30 milligrams per liter (mg/L) and 50 mg/L. The 30 mg/L value is consistent with the TMDL documents. 50 mg/L is consistent with upper-end estimates of TN concentrations in septic effluent, similar to values used in the Marion County study and best professional judgment of FL Department of Environmental Protection Watershed Assessment Staff (W. Magley). Second, because the Marion County study focused on loading to groundwater and not surface water, retention of Total Nitrogen in the soil was not incorporated into the loading calculations. To estimate the fraction of TN that reaches the surface water from septic tank effluent, a soil retention rate (S) was applied. Because the actual value for soil retention is unknown, TN loading was calculated with two soil retention values for

<sup>3</sup> Fulton, R. 1995. External Nutrient Budget and Trophic State Modeling for Lakes in the Orange Creek Basin. St. Johns River Water Management District Technical Publication SJ95-6.

comparison: 45 percent (1995 SJRWMD nutrient study) and 30 percent (P. Myers, Alachua Co. Health Dept.). These modifications allow for direct comparison with loading values from both the TMDLs and the Marion County wastewater study.

Total Nitrogen loading from the two package plants was also calculated. Table 17 of the Newnans Lake TMDL provides daily discharge and average TN concentrations for the Brittany Estates outfall from 1996-2000. The daily average discharge and TN concentrations from the TMDL were used to calculate total annual TN loading for Brittany Estates. Loading from Sportsmans Cove was calculated in a similar manner, but with average monthly discharge and TN concentrations reported by the facility as stored in the DEP Wastewater Facility Regulation database. The retention factor (S) was applied to the load from Sportsmans Cove only, as Brittany Estates discharges directly into Little Hatchett Creek.

## Results

Estimated septic tank TN loadings for each lake are shown in Tables 2A-D. Table 3 shows the estimated TN loading from the two package plants.

**TABLE 2A. TN LOADING FROM SEPTIC SYSTEMS (LBS/YEAR) – LAKE LOCHLOOSA**

| Estimated Soil TN Retention | Status       | Total TN Loading (lbs/year)       |                                   |
|-----------------------------|--------------|-----------------------------------|-----------------------------------|
|                             |              | 30 mg/L Effluent TN Concentration | 50 mg/L Effluent TN Concentration |
| 30 percent                  | Functioning  | 1373                              | 2288                              |
|                             | Failing      | 103                               | 172                               |
|                             | <b>TOTAL</b> | <b>1476</b>                       | <b>2460</b>                       |
| 45 percent                  | Functioning  | 1079                              | 1798                              |
|                             | Failing      | 103                               | 172                               |
|                             | <b>TOTAL</b> | <b>1182</b>                       | <b>1970</b>                       |

**TABLE 2B. TN LOADING FROM SEPTIC SYSTEMS (LBS/YEAR) – NEWNANS LAKE**

| Estimated Soil TN Retention | Status       | Total TN Loading (lbs/year)       |                                   |
|-----------------------------|--------------|-----------------------------------|-----------------------------------|
|                             |              | 30 mg/L Effluent TN Concentration | 50 mg/L Effluent TN Concentration |
| 30 percent                  | Functioning  | 4292                              | 7153                              |
|                             | Failing      | 323                               | 538                               |
|                             | <b>TOTAL</b> | <b>4615</b>                       | <b>7691</b>                       |
| 45 percent                  | Functioning  | 3372                              | 5620                              |
|                             | Failing      | 323                               | 538                               |
|                             | <b>TOTAL</b> | <b>3695</b>                       | <b>6158</b>                       |

**TABLE 2C. TN LOADING FROM SEPTIC SYSTEMS (LBS/YEAR) – ORANGE LAKE**

| Estimated Soil TN Retention | Status       | Total TN Loading (lbs/year)       |                                   |
|-----------------------------|--------------|-----------------------------------|-----------------------------------|
|                             |              | 30 mg/L Effluent TN Concentration | 50 mg/L Effluent TN Concentration |
| 30 percent                  | Functioning  | 2205                              | 3676                              |
|                             | Failing      | 166                               | 276                               |
|                             | <b>TOTAL</b> | <b>2371</b>                       | <b>3952</b>                       |
| 45 percent                  | Functioning  | 1733                              | 2888                              |
|                             | Failing      | 166                               | 276                               |
|                             | <b>TOTAL</b> | <b>1899</b>                       | <b>3164</b>                       |

**TABLE 2D TN LOADING FROM SEPTIC SYSTEMS (LBS/YEAR) – LAKE WAUBERG**

| Estimated Soil TN Retention | Status       | Total TN Loading (lbs/year)       |                                   |
|-----------------------------|--------------|-----------------------------------|-----------------------------------|
|                             |              | 30 mg/L Effluent TN Concentration | 50 mg/L Effluent TN Concentration |
| 30 percent                  | Functioning  | 281                               | 468                               |
|                             | Failing      | 21                                | 35                                |
|                             | <b>TOTAL</b> | <b>302</b>                        | <b>504</b>                        |
| 45 percent                  | Functioning  | 221                               | 368                               |
|                             | Failing      | 21                                | 35                                |
|                             | <b>TOTAL</b> | <b>242</b>                        | <b>403</b>                        |

**TABLE \_\_ 3. TN LOADING FROM PACKAGE PLANTS (LBS/YEAR)**


| Lake      | Package Plants in 200m Drainage Area | 30 percent Soil Retention | 45 percent Soil Retention |
|-----------|--------------------------------------|---------------------------|---------------------------|
| Lochloosa | -                                    | -                         | -                         |
| Newnans   | Brittany Estates *                   | 736                       | 736                       |
| Orange    | Sportsman's Cove                     | 5                         | 4                         |
| Wauberg   | -                                    | -                         | -                         |

\* Brittany Estates discharges directly into Little Hatchett Creek. As such, the soil retention factor was not applied.


Figure 1 shows the relative TN loading from onsite wastewater systems for each lake using the most conservative estimates (30 percent retention rate and 50 mg/L TN concentration). Figures 2A through 2D show TN loading from onsite wastewater systems relative to loading from other sources. In these figures, the onsite wastewater loading was calculated assuming a 30 percent retention rate and 50 mg/L average TN concentration to provide a maximum loading estimate. Loading from non-wastewater sources and the total baseline loading values were taken directly from the TMDL documents for comparison purposes.

Given the variety of assumptions and data used in TMDL development among the lakes, these estimates of onsite wastewater system loading are rough estimates. Additional loading from onsite systems beyond the 200m drainage area may be occurring. However, without accurate data regarding groundwater baseflow into basin lakes, this additional contribution cannot be accurately quantified even within an order of magnitude.

**FIGURE \_\_1. ESTIMATED TN LOADING FROM FUNCTIONING SEPTIC SYSTEMS, FAILING SEPTIC SYSTEMS, AND PACKAGE PLANTS**  
*(Calculated with 30 percent retention rate and 50 mg/L average TN concentration)*




**FIGURE \_\_2A. ESTIMATED TN LOADING (LBS/YEAR) AND PERCENTAGE OF BASELINE LOADING FROM VARIOUS SOURCES – LAKE LOCHLOOSA**



**Notes:**

- Stormwater runoff was not separated by land use types in the original TMDL.
- The refined wastewater loading estimate shown in this figure was calculated with a 30% retention rate & 50 mg/L average TN concentration
- See Table 6 and Section 5.8 in the Lake Lochloosa TMDL for more information about non-wastewater sources.


**FIGURE \_\_2B. ESTIMATED TN LOADING (LBS/YEAR) AND PERCENTAGE OF BASELINE LOADING FROM VARIOUS SOURCES – NEWNANS LAKE**



**Notes:**

- The original onsite wastewater loading estimate calculated for the TMDL was 800 lbs/year (0.3% of total TN loading).
- The refined wastewater loading estimate shown in this figure was calculated with a 30% retention rate & 50 mg/L average TN concentration
- See Tables 23 & 26 in the Newnans Lake TMDL for more information about non-wastewater sources.


**FIGURE 2C. ESTIMATED TN LOADING (LBS/YEAR) AND PERCENTAGE OF BASELINE LOADING FROM VARIOUS SOURCES – ORANGE LAKE**



**Notes:**

- The original onsite wastewater loading estimate calculated for the TMDL was 4630 lbs/year (5% of total TN loading).
- The refined wastewater loading estimate shown in this figure was calculated with a 30% retention rate & 50 mg/L average TN concentration
- See Tables 18 & 21 of the Orange Lake TMDL for more information about non-wastewater loading.

**FIGURE 2D. ESTIMATED TN LOADING (LBS/YEAR) AND PERCENTAGE OF BASELINE LOADING FROM VARIOUS SOURCES – LAKE WAUBERG**



**Notes:**

- The original onsite wastewater loading estimate calculated for the TMDL was 1299 lbs/year (32% of total TN loading).
- The refined wastewater loading estimate shown in this figure was calculated with a 30% retention rate & 50 mg/L average TN concentration
- See Section 5 of the Lake Wauberg TMDL for more information about non-wastewater loading.

**Conclusions**

Onsite wastewater systems are frequently identified as a significant source of Total Nitrogen loading to surface waters. However, loading values from onsite systems are often based upon the total number of systems in the watershed, and not on the loading from those systems that actually reaches an impaired surface water. The purpose of this analysis was to estimate the fraction of total loading from onsite wastewater system effluent that reaches the four impaired lakes in the Orange Creek Basin. To identify this fraction, only systems within 200m of the lake and its associated surface water drainage features were included.

Based on the information provided above, TN loading from onsite systems in the 200m drainage area ranged from 8427 lbs/year (maximum estimate for Newnans Lake) to 242 lbs/year (minimum estimate for Lake Wauberg). The maximum estimates of loading from septic tanks alone were as follows: Lochloosa-2460 lbs/year, Newnans-7691 lbs/year, Orange-3952 lbs/year, and Wauberg-504 lbs/year.

In the four subbasins, functioning septic systems are estimated to contribute significantly more TN than failing systems and package plants combined (see Figure 1). TN loading from failing septic systems was limited. Loadings from the two package plants in the 200m surface water drainage area (Brittany Estates and Sportsman's Cove) were also minimal relative to loading from functioning septic tanks in their respective subbasins.

Relative to other sources, loading from onsite wastewater systems was a small fraction of the total TN loading to Lochloosa, Newnans, and Orange Lakes. For these three lakes, loadings from onsite systems were 2-4.5% of the total baseline loading. In Lake Wauberg, loading from onsite systems primarily located on the west-southwest side of the Lake represented 10 percent of the baseline loading. Further, the maximum estimate of TN load from onsite systems in Lake Wauberg (504 lbs/year) represents approximately 25 percent of the TMDL (2062.4 lbs/year).

Onsite wastewater disposal appears to provide only a small fraction of Total Nitrogen loading to Lake Lochloosa, Newnans Lake, and Orange Lake. Addressing Total Nitrogen loads from onsite wastewater systems would have the greatest benefit for Lake Wauberg, as onsite systems contribute a larger portion of the overall loading for this lake than in the other three impaired lakes. In addition to onsite wastewater systems, all sources need to be considered when developing a plan that will successfully improve water quality in lakes of the Orange Creek Basin.

## **APPENDIX \_\_\_\_\_. DRAFT GUIDANCE ON SEPTIC TANK SYSTEM MAINTENANCE AND SEWER HOOKUP**

**Contributions from:** Alachua County Health Department, Lake County Health Department, Florida Department of Health

### **Preliminary Notes:**

- Note that the term “functioning properly” is qualitative. Basically, if a prior approved system is operating under the same conditions it was permitted for and not causing a sanitary nuisance, then it is “functioning properly.”
- Systems that were permitted prior to 1983 may not meet the scientifically researched basis for the 24” vertical separation from the absorption surface (bottom of drainfield) to the seasonal high water table. Those systems meeting the 24” vertical separation to the seasonal high water table and the 75’ lateral setback to surface waters are unlikely to pose a risk for fecal coliform loading to the creeks.

---

### **Septic Tank Maintenance:**

Unless a system is required to have an operating permit, there is no State mandate for maintenance other than insuring that the Onsite Sewage Treatment and Disposal System (OSTDS) functions properly and does not cause a sanitary nuisance.

Operating permits are required for OSTDS:

- Located in an area zoned industrial or manufacturing, or its equivalent.
- Where a business will generate commercial sewage waste.
- That utilize aerobic treatment units.
- That are performance-based treatment systems.

The current **recommendations** are that a typical residential OSTDS have its tank(s) inspected every three to five years to determine if they need to be pumped. Owners may consider increasing this inspection frequency if they have a garbage disposal.

**See:** Chapter 64E-6.003(5), Florida Administrative Code.

---

### **Conditions for Sewer Hook-up:**

An owner of an OSTDS that is functioning properly has 365 days from the time a utility notifies\* them that a sewer is “available” to connect to the central sewage system. The definition of “available” can be found in s. 381.0065(2)(a), Florida Statutes (F.S.) – see below.

An owner of an OSTDS that is in need of repair or modification in order to function properly has 90 days to connect to an “available” sewer system after written notification from the Health Department. The Health Department would issue an order to abate a sanitary nuisance.

These are two separate and distinct scenarios. County health departments do not have authority to issue permits or grant system approvals for septic tanks where a sewer is available per the s. 381.0065, F.S., definition of “available.”

**Guidance for this issue is provided by:** s. 381.0065, F.S.

---

### **Incentives for Local Governments to Connect Citizens to Central Sewer:**

Economics generally has been the primary driving force for communities to require central sewer connections. Sewerage results in higher densities and more intense use of commercial properties (especially restaurants) that OSTDS do not support or allow.

- In the Orange Creek Basin, with regards to the creek project, environmental concerns are the impetus for the efforts currently underway by the Alachua County Health Department, Gainesville Regional Utilities, and Alachua County Environmental Protection Department.
  - o Where OSTDS are found that pose a significant potential or confirmed contribution to fecal coliform loading, the option of repairing the OSTDS or extending/connecting sewer lines is being assessed.
  - o A challenge is going to be in how we address those systems that pose a potentially significant problem; if they are not obviously failing, we cannot impose a fix. We can explore options to mitigate their impact.

### **Related Statutes**

#### **381.0065**

(2) **DEFINITIONS.**--As used in ss. [381.0065](#)-381.0067, the term:

- (a) "Available," as applied to a publicly owned or investor-owned sewerage system, means that the publicly owned or investor-owned sewerage system is capable of being connected to the plumbing of an establishment or residence, is not under a Department of Environmental Protection moratorium, and has adequate permitted capacity to accept the sewage to be generated by the establishment or residence; and:
1. For a residential subdivision lot, a single-family residence, or an establishment, any of which has an estimated sewage flow of 1,000 gallons per day or less, a gravity sewer line to maintain gravity flow from the property's drain to the sewer line, or a low pressure or vacuum sewage collection line in those areas approved for low pressure or vacuum sewage collection, exists in a public easement or right-of-way that abuts the property line of the lot, residence, or establishment.
  2. For an establishment with an estimated sewage flow exceeding 1,000 gallons per day, a sewer line, force main, or lift station exists in a public easement or right-of-way that abuts the property of the establishment or is within 50 feet of the property line of the establishment as accessed via existing rights-of-way or easements.
  3. For proposed residential subdivisions with more than 50 lots, for proposed commercial subdivisions with more than 5 lots, and for areas zoned or used for an industrial or manufacturing purpose or its equivalent,

a sewerage system exists within one-fourth mile of the development as measured and accessed via existing easements or rights-of-way.

4. For repairs or modifications within areas zoned or used for an industrial or manufacturing purpose or its equivalent, a sewerage system exists within 500 feet of an establishment's or residence's sewer stub-out as measured and accessed via existing rights-of-way or easements.

**381.0016**     **Municipal regulations and ordinances.**--Any municipality may enact, in a manner prescribed by law, health regulations and ordinances not inconsistent with state public health laws and rules adopted by the department.