DATA SUPPLIES, INC. JACKSONVILLE, FLORIDA (904) 731-5700

WELL COMPLETION REPORT (Please complete in black ink or type.)

PERMIT #_____ CUP/WUP # _____ DID #_____

If permit is for multiple wells indicate the number of wells drilled 1.

Indicate remaining wells to be cancelled Ø.

WATER WELL CONTRACTOR'S (All wells drilled need an individual completion report)

SIGNATURE _____ License # 3136

I certify that the information provided in this report is accurate and true.

Grout	No. of Bags	From (Ft.)	To (Ft.)
Neat Cement:	15	77.5	0
Bentonite:			

WELL LOCATION: Site Address_____ (County) BREVARD

_____ 1/4 of ____ 1/4 of Section IRREGULAR Twp: Rge: _____

Latitude 283024 Longitude 805132

DATE STAMP

Official Use Only

Sketch of well location on property



Give distance from septic tank and house or other reference points

CHEMICAL ANALYSIS WHEN REQUIRED

Iron: _____ ppm Sulfate: _____ ppm

Chloride: _____ ppm

[ ] Lab Test [ ] Field Test Kit

Pump Type

[ ] Centrifugal [ ] Jet [ ] Submersible [ ] Turbine

Horsepower _____ Capacity _____ G.P.M. _____

Pump Depth _____ Ft. Intake Depth _____ Ft.

OWNER'S NAME SJRWMD BR2167

COMPLETION DATE 2/24/10 Florida Unique I.D. _____

WELL USE: DEP/Public ____ Irrigation ____ Domestic ____ Monitor ✓

HRS Limited ____ 62-524 ____ Other _____

DRILL METHOD [ ] Rotary [ ] Cable Tool [✓] Combination

[ ] Jet [ ] Auger Other _____

Measured Static Water Level ALS Measured Pumping Water Level FLOWING

After ____ Hours at ____ G.P.M. Measuring Pt. (Describe): 485 gpm

Which is 3 Ft. [✓] Above [ ] Below Land Surface

Casing: [ ] Black Steel [ ] Galv. [✓] PVC Other _____

[ ] Open Hole
[✓] Screen

Casing Diameter & Depth (Ft.)

Diameter 4" SCN
From 87.5
To 77.5

Diameter 4" CSG
From 77.5
To 3' ALS

Liner [ ] or Casing [ ]
Diameter _____
From _____
To _____

Depth (Ft.) From	To	DRILL CUTTINGS LOG — Examine cuttings every 20 ft. or at formation changes. Note cavities, depth to producing zones. Color | Grain Size | Type of Material
0	20	BRN SANDY CLAY
20	70	TAN F SAND W/ SHELL, CLAY BLEBS, PHOSPHATE
70	82	GRAY FOSS. LIMESTONE
82	87.5	CAVITY

Driller's Name: *(print or type)* ALAN STORY