

<u>4</u> Protective Bollards <u>2</u> ft X <u>2</u> ft Concrete Pad with SJRWMD Survey Marker Static GWL : _____ ft bls Grout Type: <u>PORTLAND</u> Quantity: <u>21</u> Grout Type: <u>PORTLAND</u> Quantity: <u>21</u> Seal Type: <u>BENTONITE CHIPS</u> Quantity: <u>1 BAG</u> Filter Pack Type: <u>20/30</u> Quantity: <u>18</u> PVC Bottom Cap (6 inches)		Locking Compression Cap with Hinged Lid and <u>6" X 5'</u> Steel Protective Outer Casing LSD (est. @ ~ _____ ft NGVD) Casing Type: <u>PVC</u> Diameter: <u>8"</u> Depth: <u>58'</u> ft Casing Type: <u>PVC</u> Diameter: <u>4"</u> Depth: <u>80'</u> ft Tag Holeplug @ <u>76.0'</u> ft bls Tag Sand @ <u>78.0'</u> ft bls Screen Type: <u>PVC</u> Slot Size: <u>.010</u> Interval: <u>80-100'</u> Total Depth @ <u>100.5'</u> ft bls
<u>8"</u> inch dia. bore		
Not to Scale		

Site: <u>SJRWMD WRIGHT PROPERTY</u> Driller: <u>HUDSON</u> Method: <u>ROTARY</u> Date Completed: <u>9-30-09</u>	SJRWMD Well ID: <u>D-1495</u>
---	---