

ST. JOHNS RIVER WATER MANAGEMENT DISTRICT
HYDROLOGIC DATA SERVICES
STATION DESCRIPTION

(V-1151) Blue Spg N

Updated on: 4/1/2009

Description prepared by: B.Player

Station established on: 12/30/2008

Description of station: 4" PVC non-flowing well

Hydron number: 30432904

History of Equipment: On 2/19/2010 a CR800 data logger w/105S Shaft Encoder, typical tape, weight, and float arrangement- recording hourly data through Air-Link modem using cellular telemetry network.

Manual WL Requirement: Electric Tape or steel tape & chalk

Ground water:

Aquifer code: FA

Depth of well: 140.0

Depth of casing: 90.0

ST. JOHNS RIVER WATER MANAGEMENT DISTRICT
HYDROLOGIC DATA SERVICES
STATION DESCRIPTION

V-1151 Blue Spg N

Updated on: 4/1/2009

Description prepared by: B.Player

Station established on: 12/30/2008

Description of station: 4" PVC non-flowing well

Hydron number: 30432904

History of Location: Blue Springs SP

History of Equipment: Only water levels at this time quarterly.

Manual WL Requirement:

Electric Tape:

Steel Tape & Chalk:

Ground water:

Aquifer code: Floridian

M.P. elevation: 500.0

M.P. location: TOC 4" PVC

Depth of well: 140.0

Depth of casing: 90.0

ST. JOHNS RIVER WATER MANAGEMENT DISTRICT
HYDROLOGIC DATA SERVICES
STATION DESCRIPTION
V-1151

Updated on: 4/1/2009

Description prepared by: B.Player

Station established on: 12/30/2008

Description of station: 4" PVC well

Hydron number: 30432904

History of Observer: Contact person is Mega Keserauski (386 785-3752)

History of Location: Blue Springs SP

History of Equipment: DTW at this time

Manual WL Requirement:

Electric Tape:

Steel Tape & Chalk:

Ground water:

Aquifer code: Floridan

M.P. elevation: 500.0

M.P. location: TOC 4" PVC

Depth of well: 140.0

Depth of casing: 90.0

WELL COMPLETION REPORT (Please complete in black ink or type.)
 Permit # V-1151 CUP# WSP DID # _____

 Permit is for multiple wells indicate the number of wells drilled _____
 Indicate remaining wells to be cancelled _____

AFTER WELL CONTRACTOR'S (All wells drilled need an individual completion report)

 SIGNATURE Robert S. Hunt License # 2899

I certify that the information provided in this report is accurate and true.

Route	No. of Bags	From (FL)	To (FL)
Coat Cement:	<u>4</u>	<u>0.0</u>	<u>23.0'</u>
Bentonite:	<u>1</u>	<u>23.0</u>	<u>25.0'</u>


 WELL LOCATION: Site Address BOULE SPRING PL (County) VOLUSIA

 1/4 of 1/4 of Section 37 Twp: 18S Rge: 30E

 Latitude 285726 Longitude 812009

DATE STAMP

Sketch of well location on property



Give distances from septic tank and house or other reference points

Official Use Only

MICHAEL ANALYSIS WHEN REQUIRED

_____ ppm Sulfate: _____ ppm

Chloride: _____ ppm

Lab Test [] Field Test Kit

Pump Type

Centrifugal [] Jet [] Submersible [] Turbine

Horsepower _____ Capacity _____ G.P.M. _____

Intake Depth _____ Ft. Intake Depth _____ Ft.

OWNER'S NAME SJR WMDCOMPLETION DATE 11/13/06 Florida Unique I.D. _____
 WELL USE: DEP/Public _____ Irrigation _____ Domestic _____ Monitor X

HRS Limited _____ 62-524 _____ Other _____

 DRILL METHOD (X) Rotary [] Cable Tool [] Combination

[] Jet [] Auger Other _____

Measured Static Water Level _____		Measured Pumping Water Level _____	
After _____ Hours at _____ G.P.M. Measuring Pt. (Describe): _____			
Which is _____ Ft. [] Above [] Below Land Surface			
Casing: [] Black Steel [] Galv. <u>(X)</u> PVC Other _____			
[] Open Hole	Depth (FL)	DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Note cavities, depth to producing zones.	
<u>(X)</u> Screen	From To	Color Grain Size Type of Material	
Casing Diameter & Depth (FL)	From To		
Diameter <u>4"</u>	<u>0.0</u>	<u>YELLOW ORANGE</u>	
From <u>0.0</u>	<u>37.0'</u>	<u>FINE TO MEDIUM SAND</u>	
To <u>27.0'</u>			
SCREEN			
Diameter <u>4"</u>			
From <u>27.0'</u>			
To <u>37.0'</u>			
Liner [] or Casing []			
Diameter _____			
From _____			
To _____			

Driller's Name:

(print or type)

KEVIN REFFUSE

