



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION GROUND WATER MANAGEMENT

SPRINGS SAMPLING FIELD SHEET

STATION INFORMATION

STATION ID WAKULLA D TUNNEL DATE 2/5/14 TIME(EST) 12:55 (24HR)
SPRING NAME WAKULLA WEATHER: CLEAR ☒ PARTLY-CLOUDY ☐ CLOUDY ☐ RAIN ☐

WATER QUALITY MEASUREMENTS

Analytes collected for this site are as listed per the container inventory, including any QA/QC samples ☒ YES ☐ NO

CHEMICAL STABILITY MONITORING

Time	Temperature (°C)	Conductivity (µs/cm)	DO (% sat)	DO (mg/l)	p H (su)
12:44	20.35	305	29.2	2.64	6.98
12:49	20.37	305	29.2	2.63	6.99
12:54	20.33	305	29.0	2.62	6.98

Stability Criteria: Temp $\pm 0.2^{\circ}\text{C}$ Sp Cond $\pm 5\%$ of reading pH ± 0.2 SU DO $\leq 20\%$ or 0.2 mg/l Turbidity $\leq 20\%$ or 5 NTUs

FINAL FIELD READING

Meter ID	Temperature (°C)	Conductivity (µs/cm)	D.O. (% sat)	D.O. (mg/l)	p H (su)
101901	20.35	304	29.0	2.62	6.99

SAMPLE PRESERVATION

Were all samples collected using the appropriate 0.45-micron filter (when applicable) & Preserved with the appropriate type and amount of acid (sulfuric for nutrients & nitric for metals)? ☒ YES ☐ NO

Nitric Acid Lot # 1112080 Sulfuric Acid Lot # 120591 Filter Lot # 73050004

Were all collected samples properly preserved and stored on wet ice at 4°C within 15 minutes? ☒ YES ☐ NO

RQ LABEL

RQ-2014-02-03-20

SPRG1401

SITE LABEL



WAKULLA D TUNNEL

SPRG1401 WAKULLA D TUNNEL

QA/QC Taken? YES ☒ NO ☐

TIME(EST) _____ (24HR)

BLANK TYPE EQUIPMENT FIELD

PERISTALTIC PUMP ID # 2

QA/QC LABEL
(if applicable)



QAQC BLANK 2

SPRG1401

C ID)

COMMENTS

clear

SAMPLER NAMES & SIGNATURES (All team members present)

Edgar Wade

Gary Maddox