

Chemical Analysis Report

NE-DIST-2021-01-21-01

Florida Department of Environmental Protection
Central Laboratory
2600 Blair Stone Road
Tallahassee, FL 32399-2400
DOH Accreditation E31780

Event Description: **Callahan 2021**
Request ID: **RQ-2021-01-18-17**
Customer: **NE-DIST**
Project ID: **SMP**

Send Reports to:
FL Dept. of Environmental Protection
8800 Baymeadows Way West
Suite 100
Jacksonville, FL 32256
Attn: Jeremy Parrish

For additional information please contact
Colin Wright, Ph.D.
Liang-Tsair Lin, Ph.D.
Kerry Tate, Ph.D.
Dr. rer. nat. Bettina Steinbock
Thekkekalathil Chandrasekhar, Ph.D, QA Officer
Phone (850) 245-8085

Certified by: Kerry Tate, Ph.D., Environmental Administrator

Date Certified: 11-FEB-2021 10:10

A handwritten signature in black ink that reads "Kerry Tate". The signature is written in a cursive, flowing style with a horizontal line above the first name.

Case Narrative

Unless otherwise noted, all samples included in this report were received in accordance with protocols referenced in Chapter 62-160, Florida Administrative Code (F.A.C.). Results published in this report pertain only to the samples as submitted to, and received by the laboratory. All times in this report are adjusted to the applicable Eastern Time Zone (EST or EDT).

Results for the following analytical groups are included in this report: Metals and Nutrients.

Scientific notation may be used in reporting very large or small values. Values reported using scientific notation will take the form of the following example: 1.3E+03, which is equivalent to 1.3×10^3 or 1300.

Unless otherwise noted, analytical values for soil and sediment samples are reported on a dry weight basis, and analytical values for waste and tissue samples are reported on a wet weight basis.

Results for TNI accredited tests met requirements established by The NELAC Institute. A double asterisk (**) is used to indicate an analyte/matrix/method for which the laboratory is not TNI accredited by the Florida Department of Health Environmental Laboratory Certification Program or where accreditation for that field of testing is not applicable.

Any significant anomalies or deviations from established protocols are documented in Non-Conformance Reports, which, where appropriate, are included within this analytical report. Additional comments related to specific analytical tests may be included as remarks following the analytical results for each sample. Such comments and remarks are for informational purposes only and are not intended to convey judgement about the usability of the reported data.

A quality control report on the performance of the test method for the submitted samples is included. Uncertainty associated with the analytical results contained in this report can be estimated from the reported quality assurance results and from published quality control acceptance limits for each analytical test. Matrix quality control results (matrix spike recoveries and matrix sample precision) pertain only to the matrix sample tested and do not necessarily reflect test method performance for other samples.

Typical matrix quality control (QC) measurements may include matrix spike recovery, matrix spike duplicate recovery, matrix spike precision and matrix sample precision. Not all matrix QC results may be available or reportable; where they are not an explanation is provided. Typical reasons for unavailable QC results include, but are not limited to, a) insufficient matrix sample to perform some or all QC measurements; b) analyte concentration in the sample replicated was too low for a meaningful measurement of precision and c) analyte concentration in the matrix sample spiked was too high (relative to the amount of analyte spiked) for a meaningful measurement of recovery. Where matrix QC results are unavailable, other method performance metrics (e.g., LCS recovery, LCS precision, surrogate recovery) may be used to assess performance of the method. Comments explaining any missing QC measurements are not intended to convey any adverse conclusions about the quality of the reported data.

Precision is reported as relative percent difference unless otherwise noted.

Quality Control codes as defined below may be used in this report to indicate results that are associated with one or more quality control elements which did not fall within established test method criteria. Such results may be qualified as estimates using a J qualifier as required by 62-160 F.A.C. Explanations are included in the report for any results that were reported as estimates for other reasons.

QC Codes used in this report may include:

- LCS – Recovery for the batch Laboratory Control Sample (LCS) was outside existing control limits;
- MS – Recovery for the batch matrix spike (MS) was outside existing control limits;
- CCV – Recovery for a continuing calibration verification (CCV) standard was outside existing control limits;
- SUR – Recovery of a surrogate (SUR) for associated analytes was outside existing control limits;
- RPD – The precision, measured as relative percent difference (RPD), of batch replicate measurements was outside existing control limits;
- RSD – The precision, measured as relative standard deviation (RSD), of batch replicate measurements was outside existing control limits;
- SMP – Sample - used precision derived from replicate analyses of a sample;

The following data qualifiers are used, where applicable, in this report as specified in 62-160 F.A.C.

- A - Value reported is the mean of two or more determinations.
- B - Results based on colony counts outside the acceptable range.
- I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
- J - Estimated value and/or the analysis did not meet established quality control criteria.
- K - Actual value is known to be less than value given.
- L - Actual value is known to be greater than value given.
- N - Presumptive evidence of presence of material.
- O - Sampled, but analysis lost or not performed.
- Q - Sample held beyond normal holding time.
- T - Value reported is less than the criterion of detection.
- U - Material was analyzed for but not detected. The reported value is the method detection limit for the sample analyzed.
- V - Analyte was detected in both sample and method blank.
- X - Too few individuals to calculate SCI value.
- Y - The laboratory analysis was from an unpreserved or improperly preserved sample. The data may not be accurate.
- Z - Colonies were too numerous to count (TNTC).

Quality control information from overflow laboratories may not be included in this report. Please refer to the associated report from the overflow laboratory for additional information.

Sample Location: Cushing Creek At Lem Turner Rd.

Collection Date/Time: 01/20/2021 12:10

Field ID: G4NE0306

Matrix: W-SURF-FRH

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2220315	EPA 180.1 Rev. 2.0	Turbidity	5.1		NTU	P392715	
	EPA 300.0 Rev. 2.1	Chloride	26		mg Cl/L	P392789	
		Sulfate	14		mg SO4/L	P392790	
	SM 2120 B-2011	Color (true)	190		PCU	P392710	
	SM 2320 B-2011	Total Alkalinity	54		mg CaCO3/L	P393214	
	SM 2540 C-2011	TDS	178	A	mg/L	P393018	
	SM 2540 D-2011	TSS	3	IA	mg/L	P392978	
	SM 4500 F-C-2011	Fluoride	0.11		mg F/L	P392867	
2220316	EPA 350.1 Rev. 2.0	Ammonia-N	0.024		mg N/L	P393334	
	EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	0.60		mg N/L	P393057	
	EPA 353.2 Rev. 2.0	NO2NO3-N	0.014		mg N/L	P392814	
	EPA 365.1 Rev. 2.0	Total-P	0.039		mg P/L	P392787	
	SM 5310 B-2011	Organic Carbon	21		mg C/L	P392985	
2220317	EPA 365.1 Rev. 2.0 dissolved	O-Phosphate-P	0.017		mg P/L	P392703	

Ref. Method and Comment:

SM 2540 D-2011: Batch relative percent difference is unavailable because of low analyte concentration in the QC sample.

Sample Location: Thomas Cr 4 Mi Below City Prison

Collection Date/Time: 01/20/2021 10:35

Field ID: 19020033

Matrix: W-SURF-FRH

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2220312	EPA 180.1 Rev. 2.0	Turbidity	8.8	A	NTU	P392715	
	EPA 300.0 Rev. 2.1	Bromide	0.083		mg Br/L	P393037	
	SM 2320 B-2011	Total Alkalinity	16		mg CaCO3/L	P393214	
	SM 2540 D-2011	TSS	21		mg/L	P392981	
	SM 4500 F-C-2011	Fluoride	0.054	I	mg F/L	P392867	
2220313	EPA 350.1 Rev. 2.0	Ammonia-N	0.031		mg N/L	P393334	
	EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	0.98		mg N/L	P393057	
	EPA 353.2 Rev. 2.0	NO2NO3-N	0.031		mg N/L	P392814	
	EPA 365.1 Rev. 2.0	Total-P	0.13		mg P/L	P392786	
	SM 5310 B-2011	Organic Carbon	24		mg C/L	P392985	
2220314	EPA 365.1 Rev. 2.0 dissolved	O-Phosphate-P	0.094		mg P/L	P392703	

Ref. Method and Comment:

SM 2540 D-2011: Batch relative percent difference is unavailable because of low analyte concentration in the QC sample.

Sample Location: FB 012021

Collection Date/Time: 01/20/2021 10:40

Field ID: FB 012021

Matrix: W-FIELD-BK

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2220318	EPA 180.1 Rev. 2.0	Turbidity	0.10	U	NTU	P392715	
	EPA 300.0 Rev. 2.1	Bromide	0.013	U	mg Br/L	P393037	
	SM 2320 B-2011	Total Alkalinity	0.65	U	mg CaCO3/L	P393214	
	SM 2540 D-2011	TSS	2	U	mg/L	P392981	
	SM 4500 F-C-2011	Fluoride	0.035	U	mg F/L	P392867	
2220319	EPA 350.1 Rev. 2.0	Ammonia-N	0.002	U	mg N/L	P393334	
	EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	0.080	U	mg N/L	P393091	
	EPA 353.2 Rev. 2.0	NO2NO3-N	0.004	U	mg N/L	P392814	
	EPA 365.1 Rev. 2.0	Total-P	0.002	U	mg P/L	P392787	
	SM 5310 B-2011	Organic Carbon	0.50	U	mg C/L	P392985	
2220320	EPA 365.1 Rev. 2.0 dissolved	O-Phosphate-P	0.004	U	mg P/L	P392703	
2220339	EPA 200.7 Rev. 4.4	Calcium	0.075	U	mg/L	P392709	
		Iron	30	U	ug/L	P392709	
		Magnesium	0.040	U	mg/L	P392709	
		Manganese	1.0	U	ug/L	P392709	
		Zinc	5.0	U	ug/L	P392709	
	EPA 200.8 Rev. 5.4	Aluminum	5.0	U	ug/L	P392709	
		Antimony	0.050	U	ug/L	P392709	
		Arsenic	0.050	U	ug/L	P392709	
		Beryllium	0.010	U	ug/L	P392709	
		Cadmium	0.020	U	ug/L	P392709	
		Chromium	0.40	U	ug/L	P392709	
		Copper	0.40	U	ug/L	P392709	
		Lead	0.20	U	ug/L	P392709	
		Nickel	0.50	U	ug/L	P392709	
		Selenium	0.20	U	ug/L	P392709	
		Silver	0.010	U	ug/L	P392709	
		Thallium	0.10	U	ug/L	P392709	

Ref. Method and Comment:

SM 2540 D-2011: Batch relative percent difference is unavailable because of low analyte concentration in the QC sample.

EPA 351.2 Rev. 2.0: Batch matrix spike recoveries are unavailable because of high analyte concentration in the QC sample.

Sample Location: Thomas Creek 5 Miles Down From Ethel

Collection Date/Time: 01/20/2021 10:25

Field ID: G4NE0298

Matrix: W-SURF-FRH

Sample ID	Ref. Method	Component	Result	Code	Units	Batch ID	QC Codes
2220338	EPA 200.7 Rev. 4.4	Calcium	9.07		mg/L	P392709	
		Iron	360		ug/L	P392709	
		Magnesium	4.27		mg/L	P392709	
		Manganese	6.0		ug/L	P392709	
		Zinc	5.0	U	ug/L	P392709	
	EPA 200.8 Rev. 5.4	Aluminum	246		ug/L	P392709	
		Antimony	0.050	U	ug/L	P392709	
		Arsenic	0.42		ug/L	P392709	
		Beryllium	0.018	I	ug/L	P392709	
		Cadmium	0.020	U	ug/L	P392709	
		Chromium	0.55	I	ug/L	P392709	
		Copper	0.40	U	ug/L	P392709	
		Lead	0.35	I	ug/L	P392709	
		Nickel	0.51	I	ug/L	P392709	
		Selenium	0.20	U	ug/L	P392709	
		Silver	0.010	U	ug/L	P392709	
		Thallium	0.10	U	ug/L	P392709	

Quality Assurance Report

Method Blank Results

Reference Method: EPA 180.1 Rev. 2.0
Batch ID: P392715

Component	Result	Code	Units
Turbidity	0.10	U	NTU

Reference Method: EPA 200.7 Rev. 4.4
Batch ID: P392709

Component	Result	Code	Units
Calcium	0.075	U	mg/L
Iron	30	U	ug/L
Magnesium	0.040	U	mg/L
Manganese	1.0	U	ug/L
Zinc	5.0	U	ug/L

Reference Method: EPA 200.8 Rev. 5.4
Batch ID: P392709

Component	Result	Code	Units
Aluminum	5.0	U	ug/L
Antimony	0.050	U	ug/L
Arsenic	0.050	U	ug/L
Beryllium	0.010	U	ug/L
Cadmium	0.020	U	ug/L
Chromium	0.40	U	ug/L
Copper	0.40	U	ug/L
Lead	0.20	U	ug/L
Nickel	0.50	U	ug/L
Selenium	0.20	U	ug/L
Silver	0.010	U	ug/L
Thallium	0.10	U	ug/L

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392789

Component	Result	Code	Units
Chloride	0.20	U	mg Cl/L

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392790

Component	Result	Code	Units
Sulfate	0.20	U	mg SO4/L

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P393037

Component	Result	Code	Units
Bromide	0.013	U	mg Br/L

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P393334

Component	Result	Code	Units
Ammonia-N	0.002	U	mg N/L

Quality Assurance Report Method Blank Results

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393057

Component	Result	Code	Units
Kjeldahl Nitrogen	0.080	U	mg N/L

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393091

Component	Result	Code	Units
Kjeldahl Nitrogen	0.080	U	mg N/L

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P392814

Component	Result	Code	Units
NO2NO3-N	0.004	U	mg N/L

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392786

Component	Result	Code	Units
Total-P	0.002	U	mg P/L

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392787

Component	Result	Code	Units
Total-P	0.002	U	mg P/L

Reference Method: EPA 365.1 Rev. 2.0 dissolved
Batch ID: P392703

Component	Result	Code	Units
O-Phosphate-P	0.004	U	mg P/L

Reference Method: SM 2120 B-2011
Batch ID: P392710

Component	Result	Code	Units
Color (true)	2.5	U	PCU

Reference Method: SM 2320 B-2011
Batch ID: P393214

Component	Result	Code	Units
Total Alkalinity	0.65	U	mg CaCO3/L

Reference Method: SM 2540 C-2011
Batch ID: P393018

Component	Result	Code	Units
TDS	15	U	mg/L

Quality Assurance Report

Method Blank Results

Reference Method: SM 2540 D-2011
Batch ID: P392978

Component	Result	Code	Units
TSS	2	U	mg/L

Reference Method: SM 2540 D-2011
Batch ID: P392981

Component	Result	Code	Units
TSS	2	U	mg/L

Reference Method: SM 4500 F-C-2011
Batch ID: P392867

Component	Result	Code	Units
Fluoride	0.035	U	mg F/L

Reference Method: SM 5310 B-2011
Batch ID: P392985

Component	Result	Code	Units
Organic Carbon	0.50	U	mg C/L

Quality Assurance Report Laboratory Control Sample Accuracy

Reference Method: EPA 200.7 Rev. 4.4
Batch ID: P392709

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Calcium	106		P	85 - 115
Iron	108		P	85 - 115
Magnesium	107		P	85 - 115
Manganese	99.4		P	85 - 115
Zinc	101		P	85 - 115

Reference Method: EPA 200.8 Rev. 5.4
Batch ID: P392709

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Aluminum	97.4		P	85 - 115
Antimony	104		P	85 - 115
Arsenic	101		P	85 - 115
Beryllium	96.3		P	85 - 115
Cadmium	96.7		P	85 - 115
Chromium	106		P	85 - 115
Copper	98.9		P	85 - 115
Lead	103		P	85 - 115
Nickel	99.7		P	85 - 115
Selenium	98.6		P	85 - 115
Silver	109		P	85 - 115
Thallium	101		P	85 - 115

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392789

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Chloride	101		P	90 - 110

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392790

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Sulfate	103		P	90 - 110

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P393037

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Bromide	99.0		P	90 - 110

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P393334

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Ammonia-N	103		P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393057

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Kjeldahl Nitrogen	96.1		P	90 - 110

Quality Assurance Report

Laboratory Control Sample Accuracy

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393091

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Kjeldahl Nitrogen	96.1		P	90 - 110

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P392814

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
NO2NO3-N	100		P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392786

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Total-P	104		P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392787

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Total-P	105		P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0 dissolved
Batch ID: P392703

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
O-Phosphate-P	97.1		P	90 - 110

Reference Method: SM 2120 B-2011
Batch ID: P392710

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Color (true)	99.5		P	85 - 115

Reference Method: SM 2320 B-2011
Batch ID: P393214

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Total Alkalinity	97.1		P	93 - 104

Reference Method: SM 4500 F-C-2011
Batch ID: P392867

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Fluoride	98.6		P	90 - 106

Reference Method: SM 5310 B-2011
Batch ID: P392985

Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
Organic Carbon	99.2		P	85 - 115

Quality Assurance Report Matrix Spike Accuracy

Reference Method: EPA 200.7 Rev. 4.4

Batch ID: P392709

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220092	Calcium	109		P	80 - 120
2220092	Iron	110		P	80 - 120
2220092	Magnesium	109		P	80 - 120
2220092	Manganese	101		P	80 - 120
2220092	Zinc	104		P	80 - 120
2220307	Calcium	111	110	P/P	80 - 120
2220307	Iron	113	114	P/P	80 - 120
2220307	Magnesium	111	112	P/P	80 - 120
2220307	Manganese	105	102	P/P	80 - 120
2220307	Zinc	106	104	P/P	80 - 120

Reference Method: EPA 200.8 Rev. 5.4

Batch ID: P392709

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220092	Aluminum	95.1		P	80 - 120
2220092	Antimony	100		P	80 - 120
2220092	Arsenic	96.5		P	80 - 120
2220092	Beryllium	93.1		P	80 - 120
2220092	Cadmium	93.8		P	80 - 120
2220092	Chromium	102		P	80 - 120
2220092	Copper	94.8		P	80 - 120
2220092	Lead	101		P	80 - 120
2220092	Nickel	94.0		P	80 - 120
2220092	Selenium	92.0		P	80 - 120
2220092	Silver	106		P	80 - 120
2220092	Thallium	102		P	80 - 120
2220307	Aluminum	93.8	96.0	P/P	80 - 120
2220307	Antimony	102	103	P/P	80 - 120
2220307	Arsenic	96.9	98.2	P/P	80 - 120
2220307	Beryllium	92.6	93.7	P/P	80 - 120
2220307	Cadmium	95.2	96.8	P/P	80 - 120
2220307	Chromium	106	108	P/P	80 - 120
2220307	Copper	95.5	96.9	P/P	80 - 120
2220307	Lead	102	103	P/P	80 - 120
2220307	Nickel	97.9	98.9	P/P	80 - 120
2220307	Selenium	92.8	94.9	P/P	80 - 120
2220307	Silver	109	108	P/P	80 - 120
2220307	Thallium	99.8	102	P/P	80 - 120

Reference Method: EPA 300.0 Rev. 2.1

Batch ID: P392789

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220281	Chloride	102		P	90 - 110
2220423	Chloride	102		P	90 - 110

Reference Method: EPA 300.0 Rev. 2.1

Batch ID: P392790

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220281	Sulfate	103		P	90 - 110

Quality Assurance Report Matrix Spike Accuracy

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392790

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220423	Sulfate	102		P	90 - 110

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P393037

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2219957	Bromide	90.3		P	90 - 110
2220312	Bromide	97.8	97.3	P/P	90 - 110

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P393334

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220302	Ammonia-N	103	93.9	P/P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393057

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220178	Kjeldahl Nitrogen	94.1	106	P/P	90 - 110

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P392814

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220313	NO2NO3-N	94.5	94.0	P/P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392786

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220161	Total-P	102	103	P/P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392787

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220316	Total-P	104	103	P/P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0 dissolved
Batch ID: P392703

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220317	O-Phosphate-P	96.0	95.8	P/P	90 - 110

Reference Method: SM 4500 F-C-2011
Batch ID: P392867

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220650	Fluoride	98.3	99.5	P/P	94 - 107

Quality Assurance Report

Matrix Spike Accuracy

Reference Method: SM 5310 B-2011
Batch ID: P392985

Spiked Sample	Component	% Rec.1	% Rec.2	Pass/Fail	Control Limits
2220380	Organic Carbon	100	99.2	P/P	85 - 115

Quality Assurance Report Precision

Reference Method: EPA 180.1 Rev. 2.0
Batch ID: P392715

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220312	Turbidity	0.341	Sample	P	0 - 20

Reference Method: EPA 200.7 Rev. 4.4
Batch ID: P392709

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220307	Calcium	0.647	Spike	P	0 - 20
2220307	Iron	0.954	Spike	P	0 - 20
2220307	Magnesium	0.962	Spike	P	0 - 20
2220307	Manganese	2.15	Spike	P	0 - 20
2220307	Zinc	1.66	Spike	P	0 - 20

Reference Method: EPA 200.8 Rev. 5.4
Batch ID: P392709

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220307	Aluminum	2.27	Spike	P	0 - 20
2220307	Antimony	1.45	Spike	P	0 - 20
2220307	Arsenic	1.39	Spike	P	0 - 20
2220307	Beryllium	1.05	Spike	P	0 - 20
2220307	Cadmium	1.73	Spike	P	0 - 20
2220307	Chromium	1.98	Spike	P	0 - 20
2220307	Copper	1.46	Spike	P	0 - 20
2220307	Lead	1.43	Spike	P	0 - 20
2220307	Nickel	1.07	Spike	P	0 - 20
2220307	Selenium	2.27	Spike	P	0 - 20
2220307	Silver	0.393	Spike	P	0 - 20
2220307	Thallium	2.09	Spike	P	0 - 20

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392789

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220423	Chloride	0.819	Sample	P	0 - 20

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P392790

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220423	Sulfate	1.08	Sample	P	0 - 20

Reference Method: EPA 300.0 Rev. 2.1
Batch ID: P393037

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220312	Bromide	0.421	Spike	P	0 - 20

Quality Assurance Report Precision

Reference Method: EPA 350.1 Rev. 2.0
Batch ID: P393334

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220302	Ammonia-N	8.69	Spike	P	0 - 20

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393057

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220178	Kjeldahl Nitrogen	6.44	Spike	P	0 - 20

Reference Method: EPA 351.2 Rev. 2.0
Batch ID: P393091

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220350	Kjeldahl Nitrogen	3.80	Spike	P	0 - 20

Reference Method: EPA 353.2 Rev. 2.0
Batch ID: P392814

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220313	NO2NO3-N	0.456	Spike	P	0 - 20

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392786

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220161	Total-P	1.50	Spike	P	0 - 20

Reference Method: EPA 365.1 Rev. 2.0
Batch ID: P392787

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220316	Total-P	0.311	Spike	P	0 - 20

Reference Method: EPA 365.1 Rev. 2.0 dissolved
Batch ID: P392703

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220317	O-Phosphate-P	0.177	Spike	P	0 - 20

Reference Method: SM 2120 B-2011
Batch ID: P392710

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220321	Color (true)	1.31	Sample	P	0 - 20

Quality Assurance Report Precision

Reference Method: SM 2320 B-2011
Batch ID: P393214

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220650	Total Alkalinity	1.41	Sample	P	0 - 8.1

Reference Method: SM 2540 C-2011
Batch ID: P393018

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220315	TDS	5.04	Sample	P	0 - 10

Reference Method: SM 4500 F-C-2011
Batch ID: P392867

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220650	Fluoride	0.927	Spike	P	0 - 2.8

Reference Method: SM 5310 B-2011
Batch ID: P392985

Replicated Lab Sample	Component	% RSD/RPD	Sample/Spike/LCS*	Pass/Fail	Control Limits
2220380	Organic Carbon	0.680	Spike	P	0 - 20

* Sample, spike and/or laboratory control sample precision (LCS) is reported.

Quality Assurance Report Calibration Verification

Reference Method: EPA 300.0 Rev. 2.1

Run ID: A103154

Included Lab Sample IDs: 2220315

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Chloride	99.9	101	P/P	90 - 110
Sulfate	100	101	P/P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0 dissolved

Run ID: A103162

Included Lab Sample IDs: 2220314, 2220317, 2220320

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
O-Phosphate-P	98.6	99.2	P/P	90 - 110
O-Phosphate-P	98.7	98.6	P/P	90 - 110
O-Phosphate-P	99.2	99.2	P/P	90 - 110

Reference Method: SM 2120 B-2011

Run ID: A103163

Included Lab Sample IDs: 2220315

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Color (true)	101	102	P/P	90 - 115

Reference Method: EPA 180.1 Rev. 2.0

Run ID: A103165

Included Lab Sample IDs: 2220312, 2220315, 2220318

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Turbidity	102	102	P/P	95 - 105

Reference Method: EPA 353.2 Rev. 2.0

Run ID: A103210

Included Lab Sample IDs: 2220313, 2220316, 2220319

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
NO2NO3-N	100	100	P/P	90 - 110

Reference Method: EPA 200.7 Rev. 4.4

Run ID: A103221

Included Lab Sample IDs: 2220338, 2220339

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Calcium	102	103	P/P	90 - 110
Calcium	99.5	99.8	P/P	90 - 110
Iron	102	104	P/P	90 - 110
Iron	105	104	P/P	90 - 110
Magnesium	103	102	P/P	90 - 110
Magnesium	99.4	99.8	P/P	90 - 110
Manganese	102	102	P/P	90 - 110
Manganese	102	102	P/P	90 - 110
Zinc	105	104	P/P	90 - 110
Zinc	97.7	104	P/P	90 - 110

Quality Assurance Report Calibration Verification

Reference Method: EPA 365.1 Rev. 2.0

Run ID: A103224

Included Lab Sample IDs: 2220313

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Total-P	101	100	P/P	90 - 110

Reference Method: SM 4500 F-C-2011

Run ID: A103225

Included Lab Sample IDs: 2220312, 2220315, 2220318

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Fluoride	101	102	P/P	90 - 110

Reference Method: EPA 365.1 Rev. 2.0

Run ID: A103237

Included Lab Sample IDs: 2220316, 2220319

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Total-P	99.5	95.8	P/P	90 - 110

Reference Method: SM 5310 B-2011

Run ID: A103265

Included Lab Sample IDs: 2220313, 2220316, 2220319

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Organic Carbon	100	99.6	P/P	90 - 110
Organic Carbon	101	100	P/P	90 - 110

Reference Method: EPA 300.0 Rev. 2.1

Run ID: A103266

Included Lab Sample IDs: 2220312, 2220318

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Bromide	96.0	96.5	P/P	90 - 110
Bromide	96.5	96.8	P/P	90 - 110

Reference Method: EPA 200.8 Rev. 5.4

Run ID: A103276

Included Lab Sample IDs: 2220338, 2220339

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Aluminum	97.0	97.0	P/P	90 - 110
Aluminum	97.2	98.0	P/P	90 - 110
Antimony	99.3	99.4	P/P	90 - 110
Antimony	99.6	100	P/P	90 - 110
Arsenic	101	101	P/P	90 - 110
Arsenic	97.7	97.7	P/P	90 - 110
Beryllium	96.3	96.8	P/P	90 - 110
Beryllium	99.3	98.3	P/P	90 - 110
Cadmium	97.3	97.4	P/P	90 - 110
Chromium	103	106	P/P	90 - 110
Chromium	104	105	P/P	90 - 110
Copper	94.2	94.9	P/P	90 - 110
Copper	97.2	99.2	P/P	90 - 110
Lead	102	102	P/P	90 - 110

Quality Assurance Report Calibration Verification

Reference Method: EPA 200.8 Rev. 5.4

Run ID: A103276

Included Lab Sample IDs: 2220338, 2220339

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Lead	102	102	P/P	90 - 110
Nickel	95.5	96.6	P/P	90 - 110
Nickel	98.0	100	P/P	90 - 110
Selenium	96.4	96.1	P/P	90 - 110
Selenium	98.1	99.8	P/P	90 - 110
Silver	104	106	P/P	90 - 110
Silver	105	107	P/P	90 - 110
Thallium	103	104	P/P	90 - 110
Thallium	103	103	P/P	90 - 110

Reference Method: EPA 200.8 Rev. 5.4

Run ID: A103299

Included Lab Sample IDs: 2220338

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Cadmium	98.7	97.6	P/P	90 - 110

Reference Method: EPA 351.2 Rev. 2.0

Run ID: A103322

Included Lab Sample IDs: 2220313, 2220316, 2220319

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Kjeldahl Nitrogen	97.7	99.3	P/P	90 - 110
Kjeldahl Nitrogen	99.4	98.5	P/P	90 - 110

Reference Method: SM 2320 B-2011

Run ID: A103352

Included Lab Sample IDs: 2220312, 2220315, 2220318

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Total Alkalinity	93.7	95.3	P/P	90 - 110

Reference Method: EPA 350.1 Rev. 2.0

Run ID: A103396

Included Lab Sample IDs: 2220313, 2220316, 2220319

Component	% Rec.1	% Rec.2	Pass/Fail*	Control Limits
Ammonia-N	94.7	103	P/P	90 - 110

* Pass/Fail determinations are made for each bracketing calibration verification check.

Control limits for initial calibration checks may be different from those for continuing checks, depending on method requirements.

Where they are different, both control limits are provided.

Quality Assurance Report Summary

Ref. Method	Analyte	LCS % Recovery	MS % Recovery			Precision SMP	MS
			LCS				
EPA 180.1 Rev. 2.0	Turbidity					0.341	
EPA 200.7 Rev. 4.4	Calcium	106	109	111	110		0.647
	Iron	108	110	113	114		0.954
	Magnesium	107	109	111	112		0.962
	Manganese	99.4	101	105	102		2.15
	Zinc	101	104	106	104		1.66
EPA 200.8 Rev. 5.4	Aluminum	97.4	93.8	96.0	95.1		2.27
	Antimony	104	102	103	100		1.45
	Arsenic	101	96.9	98.2	96.5		1.39
	Beryllium	96.3	92.6	93.7	93.1		1.05
	Cadmium	96.7	95.2	96.8	93.8		1.73
	Chromium	106	106	108	102		1.98
	Copper	98.9	95.5	96.9	94.8		1.46
	Lead	103	102	103	101		1.43
	Nickel	99.7	97.9	98.9	94.0		1.07
	Selenium	98.6	92.8	94.9	92.0		2.27
	Silver	109	109	108	106		0.393
	Thallium	101	99.8	102	102		2.09
EPA 300.0 Rev. 2.1	Bromide	99.0	97.8	97.3	90.3		0.421
	Chloride	101	102	102		0.819	
	Sulfate	103	102	103		1.08	
EPA 350.1 Rev. 2.0	Ammonia-N	103	103	93.9			8.69
EPA 351.2 Rev. 2.0	Kjeldahl Nitrogen	96.1	94.1	106			6.44
	Kjeldahl Nitrogen	96.1					3.80
EPA 353.2 Rev. 2.0	NO2NO3-N	100	94.5	94.0			0.456
EPA 365.1 Rev. 2.0	Total-P	104	102	103			1.50
	Total-P	105	104	103			0.311
EPA 365.1 Rev. 2.0 dissolved	O-Phosphate-P	97.1	96.0	95.8			0.177
SM 2120 B-2011	Color (true)	99.5				1.31	
SM 2320 B-2011	Total Alkalinity	97.1				1.41	
SM 2540 C-2011	TDS					5.04	
SM 4500 F-C-2011	Fluoride	98.6	98.3	99.5			0.927
SM 5310 B-2011	Organic Carbon	99.2	100	99.2			0.680

Reference Method Descriptions

Method	Description	Associated Samples
EPA 180.1 Rev. 2.0	Turbidity in aqueous matrices	2220312, 2220315, 2220318
EPA 200.7 Rev. 4.4	Total Recoverable Metals analysis using ICP emission spectroscopy for aqueous samples supporting Clean Water Act Projects	2220338, 2220339
EPA 200.8 Rev. 5.4	Total Recoverable Metals analysis using ICP-MS for aqueous samples supporting Clean Water Act Projects	2220338, 2220339
EPA 300.0 Rev. 2.1	Bromide in aqueous matrices	2220312, 2220318
EPA 300.0 Rev. 2.1	Chloride in aqueous matrices	2220315
EPA 300.0 Rev. 2.1	Sulfate in aqueous matrices	2220315
EPA 350.1 Rev. 2.0	Ammonia in aqueous matrices as mg N/L	2220313, 2220316, 2220319
EPA 351.2 Rev. 2.0	Total Kjeldahl Nitrogen in aqueous matrices	2220313, 2220316, 2220319
EPA 353.2 Rev. 2.0	Nitrite/Nitrate in aqueous matrices as mg N/L	2220313, 2220316, 2220319
EPA 365.1 Rev. 2.0	Total Phosphorus in aqueous matrices as mg P/L	2220313, 2220316, 2220319
EPA 365.1 Rev. 2.0 dissolved	Ortho-phosphate, dissolved, in filtered, aqueous matrices as mg P/L	2220314, 2220317, 2220320
SM 2120 B-2011	True Color measured at 450 nm (not valid for NPDES monitoring)	2220315
SM 2320 B-2011	Alkalinity in aqueous matrices as mg CaCO3/L	2220312, 2220315, 2220318

Reference Method Descriptions

Method	Description	<u>Associated Samples</u>
SM 2540 C-2011	Total Dissolved Solids in aqueous matrices	2220315
SM 2540 D-2011	Total Suspended Solids in aqueous matrices using a maximum of 250 mL of sample	2220312, 2220315, 2220318
SM 4500 F-C-2011	Fluoride in aqueous matrices, without distillation (not valid for NPDES monitoring)	2220312, 2220315, 2220318
SM 5310 B-2011	Nonpurgeable Organic Carbon in aqueous matrices	2220313, 2220316, 2220319

Preparation and Analysis Log

Ref. Method	Received Date	Prep Date/Time	Prepared By	Analysis Date/Time	Analyzed By	Associated Samples
EPA 180.1 Rev. 2.0	01/21/2021			01/21/2021 15:02	Yen Ta	2220312, 2220315, 2220318
EPA 200.7 Rev. 4.4	01/21/2021	01/21/2021 16:35	Elliott D. Healy	01/25/2021 12:02	Betina Topolski	2220339
	01/21/2021	01/21/2021 16:35	Elliott D. Healy	01/25/2021 15:16	Betina Topolski	2220338
EPA 200.8 Rev. 5.4	01/21/2021	01/21/2021 16:35	Elliott D. Healy	01/27/2021 18:09	Alexander Thompson	2220339
	01/21/2021	01/21/2021 16:35	Elliott D. Healy	01/27/2021 20:52	Alexander Thompson	2220338
	01/21/2021	01/21/2021 16:35	Elliott D. Healy	01/28/2021 13:02	Alexander Thompson	2220338
EPA 300.0 Rev. 2.1	01/21/2021			01/22/2021 17:21	Lipi Saha	2220315
	01/21/2021			01/27/2021 14:54	Lipi Saha	2220312
	01/21/2021			01/27/2021 20:38	Lipi Saha	2220318
EPA 350.1 Rev. 2.0	01/21/2021			02/03/2021 17:08	Ping Hua	2220313
	01/21/2021			02/03/2021 17:09	Ping Hua	2220316
	01/21/2021			02/03/2021 17:11	Ping Hua	2220319
EPA 351.2 Rev. 2.0	01/21/2021	01/28/2021 13:00	Yen Ta	01/29/2021 13:36	Julia Storbeck	2220313
	01/21/2021	01/28/2021 13:00	Yen Ta	01/29/2021 13:38	Julia Storbeck	2220316
	01/21/2021	01/28/2021 13:00	Yen Ta	01/29/2021 14:17	Julia Storbeck	2220319
EPA 353.2 Rev. 2.0	01/21/2021			01/25/2021 09:51	Beverly Y. Sanders	2220313
	01/21/2021			01/25/2021 09:59	Beverly Y. Sanders	2220316
	01/21/2021			01/25/2021 10:01	Beverly Y. Sanders	2220319
EPA 365.1 Rev. 2.0	01/21/2021	01/22/2021 17:15	Shengyu Wang	01/25/2021 16:34	Lipi Saha	2220313
	01/21/2021	01/22/2021 17:15	Shengyu Wang	01/26/2021 11:05	Shengyu Wang	2220316
	01/21/2021	01/22/2021 17:15	Shengyu Wang	01/26/2021 11:06	Shengyu Wang	2220319
EPA 365.1 Rev. 2.0 dissolved	01/21/2021			01/21/2021 14:21	Blanca Fach	2220317
	01/21/2021			01/21/2021 14:32	Blanca Fach	2220320
	01/21/2021			01/21/2021 14:50	Blanca Fach	2220314
SM 2120 B-2011	01/21/2021			01/21/2021 16:29	Benjamin T. Nordmann	2220315
SM 2320 B-2011	01/21/2021			01/29/2021 17:37	Dale L. Simmons	2220312
	01/21/2021			01/29/2021 17:47	Dale L. Simmons	2220315
	01/21/2021			01/29/2021 17:53	Dale L. Simmons	2220318
SM 2540 C-2011	01/21/2021			01/22/2021 15:16	Yijie Li	2220315
SM 2540 D-2011	01/21/2021			01/22/2021 15:16	Yijie Li	2220312, 2220315, 2220318
SM 4500 F-C-2011	01/21/2021			01/23/2021 00:35	Dale L. Simmons	2220312
	01/21/2021			01/23/2021 00:48	Dale L. Simmons	2220315
	01/21/2021			01/23/2021 00:57	Dale L. Simmons	2220318
SM 5310 B-2011	01/21/2021			01/25/2021 23:24	Madeline Gruver	2220313
	01/21/2021			01/26/2021 00:02	Madeline Gruver	2220316
	01/21/2021			01/26/2021 00:14	Madeline Gruver	2220319