

From: mjarabek@weilerengineering.org
To: "LaDouceur, Therese J."
Cc: "Miller, Tina"; "Walton, Doreen"; rpalmer@weilerengineering.org
Subject: RE: Little Manatee River SP Water Treatment Modifications
Date: Tuesday, June 6, 2023 11:42:41 AM
Attachments: [image001.png](#)
[Little Manatee River Water System Plans Signed.pdf](#)

Therese,

Please see the attached plans that were delivered to the Client. The Client is going to be reviewing the plans and sending the project to bid in the coming weeks. Is there anything we need to do in the meantime?

Megan Jarabek, Permitting Specialist

Civil Engineering
The Weiler Engineering Corporation
201 W. Marion Ave.
Punta Gorda, FL 33950
Office: (941)505-1700 (ext. 211)



From: LaDouceur, Therese J. <Therese.LaDouceur@flhealth.gov>
Sent: Tuesday, June 6, 2023 11:25 AM
To: mjarabek@weilerengineering.org
Cc: Miller, Tina <tina.miller@dep.state.fl.us>; Walton, Doreen <doreen.walton@floridadep.gov>
Subject: RE: Little Manatee River SP Water Treatment Modifications

I am just following up on the new tank. Has it been ordered? I am still waiting for the information I requested below

For additional information go to the [Drinking Water Program Website](#)

Therese LaDouceur
Environmental Supervisor II
Safe Drinking Water

Florida Department of Health – Hillsborough County
1105 E Kennedy Blvd, Room 201
PO Box 5135
Tampa, FL 33675-5135
(813) 307-8059 Front Desk
(813) 559-4334 Direct Line

How is my customer service? [Click here to take our Environmental Health Customer Satisfaction Survey](#)

Please note: Florida has a very broad public records law. Most written communications to or from state officials regarding state business are public records available to the public and media upon request. Your e-mail communications may therefore be subject to public disclosure.

From: LaDouceur, Therese J.

Sent: Monday, April 24, 2023 3:39 PM

To: mjarabek@weilerengineering.org

Subject: Little Manatee River SP Water Treatment Modifications

You will not need a permit to make these replacements, but before we can approve the project, I will need spec sheets of the new 5600 gallon tank showing it is ANSI/NSF approved, a spec sheet for what you are using for lining the hydropneumatics tank. Also submit an updated as built plan, signed and sealed, showing the bypass, gravity drain, pressure relief valve screened with 24# mesh, pressure gauge and sight glass. It should include the new aerator ground storage tank, bypass and drain.

For additional information go to the [Drinking Water Program Website](#)

Therese LaDouceur
Environmental Supervisor II
Safe Drinking Water

Florida Department of Health – Hillsborough County
1105 E Kennedy Blvd, Room 201
PO Box 5135
Tampa, FL 33675-5135
(813) 307-8059 Front Desk
(813) 559-4334 Direct Line

How is my customer service? [Click here to take our Environmental Health Customer Satisfaction Survey](#)

Please note: Florida has a very broad public records law. Most written communications to or from state officials regarding state business are public records available to the public and media upon request. Your e-mail communications may therefore be subject to public disclosure.