

Jimmy Patronis
CHIEF FINANCIAL OFFICER

Julius Halas
DIVISION DIRECTOR



John Gatlin
BUREAU CHIEF

FLORIDA DEPARTMENT OF FINANCIAL SERVICES
DIVISION OF STATE FIRE MARSHAL
200 EAST GAINES STREET - Tallahassee, Florida 32399-0342
Tel. 850-413-3644

December 29, 2021

Spencer Brennalt
Kimley Horn
2615 Centennial Blvd, Suite 102
Tallahassee, FL 32308

Permit #: SFM21-000342
Region: Northwest
County: Bay
Agency:
File #: 21-001746

Subject: State Fire Marshal Plans Review Status

Project Description: St. Andrews State Park Redevelopment - This project consists of the complete redevelopment of the existing entrance area, loop road, and boat ramp area. For the purpose of this application only the smaller gate house building is included for new buildings.

Site Name:
ST. ANDREWS STATE PARK
Address: 4607 STATE PARK LN
PANAMA CITY BEACH, FL 32408

Building: Gate House
Building #:
Project #: 61197C
Review Type: Formal Plan Review

Dear Sir / Madam:

Pursuant to Sections 633.011 and 633.085, Florida Statutes, the referenced project documents were reviewed for compliance with the Uniform Fire Safety Standards. The project documents as submitted were

Approved with Comments on: 12/29/2021

Inspections Required: Underground System Intermediate Final

Please respond in writing to the attached plan review comments. These comments may also include instructions to resubmit additional information and/or corrected project documents. Any resubmittals shall be in duplicate and should reference the Permit # found in the upper right reference block.

The State Fire Marshal's "Approved" stamped set of project documents are required to be on the construction site at all times until the project is complete.

If you have any questions contact the reviewing engineer below, or write to:

Division of State Fire Marshal
Plans Review Section
200 East Gaines Street
Tallahassee, FL 32399-0342
Fax: (850) 414-6119

Sincerely,

Cody Kelly
Reviewing Engineer
Phone: 850-413-3740

Permit#: SFM21-000342

Date Approved: 12/29/2021

The following items were noted:

1. Response Required: Depict all fire extinguisher and fire extinguisher cabinet locations on the floor plan or the life safety sheets or both and clearly identify in the legends. Ensure that the entire scope of work meets the 75 foot rule and square footage requirements of NFPA 10 for number, type and placement of extinguishers.