



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, FL 32399

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

November 15, 2023

NOTICE TO APPLICANTS ADDENDUM NO. ONE (1)

John Pennekamp Coral Reef State Park – Restroom Replacement DEP BID NO. BDC16-23/24

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE, SIGNED, WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Macey Robinson, Contracts Specialist, Bureau of Design and Construction, 3800 Commonwealth Boulevard, MS #520, Tallahassee, Florida, 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The following statements supersede & supplement the corresponding items in the specifications & drawings:

1. **Question:** On sheet S102 detail 1 Piling & Column Section it calls for at the bottom of the pile (1) #9 Mid rebar. What is the length of the #9 rebar?
Answer: The #9 mid rebar should be the full length of the pile.
2. **Question:** On sheet S101 under Augercast piles paragraph 1 it states:
"AUGERCAST PILES 1. AUGERCAST PILING SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH THE GEOTECHNICAL RECOMMENDATIONS AUGERCAST PILING SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH THE GEOTECHNICAL RECOMMENDATIONS AND INSTALLATION PROCEDURES CONTAINED IN THE GEOTECHNICAL REPORT "JOHN PENNEKAMP ELEVATED RESTROOM" (UES PROJECT #: 2130.1900055, UES REPORT #: 1720074)

PREPARED BY UNIVERSAL ENGINEERING SCIENCES ON 1 NOVEMBER 2019.” This report was not included in the bid document. Please provide the Geotech report.

Answer: Please find the geotechnical report attached.

The John Pennekamp Restroom Replacement Geotech Report is hereby incorporated into the bid package and supersedes those originally posted with the bid documents. The revised bid package can be found at [publicfiles.dep.state.fl.us - /DRP/BDC/BDC Public Files FY23-24/BDC16-23-24 Pennekamp - Restroom Replacement/](https://publicfiles.dep.state.fl.us/-/DRP/BDC/BDC%20Public%20Files%20FY23-24/BDC16-23-24%20Pennekamp%20Restroom%20Replacement/). Please contact the Bureau of Design and Construction’s Contracts Section at Macey.S.Robinson@FloridaDEP.gov with any questions.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.