



FLORIDA DEPARTMENT OF Environmental Protection

South District
PO Box 2549
Fort Myers FL 33902-2549
SouthDistrict@FloridaDEP.gov

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

In the Matter of an
Application for Permit by:

Michael Foster, Bureau Chief (BDC)
Florida Department of Environmental Protection
3900 Commonwealth Blvd
Tallahassee, FL 32399
Michael.foster@floridadep.gov

Permit Number: 281237-317-DWC/CM
Project: John C Pennekamp Restroom Replacement
Connected to: Key Largo WTD
County: Monroe

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number 281237-317-DWC/CM to construct a sewage collection/transmission system pursuant to Chapter 403, Florida Statutes (FS) and Florida Administrative Code (F.A.C.) Rules 62-4 and 62-604.

NOTICE OF RIGHTS

This action is final and effective on the date filed with the Clerk of the Department unless a petition for an administrative hearing is timely filed under Sections 120.569 and 120.57, F.S., before the deadline for filing a petition. On the filing of a timely and sufficient petition, this action will not be final and effective until a subsequent order of the Department. Because the administrative hearing process is designed to formulate final agency action, the subsequent order may modify or take a different position than this action.

Petition for Administrative Hearing

A person whose substantial interests are affected by the Department's action may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, F.S. Pursuant to Rules 28-106.201 and 28-106.301, F.A.C., a petition for an administrative hearing must contain the following information:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, and telephone number of the petitioner; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests are or will be affected by the agency determination;
- (c) A statement of when and how the petitioner received notice of the agency decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts that the petitioner contends warrant reversal or modification of the agency's proposed action;
- (f) A statement of the specific rules or statutes that the petitioner contends require reversal or modification of the agency's proposed action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wishes the agency to take with respect to the agency's proposed action.

The petition must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000, or via electronic correspondence at Agency_Clerk@dep.state.fl.us. Also, a copy of the petition shall be mailed to the applicant at the address indicated above at the time of filing.

Time Period for Filing a Petition

In accordance with Rule 62-110.106(3), F.A.C., petitions for an administrative hearing by the applicant and persons entitled to written notice under Section 120.60(3), F.S., must be filed within **14** days of receipt of this written notice. Petitions filed by any persons other than the applicant, and other than those entitled to written notice under Section 120.60(3), F.S., must be filed within **14** days of publication of the notice or within 14 days of receipt of the written notice, whichever occurs first. You cannot justifiably rely on the finality of this decision unless notice of this decision and the right of substantially affected persons to challenge this decision has been duly published or otherwise provided to all persons substantially affected by the decision. While you are not required to publish notice of this action, you may elect to do so pursuant Rule 62-110.106(10)(a).

The failure to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under [Sections 120.569](#) and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C. If you do not publish notice of this action, this waiver will not apply to persons who have not received written notice of this action.

Extension of Time

Under Rule 62-110.106(4), F.A.C., a person whose substantial interests are affected by the Department's action may also request an extension of time to file a petition for an administrative hearing. The Department may, for good cause shown, grant the request for an extension of time. Requests for extension of time must be filed with the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000, or via electronic correspondence at Agency_Clerk@dep.state.fl.us, before the deadline for filing a petition for an administrative hearing. A timely request for extension of time shall toll the running of the time period for filing a petition until the request is acted upon.

Mediation

Mediation is not available in this proceeding.

Judicial Review

Once this decision becomes final, any party to this action has the right to seek judicial review pursuant to Section 120.68, F.S., by filing a Notice of Appeal pursuant to Florida Rules of Appellate Procedure 9.110 and 9.190 with the Clerk of the Department in the Office of General Counsel (Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000) and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice must be filed within 30 days from the date this action is filed with the Clerk of the Department.

EXECUTION AND CLERKING

Executed in Fort Myers, Florida

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

Attachment:

Permit No. 281237-317-DWC

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this document and all attachments were sent on the filing date below to the listed persons:

R. Jeff Weiler, P.E. weiler7@me.com
Robin Palmer rpalmer@weilerengineering.org
Peter Rosasco construction@klwtd.com

FILING AND ACKNOWLEDGMENT

FILED, on this date, pursuant to Section 120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.



May 21, 2020

Clerk

Date



FLORIDA DEPARTMENT OF Environmental Protection

South District
PO Box 2549
Fort Myers FL 33902-2549
SouthDistrict@FloridaDEP.gov

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Noah Valenstein
Secretary

Michael Foster, Bureau Chief (BDC)
Florida Department of Environmental Protection
3900 Commonwealth Blvd
Tallahassee, FL 32399
Michael.foster@floridadep.gov

Permit Number: 281237-317-DWC/CM
Issued: May 21, 2020
Expires: May 20, 2025
Project: John C Pennekamp Restroom Replacement
Connected to: Key Largo WTD
County: Monroe

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4 and 62-604, Florida Administrative Code (F.A.C).

The above named permittee is hereby authorized to construct the facilities shown on the application and other documents on file with the Department and made a part hereof and specifically described as follows:

DESCRIPTION OF PROJECT: Replacement of the existing restroom facility by installation of 50 LF of 1.5" PVC SCH 80 force main and a new grinder pump station, per application materials received on April 7, 2020, with additional information last received on May 14, 2020.

LOCATION OF PROJECT: Section 14, Township 61S, Range 39E in Village of Islamorada, Florida, Monroe County.

OWNER OF SYSTEM: The owner and maintenance of the collection system after the system is placed into service shall be John Pennekamp Coral Reef State Park.

IN ACCORDANCE WITH: The limitations, requirements and other conditions set forth in this permit.

PERMIT CONDITIONS:

1. This permit is subject to the general conditions of Rule 62-4.160, F.A.C., as applicable. This rule is available at the Department's Internet site at: <http://www.flrules.org> [62-4.160, 5-1-03].
2. Upon completion of construction of the collection/transmission system project, and before placing the facilities into operation for any purpose other than testing for leaks or testing equipment operation, the permittee shall submit to the Department's South District Office at P.O. Box 2549, Fort Myers, FL 33902-2549 (by mail) or 2295 Victoria Avenue, Suite 364, Fort Myers, FL 33901 (by other delivery service) Form 62-604.300(8)(b), Request for Approval to Place a Domestic Wastewater Collection/Transmission System into Operation. This form is available at the Department's Internet site at: https://floridadep.gov/sites/default/files/62-604.300_8b.pdf [62-604.700(2), 11-6-03].
3. The new or modified collection/transmission facilities shall not be placed into service until the Department clears the project for use [62-604.700(3), 11-6-03].
4. Permit revisions shall only be made in accordance with Rule 62-4.050(4)(s), F.A.C. Request for revisions shall be made to the Department in writing and shall include the appropriate fee. Revisions not covered under Rule 62-4.050(4)(s), F.A.C., shall require a new permit [62-604.600(8), 11-6-03].
5. Abnormal events shall be reported to the Department's South District Office in accordance with Rule 62-604.550, F.A.C. For unauthorized spills of wastewater in excess of 1000 gallons per incident, or where information indicates that public health or the environment may be endangered, oral reports shall be provided to the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519 as soon as practical, but no later than 24 hours from the time the permittee or other designee becomes aware of the circumstances. Unauthorized releases or spills less than 1000 gallons per incident

are to be reported orally to the Department's South District Office at phone number (239)-344-5600 within 24 hours from the time the permittee, or other designee becomes aware of the circumstances [62-604.550, 11-6-03].

6. This permit is for CONSTRUCTION ONLY of the collection/transmission system project. This permit does not authorize the connection of this collection/transmission system project to the designated wastewater treatment plant. This permit shall not be construed to infer that the clearance necessary for connection shall be granted.

SPECIFIC PERMIT CONDITIONS

1. All new wastewater collection/transmission systems and modifications of existing systems shall be located at least 100 feet from a public drinking water supply well.
2. Except as provided in Section 62-604.400(3), F.A.C., sewer pipes/force mains should cross under water mains.
3. For sewer crossings, all crossings shall be arranged so that the sewer pipe joints are equidistant as far as possible from the water main joints. At crossings, all vacuum sewer joints must maintain a minimum distance of 3 feet from water main joints. All gravity or pressure type sanitary sewers and wastewater force main joints shall maintain a minimum distance of 6 feet from water main joints.
4. Except as provided under 62-604.400(3), F.A.C., all sewers and force mains shall be laid at least 10 feet horizontally (outside to outside) from a water main and 3 feet minimum (outside to outside) from a reclaimed water pipe permitted under Part III of Chapter 62-610, F.A.C.
5. A vertical separation of at least 18 inches must be maintained when a sewer pipe crosses a water main, except as provided under Section 62-604.400(3), F.A.C.
6. When any existing asbestos cement (AC) pipes are replaced under this permit, the permittee shall do so in accordance with the applicable rules of Federal Asbestos Regulation and Florida DEP requirements. For specific requirements applicable to AC pipes, the permittee should contact the Department prior to commencing any such activities at (239) 344-5600. Please be aware that a notification is required to be submitted to the Department for a regulated project.
7. The operation and maintenance of the collection system shall be in accordance with the requirements of section 62-604.500, F.A.C.
8. This project has been approved with the use of 6" gravity sewer due to low flow and the 6" service connection provided by the Village of Islamorada.

Executed in Fort Myers, Florida
STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of District Management