



FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, FL 32399

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

April 2, 2024

NOTICE TO APPLICANTS ADDENDUM NO. FIVE (5)

**John Pennekamp Coral Reef State Park- Restroom Replacement
DEP BID NO. BDC22-23/24**

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED
PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE, SIGNED, WITH
YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Laurinda Micheels, Contracts Specialist, Bureau of Design and Construction, 3800 Commonwealth Blvd., MS #520, Tallahassee, Florida, 32399-3000. Failure to do so may be grounds for rejection of the Bid.

Signature of Contractor and Date

The following statements supersede & supplement the corresponding items in the specifications & drawings:

- 1. Question:** There are concerns with crossing the wooden bridge leading to the project location. Specifically, the weight of concrete trucks, dump trucks, cranes, etc. What is the bridge gross weight limit?

Answer: The contractor shall be advised there is a maximum limit of 31.5 tons per axle on the Beach Road over Calley Slough Bridge.
- 2. Question:** Can the question deadline and due date be extended until after the bridge load rating is answered for additional questions that could arise based on the bridge rating?

Answer: The issue of this addendum does not affect the bid opening date of April 11, 2024.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.