

Carron, Theresa

From: Leslie Weiss <lahope@hydraengineering.com>
Sent: Thursday, December 14, 2023 9:16 AM
To: Carron, Theresa
Cc: Alexis Browning; Dylan Jones
Subject: RE: Alafia SP Hurrah Creek Bridge Replacement

EXTERNAL MESSAGE

This email originated outside of DEP. Please use caution when opening attachments, clicking links, or responding to this email.

Good morning Teri,

There should not be any need for a pre-demolition and lead-based paint survey for the existing structure since it is wood.

Thanks!

Leslie Weiss, PE, GCG, F.ASCE
President
Hydra Engineering & Construction, LLC
36 Jasper Thomas Road
Crawfordville, FL 32327
Office (850) 926-2593

From: Carron, Theresa <Theresa.Carron@dep.state.fl.us>
Sent: Tuesday, December 12, 2023 11:35 AM
To: Leslie Weiss <lahope@hydraengineering.com>; Leslie Weiss <lahope@hydraengineering.com>
Subject: Alafia SP Hurrah Creek Bridge Replacement

Hi Leslie,

I know we are getting close with permitting. I called Aaron/FELSI this morning.

I submitted a compliance review request to DHR today because of the excavation and pile installations required for this project. I'll send you DHR's response when I get it.

Do you think a pre-demolition asbestos and lead-based paint survey is needed on the existing structure? Please advise.

Thanks,
Teri



Theresa Carron
Project Manager
Bureau of Design and Construction
Division of Recreation and Parks
3800 Commonwealth Boulevard, MS 520
Theresa.Carron@FloridaDEP.gov

Office: 850-245-2721

Cell: 850-294-4642

This communication does not constitute an authorization for any increase in the scope of work, cost, or time for the project being discussed. All changes to services, cost, or time must be accomplished in accordance with the formal process outlined in the contract. The DEP objects to, and shall not be responsible for, any changes to services, costs, or additional time not authorized by an executed Contract Amendment, Task Assignment Change Order, Construction Change Order, or Construction Change Directive, as appropriate for the contract.

