FLORIDA DEPARTMENT OF Environmental Protection

Marjory Stoneman Douglas Building
3900 Commonwealth Boulevard
Tallahassee, FL 32399

Ron DeSantis
Governor

Jay Collins
Lt. Governor

Alexis A. Lambert
Secretary

November 21, 2025

NOTICE TO APPLICANTS
ADDENDUM NO. ONE (1)

O'Leno State Park – Boardwalk Replacement
DEP BID NO. BDC09-25/26

TO BIDDERS AND PLAN HOLDERS ON THE ABOVE REFERENCED PROJECT: PLEASE NOTE CONTENTS HEREIN AND INCLUDE, SIGNED, WITH YOUR BID SUBMISSION.

NOTICE

It will be required that this addendum be signed in acknowledgment of receipt and that it be included with your Bid when same is submitted to Laurinda Micheels, Contracts Specialist, Bureau of Design and Construction, 3800 Commonwealth Blvd., MS #520, Tallahassee, Florida, 32399-3000. Failure to do so may be grounds for rejection of the Bid.

_____
Signature of Contractor and Date

The following statements supersede & supplement the corresponding items in the specifications & drawings:

1. **Question:** Is there more information about the piles? I do see 2 7/8" with a 10/12 design but I did not see an actual count. Are there only 12? How deep is the estimated depth?
   Answer: The total number of piles indicated in the plans is twelve (12). With respect to the depth of the piles, due to the limited soil information the actual depth required to achieve the design compression load of 8 kips is unknown; however, based on work performed on a previous project, we anticipate the load can be achieved with piles embedded into the soil 20 ft and less. Ultimately, the installed length to achieve the required capacity will be the responsibility of the contractor.

In all other respects, the contract documents of which this is an Addendum, and attachments relative thereto, shall remain in full force and effect.