DWELLING #1

100'-¾" LINE

DWELLING #2

200'-1" LINE

DWELLING #3

¾

DWELLING #4

¾

PUMP HOUSE

3" WELL

20'-1½" LINE

45'-1¼" LINE

3000 GAL. PRESSURE TANK

35'-2½" LINE

15'-2½"

DISCARDED FIRE PLUG

40'-1"

90'-1"

DWELLING #5

DWELLING #6

7200 V.

710'-1½" LINE

900'-1¼" LINE

DWELLING #7

SHOP

500'-1" LINE

7200 V. SINGLE PHASE

GUEST HOUSE

1100'-1¼" LINE

7200 V. SINGLE PHASE

DWELLING #8

DWELLING #9

100'-¾" LINE

To REYNOLDS

To BLOUNTS CAMP

7200 V

POWER PLANT

960'-1" LINE

240'-¾" LINE

2300 V. 3 PHASE BRADWELL

2300-41 S.P. DIST.

STORE ROOM

CLUB HOUSE

7200 V. SINGLE PHASE DIST.

N

WATER AND ELECTRIC DISTRIBUTION

JACKSON BLUFF

NOT TO SCALE

DISTANCES AS MARKED 5-5-55 FMR

DOES NOT INCLUDE VARIOUS WATER TAPS INSTALLED BY EMPLOYEES TO GARDENS.

DWG. No. D-405-J

RECEIVED
FLORIDA POWER CORP.
MAR. 18 1952
PRODUCTION DEPT.
STORES & PURCHASING DIV.