



Department of Environmental Protection

2600 Blair Stone Road ♦ Tallahassee, Florida 32399-2400

DEP Form: 62-762.901(9)

Form Title: Storage Tank Equipment

Registration Form

Effective Date: July 2019

Incorporated in Rule 62-762.851, F.A.C.

Storage Tank System Equipment Registration Form

Fill out completely

General Information

Company Name:

Contact Name:

Company Address:

City, State:

Zip:

E-mail:

Contact Number:

Product Name:

Product Type:

Model Number(s):

Rule(s) citation that registration is being requested within Chapter 62-761 (UST), and/or 62-762 (AST), F.A.C.:

Write a brief description of equipment registration request including product limitations:

Information Checklist (Choose Yes, No, or N/A - Not Applicable):

Yes No N/A

1. Third-party Certification by a Nationally Recognized Testing Laboratory? (Required)
2. Documentation of third-party evaluation that the equipment meets DEP Rules?
3. Documents included about the qualifications of the Nationally Recognized Testing Laboratory?
4. Technical information and drawings included?
5. Installation instructions included?
6. Annual Operability Testing Requirements (Rules 62-761.500, 62-762.501, & 62-762.502 F.A.C.)?
7. Integrity Testing Requirements (Rules 62-761.700, 62-762.701, & 62-762.702, F.A.C.)?
8. Compatible with fuel blends containing >10% ethanol or >20% biodiesel?
9. Has the product been approved or registered in other countries or states? (If so provide list)
10. Any requirements for company-certified installers or trainers?
11. Was this product(s) previously approved or registered by the Department? If yes, EQ-
12. Any changes or modifications to the equipment since the last submittal to DEP?

Document Information: Provide supporting documents indicated as "Yes" above including this form via email to Tanknotify@floridadep.gov, or documents can be sent to FDEP, Division of Waste Management, 2600 Blair Stone Road, MS 4560, Tallahassee, FL 32399.

Write a brief description of equipment installation and performance in the U.S.:

Equipment Registration Certification:

To the best of my knowledge and belief, all information submitted on this form is true, accurate and complete.

Printed Name and Title

Signature (right click to sign)

Date

For Department Use Only:

Date Application Received:

Application complete:

Yes:

No: Re

EQ-

Date of complete or incomplete letter sent:

Date Equipment Requires Renewal:

Storage tank system equipment requires renewal every 5 years in accordance with subsection 62-762.851(2), F.A.C.

Certificate of Compliance

Certificate Number:

UL-US-2448143-0

Report Reference:

MH67200-20241210

Issue Date:

2024-12-19

Issued to:

**Custom Site Solutions LLC
1605 White Lake Drive Inverness, FL 34453
United States**

This certificate confirms that representative samples of:
EFVT - Special-purpose Tanks

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 142A, 1st Ed., Issue Date: 2018-5-25, Revision Date: 2021-1-21

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2448143-0
Report reference MH67200-20241210
Date 2024-12-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
Generator Base Tanks	Fixed and Stationary Storage Tanks



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

D

C

B

A

PARTS LIST				
QTY	PART NUMBER	Length	Width	Thickness
1	19	71.750 in	145.750 in	0.179 in


FITTINGS	
FITTING	DESCRIPTION
A	2" X 1/2" NPT FUEL SUPPLY DROP TUBE
B	2" X 1/2" NPT FUEL RETURN DROP TUBE
C	NOT USED
D	1-1/2" NPT FUEL GAUGE
E	2" NPT NORMAL VENT
F	6" NPT PRIMARY EMERGENCY VENT
G	2" NPT TOP MOUNT BASIN SWITCH
H	2" NPT IOCKABLE FUEL FILL
J	6" NPT SECONDARY EMERGENCY VENT
K	2" NPT SPARE PORT (QTY: 2)

D


C

B

A



DRAWN Golden Ticket Sol.	7/4/2024	Customer: CCS		
CHECKED		TITLE		
QA		TEST TANK (End Stub)		
MFG				
APPROVED		SIZE D	DWG NO Foundation Tank (End Stub)	REV .03
		SCALE 1 / 8	SHEET 2 OF 7	



D

C

B


A

D

C

B

A



DRAWN	Golden Ticket Sol.	7/4/2024	Customer: CCS		
CHECKED			TITLE		
QA			TEST TANK (End Stub)		
MFG			REV		
APPROVED			Foundation Tank (End Stub) ⁰³		
SCALE	1 / 10		SHEET 7 OF 7		