Department of
Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

January 24, 2003

Certified Mail
Return Receipt Requested: 7001 0320 0001 7977 0062

Mr. Tony P. Adamson
VP Sales & Marketing
Total Containment, Inc.
P.O. Box 939
Oaks, Pennsylvania 19456

RE: DEP Approval of The Omniflex model numbers CP 1503, CP 1503F, CP 1503BF, CP2503F, and CP2503BF piping systems, File No. EQ-552

Dear Mr. Adamson:

The Bureau of Petroleum Storage Systems has concluded its review of the Equipment Approval requests dated December 23, and December 26, 2002, that were submitted for the above referenced equipment pursuant to Rule 62-761.850, Florida Administrative Code (F.A.C.), by Total Containment, Inc., (TCI).

Based on the information provided, the Department finds that TCI's Omniflex model numbers CP 1503, CP 1503F, CP 1503BF, CP2503F, and CP2503BF piping systems will provide, in conjunction with the conditions below, environmental protection substantially equivalent to that provided by compliance with the requirements established in Rules 62-761.500(1)(e), 62-761.500(4)(b)1., and 62-761.500(4)(e)1., F.A.C.

Pursuant to Rule 62-761.850, F.A.C., the request for the use of the above referenced products is approved in the State of Florida as small diameter piping with secondary containment that is in contact with the soil provided the following conditions are followed:

a) The Omniflex piping system model numbers CP 1503, CP 1503F, CP 1503BF, CP2503F, and CP2503BF must be installed in accordance with TCI installation instructions for direct burial or for installation within TCI SP 4500 secondary containment piping. The piping may also be installed within another approved non-polyethylene impervious secondary containment system that is