



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

August 11, 2009

Certified Mail

Return Receipt Requested: 7008 0150 0001 8479 0181

Mr. Greg Ludwig
Eco-Tank Systems, LLC
P.O. Box 474
Pottstown, Pennsylvania 19464

RE: Approval of the Eco-Tank TABS-C, TABS-CF, & TABS-F Systems
File No. EQ-738

Dear Mr. Ludwig:

The Bureau of Petroleum Storage Systems has concluded its review of the Equipment Approval request dated July 30, 2009, submitted for the above referenced equipment pursuant to Rule 62-761.850, Florida Administrative Code (F.A.C.).

Based on information provided by Eco-Tank Systems, LLC, the Department finds that the applicant's Eco-Tank TABS-C, TABS-CF, & TABS-F Systems will provide environmental protection substantially equivalent to that provided by compliance with the requirements established in Rules 62-762.501(1)(e), and 62-762.501(2)(f), F.A.C.


Pursuant to Rule 62-762.851, F.A.C., the request for the use of the Eco-Tank TABS-C, TABS-CF, & TABS-F Systems is approved as an aboveground storage tank overfill retention and tank shell monitoring system/Alternative Diked Field in the State of Florida provided that the system is equipped and operated with the following:

- a. Continuous tank shell monitoring with approved probes, cables, or electronic sensors;
 - b. Immediate electronic notification to the owner or operator of overfills and leaks from the tank shell;
 - c. Stormwater management;
 - d. An approved high and a high-high level overfill alarm system with an annual test of operability;
 - e. An impervious overfill retention system that will contain a volume of product that would be transferred at maximum flow rate for a period of five minutes by the pump(s) used for filling the tank; and
 - f. An automatic system for shutting off the pump(s) used for filling the tank by an electronic signal from the continuous tank shell monitoring system.
- The system must be designed to operate in conjunction with the impervious

Mr. Greg Ludwig
August 11, 2009
Page 6

Counsel at (850)245-2242. Contact with any of the above does not constitute a petition for administrative hearing (or time extension) or agreement to mediate.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael E. Ashe" with a stylized flourish at the end.

Michael E. Ashe, Chief
Bureau of Petroleum Storage Systems

MEA/fgm

FILING AND ACKNOWLEDGMENT
FILED, on this date, pursuant to §120.52
Florida Statutes, with the designated
Department Clerk, receipt of which is
hereby acknowledged.

A handwritten signature in black ink, appearing to read "Cheryl Stafford".

Clerk
(or Deputy Clerk)

8/11/09
Date