



Department of Environmental Protection

2600 Blair Stone Road ♦ Tallahassee, Florida 32399-2400

DEP Form: 62-762.901(9)
Form Title: Storage Tank Equipment
Registration Form
Effective Date: July 2019
Incorporated in Rule 62-762.851-F.A.C.

Storage Tank System Equipment Registration Form

Fill out completely

General Information

Company Name: Freeman Enclosure Systems Contact Name: Cassie Freeman
Company Address: 4160 Half Acre Rd City, State: Batavia, Ohio Zip: 45103
E-mail: cassie.freeman@freemanenclosures.com Contact Number: (513) 488-8563
Product Name: UL listed Double Wall above ground storage Tank
Model Number(s): _____ Product Type: steel double wall diesel storage tank
Rule(s) citation that registration is being requested within Chapter 62-761 (UST), and/or 62-762 (AST), F.A.C.: 62-762.501(2)(b)1 and 62-762.81(2)

Write a brief description of equipment registration request including product limitations:

Request that our UL 142 tanks (MH 47836) and STI's UL2085 tank (MH20579) be approved to be installed in the State of Florida compliant to local rules and regulations.

Information Checklist (Choose Yes, No, or N/A - Not Applicable):

	Yes	No	N/A
1. Third-party Certification by a Nationally Recognized Testing Laboratory? (Required)	☒	☐	☐
2. Documentation of third-party evaluation that the equipment meets DEP Rules?	☐	☒	☐
3. Documents included about the qualifications of the Nationally Recognized Testing Laboratory?	☒	☐	☐
4. Technical information and drawings included?	☒	☐	☐
5. Installation instructions included?	☐	☐	☒
6. Annual Operability Testing Requirements (Rules 62-761.500, 62-762.501, & 62-762.502 F.A.C.)?	☐	☐	☒
7. Integrity Testing Requirements (Rules 62-761.700, 62-762.701, & 62-762.702, F.A.C.)?	☒	☐	☐
8. Compatible with fuel blends containing >10% ethanol or >20% biodiesel?	☒	☐	☐
9. Has the product been approved or registered in other countries or states? (If so provide list)	☐	☒	☐
10. Any requirements for company-certified installers or trainers?	☐	☒	☐
11. Was this product(s) previously approved or registered by the Department? If yes, EQ- <u>785-R</u>	☒	☐	☐
12. Any changes or modifications to the equipment since the last submittal to DEP?	☐	☒	☐

Document Information: Provide supporting documents indicated as "Yes" above including this form via email to Tanknotify@floridadep.gov, or documents can be sent to FDEP, Division of Waste Management, 2600 Blair Stone Road, MS 4560, Tallahassee, FL 32399.

Write a brief description of equipment installation and performance in the U.S.:

Installation is intended for stationary use only. Installation is mostly for Sub base installation in combination with emergency generator systems. Installation can also include stand-alone applications. All designs are in accordance with UL142 or UL2085.

Equipment Registration Certification:

To the best of my knowledge and belief, all information submitted on this form is true, accurate and complete.

Cassie Freeman Engineering Mgr.
Printed Name and Title

Cassie Freeman
Signature (right click to sign)

12/9/22
Date

For Department Use Only:

Date Application Received: 12/9/2022 Application complete: Yes: ☒ No: ☐

EQ- 785-R Date of complete or incomplete letter sent: 12/13/2022 Date Equipment Requires Renewal: 12/13/2027

Storage tank system equipment requires renewal every 5 years in accordance with subsection 62-762.851(2), F.A.C.

**EFVT.MH47836**
Special-purpose Tanks[Page Bottom](#)

Special-purpose Tanks[See General Information for Special-purpose Tanks](#)**FREEMAN ENCLOSURE SYSTEMS L L C**

MH47836

4160 HALF ACRE RD
BATAVIA, OH 45103 USA**Secondary containment generator base tank.**[Last Updated](#) on 2010-10-25[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".



the standard in safety

Underwriters
Laboratories

File MH47836

Vol 1

Issued: 2010-10-25
Revised: 2010-10-25

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

SPECIAL-PURPOSE TANKS
(EFVT, EFVT7)

Manufacturer: FREEMAN ENCLOSURE SYSTEMS L L C
(100546-228) 4160 HALF ACRE RD
BATAVIA OH 45103

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products covered by this Procedure, in accordance with the applicable UL Services Agreement.

The prescribed Mark or Marking shall be used only at the above manufacturing location on such products which comply with this Procedure and any other applicable requirements.

The Procedure contains information for the use of the above named Manufacturer and representatives of Underwriters Laboratories Inc. and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it is not to be copied, either wholly or in part, and that it will be returned to Underwriters Laboratories Inc. (UL) or any authorized licensee of UL, upon request.

This PROCEDURE, and any subsequent revision, is the property of Underwriters Laboratories Inc. (UL) and the authorized licensee of UL and is not transferable.

Underwriters Laboratories Inc.

Stephen Hewson
Senior Vice President
Global Follow-Up Service Operations

William R. Carney
Director
North American Certification Program

41 Minor Tank Accessories

41.1 If provided, minor accessories intended for factory assembly or field installation to the tank shall comply with the requirements in [41.2](#).

41.2 Mounting brackets for small equipment shall not exceed 4.0 sq ft (single side projected area), and shall be constructed of at least 0.093 inch thick steel. Mounting brackets greater than 4.0 ft² shall comply with the Static Load Test in [38.3](#). The brackets and supporting structure shall be welded to the tank, or provided with bolted connections that are welded to the tank.

PERFORMANCE TEST METHODS

42 Tank Leakage Test

42.1 Caution

42.1.1 Caution – Testing with air pressure presents a risk of injury to persons and personnel should be instructed in precautions to be taken during such testing. The precautions should include the use of a pressure-relief device that will reduce the risk of the tank becoming pressurized in excess of the specified test pressure.

42.2 Primary containment tanks

42.2.1 The leakage test is to be conducted before painting the tank by a method described in (a) – (b). There shall be no evidence of leakage or sign of permanent deformation following the leakage test. For a production leakage test, the tank wall, head, or roof may deflect but shall return to its original general position and shape when the test pressure is released.

Note 1 – Permanent deformation for the purpose of leak test pass/fail assessment is metal bending with creases that can't be easily returned to the original condition. It is not intended to fail slight bulges and or sags that may be reduced by applying a minor force or pressure/vacuum.

Note 2 – For the production leak test, "... may deflect but shall return to its original position and shape..." is intended as a rough guideline, as it is recognized tanks are not precision products and may have naturally occurring deflections, so is not intended as a quality control measure. The degree of fabricating precision is to be determined by the manufacturer and purchaser.

a) Apply internal air pressure and use soap-suds, or equivalent material for the detection of leaks. For a horizontal tank, the test gauge pressure is to be not less than 3 psi (21 kPa) or more than 5 psi (35 kPa). For a vertical tank, the test gauge pressure is not to be less than 1-1/2 psi (10 kPa) nor more than 2-1/2 psi (17 kPa) or that gauge pressure above 1-1/2 psi which first causes visible deformation of the tank. For a rectangular tank, the test gauge pressure is not to be less than 1-1/2 psi (10 kPa) nor more than 3 psi (21 kPa) or that gauge pressure above 1-1/2 psi which first causes visible deformation of the tank; or

b) Completely fill the tank with water, applying the pressure specified in (a) hydrostatically, and examine the tank for leakage.

Note 3 – For guidance purposes, the clause "...which first causes visible deformation..." is intended to alert the test operator to be cautious of over pressure or vacuum which may cause difficulty in complying with [42.2.1](#).

42.2.2 Each compartment of a tank having two or more compartments is to be tested separately for leakage.

42.3 Secondary containment tanks

42.3.1 After completion of the primary containment shell, the tank is to be checked for leakage using the method described in [42.2.1](#) and [42.2.2](#) for primary containment tanks.

42.3.2 Upon completion of the finished secondary containment tank, the primary tank is again to be pressurized using the applicable method described in [42.2.1](#) – [42.2.2](#). For Performance Tests, the pressure shall be held for 1 hour to check for leakage. A continuous drop in pressure will be considered evidence of leakage. For production testing, the pressure shall be held in the primary tank only for the duration required to test the interstice using the method described in [42.3.3](#).

42.3.3 While maintaining pressure on the primary tank, the interstitial (annular) space bounded by the primary and secondary tank is to be pressurized to the pressures indicated in [42.2.1](#) and checked for external leakage by applying a leak detection solution. There shall be no evidence of leakage or sign of permanent deformation following the leakage test. A tank wall, head, or roof may deflect when subjected to the leakage test pressure, but shall return to its original position and shape when the test pressure is released.

42.3.4 As an option to the leakage test described in [42.3.2](#) and [42.3.3](#), the annular space may be tested by applying a vacuum of at least 13 inches of mercury for a minimum of 12 hours. If the tank is unable to maintain the vacuum (plus or minus 2 inches of mercury) for the specified time, the tank shall be retested using the method described in [42.3.2](#) and [42.3.3](#).

43 Hydrostatic Strength Test

43.1 General

43.1.1 The hydrostatic strength test is to be conducted as described in [43.3.1](#) and [43.4.1](#) using the test apparatus described in [43.2.1](#). Neither the primary containment tank nor the secondary containment shell shall rupture or leak when subjected to this test.

43.2 Test apparatus

43.2.1 The source of water pressure is to be capable of maintaining a gauge pressure of at least 30 psi (207 kPa) for a period of not less than 2 minutes. The pressure gauges are to be calibrated and have a dial range gauge pressure of 0 – 50 or 0 – 60 psi (345 or 415 kPa), a face size of at least 3-1/2 inches (89 mm) in diameter, graduations of a gauge pressure of 1 psi or 10 kPa maximum, and an accuracy of ± 1 percent of the full scale reading. Piping and fittings as shown in [Figure 43.1](#) are to be appropriate for the test pressure.

Fireguard®

LICENSED MANUFACTURER

Freeman Enclosure Systems, LLC
is a member of

STEEL TANK INSTITUTE

Division of STI/SPFA

and participant in the Fireguard® program
and is hereby authorized to manufacture Aboveground Tanks in accordance with the
Specification for Fire-Rated Lightweight Double Wall Steel Aboveground Storage Tanks

BOARD OF DIRECTORS

Henry C. Lott
President

Charm. Shaw
Secretary



Generator Base Tank

LICENSED MANUFACTURER

Freeman Enclosure Systems, LLC
is a member of

STEEL TANK INSTITUTE

Division of STI/SPTA

and participant in the Generator Base Tank program
and is hereby authorized to manufacture Aboveground Tanks in accordance
with the Standards for Aboveground Tanks used as a Generator Base Tank.

BOARD OF DIRECTORS

Terry Cagle
President

Wayne Dyer
Secretary



GENERAL NOTES:

1. EMERGENCY VENT SIZING BASED ON UL142 TABLE 8.1.
2. PORTS PER UL 142 SECTION 10
3. NORMAL VENTING PER UL 142 SECTION 8.11, TABLE 8.2
4. WELDS AND JOINTS PER UL SECTION 6 FIGURE 6.1, 6.2

GENERAL DESCRIPTION:

SUB BASE FUEL SUPPLY TANK
MINIMUM 10 GAUGE (.125") CONSTRUCTION
UL 142 OR UL 2085 LISTED DOUBLE WALL
NORMAL AND EMERGENCY VENTS
LOW LEVEL, HIGH LEVEL AND LEAK DETECTION
FLOAT SWITCHES
FILL
MECHANICAL FUEL GAUGE

ELECTRICAL
LEVEL ALARM PANEL

TANK DATA:
UNDERWRITERS LABORATORIES LISTING MH47836

CAPACITY GALLONS: 0-11,999
GALLONS PER IN OF DEPTH: NA
RUN TIME @FULL LOAD Hrs: NA
TANK WEIGHT DRY lbs: NA
TANK WEIGHT WET: lbs: NA
CONDUIT STUB AREA: (STRAIGHT)
TANK DIMS INCHES: 600 MAXL X 164 MAXW
X 50 MAXH
STATE SPEC: FLORIDA FDEP

TANK PORTS** :

A = 2" NORMAL TANK VENT
B = 3-12" EMERGENCY BASIN VENT
C = 3-12" EMERGENCY TANK VENT
D = 2" TANK SPARE PORT (FNPT)
E = MECHANICAL FUEL LEVEL GAUGE
F = 2" FILL
G = ENGINE SUPPLY
H = ENGINE RETURN
I = 2" TANK SPARE PORT (FNPT)
J = LOW LEVEL FLOAT SWITCH (EQ-682)
K = LEAK DETECTION FLOAT SWITCH (EQ-682)
L = HIGH LEVEL FLOAT SWITCH (EQ-682)


** TANK PORTS VARY IN LOCATION DUE TO INNER
CONSTRUCTION OF SUB BASE TANK, AND LOCATION
OF EQUIPMENT. DEPICTION SHOWN IS A
GENERALIZED LOCATION.

TANK EQUIPMENT:


M = FILL ALARM PANEL, LEAK ALARM PANEL.
AP-3, AP-3R OR OTHER APPROVED DEVICE
FROM EQ LIST
N = FUEL FILL STOP VALVE AS REQUIRED FROM
APPROVED EQ DEVICE LIST
P = OVERFILL SPILL CONTAINMENT F5G OR OTHER
APPROVED DEVICE FROM EQ LIST

REVISIONS:

EDITION	DESCRIPTION	DATE
0	ORIGINAL SUBMISSION RELEASE	02/23/12



OPEN CONDUIT STUB AREA




HEIGHT

2.00

WIDTH

2" SPACE FOR VISUAL
LEAK INSPECTION



THIS DOCUMENT IS CREATED BY AND IS THE PROPERTY OF FREEMAN ENCLOSURE SYSTEMS LLC. ITS USE IS AUTHORIZED ONLY FOR RESPONDING TO A REQUEST FOR QUOTATION OR FOR THE PERFORMANCE OF WORK FOR FREEMAN ENCLOSURE SYSTEMS LLC. THIS DRAWING IS NOT INTENDED TO BE USED FOR CONSTRUCTION OR DISTRIBUTION WITHOUT CONSENT. ALL DIMENSIONS ARE IN INCHES UNLESS SPECIFIED.	Designed by CFS	Checked by KF	FName APPROVAL	Date 12/19/11	Reference NA	Edition 0
	FLORIDA FDEP			FREEMAN ENCLOSURE SYSTEMS		
	Drawing Number S3810224	Scale N.T.S.	Sheet 1/1			



Department of Environmental Protection

2600 Blair Stone Road ♦ Tallahassee, Florida 32399-2400

DEP Form: 62-762.901(9)

Form Title: Storage Tank Equipment

Registration Form

Effective Date: January 2017

Incorporated in Rule 62-762.851, F.A.C.

Storage Tank Equipment Registration Form

Fill out completely

General Information

Company Name: Freeman Enclosure Systems Contact Name: Cassie Freeman
Company Address: 4160 Half Acre Rd City: Batavia Zip: 45103
E-mail: Cassie.Freeman@FreemanEnclosures.com Contact Number: 513-488-8563
Product Name: AST (above ground storage tanks) and accessories
Model Number(s): _____ Product Type: AST's, spill containment, alarm panels
Rule(s) citation within Chapter 62-761, or 62-762, F.A.C. that registration is being requested: _____
62-762.501(1)(e), 62-761.500(2)(b)

Write a brief description of equipment registration request including product limitations:

- 1) UL 142, 2085 listed AST (special purpose to be used as standby generator tank.) UL file numbers have not changed. We are only updating drawing.
2) Spill containment, 7 (new) and 5 gallon (updated) capacities. 3) Alarm Panels (updated wiring and look) both 12V and 24V. AP3 and AP3R to be replaced.

Information Checklist

	Yes	No	N/A
1. Third-party Certification by a Nationally Recognized Testing Laboratory?	☐	☐	☒
2. Documentation of third-party evaluation that the equipment meets DEP Rules?	☐	☐	☒
3. Documents included about the qualifications of the Nationally Recognized Testing Laboratory?	☐	☐	☒
4. Installation instructions included?	☐	☒	☐
5. Technical information and drawings included?	☒	☐	☐
6. Annual Operability Testing Requirements (Rules 62-761.700, 62-762.701, & 62-762.702 F.A.C.)?	☐	☐	☒
7. Compatible with fuel blends containing >10% ethanol or >20% biodiesel?	☐	☒	☐
8. Has the product been approved or registered in other countries or states? (If so provide list)	☐	☐	☒
9. Any requirements for company-certified installers or trainers?	☐	☒	☐
10. Was this product(s) previously approved or registered by the Department?	☒	☐	☐
If yes, please specify the Equipment Number: <u>EQ- 785</u>			
	☒	☐	☐
11. Any changes or modifications to the equipment since the last submittal to DEP?	☒	☐	☐

Document Information: Provide supporting documents indicated as "Yes" above including this form via email to Tanknotify@dep.state.fl.us, or documents can be sent to FDEP, Division of Waste Management, 2600 Blair Stone Road, MS 4560, Tallahassee, FL 32399.

Write a brief description of equipment installation and performance in the U.S.:

AST to be installed by end user, owner on level flat surface. Spill containment and alarm panel pre-installed at factory by Freeman before shipment. No modifications or installation required unless items shipped loose at user's request.

Equipment Registration Certification:

To the best of my knowledge and belief, all information submitted on this form is true, accurate and complete.

Printed Name and Title


Cassondre Freeman
2017.04.21 14:44:54 -04'00'
Signature

4/21/17
Date

For Department Use Only:

Date Application Received: 4/21/2017 Renew by 4/26/2022 Application complete: Yes: ☒ No: ☐

EQ- 785-R Date of complete or incomplete letter sent: 4/26/2017 Date of entry to the DEP Equipment Registration List: 4/26/2017



Department of Environmental Protection

2600 Blair Stone Road ♦ Tallahassee, Florida 32399-2400

DEP Form: 62-762.901(9)

Form Title: Storage Tank Equipment

Registration Form

Effective Date: January 2017

Incorporated in Rule 62-762.851, F.A.C.

Storage Tank Equipment Registration Form

Fill out completely

General Information

Company Name: Freeman Enclosure Systems

Contact Name: Cassie Freeman

Company Address: 4160 Half Acre Rd

City: Batavia

Zip: 45103

E-mail: Cassie.Freeman@FreemanEnclosures.com

Contact Number: 513-488-8563

Product Name: AST (above ground storage tanks) and accessories

Model Number(s): _____

Product Type: AST's, spill containment, alarm panels

Rule(s) citation within Chapter 62-761, or 62-762, F.A.C. that registration is being requested: _____

62-762.501(1)(e), 62-761.500(2)(b)

Write a brief description of equipment registration request including product limitations:

- 1) UL 142, 2085 listed AST (special purpose to be used as standby generator tank.) UL file numbers have not changed. We are only updating drawing.
2) Spill containment, 7 (new) and 5 gallon (updated) capacities. 3) Alarm Panels (updated wiring and look) both 12V and 24V. AP3 and AP3R to be replaced.

Information Checklist

- | | Yes | No | N/A |
|---|-------------------------------------|-------------------------------------|-------------------------------------|
| 1. Third-party Certification by a Nationally Recognized Testing Laboratory? | ☐ | ☐ | ☒ |
| 2. Documentation of third-party evaluation that the equipment meets DEP Rules? | ☐ | ☐ | ☒ |
| 3. Documents included about the qualifications of the Nationally Recognized Testing Laboratory? | ☐ | ☐ | ☒ |
| 4. Installation instructions included? | ☐ | ☒ | ☐ |
| 5. Technical information and drawings included? | ☒ | ☐ | ☐ |
| 6. Annual Operability Testing Requirements (Rules 62-761.700, 62-762.701, & 62-762.702 F.A.C.)? | ☐ | ☐ | ☒ |
| 7. Compatible with fuel blends containing >10% ethanol or >20% biodiesel? | ☐ | ☒ | ☐ |
| 8. Has the product been approved or registered in other countries or states? (If so provide list) | ☐ | ☐ | ☒ |
| 9. Any requirements for company-certified installers or trainers? | ☐ | ☒ | ☐ |
| 10. Was this product(s) previously approved or registered by the Department? | ☒ | ☐ | ☐ |
| If yes, please specify the Equipment Number: <u>EQ- 785</u> | ☒ | ☐ | ☐ |
| 11. Any changes or modifications to the equipment since the last submittal to DEP? | ☒ | ☐ | ☐ |

Document Information: Provide supporting documents indicated as "Yes" above including this form via email to Tanknotify@dep.state.fl.us, or documents can be sent to FDEP, Division of Waste Management, 2600 Blair Stone Road, MS 4560, Tallahassee, FL 32399.

Write a brief description of equipment installation and performance in the U.S.:

AST to be installed by end user, owner on level flat surface. Spill containment and alarm panel pre-installed at factory by Freeman before shipment. No modifications or installation required unless items shipped loose at user's request.

Equipment Registration Certification:

To the best of my knowledge and belief, all information submitted on this form is true, accurate and complete.

Cassandre Freeman Eng. Manager
Printed Name and Title

Cassandre Freeman
Signature

4/21/17
Date

For Department Use Only:

Date Application Received: _____

Application complete:

Yes: ☐ No: ☐

EQ- ☐

Date of complete or incomplete letter sent: _____

Date of entry to the DEP Equipment Registration List: _____

GENERAL NOTES:

1. EMERGENCY VENT SIZING BASED ON UL142 TABLE 8.1.

2. PORTS PER UL 142 SECTION 10

3. NORMAL VENTING PER UL 142 SECTION 8.11, TABLE 8.2

4. WELDS AND JOINTS PER UL SECTION 6 FIGURE 6.1, 6.2

GENERAL DESCRIPTION:

SUB BASE FUEL SUPPLY TANK
MINIMUM 10 GAUGE (.125") CONSTRUCTION
UL 142 OR UL 2085 LISTED DOUBLE WALL
NORMAL AND EMERGENCY VENTS
LOW LEVEL, HIGH LEVEL AND LEAK DETECTION
FLOAT SWITCHES
FILL
MECHANICAL FUEL GAUGE

ELECTRICAL
LEVEL ALARM PANEL

TANK DATA:
UNDERWRITERS LABORATORIES LISTING MH47836

CAPACITY GALLONS: 0-11,999

GALLONS PER IN OF DEPTH: NA

RUN TIME @FULL LOAD Hrs: NA

TANK WEIGHT DRY lbs: NA

TANK WEIGHT WET lbs: NA

CONDUIT STUB AREA: (STRAIGHT SHOWN)

TANK DIMS INCHES: 600 MAXL X 164 MAXW
X 50 MAXH

STATE SPEC: FLORIDA FDEP

TANK PORTS** :

A = 2" NORMAL TANK VENT

B = 3-12" EMERGENCY BASIN VENT

C = 3-12" EMERGENCY TANK VENT

D = 2" TANK SPARE PORT (FNPT)

E = MECHANICAL FUEL LEVEL GAUGE

F = 4" FILL

G = ENGINE SUPPLY

H = ENGINE RETURN

I = 2" TANK SPARE PORT (FNPT)

J = LOW LEVEL FLOAT SWITCH (EQ-682)

K = LEAK DETECTION FLOAT SWITCH (EQ-682)

L = HIGH LEVEL FLOAT SWITCH (EQ-682)

** TANK PORTS VARY IN LOCATION DUE TO INNER CONSTRUCTION OF SUB BASE TANK, AND LOCATION OF EQUIPMENT. DEPICTION SHOWN IS A GENERALIZED LOCATION.

TANK EQUIPMENT:


M = FILL ALARM PANEL, LEAK ALARM PANEL.
4LAP3-12, 4LAP3-24 OR OTHER APPROVED
DEVICE FROM EQ LIST

N = FUEL FILL STOP VALVE AS REQUIRED FROM
APPROVED EQ DEVICE LIST. OVERFILL
PREVENTION VALVE OPTIONAL

P = OVERFILL SPILL CONTAINMENT T110 / T111 OR
OTHER APPROVED DEVICE FROM EQ LIST

REVISIONS:

EDITION	DESCRIPTION	DATE
0	ORIGINAL SUBMISSION RELEASE	02/23/12
1	RESUBMIT/GENERAL UPDATE	04/17/17





THIS DOCUMENT IS CREATED BY AND IS THE PROPERTY OF FREEMAN ENCLOSURE SYSTEMS LLC. ITS USE IS AUTHORIZED ONLY FOR RESPONDING TO A REQUEST FOR QUOTATION OR FOR THE PERFORMANCE OF WORK. FOR FREEMAN ENCLOSURE SYSTEMS LLC. THIS DRAWING IS NOT INTENDED TO BE USED FOR CONSTRUCTION OR DISTRIBUTION WITHOUT CONSENT. ALL DIMENSIONS ARE IN INCHES UNLESS SPECIFIED.





Designed by CFS	Checked by KF	Filename APPROVAL	Date 12/19/11	Reference NA	Edition 1
FLORIDA FDEP					
Drawing Number S3810224-1	Scale N.T.S.	Sheet 1/1			

LEAK TEST PROCEDURES :

- 1. INSURE BOX INTERIOR IS FREE OF FUEL RESIDUE AND DEBRIS
- 2. FILL WITH WATER TO WITHIN 1/4" FROM BOTTOM OF FILL CAP
- 3. LET STAND FOR 1 HOUR
- 4. VERIFY WATER LEVEL HAS NOT GONE DOWN
- 5. INSPECT EXTERIOR FOR VISIBLE LEAKS
- 6. IF LEAKS ARE FOUND, REMOVE, REPAIR AND REPEAT STEPS 2-4 UNTIL ALL LEAKS ARE COMPLETELY SEALED
- 7. DO NOT UNSCREW DRAIN COCK DURING TESTING. THIS WILL RELEASE WATER INTO TANK.
- 8. AFTER TEST IS COMPLETE, DRAIN WATER BY REMOVING EXTERNAL DRAIN PLUG. ADD SEALANT AND REPLACE PLUG

DRAINAGE PROCEDURES :

- 1. WHEN FUEL IS PRESENT IN CONTAINMENT BOX, UNSCREW FUEL DRAIN COCK TO RELEASE FUEL BACK INTO TANK.
- 2. THE EXTERNAL DRAIN MAY ALSO BE USED BY UNSCREWING STEEL PLUG.
- 3. USE APPROPRIATE CONTAINER FOR CATCHING DRAINED FLUIDS.
- 4. DO NOT OVER TIGHTEN FUEL DRAIN COCK AFTER DRAINING FLUID.



BILL OF MATERIALS :



- (1) 4" x 6" NIPPLE
- (1) 2" ALUMINUM SPOUT ADAPTER
- (1) 2" ALUMINUM DUST CAP
- (1) 1/4" COUPLING
- (1) FIT 1/4" PETCOCK 0858-5753
- (1) MORRISON 9095AA VALVE
- (1) 1/2" FLANGE
- (1) 1/2" PLUG
- (1) S.S. PIANO HINGE
- PAINT BLACK

LEAK TEST PROCEDURES :



- 1. INSURE BOX INTERIOR IS FREE OF FUEL RESIDUE AND DEBRIS
- 2. FILL WITH WATER TO WITHIN 1/4" FROM BOTTOM OF FILL CAP
- 3. LET STAND FOR 1 HOUR
- 4. VERIFY WATER LEVEL HAS NOT GONE DOWN
- 5. INSPECT EXTERIOR FOR VISIBLE LEAKS
- 6. IF LEAKS ARE FOUND, REMOVE, REPAIR AND REPEAT STEPS 2-4 UNTIL ALL LEAKS ARE COMPLETELY SEALED
- 7. DO NOT UNSCREW DRAIN COCK DURING TESTING. THIS WILL RELEASE WATER INTO TANK.
- 8. AFTER TEST IS COMPLETE, DRAIN WATER BY REMOVING EXTERNAL DRAIN PLUG. ADD SEALANT AND REPLACE PLUG

DRAINAGE PROCEDURES :

- 1. WHEN FUEL IS PRESENT IN CONTAINMENT BOX, UNSCREW FUEL DRAIN COCK TO RELEASE FUEL BACK INTO TANK.
- 2. THE EXTERNAL DRAIN MAY ALSO BE USED BY UNSCREWING STEEL PLUG.
- 3. USE APPROPRIATE CONTAINER FOR CATCHING DRAINED FLUIDS.
- 4. DO NOT OVER TIGHTEN FUEL DRAIN COCK AFTER DRAINING FLUID.



1/2" FLANGE & PLUG
FOR EXTERNAL DRAIN



BILL OF MATERIALS :

- (1) 2 x 8" NIPPLE
- (1) 2" FEMALE HINGED LOCKABLE CAP
- (1) 0858-5753 PETCOCK
- (1) 1/2" FLANGE
- (1) 1/2" PLUG
- (1) S.S. PIANO HINGE
- (1) 1/4" COUPLER
- PAINT BLACK

INSTALL 1/4" COUPLER
TO INSTALL PETCOCK

FUEL RETURN TO MAIN TANK

2 x 8 Npl.

3/8" HOLE 1.25" DOWN IN
COUPLER TO DRAIN FUEL



4160 HALF ACRE DR.
BATAVIA OH, 45103
513-488-8600

FUEL TANK LEVEL INDICATING SYSTEM

MODEL- 4LAP3_12VDC


CONTROLLER:
ENCLOSURE: FIBERGLASS 6" X 6" X 4"
POWER: 12VDC (GENERATOR STARTING BATTERIES)

4 PILOT LIGHTS AND 3 DPDT RELAYS ALARMS
TANK LEAK
33% LOW LEVEL
90% HIGH LEVEL
95% CRITICAL HIGH LEVEL


PILOT LIGHTS HAVE PUSH TO TEST FUNCTION.
RELAYS ARE FORM C
WITH 2 DRY ISOLATED OUTPUTS FOR
GENERATOR CONTROL & CUSTOMER CONNECTION.

ALARM HORN & SILENCE ALARM SWITCH.
TERMINALS FOR ALL CONNECTIONS.


DRAWING & REVISION HISTORY			
DATE	INITIALS	REV No.	DESCRIPTION
3/22/17	SK	2	REMOVED VENDOR PART, NUMBERS REPLACED WITH FES PART NUMBERS
07/22/15	SK	1	AS-BUILT
07/15/15	SK	NA	DRAWING CONSTRUCTION SET



NOTE
12 VDC IS TYPICALLY SUPPLIED FROM
GENERATOR BATTERIES
CONNECTED TO THE STARTER






INPUT POWER/FLOAT/GENCONTROLLER CONNECTIONS				
ITEM #	FUSE / TERMINAL #	DESCRIPTION	WIRE COLOR	CABLE TYPE
1	FU1	POWER INPUT +12VDC	RED	CUSTOMER CONNECTION
2	TB COM	- 12VDC POWER INPUT & CONTROLLER FEED	BLACK	
3	TB +12	+ 12 POWER DISTRIBUTION CONTROLLER/FLOAT FEED	BLACK	BELDEN 18/6 CABLE TAG: FT/LAP
4	TB 1	FLT1 LEAK FLOAT INPUT	WHITE	
5	TB 2	FLT2 33% LOW LEVEL FLOAT INPUT	GREEN	
6	TB 3	FLT3 90% HIGH LEVEL FLOAT INPUT	BROWN	
7	TB 4	FLT4 95% CRITICAL HIGH LEVEL FLOAT INPUT	RED	BELDEN 18/6 CABLE TAG: FL/GC
8	TB 5	ALARM COMMON INPUT TO GEN CONTROL	BLACK	
9	TB 6	LEAK ALARM INPUT TO GEN CONTROL	WHITE	
10	TB 7	LOW LEVEL ALARM INPUT TO GEN CONTROL	GREEN	
11	TB 8	CRITICAL HIGH LEVEL ALARM INPUT TO GEN CONTROL	RED	




4LAP3- 12 VDC BOM					
ITEM #	QTY	DESCRIPTION	PART #	MFG	SUPPLIER
1	1	ENCLOSURE 6X6X4	EL-LAB-HOFF-6X6X4 FG SCRCVR 4R	HOFFMANN	BECKER
2	1	ENCLOSURE BACK PLATE	EL-LAB-HOFFMAN 6X6 PANEL	HOFFMANN	BECKER
3	1	SELECT SWITCH 2 POS MAINT	EL-LAB-SQD ZB5AD2	SCHNEIDER	BECKER
4	1	PUSH BUTTON MOMENTARY RED	EL-LAB-SQD ZB5AA4	SCHNEIDER	BECKER
5	2	MOUNTING COLLAR	EL-LAB-SQD ZB5AZ009	SCHNEIDER	BECKER
6	1	CONTACT BLOCK NC	EL-LAB-SQD ZBE102	SCHNEIDER	BECKER
7	5	CONTACT BLOCK NO	EL-LAB-SQD ZBE101	SCHNEIDER	BECKER
8	2	PILOT LIGHT RED	EL-LAB-IDEC HW1P-2FQD-R-12V	IDEC	BECKER
9	1	PILOT LIGHT AMBER	EL-LAB-IDEC HW1P-2FQD-A-12V	IDEC	BECKER
10	1	PILOT LIGHT GREEN	EL-LAB-IDEC HW1P-2FQD-G-12V	IDEC	BECKER
11	1	HORN	EL-LAB-MALLORY SC628NR	SONALERT	BECKER
12	1	HORN GASKET	EL-LAB-MALLORY ACC03	SONALERT	BECKER
13	3	RELAY 12VDC & BASE	EL-LAB-WAGO 788-311	WAGO	BECKER
14	1	FUSE TERMINAL BLOCK	EL-LAB-WAGO 2002-1681	WAGO	BECKER
15	1	FUSE BLOCK END PLATE	EL-LAB-WAGO 2002-1692	WAGO	BECKER
16	4	TERMINAL 2 POLE 22-12 AWG	EL-LAB-WAGO 2002-1201	WAGO	BECKER
17	1	TERMINAL END PLATE 2 POLE 22-12 AWG	EL-LAB-WAGO 2002-1292	WAGO	BECKER
18	4	TERMINAL 3 POLE 22-12 AWG	EL-LAB-WAGO 2002-1301	WAGO	BECKER
19	1	TERMINAL END PLATE 3 POLE 22-12 AWG	EL-LAB-WAGO 2002-1392	WAGO	BECKER
20	2	TERMINAL 4 POLE 22-12 AWG	EL-LAB-WAGO 2002-1401	WAGO	BECKER
21	1	TERMINAL END PLATE 4POLE 22-12 AWG	EL-LAB-WAGO 2002-1492	WAGO	BECKER
22	2	DIN RAIL CLAMPS	EL-LAB-WAGO 249-116	WAGO	BECKER
23	5"	DIN RAIL	EL-LAB-WAGO 210-112	WAGO	BECKER
24	1	FACE PLATE	EL-LAB- 4LAP FACIAL PLATE	E C SHAW	E C SHAW

RELAY ENCLOSURE BACK PLATE LAYOUT



SCHEMATIC LEGEND





4160 HALF ACRE DR.
BATAVIA OH, 45103
513-488-8600

FUEL TANK LEVEL INDICATING SYSTEM

MODEL- 4LAP3_24VDC


CONTROLLER:
ENCLOSURE: FIBERGLASS 6" X 6" X 4"
POWER: 24VDC (GENERATOR STARTING BATTERIES)

4 PILOT LIGHTS AND 3 DPDT RELAYS ALARMS
TANK LEAK
33% LOW LEVEL
90% HIGH LEVEL
95% CRITICAL HIGH LEVEL


PILOT LIGHTS HAVE PUSH TO TEST FUNCTION.
RELAYS ARE FORM C
WITH 2 DRY ISOLATED OUTPUTS FOR
GENERATOR CONTROL & CUSTOMER CONNECTION.

ALARM HORN & SILENCE ALARM SWITCH.
TERMINALS FOR ALL CONNECTIONS.


DRAWING & REVISION HISTORY			
DATE	INITIALS	REV No.	DESCRIPTION
03/22/17	SK	3	REVISED DRAWING DETAILS
09/08/15	SK	2	FLOAT WIRE COLORS
07/22/15	SK	1	AS-BUILT
07/15/15	SK	NA	DRAWING CONSTRUCTION SET



NOTE
24 VDC IS TYPICALLY SUPPLIED FROM
GENERATOR BATTERIES
CONNECTED TO THE STARTER






INPUT POWER/FLOAT/GENCONTROLLER CONNECTIONS				
ITEM #	FUSE / TERMINAL #	DESCRIPTION	WIRE COLOR	CABLE TYPE
1	FU1	POWER INPUT +24VDC	RED	CUSTOMER CONNECTION
2	TB COM	- 24VDC POWER INPUT & CONTROLLER FEED	BLACK	
3	TB +24	+ 24 POWER DISTRIBUTION CONTROLLER/FLOAT FEED	BLACK	BELDEN 18/6 CABLE TAG: FT/LAP
4	TB 1	FLT1 LEAK FLOAT INPUT	WHITE	
5	TB 2	FLT2 33% LOW LEVEL FLOAT INPUT	GREEN	
6	TB 3	FLT3 90% HIGH LEVEL FLOAT INPUT	BROWN	
7	TB 4	FLT4 95% CRITICAL HIGH LEVEL FLOAT INPUT	RED	BELDEN 18/6 CABLE TAG: FL/GC
8	TB 5	ALARM COMMON INPUT TO GEN CONTROL	BLACK	
9	TB 6	LEAK ALARM INPUT TO GEN CONTROL	WHITE	
10	TB 7	LOW LEVEL ALARM INPUT TO GEN CONTROL	GREEN	
11	TB 8	CRITICAL HIGH LEVEL ALARM INPUT TO GEN CONTROL	RED	




4LAP3- 24 VDC BOM					
ITEM #	QTY	DESCRIPTION	PART #	MFG	SUPPLIER
1	1	ENCLOSURE 6X6X4	EL-LAB-HOFF-6X6X4 FG SCRCVR 4R	HOFFMANN	BECKER
2	1	ENCLOSURE BACK PLATE	EL-LAB-HOFFMAN 6X6 PANEL	HOFFMANN	BECKER
3	1	SELECT SWITCH 2 POS MAINT	EL-LAB-SQD ZB5AD2	SCHNEIDER	BECKER
4	1	PUSH BUTTON MOMENTARY RED	EL-LAB-SQD ZB5AA4	SCHNEIDER	BECKER
5	2	MOUNTING COLLAR	EL-LAB-SQD ZB5AZ009	SCHNEIDER	BECKER
6	1	CONTACT BLOCK NC	EL-LAB-SQD ZBE102	SCHNEIDER	BECKER
7	5	CONTACT BLOCK NO	EL-LAB-SQD ZBE101	SCHNEIDER	BECKER
8	2	PILOT LIGHT RED	EL-LAB-IDEC HW1P-2FQD-R-24V	IDEC	BECKER
9	1	PILOT LIGHT AMBER	EL-LAB-IDEC HW1P-2FQD-A-24V	IDEC	BECKER
10	1	PILOT LIGHT GREEN	EL-LAB-IDEC HW1P-2FQD-G-24V	IDEC	BECKER
11	1	HORN	EL-LAB-MALLORY SC628NR	SONALERT	BECKER
12	1	HORN GASKET	EL-LAB-MALLORY ACC03	SONALERT	BECKER
13	1	BACK PLATE ASSEMBLY (ITEMS 14-24)	EL-LAB-WAGO 60251174	WAGO	BECKER
14	3	RELAY & BASE	EL-LAB-WAGO 788-312	WAGO	BECKER
15	1	FUSE TERMINAL BLOCK	EL-LAB-WAGO 2002-1681	WAGO	BECKER
16	1	FUSE BLOCK END PLATE	EL-LAB-WAGO 2002-1692	WAGO	BECKER
17	4	TERMINAL 2 POLE 22-12 AWG	EL-LAB-WAGO 2002-1201	WAGO	BECKER
18	1	TERMINAL END PLATE 2 POLE 22-12 AWG	EL-LAB-WAGO 2002-1292	WAGO	BECKER
19	4	TERMINAL 3 POLE 22-12 AWG	EL-LAB-WAGO 2002-1301	WAGO	BECKER
20	1	TERMINAL END PLATE 3 POLE 22-12 AWG	EL-LAB-WAGO 2002-1392	WAGO	BECKER
21	2	TERMINAL 4 POLE 22-12 AWG	EL-LAB-WAGO 2002-1401	WAGO	BECKER
22	1	TERMINAL END PLATE 4POLE 22-12 AWG	EL-LAB-WAGO 2002-1492	WAGO	BECKER
23	2	DIN RAIL CLAMPS	EL-LAB-WAGO 249-116	WAGO	BECKER
24	5"	DIN RAIL	EL-LAB-WAGO 210-112	WAGO	BECKER
25	1	FACE PLATE	EL-LAB- 4LAP FACIAL PLATE	E C SHAW	E C SHAW


RELAY ENCLOSURE BACK PLATE LAYOUT



FUEL TANK FLOATS



SCHEMATIC LEGEND





Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

April 10, 2012

Certified Mail, Return Receipt Requested
Number 7009 0820 0001 2298 5434

Mr. Dale A. Freeman
Freeman Enclosure Systems, LLC
4160 Half Acre Road
Batavia, OH 45103

Subject: Approval of the Freeman Enclosure Systems, Special Purpose
Aboveground Storage Tanks under Underwriters Laboratory listings
UL142 and UL 2085, Reference File Numbers: MH47836 Vol. 1, MH47836
Vol. ST1, MH47836 Vol. ST2, MH47836 Vol. CN1, MH48714 Vol. ST1, and
MH48714 Vol. CN1.
File No. EQ-785

Dear Mr. Freeman:

The Bureau of Petroleum Storage Systems has concluded its review of the Equipment Approval request dated February 27, 2012 that was submitted for the Freeman Enclosure Systems, Special Purpose Aboveground Storage Tanks under Underwriters Laboratory listings UL142 and UL 2085, Reference File Numbers: MH47836 Vol. 1, MH47836 Vol. ST1, MH47836 Vol. ST2, MH47836 Vol. CN1, MH48714 Vol. ST1, and MH48714 Vol. CN1, pursuant to Rules 62-762.501(1)(e), and 62-761.500(2)(b), Florida Administrative Code (F.A.C.). The listed special purpose aboveground storage tanks are to be used primarily as stand-by generator tanks.

Based on the information provided by Freeman Enclosure Systems, LLC, the Department finds that the applicant's Special Purpose Aboveground Storage Tanks under Underwriters Laboratory listings UL142 and UL 2085, Reference File Numbers: MH47836 Vol. 1, MH47836 Vol. ST1, MH47836 Vol. ST2, MH47836 Vol. CN1, MH48714 Vol. ST1, and MH48714 Vol. CN1 provide environmental protection substantially equivalent to that provided by compliance with the requirements established in Rules 62-762.501(1)(e), and 62-761.500(2)(b), F.A.C. and may be installed and used as aboveground storage tanks.

April 10, 2012

Pursuant to Rule 62-762.851(2), F.A.C., the request for the use of the Freeman Enclosure Systems, Special Purpose Aboveground Storage Tanks Under Underwriters Laboratory listings UL142 and UL 2085, Reference File Numbers: MH47836 Vol. 1, MH47836 Vol. ST1, MH47836 Vol. ST2, MH47836 Vol. CN1, MH48714 Vol. ST1, and MH48714 Vol. CN1 is approved in the State of Florida as special purpose aboveground storage tanks. The aboveground storage tank systems meet the performance standards contained in Rules 62-762.501(1)(e), and 62-761.500(2)(b), F.A.C. Installation shall be made in accordance with the manufacturer's recommendations.

Please be advised that the above referenced DEP rules are subject to change. If the above rule standards are modified in the future, this order may be modified or rescind for future upgrades and installations. Additionally, if the product(s) show a consistent pattern of failure(s), and therefore does not provide substantially equivalent environmental protection, the Department may rescind this order.

The Department's Order shall become final unless a timely petition for an administrative hearing is filed under sections 120.569 and 120.57, F.S., within 21 days of receipt of this Order. Persons who have filed such a petition may seek to mediate the dispute and choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement. The procedures for petitioning a hearing and pursuing mediation are set forth below.

Persons affected by this Order have the following options:

- A. If you choose to accept the Department's decision regarding the Order, you do not have to do anything. This Order is final and effective as of the date on the top of the first page of this Order.
- B. If you choose to challenge the decision, you may do the following:
 - 1. File a request for an extension of time to file a petition for hearing with the Department's Agency Clerk in the Office of General Counsel within 21 days of receipt of this Order. This request should be made if you wish to meet with the Department in an attempt to resolve any disputes without first filing a petition for hearing or negotiate an agreement to mediate; or
 - 2. File a petition for administrative hearing with the Department's Agency Clerk in the Office of General Counsel within 21 days of receipt of this Order.
 - 3. In addition to requesting an administrative hearing, any petitioner may elect to pursue mediation under Section 120.573, F.S., and must negotiate an agreement to mediate within 10 days after the deadline for filing a petition.

How to Request an Extension of Time to File a Petition for Hearing

For good cause shown, pursuant to Rule 62-110.106(4), F.A.C., the Department may grant a request for an extension of time to file a petition for hearing. Such a request must be filed (received) by the Agency Clerk in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000, within 21 days of receipt of this Order. Petitioner, if different from the applicant, shall mail a copy of the request to the applicant at the time of filing. Failure to file a petition within this time period shall waive the right of anyone who may request an administrative hearing under Sections 120.569 and 120.57, F.S.

How to File a Petition for Administrative Hearing

A person whose substantial interests are affected by this Order may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) by the Agency Clerk in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, MS 35, Tallahassee, Florida, 32399-3000, within 21 days of receipt of this Order. Petitioner, if different from the applicant shall mail a copy of the petition to the applicant at the time of filing. Failure to file a petition within this time period shall waive the right of anyone who may request an administrative hearing under Sections 120.569 and 120.57, F.S.

Pursuant to Subsection 120.569(2), F.S., and Rule 28-106.201, F.A.C., a petition for administrative hearing shall contain the following information.

- a) The name, address, and telephone number of each petitioner; the name, address, and telephone number of the petitioner's representative, if any, the site owner's name and address, if different from the petitioner, the DEP facility number, and the name and address of the facility;
- b) A statement of when and how the petitioner received notice of the Department's action or proposed action;
- c) An explanation of how each petitioner's substantial interests are or will be affected by the Department's action or proposed action;
- d) A statement of the disputed issues of material fact, or a statement that there are no disputed facts;
- e) A concise statement of the ultimate facts alleged, including a statement of the specific facts the petitioner contends warrant reversal or modification of the Department's action or proposed action;
- f) A statement of the specific rules or statutes the petitioner contends requires reversal or modification of the Department's action or proposed action; and

April 10, 2012

- g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's action or proposed action.

How to Pursue Mediation

In addition to requesting an administrative hearing, any petitioner may elect to pursue mediation. The election may be accomplished by filing with the Department a mediation agreement with all parties to the proceeding (i.e., the applicant, the Department, and any person who has filed a timely and sufficient petition for hearing). The agreement must contain all the information required by Rule 28-106.404, F.A.C. The agreement, signed by all parties, must be received by the Agency Clerk in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000 within 10 days after the deadline for filing a petition, as set forth above. Choosing mediation will not adversely affect the right to a hearing if mediation does not result in a settlement.

Pursuant to Rule 28-106.404, F.A.C., an agreement to mediate must include the following.

- (i) The name, address, and telephone number of the persons who may attend the mediation, (also the DEP facility number, the name and address of the facility if applicable);
- (ii) The name, address, and telephone number of the mediator agreed to by the parties;
- (iii) How the costs and fees associated with the mediation will be allocated (the Department will not pay any of the costs of mediation);
- (iv) The agreement of the parties regarding the confidentiality of discussions and documents introduced during mediation to the extent authorized by law;
- (v) The date, time, and place of the first mediation session;
- (vi) The name of the party's representative who shall have authority to settle or recommend settlement; and
- (vii) The signature of the parties.

As provided in Section 120.573, F.S., the timely agreement of all parties to mediate will toll the time limitations imposed by Sections 120.569 and 120.57, F.S., for holding an administrative hearing and issuing a final order. Unless otherwise agreed by the parties, the mediation must be concluded within sixty days of the execution of the agreement. If mediation results in settlement of the administrative dispute, the Department must enter a final order incorporating the agreement of the parties. Persons seeking to protect their substantial interests that would be affected by such a modified final decision must file their petitions within 21 days of receipt of this notice,

April 10, 2012

or they shall be deemed to have waived their right to a proceeding under Sections 120.569 and 120.57, F.S. If mediation terminates without settlement of the dispute, the Department shall notify all parties in writing that the administrative hearing processes under Sections 120.569 and 120.57, F.S., are resumed.

This Order is final and effective as of the date on the top of the first page of this Order. Timely filing a petition for administrative hearing postpones the date this Order takes effect until the Department issues either a final order pursuant to an administrative hearing or mediation settlement.

Judicial Review

Any party to this Order has the right to seek judicial review of it under Section 120.68, F.S., by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the Agency Clerk of the Department in the Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within thirty days after this order is filed with the clerk of the Department (see below).

Questions

Any questions regarding the Department's review of your equipment approval should be directed to John Svec at (850)245-8845. Questions regarding legal issues should be referred to Rebecca Robinette, Office of General Counsel, at (850)245-2242. Contact with any of the above does not constitute a petition for administrative hearing, a request for a time extension to file a petition for hearing or an agreement to mediate.

Sincerely,



Robert C. Brown, P.E.
Chief, Bureau of Petroleum Storage Systems


RCB/jps

Mr. Freeman EQ-785

Page 6

April 10, 2012

FILING AND ACKNOWLEDGMENT FILED,
on this date, pursuant to §120.52 Florida Statutes,
with the designated Department Clerk, receipt of
which is hereby acknowledged.

 4-11-12

Clerk

Date




(or Deputy Clerk)

LEAK TEST PROCEDURES :

1. INSURE BOX INTERIOR IS FREE OF FUEL RESIDUE AND DEBRIS
2. FILL WITH WATER TO WITHIN 1/4" FROM BOTTOM OF FILL CAP
3. LET STAND FOR 1 HOUR
4. VERIFY WATER LEVEL HAS NOT GONE DOWN
5. INSPECT EXTERIOR FOR VISIBLE LEAKS
6. IF LEAKS ARE FOUND, REMOVE, REPAIR AND REPEAT STEPS 2-4 UNTIL ALL LEAKS ARE COMPLETELY SEALED
7. DO NOT PRESS DRAIN VALVE DURING TESTING. THIS WILL RELEASE WATER INTO TANK.
8. AFTER TEST IS COMPLETE, DRAIN WATER BY REMOVING EXTERNAL DRAIN PLUG. ADD SEALANT AND REPLACE PLUG

DRAINAGE PROCEDURES :

1. WHEN FUEL IS PRESENT IN CONTAINMENT BOX, PUSH DOWN FUEL DRAIN VALVE TO RELEASE FUEL BACK INTO TANK.
2. THE EXTERNAL DRAIN MAY ALSO BE USED BY UN SCREWING STEEL PLUG
3. USE APPROPRIATE CONTAINER FOR CATCHING DRAINED FLUIDS.



BILL OF MATERIALS :

- (1) 2" X 4" N.P.T. NIPPLE
- (1) 2" N.P.T. COUPLER
- (1) 1/2" N.P.T. FLANGE
- (1) 1/2" N.P.T. STEEL PLUG
- (1) 2" HINGED LOCKABLE CAP
- (1) 7/16" FUEL DRAIN VALVE

PAINT SCORPION BLACK

THIS DOCUMENT IS THE PROPERTY OF FREEMAN ENCLOSURE SYSTEMS, LLC. ITS USE IS AUTHORIZED ONLY FOR THE PROJECT AND FOR THE PERSONNEL SPECIFIED HEREIN. IT IS NOT TO BE REPRODUCED, COPIED, OR DISTRIBUTED OUTSIDE THE PROJECT OR PERSONNEL SPECIFIED HEREIN. ALL RIGHTS ARE RESERVED.

Generator	Designed by	Checked by	Filename	Date	Reference	Edition
N/A	LC	DF		2/24/2012	0	0
5 GAL SPILL CONTAINMENT						
Doc. #	Doc. #	Scale	Sheet	FREEMAN ENCLOSURE SYSTEMS		
FUG	D3810356	NTS	1/1			

1. EMERGENCY VENT SIZING BASED ON UL142 TABLE 8.1.
2. PORTS PER UL 142 SECTION 10
3. NORMAL VENTING PER UL 142 SECTION 8.11, TABLE 8.2
4. WELDS AND JOINTS PER UL SECTION 6 FIGURE 6.1, 6.2

SUB BASE FUEL SUPPLY TANK
MINIMUM 10 GAUGE (.125") CONSTRUCTION
UL 142 OR UL 2085 LISTED DOUBLE WALL
NORMAL AND EMERGENCY VENTS
LOW LEVEL, HIGH LEVEL AND LEAK DETECTION
FLOAT SWITCHES
FILL
MECHANICAL FUEL GAUGE

ELECTRICAL
LEVEL ALARM PANEL

TANK DATA:
UNDERWRITERS LABORATORIES LISTING MH47836

CAPACITY GALLONS: 0-11,999
GALLONS PER IN OF DEPTH: NA
RUN TIME @ FULL LOAD Hrs: NA
TANK WEIGHT DRY lbs: NA
TANK WEIGHT WET: lbs: NA
CONDUIT STUB AREA: (STRAIGHT)
TANK DIMS INCHES: 600 MAXL X 164 MAXW
X 50 MAXH
FLORIDA FDEP


A = 2" NORMAL TANK VENT
B = 3-12" EMERGENCY BASIN VENT
C = 3-12" EMERGENCY TANK VENT
D = 2" TANK SPARE PORT (FNPT)
E = MECHANICAL FUEL LEVEL GAUGE
F = 2" FILL
G = ENGINE SUPPLY
H = ENGINE RETURN
I = 2" TANK SPARE PORT (FNPT)
J = LOW LEVEL FLOAT SWITCH (EQ-682)
K = LEAK DETECTION FLOAT SWITCH (EQ-682)
L = HIGH LEVEL FLOAT SWITCH (EQ-682)

** TANK PORTS VARY IN LOCATION DUE TO INNER CONSTRUCTION OF SUB BASE TANK, AND LOCATION OF EQUIPMENT. DEPICTION SHOWN IS A GENERALIZED LOCATION.



M = FILL ALARM PANEL, LEAK ALARM PANEL,
AP-3, AP-3R OR OTHER APPROVED DEVICE
FROM EQ LIST

N = FUEL FILL STOP VALVE AS REQUIRED FROM
APPROVED EQ DEVICE LIST

P = OVERFILL SPILL CONTAINMENT F5G OR OTHER
APPROVED DEVICE FROM EQ LIST



2" SPACE FOR VISUAL
LEAK INSPECTION



<u>REVISIONS</u>		
<u>EDITION</u>	<u>DESCRIPTION</u>	<u>DATE</u>
0	ORIGINAL SUBMISSION RELEASE	02/23/12



THIS DOCUMENT IS CREATED BY AND IS THE PROPERTY OF FREEMAN ENCLOSURE SYSTEMS LLC. IT IS TO BE USED ONLY FOR RESPONDING TO A REQUEST FOR QUOTATION OR FOR THE PERFORMANCE OF A JOB FOR FREEMAN ENCLOSURE SYSTEMS LLC. THIS DRAWING IS NOT INTENDED TO BE USED FOR CONSTRUCTION OR DISTRIBUTION WITHOUT EXPLICIT PERMISSION AND INCHES UNLESS OTHERWISE NOTED.

Can make
CFS

U.S. NAVY
8F

	Filing Date APPROVED
--	------------------------------------

C. 129631

Reference
B.3.






5

FLORIDA FDEP

S3810224

N.T.S.	1/1
--------	-----





QTY	Units	Description	Part Number	Manufacturer
1	Ea.	Enclosure	AR664CHSC	Fibox
1	Ea.	Sub-Panel	ABP66	Fibox
4	In.	Wireway	G.5X2WH6	Panduit
4	In.	Cover, Wireway	C.5WH6	Panduit
4	In.	DIN Rail	AM1DP200	Square D
1	Ea.	Engraved legend plate	Custom	BCS
6	Ea.	Engraved terminal marker	Custom	BCS
5	Ea.	Terminal Block	AB1VV235U	Square D
1	Ea.	2 pole jumper	AB1ALN22	Square D
1	Ea.	End Barrier	AB1AC24	Square D
2	Ea.	End Clamp	AB1AB8P35	Square D
1	Ea.	Fused terminal block	AB1FUSE435U5X	Square D
1	Ea.	Fuse, 5x20mm, 3A	GMC-3A	Bussmann
1	Ea.	Switch, 2 Position	ZB4BD2	Square D
1	Ea.	Mounting base and N.C. contact	ZB4BZ102	Square D
3	Ea.	Light Module	ZB4BVB4	Square D
3	Ea.	Pilot Light Head	ZB4BV043	Square D
1	Ea.	6-28VDC Alarm Horn	SC628NR	Mallory-Sonalert
1	Ea.	NEMA 3R gasket for Alarm Horn	ACC03	Mallory-Sonalert
1	Ea.	Lighted Pushbutton Module	ZB4BW343	Square D
1	Ea.	Pilot Light Head W/ 2 NO Contacts	ZB4BW0B43	Square D
2	Ea.	NO Contact	ZBE101	Square D





TEST PROCEDURE:

1. PRESS, AND HOLD "PUSH TO TEST" BUTTON
2. ALL LIGHTS SHOULD ILLUMINATE
3. ALARM SHOULD SOUND
4. RELEASE BUTTON
5. REPAIR AND RETEST AS REQUIRED

NOTE:

1. ALL FLOAT SWITCHES CONNECTED ARE FDEP APPROVED FROM EQ LIST

THIS DOCUMENT IS CREATED BY AND IS THE PROPERTY OF FREEMAN ENCLOSURE SYSTEMS, LLC. ITS USE IS LIMITED TO THE PROJECT FOR WHICH IT WAS REQUESTED. NO QUOTATION OR FOR THE PERFORMANCE OF WORK FOR ANY OTHER PROJECT OR FOR ANY OTHER PURPOSE IS INTENDED TO BE USED FOR ANY OTHER PROJECT OR FOR ANY OTHER PURPOSE.		Designed by BCS	Checked by LF	Submitted SUBMITTAL	By DETAIL	Reference NA	Revision 0
AP-3 ALARM PANEL		Order # D3810347	Lead N.T.S.	Sheet 1/1			



QTY	Units	Description	Part Number	Manufacturer
1	Ea.	Enclosure	AR664CHSC	Fibox
1	Ea.	Sub-Panel	ABP66	Fibox
4	In.	Wireway	G 5X2WH6	Panduit
4	In.	Cover, Wireway	C 5WH6	Panduit
4	In.	DIN Rail	AM1DP200	Square D
1	Ea.	Engraved legend plate	Custom	BCS
6	Ea.	Engraved terminal marker	Custom	BCS
5	Ea.	Terminal Block	AB1VV235U	Square D
1	Ea.	2 pole jumper	AB1ALN22	Square D
2	Ea.	End Barrier	AB1AC24	Square D
2	Ea.	End Clamp	AB1AB8P35	Square D
1	Ea.	Fused terminal block	AB1FUSE435UX	Square D
1	Ea.	Fuse, 5x20mm, 3A	GMC-3A	Bussmann
1	Ea.	Switch, 2 Position	ZB4BD2	Square D
1	Ea.	Mounting base and N.C. contact	ZB4BZ102	Square D
3	Ea.	Light Module	ZB4BVB4	Square D
3	Ea.	Pilot Light Head	ZB4BV043	Square D
1	Ea.	6-28VDC Alarm Horn	SC628NR	Mallory-Sonalert
1	Ea.	NEMA 3R gasket for Alarm Horn	ACC03	Mallory-Sonalert
3	Ea.	Socket, Relay	RSZE1S35M	Square D
1	Ea.	Lighted Pushbutton Module	ZB4BW343	Square D
1	Ea.	Pilot Light Head W/ 2 NO Contacts	ZB4BW0B43	Square D
2	Ea.	NO Contact	ZBE101	Square D

TEST PROCEDURE:

1. PRESS, AND HOLD "PUSH TO TEST" BUTTON
2. ALL LIGHTS SHOULD ILLUMINATE
3. ALARM SHOULD SOUND
4. RELEASE BUTTON
5. REPAIR AND RETEST AS REQUIRED


NOTE:

1. ALL FLOAT SWITCHES CONNECTED ARE FDEP APPROVED FROM EQ LIST

THIS DOCUMENT IS TO BE USED BY AND IS THE PROPERTY OF THE BUREAU OF LOGGING SYSTEMS, INC. (BLS) AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF BLS. THIS DOCUMENT IS NOT INTENDED TO BE USED FOR OTHER THAN THE PURPOSES SPECIFIED.		Drawn by BCS	Checked by DF	Revision SUBMITTAL	Date DETAIL	Reference NA	Sheet 0
AP-3R ALARM PANEL		Quantity D3810348	Scale N.T.S.	Sheet 1/1			



EQ 785



February 27, 2012

Florida Department of Environmental Protection
Farid Moghadam
Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399

RE: Product Review Request for DEP Approval

Dear Mr. Moghadam,

Freeman Enclosure Systems, LLC manufactures AST diesel fuel storage systems for primarily for stand-by power generators under Underwriters Laboratory listings UL142 and UL2085.

Reference file numbers are as follows:

MH47836 Vol. 1 – UL142 Secondary Containment Generator Base Tank (EFVT, EFVT7)
MH47836 Vol. ST1 – UL142 Secondary Containment Generator Base Tank (EFVT)
MH47836 Vol. ST2 – UL2085 Protected Secondary Containment Generator Base Tank (EFVT)
MH47836 Vol. CN1 – UL142 Secondary Containment Generator Base Tank for Canada (EFVT7)
MH48714 Vol. ST1 – UL2085 Protected Aboveground Tanks for Flammable and Combustible Liquids (EELU)
MH48714 Vol. ST1 – UL2085 Protected Aboveground Tanks for Flammable and Combustible Liquids for Canada (EELU7)

All tank construction, design, materials and installed accessories are intended to meet the applicable requirements of the Florida Administrative Code chapter 62-762 Aboveground Storage Tank Systems.

We request review of the attached material for the purpose of assigning an EQ designation number to Freeman Enclosure Systems, LLC. If you have any questions or require clarification please don't hesitate to call me at 513-200-4009 or email Dale@FreemanStrategic.com.

Thank you for your time and consideration.

Sincerely,

Dale A Freeman, President
Freeman Enclosure Systems, LLC



**EFVT.MH47836
Special-purpose Tanks**[Page Bottom](#)**Special-purpose Tanks**[See General Information for Special-purpose Tanks](#)**FREEMAN ENCLOSURE SYSTEMS L L C**4160 HALF ACRE RD
BATAVIA, OH 45103 USA

MH47836

Secondary containment generator base tank.[Last Updated](#) on 2011-10-07[Questions?](#)[Print this page](#)[Notice of Disclaimer](#)[Page Top](#)[© 2012 UL LLC](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2012 UL LLC".



the standard in safety

Underwriters
Laboratories

File MH47836

Vol 1

Issued: 2010-10-25

Revised: 2010-10-25

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

SPECIAL-PURPOSE TANKS
(EFVT, EFVT7)

Manufacturer: FREEMAN ENCLOSURE SYSTEMS L L C
(100546-228) 4160 HALF ACRE RD
BATAVIA OH 45103

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc.(UL), or any authorized licensee of UL, only on products covered by this Procedure, in accordance with the applicable UL Services Agreement.

The prescribed Mark or Marking shall be used only at the above manufacturing location on such products which comply with this Procedure and any other applicable requirements.

The Procedure contains information for the use of the above named Manufacturer and representatives of Underwriters Laboratories Inc. and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it is not to be copied, either wholly or in part, and that it will be returned to Underwriters Laboratories Inc. (UL) or any authorized licensee of UL, upon request.

This PROCEDURE, and any subsequent revision, is the property of Underwriters Laboratories Inc.(UL) and the authorized licensee of UL and is not transferable.

Underwriters Laboratories Inc.

Stephen Hewson
Senior Vice President
Global Follow-Up Service Operations

William R. Carney
Director
North American Certification Program

File MH47836

Vol. 1

Index

Page 1

Issued: 2010-10-25

INDEX

Models

Section

Report Date

USL, CNL Secondary containment
generator base tanks

1

2010-10-25



File MH47836

Vol ST1

Auth. Page 1

Issued: 2011-09-23

Revised: 2011-09-23

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

SPECIAL-PURPOSE TANKS
(EFVT)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products when constructed, tested and found to be in compliance with the requirements of this Procedure and in accordance with the terms of the applicable UL Services Agreement and Follow-Up Service Terms and Conditions. UL further defines responsibilities, duties and requirements for both manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in accordance with the applicable Terms and Conditions at <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of this document from their local UL customer service representative or UL field representative. For assistance, or to obtain a paper copy of the Terms and Conditions, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified manufacturer(s) and any Listee will be considered to have agreed to Follow-Up Services and the terms of this Follow-Up Service Procedure upon the earliest use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees in accordance with the Follow-Up Services Terms and Conditions. Follow-Up Services will be governed by and incorporate by reference such GSA and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/newfustermes>. In all other events, such Follow-Up Services will be governed by and incorporate the terms of the applicable agreement and any applicable Program Terms and Conditions.

It is the responsibility of the Listee to make sure that only the products meeting the aforementioned requirements bear the authorized Marks of UL, or any authorized licensee of UL. The Applicant and the specified manufacturer(s) in this Follow-Up Services Procedure must agree to the Follow-Up Services as required by UL's Contracting Party.

This Procedure contains information for the use of the above Manufacturer(s) and representatives of UL or any licensee of UL, and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it will be returned upon request and is not to be copied in whole or in part.

This Procedure, and any subsequent revisions, is the property of UL and any authorized licensee of UL, and is not transferable. This procedure contains confidential information for use only by the above named Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is lent to the Subscribers with the understanding that it is not to be copied, either wholly or in part unless specifically allowed, and that it will be returned to UL, upon request.

UL shall not incur any obligation or liability for any loss, expense or damages, including incidental, consequential or punitive damages arising out of or in connection with the use or reliance upon this Procedure to anyone other than the above Manufacturer(s) as provided in the agreement between UL or an authorized licensee of UL, and the Manufacturer(s).

William R. Carney
Director
North American Certification Program

File MH47836 Vol ST1 Addendum To Page 1 Issued: 2011-09-23
Authorization Page Revised: 2011-09-23

LOCATION

(100546-228) FREEMAN ENCLOSURE SYSTEMS L L C
4160 HALF ACRE RD
BATAVIA OH 45103

Factory ID: NONE



File MH47836

Vol ST2

Auth. Page 1

Issued: 2011-09-23

Revised: 2011-09-23

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

SPECIAL-PURPOSE TANKS
(EFVT)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products when constructed, tested and found to be in compliance with the requirements of this Procedure and in accordance with the terms of the applicable UL Services Agreement and Follow-Up Service Terms and Conditions. UL further defines responsibilities, duties and requirements for both manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in accordance with the applicable Terms and Conditions at <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of this document from their local UL customer service representative or UL field representative. For assistance, or to obtain a paper copy of the Terms and Conditions, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified manufacturer(s) and any Listee will be considered to have agreed to Follow-Up Services and the terms of this Follow-Up Service Procedure upon the earliest use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees in accordance with the Follow-Up Services Terms and Conditions. Follow-Up Services will be governed by and incorporate by reference such GSA and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/newfusterm>. In all other events, such Follow-Up Services will be governed by and incorporate the terms of the applicable agreement and any applicable Program Terms and Conditions.

It is the responsibility of the Listee to make sure that only the products meeting the aforementioned requirements bear the authorized Marks of UL, or any authorized licensee of UL. The Applicant and the specified manufacturer(s) in this Follow-Up Services Procedure must agree to the Follow-Up Services as required by UL's Contracting Party.

This Procedure contains information for the use of the above Manufacturer(s) and representatives of UL or any licensee of UL, and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it will be returned upon request and is not to be copied in whole or in part.

This Procedure, and any subsequent revisions, is the property of UL and any authorized licensee of UL, and is not transferable. This procedure contains confidential information for use only by the above named Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is lent to the Subscribers with the understanding that it is not to be copied, either wholly or in part unless specifically allowed, and that it will be returned to UL, upon request.

UL shall not incur any obligation or liability for any loss, expense or damages, including incidental, consequential or punitive damages arising out of or in connection with the use or reliance upon this Procedure to anyone other than the above Manufacturer(s) as provided in the agreement between UL or an authorized licensee of UL, and the Manufacturer(s).

Willam R. Carney
Director
North American Certification Program

File MH47836 Vol ST2 Addendum To Page 1 Issued: 2011-09-23
Authorization Page Revised: 2011-09-23

LOCATION

(100546-228) FREEMAN ENCLOSURE SYSTEMS L L C
4160 HALF ACRE RD
BATAVIA OH 45103

Factory ID: NONE



File MH47836

Vol CN3

Auth. Page 1

Issued: 2011-09-23

Revised: 2011-09-23

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

SPECIAL-PURPOSE TANKS CERTIFIED FOR CANADA
(EFVT7)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products when constructed, tested and found to be in compliance with the requirements of this Procedure and in accordance with the terms of the applicable UL Services Agreement and Follow-Up Service Terms and Conditions. UL further defines responsibilities, duties and requirements for both manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in accordance with the applicable Terms and Conditions at <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of this document from their local UL customer service representative or UL field representative. For assistance, or to obtain a paper copy of the Terms and Conditions, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified manufacturer(s) and any Listee will be considered to have agreed to Follow-Up Services and the terms of this Follow-Up Service Procedure upon the earliest use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees in accordance with the Follow-Up Services Terms and Conditions. Follow-Up Services will be governed by and incorporate by reference such GSA and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/newfustermis>. In all other events, such Follow-Up Services will be governed by and incorporate the terms of the applicable agreement and any applicable Program Terms and Conditions.

It is the responsibility of the Listee to make sure that only the products meeting the aforementioned requirements bear the authorized Marks of UL, or any authorized licensee of UL. The Applicant and the specified manufacturer(s) in this Follow-Up Services Procedure must agree to the Follow-Up Services as required by UL's Contracting Party.

This Procedure contains information for the use of the above Manufacturer(s) and representatives of UL or any licensee of UL, and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it will be returned upon request and is not to be copied in whole or in part.

This Procedure, and any subsequent revisions, is the property of UL and any authorized licensee of UL, and is not transferable. This procedure contains confidential information for use only by the above named Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is lent to the Subscribers with the understanding that it is not to be copied, either wholly or in part unless specifically allowed, and that it will be returned to UL, upon request.

UL shall not incur any obligation or liability for any loss, expense or damages, including incidental, consequential or punitive damages arising out of or in connection with the use or reliance upon this Procedure to anyone other than the above Manufacturer(s) as provided in the agreement between UL or an authorized licensee of UL, and the Manufacturer(s).

William R. Carney
Director
North American Certification Program

File MH47836 Vol CN3 Addendum To Page 1
Authorization Page

Issued: 2011-09-23
Revised: 2011-09-23

LOCATION
(100546-228) FREEMAN ENCLOSURE SYSTEMS L L C
4160 HALF ACRE RD
BATAVIA OH 45103
Factory ID: NONE



EELU.MH48714

Protected Aboveground Tanks for Flammable and Combustible Liquids

[Page Bottom](#)

Protected Aboveground Tanks for Flammable and Combustible Liquids

[See General Information for Protected Aboveground Tanks for Flammable and Combustible Liquids](#)

FREEMAN ENCLOSURE SYSTEMS L L C

MH48714

4160 HALF ACRE RD
BATAVIA, OH 45103 USA

Protected Aboveground Tanks for Flammable and Combustible Liquids.

[Last Updated](#) on 2011-10-07

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[© 2012 UL LLC](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2012 UL LLC".



File MH48714

Vol ST1

Auth. Page 1

Issued: 2011-09-23

Revised: 2011-09-23

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

PROTECTED ABOVEGROUND TANKS FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS
(EELU)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products when constructed, tested and found to be in compliance with the requirements of this Procedure and in accordance with the terms of the applicable UL Services Agreement and Follow-Up Service Terms and Conditions. UL further defines responsibilities, duties and requirements for both manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in accordance with the applicable Terms and Conditions at <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of this document from their local UL customer service representative or UL field representative. For assistance or to obtain a paper copy of the Terms and Conditions, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified manufacturer(s) and any Listee will be considered to have agreed to Follow-Up Services and the terms of this Follow-Up Service Procedure upon the earliest use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees in accordance with the Follow-Up Services Terms and Conditions. Follow-Up Services will be governed by and incorporate by reference such GSA and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/newfusterm>. In all other events, such Follow-Up Services will be governed by and incorporate the terms of the applicable agreement and any applicable Program Terms and Conditions.

It is the responsibility of the Listee to make sure that only the products meeting the aforementioned requirements bear the authorized Marks of UL, or any authorized licensee of UL. The Applicant and the specified manufacturer(s) in this Follow-Up Services Procedure must agree to the Follow-Up Services as required by UL's Contracting Party.

This Procedure contains information for the use of the above Manufacturer(s) and representatives of UL or any licensee of UL, and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it will be returned upon request and is not to be copied in whole or in part.

This Procedure, and any subsequent revisions, is the property of UL and any authorized licensee of UL, and is not transferable. This procedure contains confidential information for use only by the above named Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is lent to the Subscribers with the understanding that it is not to be copied, either wholly or in part unless specifically allowed, and that it will be returned to UL, upon request.

UL shall not incur any obligation or liability for any loss, expense or damages, including incidental, consequential or punitive damages arising out of or in connection with the use or reliance upon this Procedure to anyone other than the above Manufacturer(s) as provided in the agreement between UL or an authorized licensee of UL, and the Manufacturer(s).

William R. Carney
Director
North American Certification Program

File MH48714 Vol ST1 Addendum To Page 1 Issued: 2011-09-23
Authorization Page Revised: 2011-09-23

LOCATION
(100546-228) FREEMAN ENCLOSURE SYSTEMS L L C
4160 HALF ACRE RD
BATAVIA OH 45103
Factory ID: NONE



File MH48714

Vol CN1

Auth. Page 1

Issued: 2011-09-23

Revised: 2011-09-23

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

PROTECTED ABOVEGROUND TANKS FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS
CERTIFIED FOR CANADA
(EELU7)

Manufacturer: SEE ADDENDUM FOR MANUFACTURER LOCATIONS

Applicant: SAME AS MANUFACTURER
(100546-228)

Listee: SAME AS MANUFACTURER
(100546-228)

This Procedure authorizes the above manufacturer to use the marking specified by Underwriters Laboratories Inc. (UL), or any authorized licensee of UL, only on products when constructed, tested and found to be in compliance with the requirements of this Procedure and in accordance with the terms of the applicable UL Services Agreement and Follow-Up Service Terms and Conditions. UL further defines responsibilities, duties and requirements for both manufacturers and UL representatives in the document titled, "UL Mark Surveillance Requirements" that can be located at the following web-site: <http://www.ul.com/fus> and in accordance with the applicable Terms and Conditions at <http://www.ul.com/responsibilities>. Manufacturers without Internet access may obtain the current version of this document from their local UL customer service representative or UL field representative. For assistance, or to obtain a paper copy of the Terms and Conditions, please contact UL's Customer Service at <http://www.ul.com/global/eng/pages/corporate/contactus>, select a location and enter your request, or call the number listed for that location.

The Applicant, the specified manufacturer(s) and any Listee will be considered to have agreed to Follow-Up Services and the terms of this Follow-Up Service Procedure upon the earliest use of the prescribed UL Mark, acceptance of the factory inspection, or payment of the Follow-Up Service fees in accordance with the Follow-Up Services Terms and Conditions. Follow-Up Services will be governed by and incorporate by reference such GSA and the Follow-Up Service Terms which can be accessed by clicking here: <http://www.ul.com/contracts/newfustermes>. In all other events, such Follow-Up Services will be governed by and incorporate the terms of the applicable agreement and any applicable Program Terms and Conditions.

It is the responsibility of the Listee to make sure that only the products meeting the aforementioned requirements bear the authorized Marks of UL, or any authorized licensee of UL. The Applicant and the specified manufacturer(s) in this Follow-Up Services Procedure must agree to the Follow-Up Services as required by UL's Contracting Party.

This Procedure contains information for the use of the above Manufacturer(s) and representatives of UL or any licensee of UL, and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it will be returned upon request and is not to be copied in whole or in part.

This Procedure, and any subsequent revisions, is the property of UL and any authorized licensee of UL, and is not transferable. This procedure contains confidential information for use only by the above named Manufacturer(s) and representatives of UL and is not to be used for any other purpose. It is lent to the Subscribers with the understanding that it is not to be copied, either wholly or in part unless specifically allowed, and that it will be returned to UL, upon request.

UL shall not incur any obligation or liability for any loss, expense or damages, including incidental, consequential or punitive damages arising out of or in connection with the use or reliance upon this Procedure to anyone other than the above Manufacturer(s) as provided in the agreement between UL or an authorized licensee of UL, and the Manufacturer(s).

Willam R. Carney
Director
North American Certification Program

File MH48714 Vol CN1 Addendum To Page 1 Issued: 2011-09-23
Authorization Page Revised: 2011-09-23

LOCATION
(100546-228) FREEMAN ENCLOUSRE SYSTEMS L L C
4160 HALF ACRE RD
BATAVIA OH 45103
Factory ID: NONE