


NWFD-3098

NORTHWEST FLORIDA WATER MANAGEMENT DISTRICT

FILE NO. LN-55
B.O.G. NO. W-WELL NUMBER 11B BASIN LAT. 30°29'34" LONG. 84°03'27" COUNTY Leon DATE Aug 6 1979 PERMIT NO. LOCATION T 1N R 3E SEC 17 NW¼ of NW¼ of NW¼ MAP OR QUAD Lloyd 7' ☒ 15' ☐OWNER Deanna Hungerford ADDRESS P.O. Box 865 Tallahassee, FL 32302WELL DEPTH 173 ft. CASSED 63 ft. OPEN HOLE 110 ft. WELL FINISHED: SCREENED SCREEN INTERVAL OPEN HOLE ☒START OF LOG (LSD) 0 ft. TOP OF CASING TO LSD .5' DEPTH LOGGED TOP ft. BOTTOM ft. TOTAL FT. LOGGED 692'CONDITION good. DATE DRILLED ~ 4 yr old. GROUTED - DATE - CAPPED TYPE OF CASING FLOWING no GPM - HEAD - IN. TOP OF LS LSD 53' MSL ELEVATION OF LSD TO MSL 100 SIZE 4"FORMATION FORMATION TOP REFERENCE TO LSD ft. MSL ft.AQUIFER Floridan WATER LEVEL REFERENCE TO LSD 72 FT. MSL + 28 ft. ARTESIAN HEAD ft.

TYPE OF LOG	INTERVAL TO	VERT. SCALE	HORZ. SCALE	DIRECTION LOGGED	SPEED FT./MIN.	REMARKS
Gamma w/ccl TC= <u>2</u>	<u>4</u> <u>172</u>	<u>1"20ft</u>	<u>200 CPS</u>			
Caliper-Arms= <u>"</u>	<u>25</u> <u>172</u>	<u>20</u>	<u>0F</u>			
Temp w/ccl	<u>10</u> <u>168</u>	<u>20</u>				
Fluid Resistivity						
Electric -16,64 R _p						
Flow Meter						
Sampler - Depth(s)						
Neutron						
CCL						

LOCATION:

Pump Test info - Pumped @ gpm static pumping level dd specific capacity T = S =
USE OF WELL Anode Drainage Observation Oil-Gas Recharge Test Abandoned Withdrawal ☒ Waste Irrigation Public Supply QUALITY WATER SAMPLE Yes No ☒ Date Depth(s) pH Salinity Conductivity Temp. Chloride DRILLER Carr TYPE OF RIG Cable PUMP INTAKE DEPTH 105 TYPE OF PUMP Sub. hp 1 1/2 DRILLER SAMPLES noStart of Logging 1 pm Finished logging 2:30 Total Time 1.5 hr. Operator/observer Kwader / Well Accessibility behind trailerLithological Summary REMARKS: Pump pulled - motor seized. MAY put a larger pump in. casing above
water level - blows Air. well located E of Lloyd, NE of Bied sink and St. Lukes Church, ESE of
Patty sink. SSE of BM 131

THIS LOG FOR HYDROGEOLOGICAL DATA ONLY - NOT FOR CONTRACTUAL SATISFACTION

CALIPER

LN-55

8-6-79

-20

- 4" STEEL CASING

50

- Bottom of CASING 63'

WATER LEVEL

100 -

FIRM LIMESTONE

- 150

T.D. 173'

2

4

6

8

10

12

14

16

NATURAL GAMMA LOG

NW FIO-3098

SANDY CLAY

LN-55

8-6-79

CLAYEY SAND

- 50

Soft
Limestone

- Bottom of CASING 63'

- WATER LEVEL 72'

Firm Limestone

100

PUMP

- Soft STREAK

Soft
Limestone

- 150

- Total Depth 173'
100 COUNTS PER SECOND

TEMPERATURE

NWFI D-3098

LN-55

8-6-79

- WATER LEVEL -72'

50

100

150

CASING COLLAR LOCATOR

LN-55

8-6-79

0

50

100

150

> Casing COLLARS

- Bottom of Casing 63'

- Sensitivity Check