

SE-12


NW FID-1352

NORTHWEST FLORIDA WATER MANAGEMENT DISTRICT

FILE NO. LN-83B.O.G. NO. W-WELL NUMBER BASIN LAT. 302208 LONG. 841238 COUNTY Leah DATE 6/12/80 PERMIT NO. LOCATION T 15 R 16 SEC 26 SW 4 of NW 4 of NW 4 MAP OR QUAD 7' ☐ 15' ☐OWNER U.S.G.S. / City of Tallahassee, SE-12 ADDRESS WELL DEPTH 48 ft. CASED 47 ft. OPEN HOLE 1 ft. WELL FINISHED: SCREENED No SCREEN INTERVAL N/A OPEN HOLE YesSTART OF LOG LSD + 0 ft. TOP OF CASING TO LSD 2 DEPTH LOGGED TOP 0 ft. BOTTOM 48 ft. TOTAL FT. LOGGED 96'CONDITION New DATE DRILLED 6/80 GROUTED Yes DATE 6/80 CAPPED Yes TYPE OF CASING PVCFLOWING No GPM N/A HEAD IN. TOP OF LS LSD MSL ELEVATION OF LSD TO MSL 46.56 SIZE 4"FORMATION FORMATION TOP REFERENCE TO LSD ft. MSL ft.AQUIFER Floridan WATER LEVEL REFERENCE TO LSD -31 FT. MSL 15.56 ft. ARTESIAN HEAD ft.

TYPE OF LOG	INTERVAL TO		VERT. SCALE	HORZ. SCALE	DIRECTION LOGGED	SPEED FT./MIN.	REMARKS
Gamma w/ccl TC=	4	48	1" 20ft.	0.700 CPS	up	25'/min	
Caliper-Arms= 18"	4	48	1"-20"	~	down	25'/min	
Temp w/ccl							
Fluid Resistivity							
Electric -16,64 R _p							
Flow Meter							
Sampler - Depth(s)							
Neutron							


LOCATION:

Pump Test info - Pumped @ N/A gpm static pumping level dd specific capacity T = S =
USE OF WELL Anode Drainage Observation Oil-Gas Recharge Test Abandoned Withdrawal Waste Irrigation Public Supply QUALITY WATER SAMPLE Yes No Date N/A Depth(s) pH Salinity Conductivity Temp. Chloride DRILLER Rowe Bros. TYPE OF RIG Mud Rotary PUMP INTAKE DEPTH TYPE OF PUMP hp DRILLER SAMPLES YesStart of Logging Finished logging Total Time hr. Operator/observer Pratt / 1Well Accessibility goodLithological Summary REMARKS: Located at Southeast Spang Field

THIS LOG FOR HYDROGEOLOGICAL DATA ONLY - NOT FOR CONTRACTUAL SATISFACTION

0 cps
|

100 cps
| 0



Natural Gamma
NWFIID-1352


LN-83
6/12/80

Water level 31'

Total depth 48'

LN-83

6/12/80



Temperature
NWFIID-1352

Water level 31'

Total depth 48'