

WELL NUMBER _____ BASIN _____ LAT. 30°45'51" LONG. 85°34'27" COUNTY Washington DATE 7/18/80 PERMIT NO. _____
LOCATION T9N R13W SEC 18 SW 1/4 of NW 1/4 of SE 1/4 MAP OR QUAD UASAM Quad, 7.5' 1950 1' 15' 15'
OWNER Chauncy Stephens ADDRESS _____
WELL DEPTH 196 ft. CASING 196 ft. OPEN HOLE 0 ft. WELL FINISHED: SCREENED 1/2 SCREEN INTERVAL N/A OPEN HOLE Yes
START OF LOG LSD ± 0 ft. TOP OF CASING TO LSD .5' DEPTH LOGGED TOP 0 ft. BOTTOM 196 ft. TOTAL FT. LOGGED 588'
CONDITION old, caved DATE DRILLED ? GROUTED ? DATE ? CAPPED 1/2 TYPE OF CASING PVC
FLOWING No GPM N/A HEAD - IN. TOP OF LS LSD _____ MSL _____ ELEVATION OF LSD TO MSL 130 SIZE 4"
FORMATION _____ FORMATION TOP REFERENCE TO LSD _____ ft. MSL _____ ft.
AQUIFER Florida WATER LEVEL REFERENCE TO LSD -68 FT. MSL 62 ft. ARTESIAN HEAD _____ ft.

TYPE OF LOG	INTERVAL TO	VERT. SCALE	HORZ. SCALE	DIRECTION LOGGED	SPEED FT./MIN.	REMARKS
Gamma w/ccl TC=	4 196	1"=20 ft.	1"=10 CPS	up	25'/min	
Caliper-Arms= 18"	124 196	1"=20'	2"=18"	up	15'/min	
Temp w/ccl	10 112	1"=20'		down	25'/min	
Fluid Resistivity						
Electric -16,64 Rp						
Flow Meter						
Sampler - Depth(s)						
Neutron						

LOCATION:

R 13W

T	9N	18

over

Pump Test info - Pumped @ N/A gpm static _____ pumping level _____ dd _____ specific capacity _____ T = _____ S = _____
USE OF WELL Anode _____ Drainage _____ Observation _____ Oil-Gas _____ Recharge _____ Test _____ Abandoned _____ Withdrawal _____ Waste _____ Irrigation _____ Public Supply _____
QUALITY WATER SAMPLE Yes _____ No _____ Date N/A Depth(s) _____ pH _____ Salinity _____ Conductivity _____ Temp. _____ Chloride _____
DRILLER Unknown TYPE OF RIG Unknown PUMP INTAKE DEPTH _____ TYPE OF PUMP _____ hp _____ DRILLER SAMPLES _____
Start of Logging 12:30 Finished logging 1:30 Total Time 1 hr. Operator/observer Pratt 1

Well Accessibility goodLithological Summary there is a bronze clay in the bottom of this cased well. this clay came out of the well on the end of the caliper tool

REMARKS: _____

THIS LOG FOR HYDROGEOLOGICAL DATA ONLY - NOT FOR CONTRACTUAL SATISFACTION

NWFWMD Form No. 42

