

WELL NUMBER 12A LAT. 30° 46' 42" LONG. 85° 32' 51" COUNTY WASHINGTON DATE 5-3-78 PERMIT NO. 80411
LOCATION T 4N R 14W SEC 4 NE 1/4 of NW 1/4 of SW 1/4 MAP OR QUAD CHIPLEY (1:24000) NS-11
OWNER Hardy House Restaurant HARDY ADDRESS Just W. of Chipley CHIPLEY, FLA.
WELL DEPTH 343 ft. CASED 246 ft. OPEN HOLE 97 ft. DEPTH LOGGED TOP 3 ft. BOTTOM 343 ft. TOTAL FT. LOGGED 1029
START OF LOG LSD 0 ft. TOP OF CASING TO LSD 0.5 ft.
CONDITION New DATE DRILLED 5-1-78 GROUTED ? DATE 5-3-78 CAPPED ? TYPE OF CASING PVC SIZE 4"
FLOWING NO GPM — HEAD — IN. ELEVATION OF LSD TO MSL 84 Top of LS LSD — MSL —
FORMATION — FORMATION TOP REFERENCE TO LSD — MSL —
AQUIFER Floridan WATER LEVEL REFERENCE TO LSD -17' MSL +67' ARTESIAN HEAD —
TYPE OF LOG Gamma INTERVAL TO 4 VERT. SCALE 1" = 20 ft. HORZ. SCALE 0-200 CPS LOGGED DIRECTION UP SPEED 23 FT./MIN. REMARKS —
Gamma w/ TC=2 4 340 1 20 0-200 CPS UP 23 —
Caliper 4 343 20 62-70°F DOWN 30 —
Temp w/ — — — — — — —
Fluid Resistivity — — — — — — —
Electric — — — — — — —
Flow Meter — — — — — — —
Sampler — — — — — — —
REPEAT TEMP. 170 300 20 — UP 40 —
USE OF WELL Anode — Drainage — Observation — Oil-Gas — Recharge — Test — Abandoned — Withdrawal ✓ Waste — Irrigation —
QUALITY WATER SAMPLE Yes — No ✓ Date — Depth(s) — pH — Salinity — Conductivity — Temp. 62-70°F
DRILLER Dee Faison TYPE OF RIG Rotary PUMP INTAKE DEPTH — TYPE OF PUMP — DRILLER SAMPLES NO
Start of Log 3:30 Finished logging 5:00 Total time 1.5 hr Operator/observer KWADER / DEUERLING
Well Accessibility Easy access, next to power pole + catfish pond behind Hardy House Restaurant
Lithological Summary —
REMARKS: Well much deeper than surrounding wells in area (343' compared to ~125' for others)

THIS LOG FOR HYDROGEOLOGICAL DATA ONLY - NOT FOR CONTRACTUAL SATISFACTION

NWFWMD Form No.

