



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, Florida 33902-2549

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

CERTIFIED MAIL NO.: 7008 0500 0000 7775 3041
RETURN RECEIPT REQUESTED

In the Matter of an
Application for Permit by:

Sportsman's Village Condominium Association, Inc.
Ms. Phyllis Miller, President
P.O. Box 455
Moore Haven, FL 33471

Glades County - DW
Sportsman's Village WWTP
PA File No. FLA014260-006-DW3P
Caloosahatchee TMDL Basin

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number FLA014260 to operate a domestic wastewater treatment plant. The permitted capacity for the three-month average daily flow is 0.030 million gallons per day. This permit is issued under Section(s) 403.087, Florida Statutes.

Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, Florida Statutes, within fourteen days of receipt of notice. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request enlargement of the time for filing a petition for an administrative hearing. The request must be filed (received by the clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes, must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first. Under Section 120.60(3), Florida Statutes, however, any person who has asked the Department for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within fourteen days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

FACILITY: Sportsman's Village WWTP
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PA File #: FLA014260-006-DW3P

A petition that disputes the material facts on which the Department's action is based must contain the following information:

- (a) The name, address, and telephone number of each petitioner; the name, address, and telephone number of the petitioner's representative, if any; the Department permit identification number and the county in which the subject matter or activity is located;
- (b) A statement of how and when each petitioner received notice of the Department action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department action;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A statement of facts that the petitioner contends warrant reversal or modification of the Department action;
- (f) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.


Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This permit action is final and effective on the date filed with the clerk of the Department unless a petition is filed in accordance with the above. Upon the timely filing of a petition this permit will not be effective until further order of the Department.

Any party to the permit has the right to seek judicial review of the permit action under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the clerk of the Department in the Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000; and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when this permit action is filed with the clerk of the Department.

Executed in Fort Myers, Florida

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

FACILITY: Sportsman's Village WWTP
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PA File No.: FLA014260-006-DW3P

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52, Florida Statutes, with the designated deputy clerk, receipt of which is hereby acknowledged.

Maria A. Colman 4/13/09
[Clerk] [Date]

CERTIFICATE OF SERVICE

The undersigned hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were mailed before the close of business on April 13, 2009, to the listed persons.

JMI/NWM/jl

Copies furnished to:
Scott F. Jones, P.E.
Keith Kleinmann



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, Florida 33902-2549

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:

Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER:

FLA014260

PA FILE NUMBER:

FLA014260-006-DW3P

ISSUANCE DATE:

April 13, 2009

EXPIRATION DATE:

April 12, 2014

RESPONSIBLE AUTHORITY:

Ms. Phyllis Miller
President
P.O. Box 455
Moore Haven, FL 33471

(863) 946-0886

FACILITY:

Sportsman's Village WWTP
1 Daniels Road
Moore Haven, FL 33471
Glades County
Latitude: 26° 50' 00" N Longitude: 81° 04' 00" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). The above named permittee is hereby authorized to operate the facilities shown on the application and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

TREATMENT FACILITIES:

Sportsman's Village WWTP is a domestic wastewater treatment plant. The permitted capacity for the three-month average daily flow (TMADF) is 0.030 million gallons per day (MGD). The facility uses an extended aeration process. The plant consists of one 12,000-gallon surge tank, two aeration tanks (total volume of 50,000 gallons), two 5,100-gallon clarifiers, two 875-gallon chlorine contact chambers, a chlorine tablet disinfection system and two aerobic digesters (total volume of 12,780 gallons).

REUSE:

Land Application: The treated effluent is disposed in a rapid infiltration basin system (R-001). R-001 consists of two 0.22-acre rapid infiltration basins located on the facility property. The permitted capacity for R-001 is 0.030 MGD TMADF.

IN ACCORDANCE WITH: The limitations, monitoring requirements and other conditions set forth in Pages 1 through 14 of this permit.

FACILITY: Sportsman's Village WWTP
 PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
 PA FILE NUMBER: FLA014260-006

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Reuse and Land Application Systems

- During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.8:

			Reclaimed Water Limitations				Monitoring Requirements			
Parameter	Units	Max/Min	Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	20.0	30.0	45.0	60.0	Monthly	Grab	EFF-01	
Solids, Total Suspended	MG/L	Maximum	20.0	30.0	45.0	60.0	Monthly	Grab	EFF-01	
pH	SU	Range	-	-	-	6.0 to 8.5	5 Days/Week	Grab	EFF-01	
Coliform, Fecal	#/100ML	Maximum	See Permit Condition I.A.3.				Monthly	Grab	EFF-01	
Total Residual Chlorine (For Disinfection)	MG/L	Minimum	-	-	-	0.5	5 Days/Week	Grab	EFF-01	See Cond.I.A.4
Nitrogen, Nitrate, Total (as N)	MG/L	Maximum	-	-	-	12.0	Monthly	Grab	EFF-01	

FACILITY: Sportsman's Village WW
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
PA FILE NUMBER: FLA014260-006

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I. A. 1. and as described below:

Monitoring Location Site Number	Description of Monitoring Location
EFF-01	After chlorination and before discharge to the percolation ponds.

3. The arithmetic mean of the monthly fecal coliform values collected during an annual period shall not exceed 200 per 100 mL of reclaimed water sample. The geometric mean of the fecal coliform values for a minimum of 10 samples of reclaimed water, each collected on a separate day during a period of 30 consecutive days (monthly), shall not exceed 200 per 100 mL of sample. No more than 10 percent of the samples collected (the 90th percentile value) during a period of 30 consecutive days shall exceed 400 fecal coliform values per 100 mL of sample. Any one sample shall not exceed 800 fecal coliform values per 100 mL of sample. Note: To report the 90th percentile value, list the fecal coliform values obtained during the month in ascending order. Report the value of the sample that corresponds to the 90th percentile (multiply the number of samples by 0.9). For example, for 30 samples, report the corresponding fecal coliform number for the 27th value of ascending order. [62-610.510 and 62-600.440(4)(c)]
4. A minimum of 0.5 mg/L total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-610.510 and 62-600.440(4)(b)]

FACILITY: Sportsman's Village WWTP
 PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
 PA FILE NUMBER: FLA014260-006

B. Other Limitations and Monitoring and Reporting Requirements

- During the period beginning on the issuance date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.8:

			Limitations				Monitoring Requirements			
Parameter	Units	Max/Min	Annual Average	Monthly Average	Weekly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow	MGD	Maximum	-	-	-	-	5 Days/Week	Elapsed time meters	FLW-01	See Cond.I.B.3, 5
Percent Capacity, (TMADF/Permitted Capacity) x 100	PERCENT	Maximum	-	Report	-	-	Monthly	Calculated	FLW-01	
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	-	Report	-	-	Monthly	Grab	INF-01	See Cond.I.B.4
Solids, Total Suspended	MG/L	Maximum	-	Report	-	-	Monthly	Grab	INF-01	See Cond.I.B.4

FACILITY: Sportsman's Village WWT
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
PA FILE NUMBER: FLA014260-006

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I. B. 1 and as described below:

Monitoring Location Site Number	Description of Monitoring Location
FLW-01	Elapsed time meter measurements at the influent lift station.
INF-01	At the flow splitter box.

3. The three-month average daily flow to the treatment plant shall not exceed 0.030 MGD.
4. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
5. Meters shall be utilized to measure flow and calibrated at least annually. [62-601.200(17) and .500(6)]
6. Parameters which must be monitored as a result of a surface water discharge shall be analyzed using a sufficiently sensitive method to assure compliance with applicable water quality standards and effluent limitations in accordance with 40 CFR (Code of Federal Regulations) Part 136. All monitoring shall be representative of the monitored activity. [62-620.320(6)]
7. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
8. Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department's South District Office Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e., monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type	Monitoring Period	Due Date
Monthly or Toxicity	First day of month – last day of month	28 th day of following month
Quarterly	January 1 - March 31 April 1 – June 30 July 1 – September 30 October 1 – December 31	April 28 July 28 October 28 January 28
Semiannual	January 1 – June 30 July 1 – December 31	July 28 January 28
Annual	January 1 – December 31	January 28

DMRs shall be submitted for each required monitoring period including months of no discharge. The permittee shall make copies of the attached DMR form and shall submit the completed DMR form to the Department's South District Office at the address specified in Permit Condition I.B. 9 by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18)][62-601.300(1), (2), and (3)]

9. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's South District Office at the address specified below:

South District Office
Department of Environmental Protection
P.O. Box 2549
Ft. Myers, Florida 33902-2549

Phone Number - 239-332-6975

FAX Number - 239-332-6969

All FAX copies shall be followed by original copies. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. [62-620.305]

II. RESIDUALS MANAGEMENT REQUIREMENTS

The method of residuals use or disposal by this facility is transport to Tir na n'Og Ranch RMF, 24 NE 325th Trail Okeechobee, FL 34972 or disposal in a Class I or II solid waste landfill.

1. The permittee shall be responsible for proper treatment, management, use, and land application or disposal of its residuals. [62-640.300(5)]
3. The permittee shall not be held responsible for treatment, management, use, or land application violations that occur after its residuals have been accepted by a permitted residuals management facility with which the source facility has an agreement in accordance with Rule 62-640.880(1)(c), F.A.C., for further treatment, management, use or land application. [62-640.300(5)]
4. Disposal of residuals, septage, and other solids in a solid waste landfill, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. [62-640.100(6)(k)3 & 4]
5. If the permittee intends to accept residuals from other facilities, a permit revision is required pursuant to Rule 62-640.880(2)(d), F.A.C. [62-640.880(2)(d)]
6. The permittee shall keep hauling records to track the transport of residuals between facilities. The hauling records shall contain the following information:

Source Facility

1. Date and Time Shipped
2. Amount of Residuals Shipped
3. Degree of Treatment (if applicable)
4. Name and ID Number of Residuals Management Facility or Treatment Facility
5. Signature of Responsible Party at Source Facility
6. Signature of Hauler and Name of Hauling Firm

Residuals Management Facility or Treatment Facility

1. Date and Time Received
2. Amount of Residuals Received
3. Name and ID Number of Source Facility
4. Signature of Hauler
5. Signature of Responsible Party at Residuals Management Facility or Treatment Facility

These records shall be kept for five years and shall be made available for inspection upon request by the Department. A copy of the hauling records information maintained by the source facility shall be provided upon delivery of the residuals to the residuals management facility or treatment facility. The permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of residuals leaving the source facility and arriving at the residuals management facility or treatment facility. [62-640.880(4)]

7. Storage of residuals or other solids at the permitted facility shall require prior written notification to the Department. [62-640.300(4)]

III. GROUND WATER REQUIREMENTS

Section III is not applicable to this facility.

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

Part IV Rapid Infiltration Basins (R-001)

1. Advisory signs shall be posted around the site boundaries to designate the nature of the project area. [62-610.518]
2. The annual average hydraulic loading rate to the rapid infiltration basins shall be limited to a maximum of 5.08 inches per day (as applied to the entire bottom area). [62-610.523(3)]
3. The rapid infiltration basins normally shall be loaded for 5 days and shall be rested for 5 days. Infiltration ponds, basins, or trenches shall be allowed to dry during the resting portion of the cycle. [62-610.523(4)]
4. The rapid infiltration basins shall be routinely maintained to control vegetation growth and to maintain percolation capability by scarification or removal of deposited solids. Basin bottoms shall be maintained to be level. [62-610.523(6) and (7)]
5. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. [62-610.514 and 62-610.414]
6. Overflows from emergency discharge facilities on storage ponds or on infiltration ponds, basins, or trenches shall be reported as an abnormal event to the Department's South District Office within 24 hours of an occurrence. The provisions of Rule 62-610.800(9), F.A.C., shall be met. [62-610.800(9)]

V. OPERATION AND MAINTENANCE REQUIREMENTS

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of an operator certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator 1/2 hour/day for 5 days/week and one weekend visit. The lead operator must be a Class C operator, or higher.

[62-620.630(3)] [62-699.310] [62-610.462]

2. An operator meeting the lead operator classification level of the plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. [62-699.311(1)]
3. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(5)]
4. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1)]
5. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility:
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation and a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;

FACILITY: Sportsman's Village WWTP
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
PA FILE NUMBER: FLA014260-006

- b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
- c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
- d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
- e. A copy of the current permit;
- f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
- g. A copy of the facility record drawings;
- h. Copies of the licenses of the current certified operators; and
- i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and certification number of the operator and the signature of the person making any entries; date and time in and out; specific operation and maintenance activities; tests performed and samples taken; and major repairs made. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed.

[62-620.350]

VI. SCHEDULES

Section VI is not applicable to this facility.

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

This facility is not required to have a pretreatment program at this time. [62-625.500]

VIII. OTHER SPECIFIC CONDITIONS

1. Prior to placing the modified portions of the existing facilities into operation or any individual unit processes into operation, for any purpose other than testing for leaks and equipment operation, the permittee shall complete and submit to the Department DEP Form 62-620.910(12), Notification of Completion of Construction for Domestic Wastewater Facilities. [62-620.630(2)]
2. Within six months after a facility is placed in operation, the permittee shall provide written certification to the Department on Form 62-620.910(13) that record drawings pursuant to Chapter 62-600, F.A.C., and that an operation and maintenance manual pursuant to Chapters 62-600 and 62-610, F.A.C., as applicable, are available at the location specified on the form. [62-620.630(7)]
3. The permittee shall apply for renewal of this permit at least 180 days before the expiration date of the permit using the appropriate forms listed in Rule 62-620.910, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C. The existing permit shall not expire until the Department has taken final action on the application renewal in accordance with the provisions of 62-620.335(3) and (4), F.A.C. [62-620.335(1)-(4)]
4. Florida water quality criteria and standards shall not be violated as a result of any discharge or land application of reclaimed water or residuals from this facility. [62-610.850(1)(a) and (2)(a)]
5. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to

ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. [62-600.410(8) and 62-640.400(6)]

6. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. [62-604.130(3)]
7. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.550] [62-620.610(20)]
8. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health or safety problems.[62-604.130(5)]
9. The treatment facility, storage ponds, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-610.518(1)] [and 62-600.400(2)(b)]
10. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-701.300(1)(a)]
11. The Permittee shall provide verbal notice to the Department as soon as practical after discovery of a sinkhole within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The Permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department in a written report within 7 days of the sinkhole discovery. [62-4.070(3)]
12. The permittee shall provide adequate notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C. if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

[62-620.625(2)]

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5)]
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. [62-620.610(6)]
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7)]
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8)]
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, Florida Statutes, or Rule 62-620.302, Florida Administrative Code. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. [62-620.610(10)]
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. [62-620.610(11)]
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. [62-620.610(12)]
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. [62-620.610(13)]
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. [62-620.610(14)]
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. [62-620.610(15)]
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300 and the Department of Environmental Protection Guide to Wastewater Permitting at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2) for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16)]
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.

[62-620.610(17)]

18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.

FACILITY: Sportsman's Village WWT
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
PA FILE NUMBER: FLA014260-006

- b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
- c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
- d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
- e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
- f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220 and 62-160.330, F.A.C.

[62-620.610(18)]

- 19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. *[62-620.610(19)]*
- 20. The permittee shall report to the Department any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 - a. The following shall be included as information which must be reported within 24 hours under this condition:
 - 1. Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - 2. Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - 3. Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - 4. Any unauthorized discharge to surface or ground waters.
 - b. Oral reports as required by this subsection shall be provided as follows:
 - 1. For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph a.4 that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the Department by calling the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - a) Name, address, and telephone number of person reporting;
 - b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - c) Date and time of the discharge and status of discharge (ongoing or ceased);

- d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - e) Estimated amount of the discharge;
 - f) Location or address of the discharge;
 - g) Source and cause of the discharge;
 - h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - i) Description of area affected by the discharge, including name of water body affected, if any; and
 - j) Other persons or agencies contacted.
2. Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department shall waive the written report.

[62-620.610(20)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX. 17., 18. and 19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX. 20 of this permit. [62-620.610(21)]

22. Bypass Provisions.

- a. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 - 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - 3. The permittee submitted notices as required under Permit Condition IX. 22. b. of this permit.
- b. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX. 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- c. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX. 22. a. 1. through 3. of this permit.
- d. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX. 22. a. through c. of this permit.

[62-620.610(22)]

FACILITY: Sportsman's Village WWT
PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT NUMBER: FLA014260
PA FILE NUMBER: FLA014260-006


23. Upset Provisions

- a. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 1. An upset occurred and that the permittee can identify the cause of the upset;
 2. The permitted facility was at the time being properly operated;
 3. The permittee submitted notice of the upset as required in Permit Condition IX. 20. of this permit; and
 4. The permittee complied with any remedial measures required under Permit Condition IX. 5. of this permit.
- b. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- c. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

Executed in Fort Myers, Florida

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

DATE: April 13, 2009

**STATEMENT OF BASIS
FOR
STATE OF FLORIDA
DOMESTIC WASTEWATER FACILITY PERMIT**

PERMIT NUMBER: FLA014260-006-DW3P/NR

FACILITY NAME: Sportsman's Village WWTP

FACILITY LOCATION: Moore Haven
Glades County

NAME OF PERMITTEE: Sportsman's Village Condominium Association, Inc.

PERMIT WRITER: Nolin Moon

1. **BASIS FOR EFFLUENT AND RECLAIMED WATER LIMITS AND MONITORING REQUIREMENTS
(INCLUDING EFFLUENT MONITORING REQUIREMENTS)**

The following table provides the basis for Part I. A. provisions.

Land Application System R-001 (rapid infiltration basin):

Parameter	Limit	Basis	Rationale
BOD, Carbonaceous 5 day, 20C (MG/L)	20.0	Annual Average	62-610.510 & 62-600.740(1)(b)1.a. FAC
	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
	60.0	Single Sample Max.	62-600.740(1)(b)1.d. FAC
Solids, Total Suspended (MG/L)	20.0	Annual Average	62-610.510 & 62-600.740(1)(b)1.a. FAC
	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
	60.0	Single Sample Max.	62-600.740(1)(b)1.d. FAC
pH (SU)	6.0 to 8.5	Minimum and Maximum	62-600.445 FAC
Coliform, Fecal (#/100ML)	200	Annual Average	62-610.510 & 62-600.440(4)(c)1. FAC
	200	Monthly Geo. Mean	62-600.440(4)(c)2. FAC
	400	90th Percentile	62-600.440(4)(c)3. FAC
	800	Single Sample Max.	62-600.440(4)(c)4. FAC
Total Residual Chlorine (For Disinfection) (MG/L)	0.5	Minimum	62-610.510 & 62-600.440(4)(b) FAC
Nitrogen, Nitrate, Total (as N) (MG/L)	12.0	Single Sample Max.	62-610.510(1) FAC

The following table provides the basis for Part I. B. provisions.

Other Limitations and Monitoring Requirements:

Parameter	Limit	Basis	Rationale
Flow (MGD)	0.03	Three Month Average	62-600.400(3)(b)FAC
Percent Capacity, (TMADF/Permitted Capacity) x 100 (PERCENT)	Report	Monthly Average	62-600.405(4) FAC
BOD, Carbonaceous 5 day, 20C (MG/L)	Report	Monthly Average	62-601.300(1)FAC
Solids, Total Suspended (MG/L)	Report	Monthly Average	62-601.300(1)FAC
Monitoring Frequency and Sample Type	-	All Parameters	62-601 FAC & 62-699 FAC and/or BPJ of permit writer
Sampling Location	-	All Parameters	62-601, 62-610.412, 62-610.463(1), 62- 610.568, 62-610.613 FAC and/or BPJ of permit writer

2. RESIDUALS MANAGEMENT

The method of residuals use or disposal by this facility is transport to Tir na n'Og Ranch RMF or disposal in a Class I or II solid waste landfill.

3. GROUND WATER MONITORING REQUIREMENTS

Ground water monitoring requirements have been established in accordance with Rules 62-601 and 62-522, F.A.C.

4. SCHEDULES FOR IMPROVEMENT ACTIONS, CONSTRUCTION, AND ENGINEERING STUDIES

This section is not applicable to this facility

5. INDUSTRIAL PRETREATMENT REQUIREMENTS

At this time, the facility is not required to develop an approved industrial pretreatment program. However, the Department reserves the right to require an approved program if future conditions warrant.

6. ADMINISTRATIVE ORDERS (AO) AND CONSENT ORDERS (CO)

This permit is not accompanied by an AO, and there are no unresolved compliance issues for this facility.

7. EFFECTS OF SURFACE WATER DISCHARGE ON THREATENED OR ENDANGERED SPECIES

The Department does not anticipate adverse impacts on threatened or endangered species as a result of permit issuance.

8. APPLICABLE RULES

The following were used as the basis of the permit limitations/conditions:

- a. FAC refers to various portions of the Florida Administrative Code.

The effective dates of FAC Rule Chapters cited in the table are as follows:

<u>Chapter</u>	<u>Effective Date</u>
62-4	04-02-08
62-160	06-08-04
62-302	04-02-08
62-520	12-09-96
62-522	08-27-01
62-550	09-18-07
62-600	12-24-96
62-601	12-24-96
62-602	10-15-07
62-610	11-19-07
62-620	04-02-08
62-625	01-08-97
62-640	03-30-98
62-650	12-26-96
62-699	10-15-07

- b. FS refers to various portions of the Florida Statutes

- c. CFR refers to various portions of the Code of Federal Regulations, Title 40

- d. BPJ refers to Best Professional Judgment

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, South District, P.O. Box 2549, Ft. Myers, FL, 33902-2549

PERMITTEE NAME: Sportsman's Village Condominium Association, Inc.
MAILING ADDRESS: P.O. Box 455
Moore Haven, FL 33471

PERMIT NUMBER: FLA014260

LIMIT: Final
CLASS SIZE: N/A

REPORT: Monthly
GROUP: Domestic

FACILITY: Sportsman's Village WWTP
LOCATION: 1 Daniels Road
Moore Haven, FL 33471

MONITORING GROUP NUMBER: R-001
MONITORING GROUP DESC: Effluent and Influent

COUNTY: Glades

NO DISCHARGE FROM SITE: ☐

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
BOD, Carbonaceous 5 day, 20C	Sample Measurement							
PARM Code 80082 Y Mon.Site No. EFF-01	Permit Requirement			20.0 (An.Avg.)	MG/L		Monthly	Grab
BOD, Carbonaceous 5 day, 20C	Sample Measurement							
PARM Code 80082 I Mon.Site No. EFF-01	Permit Requirement			Report (Mo.Avg.)	60.0 (Max.)	MG/L	Monthly	Grab
Solids, Total Suspended	Sample Measurement							
PARM Code 00530 Y Mon.Site No. EFF-01	Permit Requirement			20.0 (An.Avg.)	MG/L		Monthly	Grab
Solids, Total Suspended	Sample Measurement							
PARM Code 00530 I Mon.Site No. EFF-01	Permit Requirement			Report (Mo.Avg.)	60.0 (Max.)	MG/L	Monthly	Grab
pH	Sample Measurement							
PARM Code 00400 I Mon.Site No. EFF-01	Permit Requirement			6.0 (Min.)	8.5 (Max.)	SU	5 Days/Week	Grab
Coliform, Fecal	Sample Measurement							
PARM Code 74055 Y Mon.Site No. EFF-01	Permit Requirement			200 (An.Avg.)	#/100ML		Monthly	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Sportsman's Village WWTP

MONITORING GROUP NUMBER: R-001

PERMIT NUMBER: FLA014260

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Coliform, Fecal	Sample Measurement										
PARM Code 74055 1 Mon.Site No. EFF-01	Permit Requirement				Report (Mo.Geo.Mean)	800 (Max.)		#/100ML		Monthly	Grab
Total Residual Chlorine (For Disinfection)	Sample Measurement										
PARM Code 50060 1 Mon.Site No. EFF-01	Permit Requirement				0.5 (Min.)			MG/L		5 Days/Week	Grab
Nitrogen, Nitrate, Total (as N)	Sample Measurement										
PARM Code 00620 1 Mon.Site No. EFF-01	Permit Requirement				12.0 (Max.)			MG/L		Monthly	Grab
Flow	Sample Measurement										
PARM Code 50050 1 Mon.Site No. FLW-01	Permit Requirement	0.03 (3-Mo.Avg.)	Report (Mo.Avg.)	MGD						5 Days/Week	Meter
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 1 Mon.Site No. FLW-01	Permit Requirement				Report			PERCENT		Monthly	Calculated
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 G Mon.Site No. INF-01	Permit Requirement				Report (Mo.Avg.)			MG/L		Monthly	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 G Mon.Site No. INF-01	Permit Requirement				Report (Mo.Avg.)			MG/L		Monthly	Grab
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

DAILY SAMPLE RESULTS - PART B

Permit Number:
Monitoring Period

FLA014260
From:

To:

Facility: Sportsman's Village WWTP

	CBOD5 (MG/L)	Fecal Coliform Bacteria (#/100ML)	Nitrogen, Nitrate, Total (as N) (MG/L)	pH (SU)	TSS (MG/L)	TRC (For Disinfect.) (MG/L)	Flow (MGD)	Percent Capacity, (TMADF/Permitted Capacity) x 100 (PERCENT)	CBOD5 (MG/L)	TSS (MG/L)	
Code	80082	74055	00620	00400	00530	50060	50050	00180	80082	00530	
Mon. Site	EFF-01	EFF-01	EFF-01	EFF-01	EFF-01	EFF-01	FLW-01	FLW-01	INF-01	INF-01	
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											

PLANT STAFFING:

Day Shift Operator Class: _____ Certificate No: _____ Name: _____

Evening Shift Operator Class: _____ Certificate No: _____ Name: _____

Night Shift Operator Class: _____ Certificate No: _____ Name: _____

Lead Operator Class: _____ Certificate No: _____ Name: _____

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions as well as the SUPPLEMENTAL INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

- Results greater than or equal to the PQL shall be reported as the measured quantity.
- Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
- Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

Add the results to get the Total and divide by the number of days in the month to get the Monthly Average.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

Department of Environmental Protection
South District Office
Post Office Box 2549
Fort Myers, Florida 33902-2549

CERTIFICATION


APPLICATION NUMBER: FHA 014260-006

NAME: Spartan's Village WRP

I HEREBY CERTIFY that the engineering features described in the above referenced application provide reasonable assurance of compliance with applicable effluent provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Title 62. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including, but not limited to, the electrical, mechanical, structural and geological features).

Name Charles DAVALL P.E.

Certification No.: 44406



U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

Postage \$
 Certified Fee
 Return Receipt Fee
 (Endorsement Required)
 Restricted Delivery Fee
 (Endorsement Required)

Postmark
 Here

**PHYLLIS MILLER PRESIDENT
 SPORTMAN'S VILLAGE CONDO ASSOC INC
 P O BOX 455
 MOORE HAVEN FL 33471**

PS Form 3800, August 2006

See Reverse for Instructions

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

**PHYLLIS MILLER PRESIDENT
 SPORTMAN'S VILLAGE CONDO ASSOC INC
 P O BOX 455
 MOORE HAVEN FL 33471**

COMPLETE THIS SECTION ON DELIVERY

A. Signature ☐ Agent
 * *Phyllis Miller* ☐ Addressee

B. Received by (Printed Name) C. Date of Delivery

D. Is delivery address different from item 1? ☐ Yes
 If YES, enter delivery address below. ☐ No

RECEIVED DEP.
APR 20 2009
SOUTH DISTRICT

Mail Type
☐ Certified Mail ☐ Express Mail
☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee) ☐ Yes

2. Article (Transit) 7008 0500 0000 7775 3041

DW/NWM/JL

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540