



Florida Department of Environmental Protection

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

South District
Post Office Box 2549
Fort Myers, Florida 33902-2549
SouthDistrict@dep.state.fl.us

Jonathan P. Steverson
Secretary

Sent via electronic mail

In the Matter of an
Application for Permit by:

Hendry County Board of County Commissioners
Roger B. Greer, Utility Director
P O Box 2340
Labelle, Florida 33975
rgreer@hendryfla.net

Hendry County - DW
File Number FLA014290-007-DW2P
Port Labelle WWTP

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number FLA014290 to operate the Port Labelle WWTP, issued under Chapter 403, Florida Statutes.

Monitoring requirements under this permit are effective on the first day of the second month following the effective date of the permit. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. If not already registered to use the Department's Ez Discharge Monitoring Report (EzDMR) system, the permittee should register now in order to begin using the EzDMR system when the monitoring requirements under this permit are effective.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, Florida Statutes, within fourteen days of receipt of notice. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request an extension of the time for filing a petition for an administrative hearing. The request must be filed (received by the Clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes, must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first. Section

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

120.60(3), Florida Statutes, however, also allows that any person who has asked the Department in writing for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for an extension of time within fourteen days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information, as indicated in Rule 28-106.201, Florida Administrative Code:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, any e-mail address, any facsimile number, and telephone number of the petitioner, if the petitioner is not represented by an attorney or a qualified representative; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the determination;
- (c) A statement of when and how the petitioner received notice of the Department's decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the Department's proposed action;
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the Department's proposed action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's proposed action.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This permit action is final and effective on the date filed with the Clerk of the Department unless a petition (or request for an extension of time) is filed in accordance with the above. Upon the timely filing of a petition (or request for an extension of time), this permit will not be effective until further order of the Department.

Any party to the permit has the right to seek judicial review of the permit action under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900


PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when this permit action is filed with the Clerk of the Department.

Executed in Ft. Myers, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

CERTIFICATE OF SERVICE

The undersigned hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were mailed or emailed before the close of business on October 12, 2015, to the listed persons.

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52, Florida Statutes, with the designated Deputy Clerk, receipt of which is hereby acknowledged.



[Clerk]

October 12, 2015

[Date]

Copies furnished to:

Daniel Nelson, P.E., danny.nelson@tetrattech.com
Shane Parker, sparker@hendryfla.net
Jim Orlinski, jorlinski@hendryfl.net
Diane Loughlin, FDEP
David Rhodes, FDEP
Deanna Newburg, FDEP
Gary Maier, FDEP
Barbara Skates, FDEP
Allen Slater, allen.Slater@frwa.net



Florida Department of Environmental Protection

Rick Scott
Governor

Carlos Lopez-Cantera
Lt. Governor

South District
Post Office Box 2549
Fort Myers, Florida 33902-2549
SouthDistrict@dep.state.fl.us

Jonathan P. Steverson
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

Sent via electronic mail

PERMITTEE:

Hendry County Board of County Commissioners

RESPONSIBLE OFFICIAL:

Mr. Roger B. Greer, Utility Director
P O Box 2340
Labelle, Florida 33975
(863) 675-5376
rgreer@hendryfla.net

PERMIT NUMBER:

FLA014290

FILE NUMBER:

FLA014290-007-DW2P

EFFECTIVE DATE:

December 17, 2015

EXPIRATION DATE:

December 16, 2020

FACILITY:

Port Labelle WWTP
3490 Utility Drive
Labelle, FL 33935
Hendry County
Latitude: 26° 45' 02.0" N Longitude: 81° 22' 59.4" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. The above named permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

WASTEWATER TREATMENT:

Operate an existing 0.499 million gallons per day (MGD) annual average daily flow (AADF) extended aeration conventional activated sludge domestic wastewater treatment plant (WWTP). Major process components include 234,000 gallons total aeration, an approximately 100,000 gallon final sedimentation tank, a 16,900 gallon chlorine contact tank, and a 100,419 gallon digester. Disinfection is provided by gaseous chlorine.

REUSE OR DISPOSAL:

Land Application R-001: An existing 0.499 MGD AADF permitted capacity rapid infiltration basin system. R-001 is a reuse system which consists of three percolation ponds having a capacity of 0.499 MGD located approximately at latitude 26° 45' 07" N, longitude 81° 23' 20" W.

Demineralization concentrate from the Port LaBelle drinking water plant is blended with the reclaimed water going to the rapid infiltration basin R-001. Relief from the blending monitoring requirements in Rule 62-610.865(8), F.A.C., was granted by the Final Order Granting Petition for Variance from Rule 62-610.865(8), F.A.C., OGC File No. 11-0509, Done and Ordered August 05, 2011.

IN ACCORDANCE WITH: The limitations, monitoring requirements, and other conditions set forth in this cover sheet and Part I through Part IX on pages 1 through 19 of this permit.

PERMITTEE: Hendry County Board of County Commissioners
 FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
 PA FILE NUMBER: FLA014290-007-DW2P

I. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Reuse and Land Application Systems

- During the period beginning on the effective date and lasting through the expiration date of this permit, the permittee is authorized to direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.B.7.

			Reclaimed Water Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Monitoring	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	0.499 Report	Annual Average Monthly Average	5 Days/Week	Recording Flow Meter with Totalizer	FLW-01	See I.A.3
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
Solids, Total Suspended	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
Coliform, Fecal	#/100mL	Max Max Max	200 200 800	Monthly Geometric Mean Annual Average Single Sample	Every 2 weeks	Grab	EFA-01	See I.A.4
pH	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	5 Days/Week	Grab	EFA-01	
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	5 Days/Week	Grab	EFA-01	See I.A.5
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	Every 2 weeks	8-hr FPC	EFA-01	
Flow (Concentrate)	MGD	Max Max	0.499 Report	Annual Average Monthly Average	Continuous	Meter	FLW-02	
Solids, Total Suspended (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
Specific Conductance (Blend)	umhos/cm	Max	Report	Single Sample	Quarterly	Meter	OTH-01	See I.A.6
Fluoride, Total (as F) (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
Sodium Adsorption Ratio (Blend)	ratio	Max	Report	Single Sample	Quarterly	Calculated	OTH-01	

PERMITTEE: Hendry County Board of County Commissioners
 FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
 PA FILE NUMBER: FLA014290-007-DW2P

			Reclaimed Water Limitations		Monitoring Requirements			Notes
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Monitoring	Sample Type	Monitoring Site Number	
Sodium, Total Recoverable (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
Magnesium, Total Recoverable (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
Calcium, Total Recoverable (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
Chloride (as Cl) (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
Solids, Total Dissolved (TDS) (Blend)	mg/L	Max	Report	Single Sample	Quarterly	Grab	OTH-01	
pH (Blend)	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	Quarterly	Grab	OTH-01	

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I.A.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-01	At effluent v-notch weir.
EFA-01	Sample taken after discharge from the chlorine contact chamber and prior to disposal
FLW-02	Recording flow meter and totalizer on magnetic flow meter located on the concentrate pump station.
OTH-01	Samples are taken after the concentrate is blended with the effluent and before discharge to the percolation pond system.

3. A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-601.200(17) and .500(6)]
4. The effluent limitation for the monthly geometric mean for fecal coliform is only applicable if 10 or more values are reported. If fewer than 10 values are reported, the monthly geometric mean shall be calculated and reported on the Discharge Monitoring Report to be used to calculate the annual average. [62-600.440(4)(c)]
5. Total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-610.510, 62-600.440(4)(b) and (5)(b)]
6. The maximum specific conductance shall be limited as described in the approved operating protocol. [62-610.865(9)(a)]
7. The treatment facilities shall be operated in accordance with all approved operating protocols. Only reclaimed water that meets the criteria established in the approved operating protocol(s) may be released to system storage or to the reuse system. Reclaimed water that fails to meet the criteria in the approved operating protocol(s) shall be directed [62-610.320(6) and 62-610.463(2)]
8. Pursuant to the variance (OGC File No. 11-0509) filed on March 23, 2011 by Hendry County for the Port LaBelle Wastewater Treatment Plant and granted by the Department on August 5, 2011 the following conditions are incorporated into this permit:
- The Department reserves the right to increase monitoring frequency if any actual test results are worse than the "worst case scenario" blending analysis dated May 19, 2011, and submitted to the Department by Mr. Daniel M. Nelson, P.E., of Tetra Tech.
 - If any applicable standard related to effluent blend or ground water is exceeded, then Hendry County shall submit a proposed corrective action plan to the Department within 21 days of becoming aware of the exceedance.
 - This variance does not relieve Hendry County from liability for harm or injury to human health or welfare, animal, or plant life, or property, or from penalties therefore; nor does it allow pollution in contravention of Florida Statutes or Department rules.
 - The Department hereby expressly reserves the right to initiate appropriate legal action to address any violations of statutes or rules administered by the Department.

PERMITTEE: Hendry County Board of County Commissioners
 FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
 PA FILE NUMBER: FLA014290-007-DW2P

B. Other Limitations and Monitoring and Reporting Requirements

- During the period beginning on the effective date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7.

			Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max Max	0.499 Report Report	Annual Average Monthly Average Quarterly Average	5 Days/Week	Recording Flow Meter with Totalizer	FLW-02	See I.B.4
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	Monthly	Calculated	CAL-01	
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	Every 2 weeks	8-hr FPC	INF-01	See I.B.3
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	Every 2 weeks	8-hr FPC	INF-01	See I.B.3

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-02	Recording flow meter and totalizer on magnetic flow meter located on the concentrate pump station.
CAL-01	Calculated from flow recordings.
INF-01	Influent sample taken off the influent line discharging into the manual bar screen

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
4. A recording flow meter with totalizer shall be utilized to measure flow and calibrated at least once every 12 months. [62-601.200(17) and .500(6)]
5. The sample collection, analytical test methods and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate. The list of Department established analytical methods, and corresponding MDLs (method detection limits) and PQLs (practical quantitation limits), which is titled "FAC 62-4 MDL/PQL Table (April 26, 2006)" is available at <http://www.dep.state.fl.us/labs/library/index.htm>. The MDLs and PQLs as described in this list shall constitute the minimum acceptable MDL/PQL values and the Department shall not accept results for which the laboratory's MDLs or PQLs are greater than those described above unless alternate MDLs and/or PQLs have been specifically approved by the Department for this permit. Any method included in the list may be used for reporting as long as it meets the following requirements:
- The laboratory's reported MDL and PQL values for the particular method must be equal or less than the corresponding method values specified in the Department's approved MDL and PQL list;
 - The laboratory reported MDL for the specific parameter is less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Parameters that are listed as "report only" in the permit shall use methods that provide an MDL, which is equal to or less than the applicable water quality criteria stated in 62-302, F.A.C.; and
 - If the MDLs for all methods available in the approved list are above the stated permit limit or applicable water quality criteria for that parameter, then the method with the lowest stated MDL shall be used.

When the analytical results are below method detection or practical quantitation limits, the permittee shall report the actual laboratory MDL and/or PQL values for the analyses that were performed following the instructions on the applicable discharge monitoring report.

Where necessary, the permittee may request approval of alternate methods or for alternative MDLs or PQLs for any approved analytical method. Approval of alternate laboratory MDLs or PQLs are not necessary if the laboratory reported MDLs and PQLs are less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Approval of an analytical method not included in the above-referenced list is not necessary if the analytical method is approved in accordance with 40 CFR 136 or deemed acceptable by the Department. [62-4.246, 62-160]

6. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
7. Monitoring requirements under this permit are effective on the first day of the second month following the effective date of the permit. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. If not already registered to use the Department's Ez Discharge Monitoring Report (EzDMR) system, the permittee should register now in order to begin using the EzDMR system when the monitoring requirements under this permit are effective. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department Discharge Monitoring

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Unless specified otherwise in this permit, monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below. DMRs shall be submitted for each required monitoring period including periods of no discharge.

REPORT Type on DMR	Monitoring Period	Submit by
Monthly	First day of month - last day of month	28 th day of following month
Quarterly	January 1 - March 31 April 1 - June 30 July 1 - September 30 October 1 - December 31	April 28 July 28 October 28 January 28
Semiannual	January 1 - June 30 July 1 - December 31	July 28 January 28
Annual	January 1 - December 31	January 28

The permittee shall submit the completed DMR to the Department by the twenty-eighth (28th) of the month following the month of operation. Please contact the Department at (239) 344-5600 if you are unable to submit the completed DMR electronically using the EzDMR system.

The Department electronic EzDMR system at the time of permit issuance is available through the DEP Business Portal at: <http://www.fldepportal.com/go/submit-report/>

[62-620.610(18)][62-601.300(1),(2), and (3)]

8. Except as otherwise specified in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to the Department in a digital format when practicable. The Department's electronic mailing address is:

SouthDistrict@dep.state.fl.us

Please contact the Department at (239) 344-5600 if you are unable to submit electronically.

[62-620.305]

9. An **annual scan** of the following five parameters shall be conducted for the demineralization concentrate and the blend: **TDS, Chloride, Sulfate, Fluoride, and Sodium**. (If quarterly data is available for a parameter, it may be used to satisfy the annual scan requirement for that parameter). **At least once during each permit cycle, the full list of parameters listed as primary and secondary drinking water parameters shall be reported for the reclaimed water and the blend.** [62-610.865(8)(f) &(11) FAC]
10. The permittee shall submit an annual summary of water quality in the reclaimed water, the concentrate, the blend, and ground water monitoring wells. The summary shall include an evaluation of any adverse effects on vegetation and ground water quality and needed corrective actions, including needed revisions to the operating protocol. **The results of the annual scans and annual summary shall be submitted with the March DMR each year.** [62-610.865(8)(f) & (11) FAC]
11. Operating protocol(s) shall be reviewed and updated periodically to ensure continuous compliance with the established demineralization concentrate blend ratio and specific conductance limit. Updated operating protocols shall be submitted to the Department's South District Office for review and approval upon revision of the operating protocol(s) and with each permit application. [62-610.320(6)][62-610.865(9)]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

II. BIOSOLIDS MANAGEMENT REQUIREMENTS

A. Basic Requirements

1. Biosolids generated by this facility may be transferred to Karle Enviro-Organic Recycling Inc. or disposed of in a Class I solid waste landfill. Transferring biosolids to an alternative biosolids treatment facility does not require a permit modification. However, use of an alternative biosolids treatment facility requires submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the biosolids. [62-620.320(6), 62-640.880(1)]
2. The permittee shall monitor and keep records of the quantities of biosolids generated, received from source facilities, treated, distributed and marketed, land applied, used as a biofuel or for bioenergy, transferred to another facility, or landfilled. These records shall be kept for a minimum of five years. [62-640.650(4)(a)]
3. Biosolids quantities shall be monitored by the permittee as specified below. Results shall be reported on the permittee's Discharge Monitoring Report for Monitoring Group RMP-Q in accordance with Condition I.B.7.

			Biosolids Limitations		Monitoring Requirements		
Parameter	Units	Max/ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number
Biosolids Quantity (Landfilled)	dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-01
Biosolids Quantity (Transferred)	dry tons	Max	Report	Monthly Total	Monthly	Calculated	RMP-01

[62-640.650(5)(a)1]

4. Biosolids quantities shall be calculated as listed in Permit Condition II.3 and as described below:

Monitoring Site Number	Description of Monitoring Site Calculations
RMP-01	Calculated

5. The treatment, management, transportation, use, land application, or disposal of biosolids shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. [62-640.400(6)]
6. Storage of biosolids or other solids at this facility shall be in accordance with the Facility Biosolids Storage Plan. [62-640.300(4)]
7. Biosolids shall not be spilled from or tracked off the treatment facility site by the hauling vehicle. [62-640.400(9)]

B. Disposal

8. Disposal of biosolids, septage, and "other solids" in a solid waste disposal facility, or disposal by placement on land for purposes other than soil conditioning or fertilization, such as at a monofill, surface impoundment, waste pile, or dedicated site, shall be in accordance with Chapter 62-701, F.A.C. [62-640.100(6)(b) & (c)]

C. Transfer

9. The permittee shall not be held responsible for treatment and management violations that occur after its biosolids have been accepted by a permitted biosolids treatment facility with which the source facility has an agreement in accordance with subsection 62-640.880(1)(c), F.A.C., for further treatment, management, or disposal. [62-640.880(1)(b)]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

10. The permittee shall keep hauling records to track the transport of biosolids between the facilities. The hauling records shall contain the following information:

<u>Port LaBelle WWTP</u>	<u>Biosolids Treatment Facility or Treatment Facility</u>
1. Date and time shipped	1. Date and time received
2. Amount of biosolids shipped	2. Amount of biosolids received
3. Degree of treatment (if applicable)	3. Name and ID number of source facility
4. Name and ID Number of treatment facility	4. Signature of hauler
5. Signature of responsible party at source facility	5. Signature of responsible party at treatment facility
6. Signature of hauler and name of hauling firm	

A copy of the source facility hauling records for each shipment shall be provided upon delivery of the biosolids to the biosolids treatment facility or treatment facility. The treatment facility permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of biosolids leaving the source facility and arriving at the biosolids treatment facility or treatment facility.

[62-640.880(4)]

D. Receipt

11. If the permittee intends to accept biosolids from other facilities, a permit revision is required pursuant to paragraph 62-640.880(2)(d), F.A.C. [62-640.880(2)(d)]

III. GROUND WATER REQUIREMENTS

1. The permittee shall give at least 72-hours' notice to the Department's South District Office, prior to the installation of any monitoring wells. [62-520.600(6)(h)]
2. Before construction of new ground water monitoring wells, a soil boring shall be made at each new monitoring well location to properly determine monitoring well specifications such as well depth, screen interval, screen slot, and filter pack. [62-520.600(6)(g)]
3. **Within 30 days after installation of a monitoring well, the permittee shall submit to the Department's South District Office well completion reports and soil boring/lithologic logs on the attached DEP Form(s) 62-520.900(3), Monitoring Well Completion Report.** [62-520.600(6)(j) and .900(3)]
4. All piezometers and monitoring wells not part of the approved ground water monitoring plan shall be plugged and abandoned in accordance with Rule 62-532.500(5), F.A.C., unless future use is intended. [62-532.500(5)]
5. For the Part IV land application system(s), all ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge for Land Application Site R-001 shall extend horizontally 100 feet from the application site and vertically to the base of the surficial aquifer. [62-520.200(27)] [62-520.465]
6. The ground water minimum criteria specified in Rule 62-520.400 F.A.C., shall be met within the zone of discharge. [62-520.400 and 62-520.420(4)]
7. If the concentration for any constituent listed in Permit Condition III.10. in the natural background quality of the ground water is greater than the stated maximum, or in the case of pH is also less than the minimum, the representative background quality shall be the prevailing standard. [62-520.420(2)]
8. During the period of operation authorized by this permit, the permittee shall continue to sample ground water at the monitoring wells identified in Permit Condition III.9., below in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-520.600, F.A.C. [62-520.600] [62-610.510]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

9. The following monitoring wells shall be sampled for Reuse System R-001 located at Land Application Site RIB-001.

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Latitude (N)			Longitude (W)			Depth (Feet)	Aquifer Monitored	New or Existing
		°	'	"	°	'	"			
MWB-20672	M-4 Background well	26	45	00.70	81	23	07.19	21.5 (est)	Surficial	New
MWC-20667	M-3 Compliance well located adjacent to the on-site percolation ponds.	26	44	58.61	81	23	17.38	15	Surficial	Existing (repaired)
MWI-20671	M-1 Intermediate well located adjacent to the on-site percolation ponds.	26	45	05.55	81	23	10.35	15	Surficial	Existing

MWC = Compliance; MWB = Background; MWI = Intermediate; MWP = Piezometer

[62-520.600] [62-610.510]

10. The following parameters shall be analyzed for each monitoring well identified in Permit Condition III.9.:

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Water Level Relative to NGVD	Report	ft	In Situ	Quarterly
Nitrogen, Nitrate, Total (as N)	10	mg/L	Grab	Quarterly
Solids, Total Dissolved (TDS)	500	mg/L	Grab	Quarterly
Chloride (as Cl)	250	mg/L	Grab	Quarterly
Coliform, Fecal	0	#/100mL	Grab	Quarterly
pH	6.5 - 8.5	s.u.	Grab	Quarterly
Sulfate, Total	250	mg/L	Grab	Quarterly
Turbidity	Report	NTU	Grab	Quarterly
Sodium, Total Recoverable	160	mg/L	Grab	Quarterly

[62-520.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-601.300(6)] [62-520.310(5)]

11. Water levels shall be recorded before evacuating each well for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NAVD allowable) at a precision of plus or minus 0.01 foot. [62-520.600(11)(c)] [62-610.510(3)(b)]
12. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples. [62-160.210] [62-601.700(5)]
13. Analyses shall be conducted on unfiltered samples, unless filtered samples have been approved by the Department's South District Office as being more representative of ground water conditions. [62-520.310(5)]
14. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10) in accordance with Permit Condition I.B.7. [62-520.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-620.610(18)]
15. If any monitoring well becomes inoperable or damaged to the extent that sampling or well integrity may be affected, the permittee shall notify the Department's South District Office within two business days from discovery, and a detailed written report shall follow within ten days after notification to the Department. The written report shall detail what problem has occurred and remedial measures that have been taken to prevent recurrence or request approval for replacement of the monitoring well. All monitoring well design and replacement shall be approved by the Department's South District Office before installation. [62-520.600(6)(l)]

IV. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

E. Part IV Rapid Infiltration Basins

1. Advisory signs shall be posted around the site boundaries to designate the nature of the project area. [62-610.518]
2. The maximum annual average loading rate to the three percolation ponds shall be limited to 3 inches per day (as applied to the entire bottom area). [62-610.523(3)]
3. Percolation ponds normally shall be loaded for 1 to 7 days and shall be rested for 5 to 14 days. Infiltration ponds, basins, or trenches shall be allowed to dry during the resting portion of the cycle. [62-610.523(4)]
4. Rapid infiltration basins shall be routinely maintained to control vegetation growth and to maintain percolation capability by scarification or removal of deposited solids. Basin bottoms shall be maintained to be level. [62-610.523(6) and (7)]
5. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. [62-610.514 and 62-610.414]
6. Overflows from emergency discharge facilities on storage ponds or on infiltration ponds, basins, or trenches shall be reported as abnormal events in accordance with Permit Condition IX.20. [62-610.800(9)]

Blending of Concentrate with Reclaimed Water

7. Demineralization concentrate from The Port Labelle Reverse Osmosis Water Treatment Plant may be blended with the treated reclaimed water. Concentrate shall be blended prior to entry to the percolation ponds with the effluent of the WWTP. [62-610.865]

V. OPERATION AND MAINTENANCE REQUIREMENTS

A. Staffing Requirements

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of an operator(s) certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class C facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class C or higher operator for a minimum of 3 hours per day for 5 days per week and one visit each weekend. The lead/chief operator must be a Class C operator, or higher.

2. An operator meeting the lead/chief operator class for the plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. [62-699.311(1)]

B. Capacity Analysis Report and Operation and Maintenance Performance Report Requirements

1. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(5)]
2. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1)]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

C. Recordkeeping Requirements

1. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility.
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current permit;
 - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
 - g. A copy of any required record drawings;
 - h. Copies of the licenses of the current certified operators;
 - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and license number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities, including any preventive maintenance or repairs made or requested; results of tests performed and samples taken, unless documented on a laboratory sheet; and notation of any notification or reporting completed in accordance with Rule 62-602.650(3), F.A.C. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed; and
 - j. Records of biosolids quantities, treatment, monitoring, and hauling for at least five years.

[62-620.350, 62-602.650, 62-640.650(4)]

VI. SCHEDULES

1. For each Improvement Action listed below, the permittee shall submit a written notice of completion to the Department within 10 days of completing the Improvement Action. The following improvement actions shall be completed according to the following schedule:

Improvement Action	Completion Date
A. The engineer of record expressly recommended attention to the following: • Recoating of the interior of the plant (concrete walls and metal components) to provide protection from the wastewater. • Repair of air piping and any associated valves. • Repair of deteriorated metal components (skimmer arm, supports, etc.). • Repair of effluent weir in clarifier and support system. • Replacement of the electrical control panels and switchgear.	No specific deadline. However, all equipment shall be maintained, at a minimum, so as to function as intended. [62-600.410(6)]. The permittee is on notice of these potential weaknesses. The Department expects all equipment to be able to function as intended.

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

Improvement Action	Completion Date
B. Regarding the ground water monitoring wells, the permittee shall complete the following by March 31, 2016: - Existing M-1 (MWI-20671): Repair as needed if necessary to ensure well integrity. This existing well will continue to function as an Intermediate well. - Existing M-2 (MWC-20672): Abandon. - Existing M-3 (MWI-20670): Repair and convert to compliance well with new monitoring well ID MWC-20667. - New M-4 (MWB-20672): Construct a new background well as proposed at 26° 45' 00.70" N, 81° 23' 07.19" W.	March 31, 2016.

[62-620.320(6)]

2. The permittee shall submit notification of completion of construction on DEP Form 62-620.910(12) and shall provide notification on DEP Form 62-620.910(13) that a draft operation and maintenance manual is available prior to placing any newly constructed or modified portion of an existing facility into operation for any purpose other than testing for leaks and equipment operation. [62-620.630(2)(a) and (b)].
3. Within six months after placing any newly constructed or modified portion of an existing facility into operation for any purpose other than testing for leaks and equipment operation, the permittee shall provide written certification on DEP Form 62-620.910(13) that record drawings and an appropriate operation and maintenance manual are available in a specified location. [62-620.630(7)].
4. The permittee is not authorized to discharge to waters of the state after the expiration date of this permit, unless:
 - a. The permittee has applied for renewal of this permit at least 180 days before the expiration date of this permit using the appropriate forms listed in Rule 62-620.910, F.A.C., and in the manner established in the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C.; or
 - b. The permittee has made complete the application for renewal of this permit before the permit expiration date.

[62-620.335(1) - (4)]

VII. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

1. This facility is not required to have a pretreatment program at this time. [62-625.500]

VIII. OTHER SPECIFIC CONDITIONS

1. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. [62-600.410(8) and 62-640.400(6)]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

2. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. [62-604.130(3)]
3. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. [62-604.550] [62-620.610(20)]
4. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health and safety problems.[62-604.130(5)]
5. The treatment facility, storage ponds for Part II systems, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. [62-610.518(1) and 62-600.400(2)(b)]
6. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. [62-701.300(1)(a)]
7. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. [62-620.310(4)]
8. The permittee shall provide verbal notice to the Department's South District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department's South District Office in a written report within 7 days of the sinkhole discovery. [62-620.320(6)]
9. The permittee shall provide notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.Notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.
[62-620.625(2)]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications, or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5)]
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. [62-620.610(6)]
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7)]
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8)]
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. [62-620.610(10)]
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. [62-620.610(11)]
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. [62-620.610(12)]
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. [62-620.610(13)]
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. [62-620.610(14)]
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. [62-620.610(15)]
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16)]
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.[62-620.610(17)]
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-601, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

- b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
- c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
- d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
- e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
- f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.

[62-620.610(18)]

- 19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(19)]
- 20. The permittee shall report to the Department's South District Office any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 - a. The following shall be included as information which must be reported within 24 hours under this condition:
 - (1) Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - (4) Any unauthorized discharge to surface or ground waters.
 - b. Oral reports as required by this subsection shall be provided as follows:
 - (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4. that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the STATE WATCH OFFICE TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Watch Office:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

(2) Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department's South District Office within 24 hours from the time the permittee becomes aware of the circumstances.

- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department's South District Office shall waive the written report.

[62-620.610(20)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX.17., IX.18., or IX.19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20. of this permit. [62-620.610(21)]

22. Bypass Provisions.

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
- b. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
- (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (3) The permittee submitted notices as required under Permit Condition IX.22.c. of this permit.
- c. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX.20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX.22.b.(1) through (3) of this permit.
- e. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX.22.b. through d. of this permit.

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the permittee.
- (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
 - (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required in Permit Condition IX.20. of this permit; and

PERMITTEE: Hendry County Board of County Commissioners
FACILITY: Port Labelle WWTP

PERMIT NUMBER: FLA014290
PA FILE NUMBER: FLA014290-007-DW2P

- (4) The permittee complied with any remedial measures required under Permit Condition IX.5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.

[62-620.610(23)]

Executed in Ft. Myers, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

PERMIT ISSUANCE DATE: **October 12, 2015**

JMI/BJS/se

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, 2295 Victoria Ave, Suite 364, Ft. Myers, FL 33901-3875

PERMITTEE NAME: Hendry County Board of County Commissioners
MAILING ADDRESS: P O Box 2340
Labelle, Florida 33975-

PERMIT NUMBER: FLA014290-007-DW2P

FACILITY: Port Labelle WWTP
LOCATION: 3490 Utility Dr
Labelle, FL 33935-

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Final
N/A
R-001
consists of 3 rapid rate evaporation/perc ponds

REPORT FREQUENCY: Monthly
PROGRAM: Domestic

COUNTY: Hendry
OFFICE: South District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 Y Mon. Site No. FLW-01	Permit Requirement		0.499 (An.Avg.)	MGD						5 Days/Week	Flow Totalizer
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. FLW-01	Permit Requirement		Report (Mo.Avg.)	MGD						5 Days/Week	Flow Totalizer
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon. Site No. EFA-01	Permit Requirement				20.0 (An.Avg.)		mg/L			Every 2 weeks	8-hr FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 A Mon. Site No. EFA-01	Permit Requirement				60.0 (Max.)	45.0 (Max.Wk.Avg.)	30.0 (Mo.Avg.)	mg/L		Every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 Y Mon. Site No. EFA-01	Permit Requirement				20.0 (An.Avg.)		mg/L			Every 2 weeks	8-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 A Mon. Site No. EFA-01	Permit Requirement				60.0 (Max.)	45.0 (Max.Wk.Avg.)	30.0 (Mo.Avg.)	mg/L		Every 2 weeks	8-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

R-001

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Coliform, Fecal	Sample Measurement										
PARM Code 74055 Y Mon. Site No. EFA-01	Permit Requirement				200 (An.Avg.)			#/100mL		Every 2 weeks	Grab
Coliform, Fecal	Sample Measurement										
PARM Code 74055 A Mon. Site No. EFA-01	Permit Requirement				200 (Mo.Geo.Mn.)	800 (Max.)		#/100mL		Every 2 weeks	Grab
pH	Sample Measurement										
PARM Code 00400 A Mon. Site No. EFA-01	Permit Requirement				6.0 (Min.)	8.5 (Max.)		s.u.		5 Days/Week	Grab
Chlorine, Total Residual (For Disinfection)	Sample Measurement										
PARM Code 50060 A Mon. Site No. EFA-01	Permit Requirement				0.5 (Min.)			mg/L		5 Days/Week	Grab
Nitrogen, Nitrate, Total (as N)	Sample Measurement										
PARM Code 00620 A Mon. Site No. EFA-01	Permit Requirement					12.0 (Max.)		mg/L		Every 2 weeks	8-hr FPC
Flow (Concentrate)	Sample Measurement										
PARM Code 50050 P Mon. Site No. FLW-02	Permit Requirement		0.499 (An.Avg.)	MGD						Continuous	Meter
Flow (Concentrate)	Sample Measurement										
PARM Code 50050 Q Mon. Site No. FLW-02	Permit Requirement		Report (Mo.Avg.)	MGD						Continuous	Meter
Flow	Sample Measurement										
PARM Code 50050 R Mon. Site No. FLW-02	Permit Requirement		0.499 (An.Avg.)	MGD						5 Days/Week	Flow Totalizer
Flow	Sample Measurement										
PARM Code 50050 S Mon. Site No. FLW-02	Permit Requirement	Report (Qt.Avg.)	Report (Mo.Avg.)	MGD						5 Days/Week	Flow Totalizer
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 P Mon. Site No. CAL-01	Permit Requirement					Report (Mo.Avg.)		percent		Monthly	Calculated

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP R-001

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From:

To:

[illegible]

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, 2295 Victoria Ave, Suite 364, Ft. Myers, FL 33901-3875

PERMITTEE NAME: Hendry County Board of County Commissioners
MAILING ADDRESS: P O Box 2340
Labelle, Florida 33975-

PERMIT NUMBER:

FLA014290-007-DW2P

FACILITY: Port Labelle WWTP
LOCATION: 3490 Utility Dr
Labelle, FL 33935-

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Final
N/A
R-001
consists of 3 rapid rate evaporation/perc ponds

REPORT FREQUENCY: Quarterly
PROGRAM: Domestic

COUNTY: Hendry
OFFICE: South District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended (Blend)	Sample Measurement										
PARM Code 00530 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab
Specific Conductance (Blend)	Sample Measurement										
PARM Code 00095 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	umhos/cm		Quarterly	Meter
Fluoride, Total (as F) (Blend)	Sample Measurement										
PARM Code 00951 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab
Sodium Adsorption Ratio (Blend)	Sample Measurement										
PARM Code 00931 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	ratio		Quarterly	Calculated
Sodium, Total Recoverable (Blend)	Sample Measurement										
PARM Code 00923 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab
Magnesium, Total Recoverable (Blend)	Sample Measurement										
PARM Code 00921 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP R-001

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Calcium, Total Recoverable (Blend)	Sample Measurement										
PARM Code 00918 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab
Chloride (as Cl) (Blend)	Sample Measurement										
PARM Code 00940 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab
Solids, Total Dissolved (TDS) (Blend)	Sample Measurement										
PARM Code 70295 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	mg/L		Quarterly	Grab
pH	Sample Measurement										
PARM Code 00400 P Mon. Site No. OTH-01	Permit Requirement						Report (Max.)	s.u.		Quarterly	Grab

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, 2295 Victoria Ave, Suite 364, Ft. Myers, FL 33901-3875

PERMITTEE NAME: Hendry County Board of County Commissioners
MAILING ADDRESS: P O Box 2340
Labelle, Florida 33975-

PERMIT NUMBER: FLA014290-007-DW2P

FACILITY: Port Labelle WWTP
LOCATION: 3490 Utility Dr
Labelle, FL 33935-

LIMIT: Final
CLASS SIZE: N/A
MONITORING GROUP NUMBER: **RMP-Q**
MONITORING GROUP DESCRIPTION: Biosolids Quantity

REPORT FREQUENCY: Monthly
PROGRAM: Domestic

COUNTY: Hendry
OFFICE: South District

RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Biosolids Quantity (Landfilled)	Sample Measurement										
PARM Code B0008 + Mon. Site No. RMP-01	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated
Biosolids Quantity (Transferred)	Sample Measurement										
PARM Code B0007 + Mon. Site No. RMP-01	Permit Requirement		Report (Mo.Total)	dry tons						Monthly	Calculated

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, 2295 Victoria Ave, Suite 364, Ft. Myers, FL 33901-3875

PERMITTEE NAME: Hendry County Board of County Commissioners
 MAILING ADDRESS: P O Box 2340
 Labelle, Florida 33975-

PERMIT NUMBER: FLA014290-007-DW2P

FACILITY: Port Labelle WWTP
 LOCATION: 3490 Utility Dr
 Labelle, FL 33935-

LIMIT:
 CLASS SIZE:
 MONITORING GROUP NUMBER:
 MONITORING GROUP DESCRIPTION:
 RE-SUBMITTED DMR: ☐
 NO DISCHARGE FROM SITE: ☐
 MONITORING NOT REQUIRED: ☐
 MONITORING PERIOD

Final
 N/A
RWS-A
 Annual Reclaimed Water or Effluent Analysis

REPORT FREQUENCY: Annually
 PROGRAM: Domestic

COUNTY: Hendry
 OFFICE: South District

From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Antimony, Total Recoverable (GWS = 6)*	Sample Measurement										
PARM Code 01268 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
Arsenic, Total Recoverable (GWS = 10)	Sample Measurement										
PARM Code 00978 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
Barium, Total Recoverable (GWS = 2,000)	Sample Measurement										
PARM Code 01009 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
Beryllium, Total Recoverable (GWS = 4)	Sample Measurement										
PARM Code 00998 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
Cadmium, Total Recoverable (GWS = 5)	Sample Measurement										
PARM Code 01113 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
Chromium, Total Recoverable (GWS =100)	Sample Measurement										
PARM Code 01118 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC

*GROUND WATER STANDARD (GWS) FOR REFERENCE AND REVIEW ONLY.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Cyanide, Free (amen. to chlorination)(GWS = 200)	Sample Measurement										
PARM Code 00722 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Fluoride, Total (as F) (GWS = 4.0/2.0)	Sample Measurement										
PARM Code 00951 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Lead, Total Recoverable (GWS = 15)	Sample Measurement										
PARM Code 01114 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Mercury, Total Recoverable (GWS = 2)	Sample Measurement										
PARM Code 71901 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Nickel, Total Recoverable (GWS = 100)	Sample Measurement										
PARM Code 01074 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Nitrogen, Nitrate, Total (as N) (GWS = 10)	Sample Measurement										
PARM Code 00620 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Nitrogen, Nitrite, Total (as N) (GWS = 1)	Sample Measurement										
PARM Code 00615 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Nitrite plus Nitrate, Total 1 det. (as N)(GWS = 10)	Sample Measurement										
PARM Code 00630 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Selenium, Total Recoverable (GWS =50)	Sample Measurement										
PARM Code 00981 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Sodium, Total Recoverable (GWS = 160)	Sample Measurement										
PARM Code 00923 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Thallium, Total Recoverable (GWS = 2)	Sample Measurement										
PARM Code 00982 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
1,1-dichloroethylene (GWS = 7)	Sample Measurement										
PARM Code 34501 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,1,1-trichloroethane (GWS = 200)	Sample Measurement										
PARM Code 34506 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,1,2-trichloroethane (GWS = 5)	Sample Measurement										
PARM Code 34511 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-dichloroethane (GWS = 3)	Sample Measurement										
PARM Code 32103 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-dichloropropane (GWS = 5)	Sample Measurement										
PARM Code 34541 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2,4-trichlorobenzene (GWS = 70)	Sample Measurement										
PARM Code 34551 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Benzene (GWS = 1)	Sample Measurement										
PARM Code 34030 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Carbon tetrachloride (GWS = 3)	Sample Measurement										
PARM Code 32102 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Cis-1,2-dichloroethene (GWS = 70)	Sample Measurement										
PARM Code 81686 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Dichloromethane (methylene chloride)(GWS = 5)	Sample Measurement										
PARM Code 03821 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Ethylbenzene (GWS = 700)	Sample Measurement										
PARM Code 34371 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Monochlorobenzene (GWS = 100)	Sample Measurement										
PARM Code 34031 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-dichlorobenzene (GWS = 600)	Sample Measurement										
PARM Code 34536 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,4-dichlorobenzene (GWS = 75)	Sample Measurement										
PARM Code 34571 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Styrene, Total (GWS = 100)	Sample Measurement										
PARM Code 77128 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Tetrachloroethylene (GWS = 3)	Sample Measurement										
PARM Code 34475 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Toluene (GWS = 1,000)	Sample Measurement										
PARM Code 34010 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
1,2-trans-dichloroethylene (GWS = 100)	Sample Measurement										
PARM Code 34546 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Trichloroethylene (GWS = 3)	Sample Measurement										
PARM Code 39180 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Vinyl chloride (GWS = 1)	Sample Measurement										
PARM Code 39175 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Xylenes (GWS = 10,000)	Sample Measurement										
PARM Code 81551 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
2,3,7,8-tetrachlorodibenzo-p-dioxin(GWS = 3x10 ⁻⁵)	Sample Measurement										
PARM Code 34675 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
2,4-dichlorophenoxyacetic acid (GWS = 70)	Sample Measurement										
PARM Code 39730 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Silvex (GWS = 50)	Sample Measurement										
PARM Code 39760 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Alachlor (GWS = 2)	Sample Measurement										
PARM Code 39161 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Atrazine (GWS = 3)	Sample Measurement										
PARM Code 39033 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Benzo(a)pyrene (GWS = 0.2)	Sample Measurement										
PARM Code 34247 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Carbofuran (GWS = 40)	Sample Measurement										
PARM Code 81405 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Chlordane (tech mix. and metabolites)(GWS = 2)	Sample Measurement										
PARM Code 39350 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Dalapon (GWS = 200)	Sample Measurement										
PARM Code 38432 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Bis(2-ethylhexyl)adipate (GWS = 400)	Sample Measurement										
PARM Code 77903 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Bis (2-ethylhexyl) phthalate (GWS = 6)	Sample Measurement										
PARM Code 39100 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Dibromochloropropane (DBCP) (GWS = 0.2)	Sample Measurement										
PARM Code 82625 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Dinoseb (GWS = 7)	Sample Measurement										
PARM Code 30191 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Diquat (GWS = 20)	Sample Measurement										
PARM Code 04443 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Endothall (GWS = 100)	Sample Measurement										
PARM Code 38926 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Endrin (GWS = 2)	Sample Measurement										
PARM Code 39390 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Ethylene dibromide (1,2-dibromoethane)(GWS = 0.02)	Sample Measurement										
PARM Code 77651 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	Grab
Glyphosate (GWS = 0.7)	Sample Measurement										
PARM Code 79743 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Heptachlor (GWS = 0.4)	Sample Measurement										
PARM Code 39410 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Heptachlor epoxide (GWS = 0.2)	Sample Measurement										
PARM Code 39420 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Hexachlorobenzene (GWS = 1)	Sample Measurement										
PARM Code 39700 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Hexachlorocyclopentadiene (GWS = 50)	Sample Measurement										
PARM Code 34386 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Gamma BHC (Lindane) (GWS = 0.2)	Sample Measurement										
PARM Code 39782 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Methoxychlor (GWS = 40)	Sample Measurement										
PARM Code 39480 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Oxamyl (vydate) (GWS = 200)	Sample Measurement										
PARM Code 38865 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Pentachlorophenol (GWS = 1)	Sample Measurement										
PARM Code 39032 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Picloram (GWS = 500)	Sample Measurement										
PARM Code 39720 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Polychlorinated Biphenyls (PCBs)(GWS = 0.5)	Sample Measurement										
PARM Code 39516 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

NUMBER:

MONITORING PERIOD

From: _____

To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Simazine (GWS = 4)	Sample Measurement										
PARM Code 39055 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Toxaphene (GWS = 3)	Sample Measurement										
PARM Code 39400 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Trihalomethane, Total by summation(GWS = 0.080)	Sample Measurement										
PARM Code 82080 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	Grab
Radium 226 + Radium 228, Total (GWS = 5)	Sample Measurement										
PARM Code 11503 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	pCi/L			Annually	24-hr FPC
Alpha, Gross Particle Activity (GWS = 15)	Sample Measurement										
PARM Code 80045 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	pCi/L			Annually	24-hr FPC
Aluminum, Total Recoverable (GWS = 0.2)	Sample Measurement										
PARM Code 01104 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Chloride (as Cl) (GWS = 250)	Sample Measurement										
PARM Code 00940 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Iron, Total Recoverable (GWS = 0.3)	Sample Measurement										
PARM Code 00980 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	mg/L			Annually	24-hr FPC
Copper, Total Recoverable (GWS = 1,000)	Sample Measurement										
PARM Code 01119 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC
Manganese, Total Recoverable (GWS = 50)	Sample Measurement										
PARM Code 11123 P Mon. Site No. RWS-A	Permit Requirement					Report (Max.)	ug/L			Annually	24-hr FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Port Labelle WWTP

MONITORING GROUP
NUMBER:
MONITORING PERIOD

RWS-A

PERMIT NUMBER: FLA014290-007-DW2P

From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Silver, Total Recoverable (GWS = 100)	Sample Measurement										
PARM Code 01079 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
Sulfate, Total (GWS = 250)	Sample Measurement										
PARM Code 00945 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	mg/L		Annually	24-hr FPC
Zinc, Total Recoverable (GWS = 5,000)	Sample Measurement										
PARM Code 01094 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	ug/L		Annually	24-hr FPC
pH (GWS = 6.5-8.5)	Sample Measurement										
PARM Code 00400 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	s.u.		Annually	Grab
Solids, Total Dissolved (TDS) (GWS = 500)	Sample Measurement										
PARM Code 70295 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	mg/L		Annually	24-hr FPC
Foaming Agents (GWS = 0.5)	Sample Measurement										
PARM Code 01288 P Mon. Site No. RWS-A	Permit Requirement						Report (Max.)	mg/L		Annually	24-hr FPC

DAILY SAMPLE RESULTS - PART B

Permit Number: FLA014290-007-DW2P

Facility: **Port Labelle WWTP**

Monitoring Period From: _____ To: _____

	BOD, Carbonaceous 5 day, 20C mg/L	Chlorine, Total Residual (For Disinfection) mg/L	Coliform, Fecal #/100mL	Nitrogen, Nitrate, Total (as N) mg/L	Solids, Total Suspended mg/L	pH s.u.	Flow MGD	Flow (Concentrate) MGD	BOD, Carbonaceous 5 day, 20C (Influent) mg/L	Solids, Total Suspended (Influent) mg/L
Code	80082	50060	74055	00620	00530	00400	50050	50050	80082	00530
Mon. Site	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	FLW-01	FLW-02	INF-01	INF-01
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
Total										
Mo. Avg.										

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Port Labelle WWTP
 Permit Number: FLA014290-007-DW2P
 County: Hendry
 Office: South District

Monitoring Well ID: MWB-20672
 Well Type: Background
 Description: **M-4 Background well**
 Re-submitted DMR: ☐

Report Frequency: Quarterly
 Program: Domestic

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____
 Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Quarterly				
Chloride (as Cl)	00940		Report	mg/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
pH	00400		Report	s.u.	Grab	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		Report	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Port Labelle WWTP
 Permit Number: FLA014290-007-DW2P
 County: Hendry

Monitoring Well ID: MWC-20667
 Well Type: Compliance
 Description: **M-3 Compliance well**
 located adjacent to the
 on-site percolation
 ponds.

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period

From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Quarterly				
Chloride (as Cl)	00940		250	mg/L	Grab	Quarterly				
Coliform, Fecal	74055		0	#/100mL	Grab	Quarterly				
pH	00400		6.5 - 8.5	s.u.	Grab	Quarterly				
Sulfate, Total	00945		250	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		160	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUNDWATER MONITORING REPORT - PART D

Facility Name: Port Labelle WWTP
 Permit Number: FLA014290-007-DW2P
 County: Hendry

Monitoring Well ID: MWI-20671
 Well Type: Intermediate
 Description: **M-1 Intermediate well**
 located adjacent to the
 on-site percolation
 ponds.

Report Frequency: Quarterly
 Program: Domestic

Office: South District

Re-submitted DMR: ☐

Monitoring Period From: _____ To: _____ Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ___ Yes ___ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Quarterly				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Quarterly				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Quarterly				
Chloride (as Cl)	00940		Report	mg/L	Grab	Quarterly				
Coliform, Fecal	74055		Report	#/100mL	Grab	Quarterly				
pH	00400		Report	s.u.	Grab	Quarterly				
Sulfate, Total	00945		Report	mg/L	Grab	Quarterly				
Turbidity	00070		Report	NTU	Grab	Quarterly				
Sodium, Total Recoverable	00923		Report	mg/L	Grab	Quarterly				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. Facilities who submit their DMR(s) electronically through eDMR do not need to submit a hardcopy DMR. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used, unless indicated otherwise in the permit or on the DMR:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g. highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units. Data qualifier codes are not to be reported on Part A.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that. Data qualifier codes are not to be reported on Part D.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

**STATEMENT OF BASIS
FOR
STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT**

PERMIT NUMBER: FLA014290-007

PA FILE NUMBER: FLA014290-007-DW2P

FACILITY NAME: Port Labelle

FACILITY LOCATION: 3490 Utility Drive, Labelle, FL 33935
Hendry County

NAME OF PERMITTEE: Hendry County Board of County Commissioners

PERMIT WRITER: Barbara J. Skates

1. SUMMARY OF APPLICATION

a. Chronology of Application

Application Number: FLA014290-007-DW2P

Application Submittal Date: June 19, 2015

b. Type of Facility

Domestic Wastewater Treatment Plant

Ownership Type: County

SIC Code: 4952

c. Facility Capacity

Existing Permitted Capacity: 0.499 mgd Annual Average Daily Flow

Proposed Increase in Permitted Capacity: 0 mgd Annual Average Daily Flow

Proposed Total Permitted Capacity: 0.499 mgd Annual Average Daily Flow

d. Description of Wastewater Treatment

Operate an existing 0.499 million gallons per day (MGD) annual average daily flow (AADF) extended aeration conventional activated sludge domestic wastewater treatment plant (WWTP). Major process components include 234,000 gallons total aeration, an approximately 100,000 gallon final sedimentation tank, a 16,900 gallon chlorine contact tank, and a 100,419 gallon digester. Disinfection is provided by gaseous chlorine. A transmission system delivers reverse osmosis concentrate water to the effluent of the WWTP and blended prior to entry to the percolation ponds. See Final Order Granting Petition for: Variance from Rule 62-610.865(8), F.A.C., OGC File No. 11-0509, Done and Ordered August 05, 2011.

2. SUMMARY OF SURFACE WATER DISCHARGE

This facility does not discharge to surface waters.

3. BASIS FOR PERMIT LIMITATIONS AND MONITORING REQUIREMENTS

This facility is authorized to direct reclaimed water to Reuse System R-001, a rapid infiltration basin system, based on the following:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	0.499	Annual Average	62-600.400(3)(b) & 62-610.810(5) FAC
		Max	Report	Monthly Average	62-600.400(3)(b) & 62-610.810(5) FAC
BOD, Carbonaceous 5 day, 20C	mg/L	Max	20.0	Annual Average	62-610.510 & 62-600.740(1)(b)1.a. FAC
		Max	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
		Max	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
Solids, Total Suspended	mg/L	Max	20.0	Annual Average	62-610.510 & 62-600.740(1)(b)1.a. FAC
		Max	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
		Max	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
Coliform, Fecal	#/100mL	Max	200	Monthly Geometric Mean	62-600.440(4)(c)2. FAC
		Max	200	Annual Average	62-610.510 & 62-600.440(4)(c)1. FAC
		Max	800	Single Sample	62-600.440(4)(c)4. FAC
pH	s.u.	Min	6.0	Single Sample	62-600.445 FAC
		Max	8.5	Single Sample	62-600.445 FAC
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	62-610.510 & 62-600.440(4)(b) FAC
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	62-610.510(1) FAC
Flow (Concentrate)	MGD	Max	0.499	Annual Average	62-600.400(3)(b), 62-610.865(8)(b) & 62-610.810(5) FAC
		Max	Report	Monthly Average	62-600.400(3)(b) & 62-610.810(5) FAC
Solids, Total Suspended (Blend)	mg/L	Max	Report	Single Sample	62-610.865(8)(e) FAC
Specific Conductance (Blend)	umhos/cm	Max	See Permit Condi tion	Single Sample	62-610.865(8)(c) FAC
Fluoride, Total (as F) (Blend)	mg/L	Max	Report	Single Sample	62-610.865(8)(e) FAC
Sodium Adsorption Ratio (Blend)	ratio	Max	-	Single Sample	62-610.865(8)(e) FAC
Sodium, Total Recoverable (Blend)	mg/L	Max	Report	Single Sample	62-610.865(8)(e) FAC
Magnesium, Total Recoverable (Blend)	mg/L	Max	Report	Single Sample	62-610.865(8)(e) FAC
Calcium, Total Recoverable (Blend)	mg/L	Max	Report	Single Sample	62-610.865(8)(e) FAC
Chloride (as Cl) (Blend)	mg/L	Max	-	Single Sample	62-610.865(8)(e) FAC
Solids, Total Dissolved (TDS) (Blend)	mg/L	Max	-	Single Sample	62-610.865(8)(e) FAC
pH (Blend)				Single Sample	62-610.865(8)(e) FAC

The Blend Ratio is not required as the permittee has provided an evaluation of any adverse effects on vegetation and ground water quality. [62-610.865(8)(f) & (11) FAC]

Other Limitations and Monitoring Requirements:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	0.499	Annual Average	62-600.400(3)(b) FAC
		Max	Report	Monthly Average	62-600.400(3)(b) FAC
		Max	Report	Quarterly Average	62-600.400(3)(b) FAC
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	62-600.405(4) FAC
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	62-601.300(1) FAC
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	62-601.300(1) FAC
Monitoring Frequencies and Sample Types	-	-	-	All Parameters	62-601 FAC & 62-699 FAC and/or BPJ of permit writer
Sampling Locations	-	-	-	All Parameters	62-601, 62-610.412, 62-610.463(1), 62-610.568, 62-610.613 FAC and/or BPJ of permit writer

4. DISCUSSION OF CHANGES TO PERMIT LIMITATIONS

No significant effluent limit changes.

5. BIOSOLIDS MANAGEMENT REQUIREMENTS

Biosolids generated by this facility may be transferred to Karle Enviro-Organic Recycling, and Inc. or disposed of in a Class I solid waste landfill.

See the table below for the rationale for the biosolids quantities monitoring requirements.

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Biosolids Quantity (Landfilled)	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
Biosolids Quantity (Transferred)	dry tons	Max	Report	Monthly Total	62-640.650(5)(a)1. FAC
Monitoring Frequency	All Parameters				62-640.650(5)(a) FAC

6. GROUND WATER MONITORING REQUIREMENTS

Modify the groundwater monitoring wells for the percolation ponds as required in accordance with the permittee's proposed changes and Chapters 62-520, 532, 601, 610, and 620, F.A.C.

7. PERMIT SCHEDULES

A schedule for improvement actions is included in the permit.

8. INDUSTRIAL PRETREATMENT REQUIREMENTS

At this time, the facility is not required to develop an approved industrial pretreatment program. However, the Department reserves the right to require an approved program if future conditions warrant.

9. ADMINISTRATIVE ORDERS (AO) AND CONSENT ORDERS (CO)

This permit is not accompanied by an AO and has not entered into a CO with the Department.

10. REQUESTED VARIANCES OR ALTERNATIVES TO REQUIRED STANDARDS

Variance from Rule 62-610.865(8), F.A.C., OGC File No. 11-0509, Done and Ordered August 05, 2011

11. TERM OF THE PERMIT

Five years

12. THE ADMINISTRATIVE RECORD

The administrative record is available for online and can be accessed through the Department's Information Portal at: <http://webapps.dep.state.fl.us/DepNexus/public/electronic-documents/FLA014290/facility!search> . It is also available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at the Department's South District Office, 2295 Victoria Ave, Suite 364, Ft. Myers, Florida 33901. Please contact the Department at phone number (239) 344-5600 if you have any questions or are experiencing difficulty viewing the electronic application.



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, FL 33902-2549

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

CERTIFIED MAIL NO.: 7003 1010 0004 9018 4280
RETURN RECEIPT REQUESTED

BEFORE THE STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

In re: Hendry County

Petition for Variance

OGC File No. 11-0509

Submitted by:
Mark F. Lapp
County Attorney
Hendry County
P.O. Box 2340
LaBelle, FL 33975-2340

FINAL ORDER GRANTING PETITION FOR VARIANCE FROM RULE 62-610.865(8), F.A.C.

On March 23, 2011, a petition for variance from requirements in Rule 62-610.865(8) of the Florida Administrative Code (F.A.C.), under section 120.542 of the Florida Statutes and Rule 28-104.002, F.A.C., was filed by Hendry County for the Port LaBelle Wastewater Treatment Plant. The petition was for a variance from Rule 62-610.865(8), F.A.C., which requires continuous monitoring of effluent for specific conductance and weekly monitoring of effluent for TSS, fluoride, TDS, chlorides, pH, sodium adsorption ratio, sodium, magnesium, and calcium, for

wastewater treatment facilities that blend demineralization concentrate with reclaimed water.

The request is for a variance that would be permanent. Hendry County petitioned for a variance in order to avoid a substantial hardship on the County related to installation of continuous monitoring equipment and frequent sampling and testing. A notice of receipt of the petition was published in the Florida Administrative Weekly on April 15, 2011.

1. Petitioner's address is Hendry County, Board of County Commissioners, P.O. Box 2340, LaBelle, Florida 33975-2340.

2. The Department of Environmental Protection (Department) issued wastewater plant operating permit No. FLA014290-005 to Hendry County for the Port LaBelle Wastewater Treatment Plant on December 17, 2010. Said permit has testing requirements based upon Rule 62-610.865(8), F.A.C., because the plant blends demineralization concentrate with reclaimed water.

3. The applicable rule states in pertinent part:

62-610.865(8)(c): The blend shall be monitored continuously for specific conductance. The results of this monitoring shall be used to make continuous judgments of the quality of the blend related to inorganic constituents of the blend (such as total dissolved solids and chlorides).

62-610.865(8)(e): Total suspended solids, fluoride, total dissolved solids, chlorides, pH, and sodium adsorption ratio shall be monitored weekly in the blend. Additional parameters to be sampled and analyzed for in the blend on a weekly basis shall be established in the permit based on characterization of the concentrate and the blend contained in the engineering report.

4. Upon completion of the Port LaBelle Reverse Osmosis Water Treatment Plant in 2006, concentrate from the plant was permitted to discharge to the head of the Port LaBelle wastewater treatment plant. In an effort to reduce wastewater plant influent flows, Hendry County, with the Department's permission, moved the concentrate line from the head of the

wastewater treatment plant to the effluent side. This move triggered the applicability of Rule 62-610.865(8), F.A.C.

5. The petitioner submitted an Engineering Report showing that, with the exception of TDS, each of the parameters of the blend water will meet drinking water standards. These were worst case calculations. Actual laboratory reports demonstrate that TDS is often below the secondary drinking water MCL.

6. Hendry County is not requesting relaxation of any standards; only relaxation of the frequency of testing.

7. The purpose of the increased frequency of testing in Rule 62-610.865, F.A.C., is to protect vegetation in a widespread public access reclaimed water system. Hendry County is not sending its effluent blend to a widespread public access reclaimed water system. Hendry County disposes of the effluent blend in an on-site restricted public access rapid infiltration basin. The referenced rules would violate principles of fairness in that the effect on Hendry County is different from other similarly situated persons because the rules attempt to guard against a harm that is not present in Hendry County's situation.

8. Hendry County has established a ground water monitoring plan which included background, intermediate, and compliance wells. In addition to performing monitoring of the effluent blend, Hendry County is required to monitor the groundwater at each of these well locations. By monitoring the blended effluent quality and the groundwater quality, Hendry County will be able to take corrective action if indicated by the monitoring results.

9. Hendry County is a rural poor county that has been designated as a rural area of critical economic concern. The installation of continuous monitoring equipment and weekly sampling would place a substantial hardship on the County.

10. The purpose of the underlying statutes of promoting the reuse of reclaimed water and the development of alternative water supply development including demineralization technologies while conserving and protecting the state's natural resources will be met by monitoring at the proposed relaxed frequency. No standards are being relaxed.

11. The Department received no comments about the petition for variance.

12. For the foregoing reasons, including a showing of substantial hardship, it has been demonstrated that Hendry County has met the requirements for a variance from Rule 62-610.865(8), F.A.C., and the requested variance is hereby granted subject to the conditions below:

- a. Hendry County shall monitor the effluent blend from the Port LaBelle Wastewater Treatment Plant on a quarterly basis for specific conductivity, TDS, chlorides, TSS, fluoride, pH, sodium adsorption ratio, sodium, magnesium, and calcium. Continuous monitoring for specific conductance and continuous monitoring equipment for specific conductance is not required.
- b. The Department reserves the right to increase monitoring frequency if any actual test results are worse than the "worst case scenario" blending analysis dated May 19, 2011, and submitted to the Department by Mr. Daniel M. Nelson, P.E., of Tetra Tech.
- c. If any applicable standard related to effluent blend or ground water is exceeded, then Hendry County shall submit a proposed corrective action plan to the Department within 21 days of becoming aware of the exceedance.
- d. This variance does not relieve Hendry County from liability for harm or injury to human health or welfare, animal, or plant life, or property, or from penalties

therefore; nor does it allow pollution in contravention of Florida Statutes or Department rules.

- e. The Department hereby expressly reserves the right to initiate appropriate legal action to address any violations of statutes or rules administered by the Department.

This order will become final unless a timely petition for an administrative proceeding is filed pursuant to the provisions of sections 120.569 and 120.57 of the Florida Statutes. Any person whose substantial interests are affected by the Department's action may file such a petition. The petition must contain the information set forth below and must be filed (received) in the Department's Office of General Counsel, 3900 Commonwealth Boulevard, MS 35, Tallahassee, Florida 32399-3000. Petitions filed by Hendry County or any of the parties listed below must be filed within 21 days of receipt of this order. Petitions filed by any other person must be filed within 21 days of publication of the public notice or within 21 days of receipt of this order, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within 21 days of receipt of such notice, regardless of the date of publication. A petitioner must mail a copy of the petition to Mr. Mark F. Lapp, County Attorney, Hendry County, P.O. Box 2340, LaBelle, FL 33975-2340, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of the Florida Statutes, or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will only be at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputed the material facts on which the Department's action is based must contain the following information:

- (a) The name, address and telephone number of each petitioner; the Department case identification number and the county in which the subject matter or activity is located;
- (b) A statement of how and when each petitioner received notice of the Department action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department action;
- (d) A statement of the material facts disputed by the petitioner, if any;
- (e) A statement of facts that the petitioner contends warrant reversal or modification of the Department action;
- (f) A statement of which rules or statutes the petitioner contends require reversal or modification of the Department action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take with respect to the proposed action.

A petition that does not dispute the material facts on which the Department's action is based shall state that no such facts are in dispute and otherwise contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department final action may be different from the position taken by it in this order. Persons whose substantial interests will be affected by any such final

decision of the Department on the petitions have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under section 120.573 of the Florida Statutes is not available for this proceeding.

This action is final and effective on the date filed with the Clerk of the Department unless a petition is filed in accordance with the above.

A party to this order has the right to seek judicial review of it under section 120.68 of the Florida Statutes, by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department in the Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

DONE AND ORDERED this 5th day of August, 2011 in Fort Myers, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of District Management

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to s. 120.52, Florida Statutes, with the designated Agency Clerk, receipt of which is hereby acknowledged. All copies were mailed before the close of business on the date below to the persons listed.

Julia S. L. Moore
Clerk

8-5-11
Date

Copies furnished to:

Justin G. Wolfe
Lea Crandall
Elsa Potts
JAPC
Daniel M. Nelson, P.E.
Roger Greer, Port LaBelle Utility System

NOTICE OF RIGHTS OF SUBSTANTIALLY AFFECTED PERSONS

This determination is final and effective on the date filed with the Clerk of the Department unless a timely and sufficient petition for an administrative hearing is filed under sections 120.569 and 120.57 of the Florida Statutes as provided below. If a sufficient petition for an administrative hearing is timely filed, this determination automatically becomes only proposed agency action subject to the result of the administrative review process. Therefore, on the filing of a timely and sufficient petition, this action will not be final and effective until further order of the Department. The procedures for petitioning for a hearing are set forth in Rules 28-106.201-.202 and 62-110.106, F.A.C., and are summarized below.

Be advised that, under Florida law, your neighbors and other parties who may be substantially affected by this determination have a right to request an administrative hearing. Because the administrative hearing process is designed to re-determine final agency action, the filing of a petition for an administrative hearing may result in a final determination different from this determination. Generally speaking, the 21-day period for filing a petition begins to run on the date of publication of the notice (if published) or the date a person receives actual notice, whichever occurs first (see below).

The Department will not publish notice of this determination. Publication of notice by you is optional and is not required for you to proceed. However, in the event that an administrative hearing is held and the Department's determination is reversed, proceeding with the proposed activity before the time period for requesting an administrative hearing has expired would mean that the activity was conducted without the required permit or authorization. In cases

where notice is not published, there may be instances in which a substantial amount of time could pass before an affected person receives notice of the agency action.

If you wish to limit the time within which all substantially affected persons may request an administrative hearing, you may elect to publish, at your own expense, the notice specified below in the legal advertisement section of a newspaper of general circulation in the county where the activity is to take place. A single publication will suffice.

If you wish to limit the time within which any specific person(s) may request an administrative hearing, you may provide direct notice to such person(s), by certified mail and enclosing a copy of this determination.

For the purposes of publication, a newspaper of general circulation means a newspaper meeting the requirements of sections 50.011 and 50.031 of the Florida Statutes. In the event you do publish this notice, within seven days of publication, you must provide to the following address proof of publication issued by the newspaper as provided in section 50.051 of the Florida Statutes. If you provide direct written notice to any person as noted above, you must provide to the following address a copy of the direct written notice: Florida Department of Environmental Protection, P.O. Box 2549, Fort Myers, FL 33902-2549; Attn: Gary Maier.

NOTICE
STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION

The Department of Environmental Protection gives notice that a variance has been granted to Mr. Mark F. Lapp, County Attorney, Hendry County, Board of County Commissioners, P.O. Box 2340, LaBelle, FL 33975-2340, to provide monitoring relief from Rule 62-610.865(8), F.A.C., for the Port LaBelle Wastewater Treatment Plant. Hendry County blends the effluent from said plant with the demineralization concentrate from Port Labelle's reverse osmosis drinking water treatment plant prior to disposal in Hendry County's on-site restricted public access rapid infiltration basin. Rule 62-610.865(8), F.A.C., requires continuous monitoring of the blend for specific conductance and weekly monitoring for TSS, fluoride, TDS, chlorides, pH, and sodium adsorption ratio. This variance reduces the monitoring frequency for these parameters to quarterly. Only the monitoring frequency has been relaxed. No applicable effluent or ground water standards have been relaxed.

A person whose substantial interests are affected by the Department's action may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received by the clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Mediation is not available.

If a timely and sufficient petition for an administrative hearing is filed, other persons whose substantial interests will be affected by the outcome of the administrative process have the right to petition to intervene in the proceeding. Intervention will be permitted only at the discretion

of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code (F.A.C.).

In accordance with Rules 28-106.111(2) and 62-110.106(3)(a)(4), F.A.C., petitions for an administrative hearing must be filed within 21 days of publication of the notice or receipt of written notice, whichever occurs first. Under Rule 62-110.106(4), F.A.C., a person whose substantial interests are affected by the Department's action may also request an extension of time to file a petition for an administrative hearing. The Department may, for good cause shown, grant the request for an extension of time. Requests for extension of time must be filed with the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000 before the applicable deadline. A timely request for extension of time will toll the running of the time period for filing a petition until the request is acted upon. Upon motion by the requesting party showing that the failure to file a request for an extension of time before the deadline was the result of excusable neglect, the Department may also grant the requested extension of time.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition for an administrative hearing within the appropriate time period shall constitute a waiver of that right.

A petition that disputes the material facts on which the Department's action is based must contain the following information:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;

- (b) The name, address, and telephone number of the petitioner; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests are or will be affected by the agency determination;
- (c) A statement of when and how the petitioner received notice of the agency decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action;
- (f) A statement of the specific rules or statutes that the petitioner contends require reversal or modification of the agency's proposed action, including an explanation of how the alleged facts relate to the specific rules or statutes; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts on which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Under sections 120.569(2)(c) and (d) of the Florida Statutes, a petition for administrative hearing shall be dismissed by the agency if the petition does not substantially comply with the above requirements or is untimely filed.

Complete copies of all documents relating to this determination are available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, at Florida Department of Environmental Protection, 2295 Victoria Avenue, Suite 364, Fort Myers, FL 33901. The contact person is Brandon Ivey at 239-344-5653.