



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, FL 33902-2549

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

CERTIFIED MAIL NO.: 7010 1870 0001 8477 2605
RETURN RECEIPT REQUESTED

In the Matter of an
Application for Permit by:

Greentree South
Pamela Borton, Managing Agent
P. O. Box 2837
Labelle, Florida 33975

Hendry County-DW
Greentree South WWTP
File Number: FLA014308-007-DW3P

FILE

NOTICE OF PERMIT ISSUANCE

Enclosed is Permit Number FLA014308 to operate the Greentree South WWTP, issued under Chapter 403, Florida Statutes.

Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, Florida Statutes, within fourteen days of receipt of notice. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under Sections 120.569 and 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received by the Clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Under Rule 62-110.106(4), Florida Administrative Code, a person may request an extension of the time for filing a petition for an administrative hearing. The request must be filed (received by the Clerk) in the Office of General Counsel before the end of the time period for filing a petition for an administrative hearing.

Petitions by the applicant or any of the persons listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), Florida Statutes, must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first. Section 120.60(3), Florida Statutes, however, also allows that any person who has asked the Department for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for an extension of time within fourteen days of receipt of notice shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information, as indicated in Rule 28-106.201, Florida Administrative Code:

- (a) The name and address of each agency affected and each agency's file or identification number, if known;
- (b) The name, address, and telephone number of the petitioner; the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the determination;
- (c) A statement of when and how the petitioner received notice of the Department's decision;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the Department's proposed action;
- (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the Department's proposed action; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the Department to take with respect to the Department's proposed action.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

This permit action is final and effective on the date filed with the Clerk of the Department unless a petition (or request for an extension of time) is filed in accordance with the above. Upon the timely filing of a petition (or request for an extension of time), this permit will not be effective until further order of the Department.


Any party to the permit has the right to seek judicial review of the permit action under Section 120.68, Florida Statutes, by the filing of a notice of appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within 30 days from the date when this permit action is filed with the Clerk of the Department.

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

Executed in Fort Myers, Florida


STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52, Florida Statutes, with the designated Deputy Clerk,
receipt of which is hereby acknowledged.

 4-22-11

[Clerk] [Date]

CERTIFICATE OF SERVICE

The undersigned hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were
mailed before the close of business on April 22, 2011 to the listed persons.

JMI/BJS/jl

Cc:

James P. Elliot, P.E., Source, Inc.

Michelle Fish, FDEP, e-mail

Keith Kleinmann, FDEP, e-mail

Allen Slater, FRWA, e-mail

Rick Pringle, Operator, ww6257@comcast.net

Donald Shivers, Chairman Area housing Commission of Clewiston, LaBelle, and Hendry County



Florida Department of Environmental Protection

South District
P.O. Box 2549
Fort Myers, FL 33902-2549

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr.
Secretary

STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT

PERMITTEE:
Greentree South

RESPONSIBLE OFFICIAL:
Pamela Borton, Managing Agent
P. O. Box 2837
Labelle, Florida 33975
(863) 675-5247

PERMIT NUMBER: FLA014308
FILE NUMBER: FLA014308-007-DW3P
ISSUANCE DATE: April 21, 2011
EXPIRATION DATE: April 20, 2016

FACILITY:

Greentree South WWTP
State Road 29 South
Labelle, FL 33935
Hendry County
Latitude: 26°43' 38.2276" N Longitude: 81°26' 28.8939" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.). This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. The above named permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

WASTEWATER TREATMENT:

Operate an existing 0.020 million gallons per day (MGD) three month average daily flow (TMADF) permitted capacity extended aeration process wastewater treatment plant (WWTP) consisting of: one 5,000 gallon surge tank, four 5,000 gallon aeration basins, two 5,200 gallon final settling tanks, two 1,000 gallon chlorine contact chambers (CCC's), one 5,000 gallon digester, and two 1,000 gallon sludge holding tanks. Disinfection is provided by liquid sodium hypochlorite.

REUSE OR DISPOSAL:

Land Application R-001: An existing 0.020 MGD TMADF permitted capacity rapid infiltration basin system. R-001 is a reuse system which consists of two percolation ponds with a total area of 0.487 acres located approximately at latitude 26°43' 4" N, longitude 81°26' 24" W.

IN ACCORDANCE WITH: The limitations, monitoring requirements, and other conditions set forth in this cover sheet and Part I through Part IX on pages 1 through 18 of this permit.

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

1. RECLAIMED WATER AND EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Reuse and Land Application Systems

- During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to direct reclaimed water to Reuse System R-001. Such reclaimed water shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7.

Parameter	Units	Max/Min	Reclaimed Water Limitations		Monitoring Requirements			Notes
			Limit	Statistical Basis	Frequency of Monitoring	Sample Type	Monitoring Site Number	
BOD, Carbonaceous 5 day, 20C	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Monthly	Grab	EFA-01	
Solids, Total Suspended	mg/L	Max Max Max Max	20.0 30.0 45.0 60.0	Annual Average Monthly Average Weekly Average Single Sample	Monthly	Grab	EFA-01	
Coliform, Fecal	#/100mL	Max Max Max	200 200 800	Annual Average Monthly Geometric Mean Single Sample	Monthly	Grab	EFA-01	See I.A.3
pH	s.u.	Min Max	6.0 8.5	Single Sample Single Sample	5 Days/Week	Grab	EFA-01	
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	5 Days/Week	Grab	EFA-01	See I.A.4
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	Monthly	Grab	EFA-01	

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

2. Reclaimed water samples shall be taken at the monitoring site locations listed in Permit Condition I.A.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFA-01	After final chlorine contact tank and before discharge to the percolation pond system.

3. The effluent limitation for the monthly geometric mean for fecal coliform is only applicable if 10 or more values are reported. If fewer than 10 values are reported, the monthly geometric mean shall be calculated and reported on the Discharge Monitoring Report. [62-600.440(4)(c)]
4. Total residual chlorine must be maintained for a minimum contact time of 15 minutes based on peak hourly flow. [62-610.510, 62-600.440(4)(b) and (5)(b)]

PERMITTEE: Greentree South
 FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
 PA FILE NUMBER: FLA014308-007-DW3P

B. Other Limitations and Monitoring and Reporting Requirements

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the treatment facility shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.B.7.

Parameter	Units	Max/Min	Limitations		Monitoring Requirements			Notes
			Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	
Flow	MGD	Max Max Max	0.020 Report Report	Three Month Average Monthly Average Quarterly Average	5 Days/Week	Meter	FLW-01	See I.B.4
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	Monthly	Calculated	CAL-01	
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	Monthly	Grab	INF-01	See I.B.3
Biosolids Transferred	dry tons	--	Report	Sum of Hauls During the Month	Monthly	Calculated	RMP-1	
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	Monthly	Grab	INF-01	See I.B.3

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

2. Samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
FLW-01	Mag meter on influent force main
CAL-01	Percent capacity calculated from flow measurements.
INF-01	Sample collected at influent discharge into surge tank.
RMP-1	At the sludge digester tank.

3. Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. [62-601.500(4)]
4. A meter shall be utilized to measure flow and calibrated at least once every 12 months. [62-601.200(17) and .500(6)]
5. The sample collection, analytical test methods and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate. [62-4.246, 62-160]
6. The permittee shall provide safe access points for obtaining representative influent, reclaimed water, and effluent samples which are required by this permit. [62-601.500(5)]
7. Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type on DMR	Monitoring Period	Due Date
Monthly or Toxicity	First day of month - last day of month	28 th day of following month
Quarterly	January 1 - March 31	April 28
	April 1 - June 30	July 28
	July 1 - September 30	October 28
	October 1 - December 31	January 28
Semiannual	January 1 - June 30	July 28
	July 1 - December 30	January 28
Annual	January 1 - December 31	January 28

DMRs shall be submitted for each required monitoring period including months of no discharge. The permittee shall make copies of the attached DMR form(s) and shall submit the completed DMR form(s) to the Department's South District Office at the address specified in Permit Condition I.B.8. by the twenty-eighth (28th) of the month following the month of operation.

[62-620.610(18)][62-601.300(1),(2), and (3)]

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

8. Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's South District Office at the address specified below:

Florida Department of Environmental Protection South District Office
2295 Victoria Ave
Suite 364
Ft. Myers, Florida 33901-3881

Phone Number - (239) 344-5600

FAX Number - (850) 412-0590

(All FAX copies and e-mails shall be followed by original copies.)

[62-620.305]

9. All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. [62-620.305]

2. RESIDUALS MANAGEMENT REQUIREMENTS

1. Biosolids generated by this facility may be transported to Karle Enviro-Organic Recycling Inc., or disposed of in a Class I solid waste landfill. Transferring biosolids to an alternative biosolids treatment facility does not require a permit modification; however, use of an alternative biosolids treatment facility requires the submittal of a copy of the agreement pursuant to Rule 62-640.880(1)(c), F.A.C., along with a written notification to the Department at least 30 days before transport of the biosolids. [62-620.320(6), 62-640.880(1)]
2. The permittee shall monitor and keep records of the quantities of biosolids generated, transferred to another facility, or landfilled. These records shall be submitted to the Department within 30 days of using the site. The revised Treatment Facility Biosolids Plan shall become part of the treatment facility permit. [62-640.300(2)(c) & 62-640.650(6)(a)]
3. The permittee shall not be held responsible for treatment and management, violations that occur after its biosolids have been accepted by a permitted biosolids treatment facility with which the source facility has an agreement in accordance with Rule 62-640.880(1)(c), F.A.C., for further treatment, management, or disposal. [62-640.880(1)(b)]
4. The permittee shall keep hauling records to track the transport of biosolids between facilities. The hauling records shall contain the following information:

Greentree South WWTP

1. Date and Time Shipped.
2. Amount of Biosolids Shipped.
3. Degree of Treatment (if applicable).
4. Name and ID Number of Biosolids Treatment Facility or Treatment Facility.
5. Signature of Responsible Party at Source Facility.
6. Signature of Hauler and Name of Hauling Firm.

Biosolids Treatment Facility or Treatment Facility

1. Date and Time Received.
2. Amount of Biosolids Received.
3. Name and ID Number of Source Facility
4. Signature of Hauler.
5. Signature of Responsible Party at Biosolids Treatment Facility or Treatment Facility.

A copy of the source facility hauling records for each shipment shall be provided upon delivery of the biosolids to the biosolids treatment facility or treatment facility. The treatment facility permittee shall report to the Department within 24 hours of discovery any discrepancy in the quantity of biosolids leaving the source facility and arriving at the biosolids treatment facility or treatment facility. [62-640.880(4)]

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

5. If the permittee intends to accept biosolids from other facilities, a permit revision is required pursuant to paragraph 62-640.880(2)(d), F.A.C. [62-640.880(2)(d)]
6. Storage of biosolids or other solids at the permitted facility shall require prior written notification to the Department. [62-640.300(4)]
7. The treatment, management, transportation, use, land application, or disposal of biosolids shall not cause a violation of the odor prohibition in subsection 62-296.320(2), F.A.C. [62-640.400(6)]
8. Storage of biosolids or other solids at this facility shall be in accordance with the Facility Biosolids Storage Plan. [62-640.300(4)]
9. Biosolids shall not be spilled from or tracked off the treatment facility site by the hauling vehicle. [62-640.400(9)]

3. GROUND WATER REQUIREMENTS

1. All piezometers and monitoring wells not part of the approved ground water monitoring plan are to be plugged and abandoned in accordance with Rule 62-532.500(4), F.A.C., unless future use is intended. [62-532.500(4)]
2. With the application for permit renewal, the permittee shall submit the results of sampling monitoring well specified in the Department-approved monitoring plan for the primary and secondary drinking water parameters included in Chapter 62-550, F.A.C., (excluding asbestos, acrylamide, Dioxin, butachlor, epichlorohydrin, pesticides, and PCBs, unless reasonably expected to be a constituent of the discharge or an artifact of the site). Additional volatile and semivolatile parameters as specified in the ground water monitoring plan or permit shall be analyzed. Sampling shall occur no sooner than 180 days before submittal of the renewal application. [62-520.600(5)(b)]
3. For the Part IV land application system(s), all ground water quality criteria specified in Chapter 62-520, F.A.C., shall be met at the edge of the zone of discharge. The zone of discharge for Land Application Site R-001 shall extend horizontally 75 feet from the application site and vertically to the base of the shallow water table aquifer. [62-520.200(27)] [62-520.465]
4. During the period of operation authorized by this permit, the permittee shall continue to sample ground water at the monitoring well identified in Permit Condition III.5., below in accordance with this permit and the approved ground water monitoring plan prepared in accordance with Rule 62-520.600, F.A.C. [62-520.600] [62-610.510]
5. The following monitoring well shall be sampled for Reuse System R-001.

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Aquifer Monitored	New or Existing
MWC-24593	GT-1	Surficial	Existing

MWC = Compliance

[62-520.600] [62-610.510]

6. The following parameters shall be analyzed for the monitoring well identified in Permit Condition III.5.

Parameter	Compliance Well Limit	Units	Sample Type	Monitoring Frequency
Water Level Relative to NGVD (NAVD allowable)	Report	ft	In Situ	Semi-annually
Nitrogen, Nitrate, Total (as N)	10	mg/L	Grab	Semi-annually
Solids, Total Dissolved (TDS)	500	mg/L	Grab	Semi-annually
Arsenic, Total Recoverable	10	ug/L	Grab	Semi-annually
Chloride (as Cl)	250	mg/L	Grab	Semi-annually
Cadmium, Total Recoverable	5	ug/L	Grab	Semi-annually
Chromium, Total Recoverable	100	ug/L	Grab	Semi-annually
Lead, Total Recoverable	15	ug/L	Grab	Semi-annually
Coliform, Total	4	#/100mL	Grab	Semi-annually
pH	6.5-8.5	s.u.	In Situ	Semi-annually
Sulfate, Total	250	mg/L	Grab	Semi-annually
Turbidity	Report	NTU	Grab	Semi-annually
Temperature (C), Water	Report	Deg C	In Situ	Semi-annually
Specific Conductance	Report	umhos/cm	In Situ	Semi-annually
Oxygen, Dissolved (DO)	Report	mg/L	In Situ	Semi-annually

[62-520.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-601.300(6)] [62-520.310(5)]

7. Water levels shall be recorded before evacuating each well for sample collection. Elevation references shall include the top of the well casing and land surface at each well site (NAVD allowable) at a precision of plus or minus 0.01 foot. [62-520.600(11)(c)] [62-610.510(3)(b)]
8. Ground water monitoring wells shall be purged prior to sampling to obtain representative samples. [62-160.210] [62-601.700(5)]
9. Analyses shall be conducted on unfiltered samples, unless filtered samples have been approved by the Department's South District Office as being more representative of ground water conditions. [62-520.310(5)]
10. Ground water monitoring test results shall be submitted on Part D of Form 62-620.910(10) in accordance with Permit Condition I.B.7. [62-520.600(11)(b)] [62-601.300(3), 62-601.700, and Figure 3 of 62-601] [62-620.610(18)]
11. If any monitoring well becomes damaged or inoperable, the permittee shall notify the Department's South District Office immediately and a detailed written report shall follow within seven days. The written report shall detail what problem has occurred and remedial measures that have been taken to prevent recurrence. All monitoring well design and replacement shall be approved by the Department's South District Office prior to installation. [62-520.600] [62-620.320(6)]

12. With the application for permit renewal, the permittee shall submit the results of sampling monitoring wells specified in the Department-approved monitoring plan for the primary and secondary drinking water parameters included in Chapter 62-550, F.A.C., (excluding asbestos, acrylamide, Dioxin, butachlor, epichlorohydrin, pesticides, and PCBs, unless reasonably expected to be a constituent of the discharge or an artifact of the site). Additional volatile and semivolatile parameters as specified in the ground water monitoring plan or permit shall be analyzed. Sampling shall occur no sooner than 180 days before submittal of the renewal application. [62-520.600(5)(b)]

4. ADDITIONAL REUSE AND LAND APPLICATION REQUIREMENTS

A. Part IV Rapid Infiltration Basins

1. Advisory signs shall be posted around the site boundaries to designate the nature of the project area. [62-610.518]
2. The maximum annual average loading rate to the two percolation ponds with a total area of 0.487 acres shall be limited to 1.5 inches per day (as applied to the entire bottom area). [62-610.523(3)]
3. Rapid infiltration basins shall be routinely maintained to control vegetation growth and to maintain percolation capability by scarification or removal of deposited solids. Basin bottoms shall be maintained to be level. [62-610.523(6) and (7)]
4. Routine aquatic weed control and regular maintenance of storage pond embankments and access areas are required. [62-610.514 and 62-610.414]
5. Overflows from emergency discharge facilities on storage ponds or on infiltration ponds, basins, or trenches shall be reported as abnormal events in accordance with Permit Condition IX.20. [62-610.800(9)]
6. Percolation ponds normally shall be loaded for 1 to 7 days and shall be rested for 5 to 14 days. Infiltration ponds, basins, or trenches shall be allowed to dry during the resting portion of the cycle. [62-610.523(4)]

5. OPERATION AND MAINTENANCE REQUIREMENTS

A. Staffing Requirements

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of an operator(s) certified in accordance with Chapter 62-602, F.A.C. In accordance with Chapter 62-699, F.A.C., this facility is a Category III, Class D facility and, at a minimum, operators with appropriate certification must be on the site as follows:

A Class D or higher operator for a minimum of: 3 visits per week on nonconsecutive days for a total of 1 and 1/2 hours per week. The lead/chief operator must be a Class D operator, or higher.
2. An operator meeting the lead/chief operator class for the treatment plant shall be available during all periods of plant operation. "Available" means able to be contacted as needed to initiate the appropriate action in a timely manner. Daily checks of the plant shall be performed by the permittee or his representative or agent 5 days per week. [62-699.311(1) and (2)]

B. Capacity Analysis Report and Operation and Maintenance Performance Report Requirements

1. The application to renew this permit shall include an updated capacity analysis report prepared in accordance with Rule 62-600.405, F.A.C. [62-600.405(5)]
2. The application to renew this permit shall include a detailed operation and maintenance performance report prepared in accordance with Rule 62-600.735, F.A.C. [62-600.735(1)]

C. Recordkeeping Requirements

1. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility.
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. Monitoring information, including a copy of the laboratory certification showing the laboratory certification number, related to the residuals use and disposal activities for the time period set forth in Chapter 62-640, F.A.C., for at least three years from the date of sampling or measurement;
 - e. A copy of the current permit;
 - f. A copy of the current operation and maintenance manual as required by Chapter 62-600, F.A.C.;
 - g. A copy of any required record drawings;
 - h. Copies of the licenses of the current certified operators; and
 - i. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules. The logs shall, at a minimum, include identification of the plant; the signature and license number of the operator(s) and the signature of the person(s) making any entries; date and time in and out; specific operation and maintenance activities, including any preventive maintenance or repairs made or requested; results of tests performed and samples taken, unless documented on a laboratory sheet; and notation of any notification or reporting completed in accordance with Rule 62-602.650(3), F.A.C. The logs shall be maintained on-site in a location accessible to 24-hour inspection, protected from weather damage, and current to the last operation and maintenance performed.

[62-620.350, 62-602.650]

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

6. SCHEDULES

1. As stated in the correspondence from Source, Inc. dated March 01 and 31, 2011, the following improvement actions shall be completed according to the following schedule: **For each Improvement Action listed below, the permittee shall submit a written notice of completion to the Department within 10 days of completing the Improvement Action.**

Improvement Action	Completion Date
1. Perform an Inflow and Infiltrate (I and I) flow test to the collection system	November 30, 2011
2. Perform corrections to collection system based on I and I test results	April 30, 2012
3. Install a manual bar screen box to top of the concrete tanks straddling the surge and digester tank #1, to discharge to the surge tank	November 30, 2011
4. Level both clarifier weirs	October 31, 2011
5. Re-center the sludge draw off piping in the north clarifier	October 31, 2011
6. Scarify both pond bottoms with a grading disc to level and clean pond bottoms	May 31, 2011
7. Survey the monitoring well elevation in NGVD datum. Resubmit the revised DMR reports with water levels expressed in NGVD to the Department's South District office	June 10, 2011

[62-620.320(6)]

1. If the permittee wishes to continue operation of this wastewater facility after the expiration date of this permit, the permittee shall submit an application for renewal no later than one-hundred and eighty days (180) prior to the expiration date of this permit. Application shall be made using the appropriate forms listed in Rule 62-620.910, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C. [62-620.335(1) and (2)]

7. INDUSTRIAL PRETREATMENT PROGRAM REQUIREMENTS

1. This facility is not required to have a pretreatment program at this time. [62-625.500]

8. OTHER SPECIFIC CONDITIONS

1. In the event that the treatment facilities or equipment no longer function as intended, are no longer safe in terms of public health and safety, or odor, noise, aerosol drift, or lighting adversely affects neighboring developed areas at the levels prohibited by Rule 62-600.400(2)(a), F.A.C., corrective action (which may include additional maintenance or modifications of the permitted facilities) shall be taken by the permittee. Other corrective action may be required to ensure compliance with rules of the Department. Additionally, the treatment, management, use or land application of residuals shall not cause a violation of the odor prohibition in Rule 62-296.320(2), F.A.C. [62-600.410(8) and 62-640.400(6)]
2. The deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater; or the deliberate introduction of stormwater into collection/transmission systems designed for the introduction or conveyance of combinations of storm and domestic/industrial wastewater in amounts which may reduce the efficiency of pollutant removal by the treatment plant is prohibited, except as provided by Rule 62-610.472, F.A.C. [62-604.130(3)]

3. Collection/transmission system overflows shall be reported to the Department in accordance with Permit Condition IX. 20. *[62-604.550] [62-620.610(20)]*
4. The operating authority of a collection/transmission system and the permittee of a treatment plant are prohibited from accepting connections of wastewater discharges which have not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents):
 - a. Which may cause fire or explosion hazards; or
 - b. Which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels; or
 - c. Which are solid or viscous and obstruct flow or otherwise interfere with wastewater facility operations or treatment; or
 - d. Which result in the wastewater temperature at the introduction of the treatment plant exceeding 40°C or otherwise inhibiting treatment; or
 - e. Which result in the presence of toxic gases, vapors, or fumes that may cause worker health and safety problems.

[62-604.130(5)]

5. The treatment facility, storage ponds for Part II systems, rapid infiltration basins, and/or infiltration trenches shall be enclosed with a fence or otherwise provided with features to discourage the entry of animals and unauthorized persons. *[62-610.518(1) and 62-600.400(2)(b)]*
6. Screenings and grit removed from the wastewater facilities shall be collected in suitable containers and hauled to a Department approved Class I landfill or to a landfill approved by the Department for receipt/disposal of screenings and grit. *[62-701.300(1)(a)]*
7. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. *[62-620.310(4)]*
8. The permittee shall provide verbal notice to the Department's South District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, wastewater residuals (sludges), or reclaimed water. The permittee shall immediately implement measures appropriate to control the entry of contaminants, and shall detail these measures to the Department's South District Office in a written report within 7 days of the sinkhole discovery. *[62-620.320(6)]*
9. The permittee shall provide adequate notice to the Department of the following:
 - a. Any new introduction of pollutants into the facility from an industrial discharger which would be subject to Chapter 403, F.S., and the requirements of Chapter 62-620, F.A.C., if it were directly discharging those pollutants; and
 - b. Any substantial change in the volume or character of pollutants being introduced into that facility by a source which was identified in the permit application and known to be discharging at the time the permit was issued.

Adequate notice shall include information on the quality and quantity of effluent introduced into the facility and any anticipated impact of the change on the quantity or quality of effluent or reclaimed water to be discharged from the facility.

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

[62-620.625(2)]

9. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]
3. As provided in subsection 403.087(7), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [62-620.610(5)]
6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. [62-620.610(6)]
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. [62-620.610(7)]
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8)]
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

- a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
- b. Have access to and copy any records that shall be kept under the conditions of this permit;
- c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
- d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.

[62-620.610(9)]

10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10)]*
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11)]*
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12)]*
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13)]*
14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14)]*
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15)]*
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-

620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16)]

17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.

[62-620.610(17)]

18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-601, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
 - e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
 - f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.

[62-620.610(18)]

19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(19)]
20. The permittee shall report to the Department's South District Office any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the

anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.

- a. The following shall be included as information which must be reported within 24 hours under this condition:
 - (1) Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - (4) Any unauthorized discharge to surface or ground waters.
- b. Oral reports as required by this subsection shall be provided as follows:
 - (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4. that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.
 - (2) Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department's South District Office within 24 hours from the time the permittee becomes aware of the circumstances.
- c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department's South District Office shall waive the written report.

[62-620.610(20)]

21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX.17., IX.18., or IX.19. of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20. of this permit. [62-620.610(21)]
22. Bypass Provisions.
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
 - b. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

- (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (3) The permittee submitted notices as required under Permit Condition IX.22.b. of this permit.
- c. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX.20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX.22.a.1. through 3. of this permit.
- e. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX.22.a. through c. of this permit.

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the permittee.
- (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
 - (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required in Permit Condition IX.20. of this permit; and
 - (4) The permittee complied with any remedial measures required under Permit Condition IX.5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.


[62-620.610(23)]

PERMITTEE: Greentree South
FACILITY: Greentree South WWTP

PERMIT NUMBER: FLA014308
PA FILE NUMBER: FLA014308-007-DW3P

Executed in Fort Myers, Florida

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION



Jon M. Iglehart
Director of
District Management

DATE: April 21, 2011

JMI/BJS/jl

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, 2295 Victoria Ave, Suite 364, Ft. Myers, FL 33901-3881

PERMITTEE NAME: Greentree South
MAILING: P. O. Box 2837
ADDRESS: Labelle, Florida 33975

PERMIT NUMBER: FLA014308-007-DW3P

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP:
DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Final
N/A
REPORT FREQUENCY: Monthly
PROGRAM: Domestic

FACILITY: Greentree South WWTP
LOCATION: Sr 29 South
Labelle, FL 33935

COUNTY: Hendry
OFFICE: South District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon. Site No. EFF-01	Permit Requirement				20.0 (An. Avg.)			mg/L		Monthly	Grab
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 1 Mon. Site No. EFF-01	Permit Requirement				60.0 (Max.)	45.0 (Wk. Avg.)	30.0 (Mo. Avg.)	mg/L		Monthly	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-01	Permit Requirement						60.0 (Max.)	mg/L		Monthly	Grab
Coliform, Fecal	Sample Measurement										
PARM Code 74055 Y Mon. Site No. EFA-01	Permit Requirement				200 (An. Avg.)			#/100mL		Monthly	Grab
Coliform, Fecal	Sample Measurement										
PARM Code 74055 A Mon. Site No. EFA-01	Permit Requirement				200 (Mo. Geo. Mn.)	800 (Max.)		#/100mL		Monthly	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-01	Permit Requirement				6.0 (Min.)		8.5 (Max.)	s.u.		5 Days/Week	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Greentree South WWTP

MONITORING GROUP

R-001

PERMIT NUMBER: FLA014308-007-DW3P

NUMBER:

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Chlorine, Total Residual(For Disinfection)	Sample Measurement										
PARM Code 50060 A Mon. Site No. EFA-01	Permit Requirement				0.5 (Min.)			mg/L		5 Days/Week	Grab
Nitrogen, Nitrate, Total (as N)	Sample Measurement										
PARM Code 00620 1 Mon. Site No. EFF-01	Permit Requirement					12.0 (Max.)		mg/L		Monthly	Grab
Flow	Sample Measurement										
PARM Code 50050 Y Mon. Site No. FLW-01	Permit Requirement		0.020 (Three MoAvg.)	MGD						5 Days/Week	Meter
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. FLW-01	Permit Requirement	Report (Mo.Avg.)	Report (Qt.Avg.)	MGD						5 Days/Week	Meter
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 P Mon. Site No. CAL-01	Permit Requirement					Report (Mo.Avg.)		percent		Monthly	Calculated
BOD, Carbonaceous 5 day, 20C(Influent)	Sample Measurement										
PARM Code 80082 Q Mon. Site No. INF-01	Permit Requirement					Report (Max.)		mg/L		Monthly	Grab
Solids, Total Suspended(Influent)	Sample Measurement										
PARM Code 00530 Q Mon. Site No. INF-01	Permit Requirement					Report (Max.)		mg/L		Monthly	Grab
Biosolids transferred	Report sum of haulings										
PARM Code B0007 Mon. Site No. RMP-1	Permit Requirement							dry tons		Monthly	Calculated

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DAILY SAMPLE RESULTS - PART B

Permit Number:
Monitoring Period

FLA014308-007-DW3P

From: _____ To: _____

Facility: Greentree South WWTP

	Chlorine, Total Residual (For Disinfection) mg/L	Coliform, Fecal #/100mL	BOD, Carbonaceous 5 day, 20C mg/L	Nitrogen, Nitrate, Total (as N) mg/L	Solids, Total Suspended mg/L	pH s.u.	Flow MGD	BOD, Carbonaceous 5 day, 20C (Influent) mg/L	Solids, Total Suspended (Influent) mg/L	Biosolids transferred (dry tons)
Code	50060	74055	80082	00620	00530	00400	50050	80082	00530	B0007
Mon. Site	EFA-01	EFA-01	EFF-01	EFF-01	EFF-01	EFF-01	FLW-01	INF-01	INF-01	RMP-1
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
Total										
Mo. Avg.										

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

GROUNDWATER MONITORING REPORT - PART D

Facility Name: **Greentree South WWTP**
 Permit Number: **FLA014308-007-DW3P**
 County: **Hendry**
 Office: **South District**

Monitoring Well ID: **MWC-24593**
 Well Type: **Compliance**
 Description: **GT-1**
 Re-submitted DMR: ☐

Report Frequency: **Semi-annually**
 Program: **Domestic**

Monitoring Period From: _____ To: _____

Date Sample Obtained: _____

Time Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Frequency of Analysis	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	ft	In Situ	Semi-annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Semi-annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Semi-annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Semi-annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Semi-annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Semi-annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Semi-annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Semi-annually				
Coliform, Total	74056		4	#/100mL	Grab	Semi-annually				
pH	00400		6.5-8.5	s.u.	In Situ	Semi-annually				
Sulfate, Total	00945		250	mg/L	Grab	Semi-annually				
Turbidity	00070		Report	NTU	Grab	Semi-annually				
Temperature (C), Water	00010		Report	Deg C	In Situ	Semi-annually				
Specific Conductance	00095		Report	umhos/cm	In Situ	Semi-annually				
Oxygen, Dissolved (DO)	00300		Report	mg/L	In Situ	Semi-annually				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENTS AND EXPLANATION (Reference all attachments here):

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g. highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.

**STATEMENT OF BASIS
FOR
STATE OF FLORIDA DOMESTIC WASTEWATER FACILITY PERMIT**

PERMIT NUMBER: FLA014308-007

FACILITY NAME: Greentree South WWTP

FACILITY LOCATION: State Road 29 South, Labelle, FL 33935
Hendry County

NAME OF PERMITTEE: Greentree South

PERMIT WRITER: Barbara J. Skates

1. BASIS FOR PERMIT LIMITATIONS AND MONITORING REQUIREMENTS

This facility is authorized to direct reclaimed water to Reuse System R-001, a rapid infiltration basin system, based on the following:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
BOD, Carbonaceous 5 day, 20C	mg/L	Max	20.0	Annual Average	62-610.510 & 62-600.740(1)(b)1.a. FAC
		Max	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
		Max	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
Solids, Total Suspended	mg/L	Max	20.0	Annual Average	62-610.510 & 62-600.740(1)(b)1.a. FAC
		Max	30.0	Monthly Average	62-600.740(1)(b)1.b. FAC
		Max	45.0	Weekly Average	62-600.740(1)(b)1.c. FAC
		Max	60.0	Single Sample	62-600.740(1)(b)1.d. FAC
Coliform, Fecal	#/100mL	Max	200	Annual Average	62-610.510 & 62-600.440(4)(c)1. FAC
		Max	200	Monthly Geometric Mean	62-600.440(4)(c)2. FAC
		Max	800	Single Sample	62-600.440(4)(c)4. FAC
pH	s.u.	Min	6.0	Single Sample	62-600.445 FAC
		Max	8.5	Single Sample	62-600.445 FAC
Chlorine, Total Residual (For Disinfection)	mg/L	Min	0.5	Single Sample	62-610.510 & 62-600.440(4)(b) FAC
Nitrogen, Nitrate, Total (as N)	mg/L	Max	12.0	Single Sample	62-610.510(1) FAC

Other Limitations and Monitoring Requirements:

Parameter	Units	Max/ Min	Limit	Statistical Basis	Rationale
Flow	MGD	Max	0.025	Quarterly Average	62-600.400(3)(b) FAC
		Max	Report	Monthly Average	62-600.400(3)(b) FAC
Percent Capacity, (TMADF/Permitted Capacity) x 100	percent	Max	Report	Monthly Average	62-600.405(4) FAC
BOD, Carbonaceous 5 day, 20C (Influent)	mg/L	Max	Report	Single Sample	62-601.300(1) FAC
Solids, Total Suspended (Influent)	mg/L	Max	Report	Single Sample	62-601.300(1) FAC
Monitoring Frequencies and Sample Types	-	-	-	All Parameters	62-601 FAC & 62-699 FAC and/or BPJ of permit writer
Sampling Locations	-	-	-	All Parameters	62-601, 62-610.412, 62-610.463(1), 62-610.568, 62-610.613 FAC and/or BPJ of permit writer
Biosolids transfer	dry tons	-	Report	Sum of Haulings	62-640.880(4) FAC

Department of Environmental Protection
South District Office
2295 Victoria Avenue, Suite 364-W
P. O. Box 2549
Fort Myers, Florida 33902-2549

CERTIFICATION


PA FILE NO: FLA014308-007-DW3P

Greentree South WWTP

I HEREBY CERTIFY that the engineering features described in the above referenced application provide reasonable assurance of compliance with applicable provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Title 62, or Department policy. However, I have not evaluated and I do not certify aspects of the proposal outside of my area of expertise (including, but not limited to, the electrical, mechanical, structural, and geological features).

Name: _____ Gary A. Maier _____ P.E.

Certification No.: 44732



U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

OFFICIAL USE

Postage \$
 Certified Fee
 Return Receipt Fee
 (Endorsement Required)
 Restricted
 (Endorsement)

Postmark
 Here

Total Price
PAMELA BORTON
MANAGING AGENT
GREENTREE
P O BOX 2837
LABELLE FL 33975

Sent To
 Street, Apt.
 or PO Box
 City, State

PS Form 3800, August 2006

See Reverse for Instructions

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mail piece or, on the front if space permits.

1. Article Addressed to:

PAMELA BORTON
MANAGING AGENT
GREENTREE
P O BOX 2837
LABELLE FL 33975

2. Article
 (Tracking)

7010 1870 0001 8477 2605

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X *[Signature]*

☒ Agent
☐ Addressee

B. Received by (Printed Name)

[Signature]

C. Date of Delivery

D. Is delivery address different from item 1? ☐ Yes
 If YES, enter delivery address below: ☐ No

APR 26 2011

3. Service Type

☒ Certified Mail ☐ Express Mail
☐ Registered ☒ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee)

☐ Yes

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540