



FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION GROUND WATER MANAGEMENT

SPRINGS - SAMPLING FIELD SHEET

STATION INFORMATION

SPRING NAME	<u>Cypress Spring</u>	STATION ID		DATE	<u>9/25/13</u>	TIME(EST)	<u>12:40</u> (24HR)
SAMPLE DEPTH(meters)	<u>7.5</u>	BOTTOM VISIBLE?	☒ YES ☐ NO	WEATHER:	☐ CLEAR ☒ PARTLY-CLOUDY ☐ CLOUDY ☐ RAIN		

WATER QUALITY MEASUREMENTS

Analytes collected for this site are as listed per the container inventory, including any QA/QC samples

CHEMICAL STABILITY MONITORING

☒ YES ☐ NO

Time	Temperature (°C)	Conductivity (µs/cm)	DO (% sat)	DO (mg/l)	pH (su)
12:31	20.97	228	49.8	4.43	6.86
12:35	20.97	228	49.1	4.36	6.85
12:39	21.00	228	48.7	4.34	6.84

Stability Criteria: Temp $\pm 0.2^{\circ}\text{C}$ Sp Cond $\pm 5\%$ of reading pH ± 0.2 SU DO $\leq 20\%$ or 0.2 mg/l Turbidity $\leq 20\%$ or 5 NTUs

FINAL FIELD READING

Meter ID	Temperature (°C)	Conductivity (µs/cm)	D.O. (% sat)	D.O. (mg/l)	pH (su)
101901	21.02	228	48.5	4.32	6.83

SAMPLE PRESERVATION

Were all samples collected using the appropriate 0.45-micron filter (when applicable) & Preserved with the appropriate type and amount of acid (sulfuric for nutrients & nitric for metals)?

Nitric Acid Lot # 1112030 Sulfuric Acid Lot # 3111072 Filter Lot # 85092C

☒ YES ☐ NO

Were all collected samples properly preserved and stored on wet ice at 4°C within 15 minutes?

☒ YES ☐ NO

RQ LABEL

RQ-2013-09-02-38

SPRG1307

SITE LABEL



CYPRESS SPRING

SPRG1307 CYPRESS SPRING

QA/QC Taken?

YES

☒ NO

TIME(EST) _____ (24HR)

BLANK TYPE

EQUIPMENT

FIELD

PERISTALTIC PUMP ID # 1

QA/QC LABEL (if applicable)

(QA/QC ID)

COMMENTS

Water level is high - water up to deck height.

SAMPLER NAMES & SIGNATURES (All team members present)

Edgar Wade

Edgar Wade

Gary Maudley

Gary Maudley