

Bonita Springs
Utilities, Inc.

February 3, 2012

Florida Department of Environmental Protection
PO Box 2549
Fort Myers, FL 33902-2549


Re: Bonita Springs Utilities WWRF
Permit # FLA014443
Residuals Management

This letter is written to verify that all residuals generated at the Bonita Springs Utilities West Water Reclamation Facility were pumped to the Bonita Springs Utilities East Water Reclamation Facility for treatment to Class AA standards for the entire year 2011. No residuals were directly hauled from the WWRF for land application. This letter is written per our Permit condition 42 in the Residual Management Requirements.

Sincerely,



Andy Koebel
Director of Operations



Florida Department of Environmental Protection

Twin Towers Office Bldg, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400

Received

FEB 13 2012

BSHW

Residuals Annual Summary

RECEIVED

Part I - Facility Information

FACILITY NAME: Bonita Springs Utilities Inc EWRF FACILITY ID: 00012343

FEB 14 2012

MAILING ADDRESS: 11860 East Terry St
Bonita Springs FL 34135
MONITORING PERIOD -- From: JAN 1, 2011 To: DEC 31, 2011
~~Dept. of Environmental Protection~~
~~Domestic Waste Section~~

Total Quantity of Residuals ^{Marketed} ~~Applied~~ During Reporting Period: 584.92 dry tons

Total Number of Residuals Land Application Sites Used During Reporting Period: 0 (Parts II and III should address all residuals land application sites used)

Update of Residuals Characteristics (arithmetic average of all samples taken pursuant to Rule 62-640.650(1), F.A.C., during the reporting period):

Parameter	Units*	Ceiling Limits for Class A and B	Concentration	Parameter (continued)	Units*	Ceiling Limits for Class A and B	Concentration
Total Nitrogen	%	N/A	2.63	Copper	mg/kg	4300	388
Total Phosphorus	%	N/A	0.82	Lead	mg/kg	840	15.8
Total Potassium	%	N/A	0.30	Mercury	mg/kg	57	1.1
Total Solids	%	N/A	92.7	Molybdenum	mg/kg	75	11.26
pH	std. units	N/A	5.99	Nickel	mg/kg	420	12.65
Arsenic	mg/kg	75	1.88	Selenium	mg/kg	100	9.04
Cadmium	mg/kg	85	1.54	Zinc	mg/kg	7500	1107.8

*All units are in a dry weight basis except for total solids and pH. All sampling and analysis shall be conducted pursuant to Title 40 Code of Federal Regulations, Section 503.8, and the POTW Sludge Sampling and Analysis Guidance Document.

N/A = not applicable

Pathogen Reduction Class (Rule 62-640.600(1), F.A.C.): ☒ A ☐ B

EPA Vector Attraction Reduction Option (Rule 62-640.600(2), F.A.C.):

☐ 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5
☐ 6 ☐ 7 ☒ 8 ☐ 9 ☐ 10

Certification

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT (Type or Print) Clifford W. Morris Chief Operator BSW EWRF	TELEPHONE NO. 239-495-4247
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Clifford W. Morris</i>	DATE (YY/MM/DD) 12/02/01

* ALL SOLIDS WENT TO GLADES COUNTY
(WEDGORTH'S INC)