

NEW/RENEWAL NPDES
APPLICATION ROUTE SHEET
(DO NOT HOLD)

1. Permits Clerk:

Facility Name:

Gulf Power
Scholz Electric Generating Plant

Renewal: ☒

NPDES No. *FL0002283*

Expiration Date:

10/31/84

New: ☐

Application Rec'd Date:

5/3/84

Application Timely ☒

Yes

No

N/A

Initial/Date:

5/5/84 MB

2. Chief, SAPU:

Permit Writer Assigned:

Yvonne Martin

Initial/Date:

RC 5/5

3. Permit Writer:

Correct Signature ☒

Yes

No

Application Complete: ☐

Yes

No

If no, list items needed:

1. Form 1 - Item VIII - B, C

2. Form 2C - II.A. - water balance on line drawing

3. Form 2C - II.B. avg flow for 003 x 004

4. Form 2C - II.C. flow, volume, duration data

Initial/Date:

5/9/84

B. Form 2C - IV

C. Form 2C - Item V.C. pg. 46 → 49
not complete

4. Permits Clerk

If the application is not complete, return it to the applicant
with the appropriate form letter listing the item(s) needed.

Form 2C - V.

Part A

b. COD < 5 mg/l (20)

Part B

i. Phosphorus < .01 (.05)

n. Surfactants < .01 (.10)

Part C

13M Zinc < 5 ug/l (10)

9V Chloroethane < 5 ug (10)

10V 2-Chloroethylvinyl Ether < 5 ug (10)

12V Dichloro bromo methane < 5 ug (10)

20V Methyl Bromide < 5 ug (10)

21V Methyl Chloride < 5 ug (10)

31V Vinyl Chloride < 5 ug (10)

7A 4-Nitrophenol < 25 ug (50)

Scholz

Green is detection level
Meth 624/625 on toxicity
screening