

OCT 19 1993

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

REF: 4WM-WPEB

Mr. M. L. Gilchrist
Manager of Fuel and Environmental Affairs
Gulf Power Corporation
500 Bayfront Parkway
Post Office Box 1151
Pensacola, Florida 32520-0328

RE: Minor Permit Modification
Scholz Electric Generating Plant
NPDES Permit No. FL0002283

Dear Mr. Gilchrist:

In accordance with Title 40, Code of Federal Regulations (C.F.R.) Section 122.63, the U.S. Environmental Protection Agency, Region IV, is making a minor modification to the referenced National Pollutant Discharge Elimination System (NPDES) permits in order to change the description of the discharge contained in Page I-5. The following change has been incorporated:

Page I-5, Section D.1.: During the period beginning on the effective date of this permit and lasting through the expiration date of this permit, the permittee is authorized to discharge sanitary wastes from outfall 004^{1/} to outfall 002.

Please replace page I-5 of your permit with the enclosed page. If you have any questions concerning this modification, please contact Ms. Gracy R. Danois at the above address or at 404/347-3012, ext. 2946.

Sincerely yours,

W. Ray Cunningham, Director
Water Management Division

Enclosure

cc: Florida Department of Environmental Protection

bc: WPEB, Enforcement Section

Sign & Date: Danois GRD 10/6/93 Moore ABM 10/8 Patrick PR 10/8

Outen VO Scarbrough _____

GRD:grd:FL2283:10/04/93:disk FY-94

JHS
10/8/93

PART I

D. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS - FINAL

1. During the period beginning on the effective date and lasting through the expiration date of this permit, the permittee is authorized to discharge sanitary wastes from outfall 004^{1/} to outfall 002.

Such discharges shall be limited and monitored by the permittee as specified below:

<u>EFFLUENT CHARACTERISTIC</u>	<u>DISCHARGE LIMITATIONS</u>		<u>MONITORING REQUIREMENTS</u>	
	<u>Daily Maximum</u>	<u>Daily Average</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow, MGD	Report	Report	1/day	Representative
Biochemical Oxygen Demand, 5-Day, mg/l	60.0	30.0	1/Quarter	Grab
Total Suspended Solids, mg/l	60.0	30.0	1/Quarter	Grab

2. Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s): nearest accessible point after final treatment but prior to actual discharge or mixing with the receiving waters.

- ^{1/} Serial number assigned to an internal waste stream for the purpose of monitoring and identification.

Minor Modification Date OCT 19 1993