



Department of Environmental Protection

Best Available Copy

Lawton Chiles
Governor

Panama City Branch Office
2363 Jenks Avenue
Panama City, FL 32405

Virginia B. Wetherell
Secretary

August 31, 1994

M. L. Gilchrist, Manager
Gulf Power Company
P.O. Box 1151
Pensacola, Florida 32520-0328

RE: **INDUSTRIAL WASTEWATER TREATMENT INSPECTION**
Facility: Scholz Electric Generating Station IO32-189371
County : Jackson

Dear Mr. Gilchrist:

On 06/28/94, Mr. Robert Taylor of this Department conducted an inspection of the wastewater treatment facility.

I would appreciate your notifying us within 15 days of receipt of this letter as to what actions you have taken to address the "Inspector Comments", if any, noted on the attached inspection report form. If you have any questions, please contact Mr. Robert Taylor of our Panama City Branch Office at (904) 872-4375.

Sincerely,

Gary L. Shaffer
Gary L Shaffer
Branch Manager

GLS:rt:mlf
Attachment
cc: Rick Bradburn/DEP Pensacola
Pat Parker/Scholz EGP

Permit #	2083	File	Cmp	Type	ILW
FLOO		Folder			
Permittee	Scholz Elect.				
INITIAL & ROUTE	MS	Fils			
District cc:					

FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

WASTEWATER COMPLIANCE INSPECTION REPORT

FACILITY AND INSPECTION INFORMATION

@ = OPTIONAL

Name and Physical Location of Facility
SCHOLZ ELECTRIC PLANT
COUNTY ROAD 271 @ RT 90
SNEADS, FL

GMS ID:
1032P37371

County

Entry Date/Time
JACKSON

06/28/94

Phone
(904)444-6236

@ Exit Date/Time
06/28/94

Name(s) of Field Representative(s)
PAT PARKER
RAY WELDEN

Title
PLANT MGR.
SUPERVISOR

Phone
(904)444-6236
(904)444-6236

Name/Address of Permittee or Rep.
M.L. GILCHRIST
GULF POWER CO., P.O. BOX 1161
PENSACOLA, FLORIDA 32520-0328

Title
MGR.

Phone
(904)444-6236

@ Operator Cert. #

Inspection Type:
CSI/CEI

Samples Taken (Y/N):
N

@ Samples ID#:
N/A

Samples Split (Y/N):
N

Domestic: Industrial: X

Were Photos Taken (Y/N): N

@ Log Vol.:

@ Page:

In Compliance With Permit Conditions (Y/N): Y

Recommended Actions: SEE INSPECTION COMMENTS

Name(s) and Signature(s) of Inspector(s)

Dist. Office/Phone Number
PCBO (904) 872-4375

Date
06/28/94

@ Signature of Reviewer

District Office/Phone Number

Date

FACILITY COMPLIANCE AREA EVALUATED

S = Satisfactory; M = Marginal; U = Unsatisfactory;
Blank = Not Evaluated; * See Comments

S 1. Permit# 1032-189371	S 6. Sampling	S 11. Effluent
> 2. Comp. Schedule	S 7. Self Monitoring	> 12. Groundwater
> 3. Pretreatment	S 8. Site Review	> 13. Disposal Method
S 4. Records	> 9. Flow Measurement	> 14. Residuals Man.
> 5. Laboratory	> 10. Operation & Maint	> 15. Other

Fill This Section For All Surface Water Discharger Inspections (CEI, CBI, CBI, PAI, XSI - RI Optional)

Transaction Code	NPDES NUMBER	YR/MO/DA	Insp Type	Inspector	Fac Type
1 N 2 5 3 F L 0 0 0 2 2 8 3 11	12 9 8 1 1 0 4 17	18 S	19 S	0 2	

Inspection Type (Field 18): A = PAI, B = CBI, C = CEI, S = CSI, X = XSI, R = RI
 Inspector Code (Field 19): S = State, J = Joint EPA/State-EPA Lead, T = Joint State/EPA-State Lead
 Facility Type (Field 20): 1 = Municipal (Publicly Owned), 2 = Industrial and Privately Owned Domestic,
 3 = Agricultural, 4 = Federal

Every other field is self explanatory.

INSPECTION COMMENT

CONDUCTED COMPLIANCE SAMPLING/EVALUATION INSPECTION (SI/CEI) WITH RAY WELDON AND RANDALL TYRE. THE NEW DOMESTIC WASTEWATER AEROBIC PACKAGE PLANT WAS COMPLETE AND OPERATIONAL AT THE TIME OF INSPECTION. ALL DISCHARGE FROM THE WWTP IS TO THE ASH PONDS.

GULF POWER HAS CONSTRUCTED TWO SAMPLING PLATFORMS WHICH HAVE BEEN INSTALLED AT THE SPECIFIED INTAKE AND DISCHARGE LOCATIONS. THE PLATFORMS, MADE OF STAINLESS STEEL, ARE EQUIPED WITH AUTOSAMPLERS. THE PLATFORMS ARE ADJUSTABLE TO ACCOMMODATE CHANGING RIVER CONDITIONS.

LOG BOOKS, RECORDS AND OTHER FIELD DATA WERE INSPECTED. ALL RECORDS WERE CURRENT, PROPERLY FILED AND LOGGED. IT WAS NOTED THAT A DEFINITION OF "PERFORMED DAILY CHECK" SHOULD BE INCLUDED IN THE LOG BOOK TO ENSURE CONSISTENCY. FIELD DATA AND SAMPLES WERE WITHIN PERMIT CONDITIONS.

IN RESPONSE TO SPECIAL CONDITION 17, MURDOCK SEPTIC TANK HAULER, MALONE, IS REMOVING AND DISPOSING OF SLUDGE.