



Florida Department of Environmental Protection

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

Southeast District Office
400 N. Congress Avenue, Suite 200
West Palm Beach, FL 33401
(561) 681-6600

March 10, 2010 ELECTRONIC CORRESPONDENCE

NOTICE OF PERMIT REVISION

Mr. D. Albrey Arrington
Executive Director
Loxahatchee River Environmental Control District
2500 Jupiter Park Drive
Jupiter, Florida 33458
Email: albrey@loxahatcheeriver.org

Dear Mr. Arrington:

RE: Administrative corrections to the Discharge Monitoring Reports (DMRs) for Loxahatchee River Environmental Control District WWTF - DEP Application No. FL0034649-045-DWF/MM.

It has been brought to our attention that the Discharge Monitoring Reports (DMRs) for Permit Number FL0034649-036-DW1P that was issued November 17, 2008 for Loxahatchee River Environmental Control District WWTF contain some errors and do not reflect the monitoring that is required by the permit. Also, the Ground Water Monitoring Well naming convention contained in Section III.5. of the current permit needs to be changed for data entry consistency.

1. The table below replaces the table contained in Section III.5. of the current permit:

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Depth (Feet)	Aquifer Monitored	New or Existing
MWB-01-RB	Riverbend Background Monitoring Well-01. Located @ N end of property, 9.5 ft. S of property line, and 11 ft. W of wall gutter, SW of gate.	16.5	Surficial	Existing
MWC-02-RB	Riverbend Compliance Monitoring Well-02. Located E of tennis court, 7 ft. W, and 8 ft. S of administration building.	16.5	Surficial	Existing
MWB-01-TEQ	Tequesta Country Club Background Monitoring Well-01. Located 100 ft. S of holding pond.	24	Surficial	Existing
MWC-02-TEQ	Tequesta Country Club Compliance Monitoring Well-02. Located immediately N of holding pond.	22	Surficial	Existing
MWC-01-AC	Admiral's Cove Compliance Monitoring Well-01. Located @ NE section of Fairway #2.	20	Surficial	Existing
MWB-02-AC	Admiral's Cove Background Monitoring Well-02. Located @ SW corner of Fredrick Small Road.	21.5	Surficial	Existing

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Depth (Feet)	Aquifer Monitored	New or Existing
MWB-01-TC	Turtle Creek Background Monitoring Well-01. Located S of holding pond, 159 ft NW of golf cart path.	19	Surficial	Existing
MWC-02-TC	Turtle Creek Compliance Monitoring Well-02. Located NW of holding pond, 146 ft. from pump house @ 18th tee, and 66 ft. E of golf cart path.	19	Surficial	Existing
MWB-01-JL	Jonathan's Landing Background Monitoring Well-01. Located SE of Cassekey Island Road.	24.5	Surficial	Existing
MWC-02-JL	Jonathan's Landing Compliance Monitoring Well-02. Located E of holding pond.	23.5	Surficial	Existing
MWC-01-JH	Jupiter Hills Compliance Monitoring Well-01. Located on S side of irrigated area, and N of Tequesta production well site.	10	Surficial	Existing
MWB-03-JH	Jupiter Hills Background Monitoring Well-03. Located @ the NW corner of irrigated area.	14	Surficial	Existing
MWC-01-LC	Loxahatchee Club Compliance Monitoring Well-01. Located @ N side of Pinetree Trail, and N of Jupiter water well #18.	14.25	Surficial	Existing
MWC-02-LC	Loxahatchee Club Compliance Monitoring Well-02. Located @ E side of Maplewood Drive, and SE of Jupiter water well #19.	14.75	Surficial	Existing
MWB-03-LC	Loxahatchee Club Background Monitoring Well-03. Located E of MWC-01, and N of golf course lake.	34	Surficial	Existing
MWC-04-LC	Loxahatchee Club Compliance Monitoring Well-04. Located 1,400 ft S of Toney Penna Drive, and 150 ft. W of Pinetree Trail.	15	Surficial	Existing
MWC-01-IC	Indian Creek Compliance Monitoring Well-01. Located SE and adjacent to retention pond.	21.5	Surficial	Existing
MWC-02-IC	Indian Creek Compliance Monitoring Well-02. Located adjacent to fairway and equidistant between production wells #21 & #22, within their 500-day travel-time contour.	21	Surficial	Existing
MWC-03-IC	Indian Creek Compliance Monitoring Well-03. Located directly E of club house parking lot, and N of entrance road off Central Boulevard.	19	Surficial	Existing

Monitoring Well ID	Alternate Well Name and/or Description of Monitoring Location	Depth (Feet)	Aquifer Monitored	New or Existing
MWB-04-IC	Indian Creek Background Monitoring Well-04. Located N of green #5, and 200 ft. from irrigation area.	20.25	Surficial	Existing
MWC-01-Ab	Abacoa Compliance Monitoring Well-01. Located ~550 ft. E of Height Boulevard, and ~75 ft. S of Frederick Small Road.	19.5	Surficial	Existing
MWC-02-Ab	Abacoa Compliance Monitoring Well-02. Located ~1,450 ft. N of Donald Ross Road, and ~650 ft. W of Palmside Drive.	14.8	Surficial	Existing
MWC-03-Ab	Abacoa Compliance Monitoring Well-03. Located ~450 ft. N of Donald Ross Road and ~100 ft. E of Palmside Drive.	13.1	Surficial	Existing
MWB-04-Ab	Abacoa Background Monitoring Well-04. Located ~600 ft. W of Central Boulevard, and ~100 ft. S of Frederick Small Road.	13.4	Surficial	Existing
MWB-01-BC	Bear's Club Background Monitoring Well-01. Located on Bear's Club Drive, off Donald Ross Road, across from lift station and pump house.	17.2	Surficial	Existing
MWC-02-BC	Bear's Club Compliance Monitoring Well-02. Located in front of lift station on Bear's Club Drive	17.2	Surficial	Existing
MWC-03-BC	Bear's Club Compliance Monitoring Well-03. Located between driveways at #142 Bear's Club Drive, 30 feet past electric boxes.	17.2	Surficial	Existing
MWB-01-JUP	Jupiter CC Background Monitoring Well-01. Located at latitude 26°56'04" N, longitude 80°09'19" W	TBD	Surficial	New
MWC-02- JUP	Jupiter CC Compliance Monitoring Well-02. Located at latitude 26°56'00" N, longitude 80°09'45" W	TBD	Surficial	New
MWC-03- JUP	Jupiter CC Compliance Monitoring Well-03. Located at latitude 26°55'45" N, longitude 80°09'38" W	TBD	Surficial	New

MWB = Background; MWI = Intermediate; MWC = Compliance

2. New Discharge Monitoring Reports are attached and are for your immediate use.

All other applicable conditions included in the original permit remain unchanged. This Notice of Permit Revision shall become a part of the permit and must be attached to the original permit.

The Department's proposed agency action shall become final unless a timely petition for an administrative hearing is filed under sections 120.569 and 120.57 of the Florida Statutes before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the Department's proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received by the clerk) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000.

Petitions by the applicant or any of the parties listed below must be filed within fourteen days of receipt of this written notice. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the notice or within fourteen days of receipt of the written notice, whichever occurs first.

Under section 120.60(3) of the Florida Statutes, however, any person who has asked the Department for notice of agency action may file a petition within fourteen days of receipt of such notice, regardless of the date of publication.

The petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition or request for mediation within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 of the Florida Statutes. Any subsequent intervention (in a proceeding initiated by another party) will be only at the discretion of the presiding officer upon the filing of a motion in compliance with rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information:

- (a) The name, address, and telephone number of each petitioner; the name, address, and telephone number of the petitioner's representative, if any; the Department permit identification number and the county in which the subject matter or activity is located;
- (b) A statement of how and when each petitioner received notice of the Department action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department action;
- (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
- (e) A statement of facts that the petitioner contends warrant reversal or modification of the Department action;
- (f) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief; and
- (g) A statement of the relief sought by the petitioner, stating precisely the action that the petitioner wants the Department to take.


A petition that does not dispute the material facts on which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation under Section 120.573, Florida Statutes, is not available for this proceeding.

Executed in West Palm Beach, Florida.

Mr. D. Albrey Arrington
Executive Director
Loxahatchee River Environmental Control District
Page 5



Linda A. Brien, P.G.
Water Facilities Administrator
Southeast District

Date: 3/9/2010


LAH/TP/ba: FL0034649-045-DWF/MM

ec:

Lisa Self, DEP/SED, Lisa.Self@dep.state.fl.us
Siu-Mei Man, DEP/TLH, SiuMei.Man@dep.state.fl.us


CERTIFICATE OF SERVICE

The undersigned duly designated deputy clerk hereby certifies that this NOTICE OF PERMIT REVISION and all copies were mailed by electronic mail before the close of business on March 10, 2010 to the listed persons.
(Date)

FILING AND ACKNOWLEDGMENT

FILED, on this date, under section 120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Clerk



Date

3/10/2010

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed, mail this report to: Department of Environmental Protection, Southeast District, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401

PERMITTEE NAME: Loxahatchee Environmental Control District

PERMIT NUMBER **FL0034649**

REPORT: Monthly

MAILING ADDRESS: 2500 Jupiter Park Drive
Jupiter, Florida 33458

LIMIT: Final
CLASS SIZE: N/A

GROUP: Domestic

FACILITY: **LRECD WWTF**
LOCATION: 2500 Jupiter Park Drive
Jupiter, Florida 33458

MONITORING GROUP NUMBER: **RMP-B**
MONITORING GROUP DESCRIPTION: Class B Residuals
NO DISCHARGE FROM SITE: ☐

COUNTY: Palm Beach

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading	Units	Quality or Concentration			Units	No.Ex.	Frequency of Analysis	Sample Type
Nitrogen, Sludge, Tot, Dry Wt (as N)	Sample Measurement									
PARM Code 78470 + Mon.Site No. RMP-B	Permit Requirement	Report (Max.)	PER-CENT						Annually	Grab
Phosphorus, Sludge, Tot, Dry Wt (as P)	Sample Measurement									
PARM Code 78478 + Mon.Site No. RMP-B	Permit Requirement	Report (Max.)	PER-CENT						Annually	Grab
Potassium, Sludge, Tot, Dry Wt (as K)	Sample Measurement									
PARM Code 78472 + Mon.Site No. RMP-B	Permit Requirement	Report (Max.)	PER-CENT						Annually	Grab
Arsenic Total, Dry Weight, Sludge	Sample Measurement									
PARM Code 49565 + Mon.Site No. RMP-B	Permit Requirement			75.0 (Max.)			mg/kg		Annually	Composite
Cadmium, Sludge, Tot Dry Weight (as Cd)	Sample Measurement									
PARM Code 78476 + Mon.Site No. RMP-B	Permit Requirement			85.0 (Max.)			mg/kg		Annually	Composite
Copper, Sludge, Tot, Dry Wt. (as Cu)	Sample Measurement									
PARM Code 78475 + Mon.Site No. RMP-B	Permit Requirement			4300.0 (Max.)			mg/kg		Annually	Composite

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Loxahatchee River Environmental Control District WWTF

MONITORING GROUP NUMBER: **RMP-B**

PERMIT NUMBER: FL0034649

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Lead, Dry Weight, Sludge	Sample Measurement										
PARM Code 78468 + Mon.Site No. RMP-B	Permit Requirement				840.0 (Max.)			mg/kg		Annually	Composite
Mercury, Dry Weight, Sludge	Sample Measurement										
PARM Code 78471 + Mon.Site No. RMP-B	Permit Requirement				57.0 (Max.)			mg/kg		Annually	Composite
Molybdenum, Dry Weight, Sludge	Sample Measurement										
PARM Code 78465 + Mon.Site No. RMP-B	Permit Requirement				75.0 (Max.)			mg/kg		Annually	Composite
Nickel, Dry Weight, Sludge	Sample Measurement										
PARM Code 78469 + Mon.Site No. RMP-B	Permit Requirement				420.0 (Max.)			mg/kg		Annually	Composite
Selenium Sludge Solid	Sample Measurement										
PARM Code 61518 + Mon.Site No. RMP-B	Permit Requirement				100.0 (Max.)			mg/kg		Annually	Composite
Zinc, Dry Weight, Sludge	Sample Measurement										
PARM Code 78467 + Mon.Site No. RMP-B	Permit Requirement				7500.0 (Max.)			mg/kg		Annually	Composite
pH	Sample Measurement										
PARM Code 00400 + Mon.Site No. RMP-B	Permit Requirement				Report (Max.)			SU		Annually	Grab
Solids, Total, Sludge, Percent	Sample Measurement										
PARM Code 61553 + Mon.Site No. RMP-B	Permit Requirement				Report (Max.)			Percent		Annually	Grab
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed, mail this report to: Department of Environmental Protection, Southeast District, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401

PERMITTEE NAME: Loxahatchee Environmental Control District

PERMIT NUMBER **FL0034649**

REPORT: Monthly

MAILING ADDRESS: 2500 Jupiter Park Drive
Jupiter, Florida 33458

LIMIT: Final

GROUP: Domestic

CLASS SIZE: N/A

FACILITY: **LRECD WWTF**

MONITORING GROUP NUMBER: **D-002**

LOCATION: 2500 Jupiter Park Drive
Jupiter, Florida 33458

MONITORING GROUP DESCRIPTION: Surface water outfall from Abacoa MSSW Storage Lake System.

NO DISCHARGE FROM SITE: ☐

COUNTY: Palm Beach

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 Y Mon.Site No. STM-01	Permit Requirement	Report (An.Avg.)		MGD						Continuous	Meter
Flow	Sample Measurement										
PARM Code 50050 J Mon.Site No. STM-01	Permit Requirement	Report (Mo.Avg.)		MGD						Continuous	Meter
Duration of Discharge	Sample Measurement										
PARM Code 81381 J Mon.Site No. STM-03	Permit Requirement	Report (Max.)		Minutes						Monthly	Observed
Overflow Use, Occurrences	Sample Measurement										
PARM Code 74062 J Mon.Site No. STM-03	Permit Requirement	Report (Max.)		Occur's/ Month						Monthly	Observed
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here): _____

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed, mail this report to: Department of Environmental Protection, Southeast District, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401

PERMITTEE NAME: Loxahatchee Environmental Control District

PERMIT NUMBER **FL0034649**

REPORT: Monthly

MAILING ADDRESS: 2500 Jupiter Park Drive
Jupiter, Florida 33458

LIMIT: Final

GROUP: Domestic

CLASS SIZE: N/A

FACILITY: **LRECD WWTF**

MONITORING GROUP NUMBER: **D-003**

LOCATION: 2500 Jupiter Park Drive
Jupiter, Florida 33458

MONITORING GROUP DESCRIPTION: Surface water outfall (CS-1) from Jupiter CC MSSW Storage Lake System.

NO DISCHARGE FROM SITE: ☐

COUNTY: Palm Beach

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 Y Mon.Site No. STM-05	Permit Requirement	Report (An.Avg.)		MGD						Continuous	Meter
Flow	Sample Measurement										
PARM Code 50050 J Mon.Site No. STM-05	Permit Requirement	Report (Mo.Avg.)		MGD						Continuous	Meter
Duration of Discharge	Sample Measurement										
PARM Code 81381 J Mon.Site No. STM-06	Permit Requirement	Report (Max.)		Minutes						Monthly	Observed
Overflow Use, Occurrences	Sample Measurement										
PARM Code 74062 J Mon.Site No. STM-06	Permit Requirement	Report (Max.)		Occur's/ Month						Monthly	Observed
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here): _____

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed, mail this report to: Department of Environmental Protection, Southeast District, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401

PERMITTEE NAME: Loxahatchee Environmental Control District

PERMIT NUMBER **FL0034649**

REPORT: Monthly

MAILING ADDRESS: 2500 Jupiter Park Drive
Jupiter, Florida 33458

LIMIT: Final

GROUP: Domestic

CLASS SIZE: N/A

FACILITY: **LRECD WWTF**

MONITORING GROUP NUMBER: **D-004**

LOCATION: 2500 Jupiter Park Drive
Jupiter, Florida 33458

MONITORING GROUP DESCRIPTION: Surface water outfall (CS-2) from Jupiter CC MSSW Storage Lake System.

NO DISCHARGE FROM SITE: ☐

COUNTY: Palm Beach

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Duration of Discharge	Sample Measurement										
PARM Code 81381 J Mon.Site No. STM-06	Permit Requirement	Report (Max.)		Minutes						Monthly	Observed
Overflow Use, Occurrences	Sample Measurement										
PARM Code 74062 J Mon.Site No. STM-06	Permit Requirement	Report (Max.)		Occur's/ Month						Monthly	Observed
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here): _____

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When completed, mail this report to: Department of Environmental Protection, Southeast District, 400 North Congress Avenue, Suite 200, West Palm Beach, Florida 33401

PERMITTEE NAME: Loxahatchee Environmental Control District

PERMIT NUMBER **FL0034649**

REPORT: Monthly

MAILING ADDRESS: 2500 Jupiter Park Drive
Jupiter, Florida 33458

LIMIT: Final

GROUP: Domestic

CLASS SIZE: N/A

FACILITY: **LRECD WWTF**

MONITORING GROUP NUMBER:

R-001, including plant influent

LOCATION: 2500 Jupiter Park Drive
Jupiter, Florida 33458

MONITORING GROUP DESCRIPTION: Slow-rate public access reuse system.

NO DISCHARGE FROM SITE: ☐

COUNTY: Palm Beach

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 Y Mon.Site No. PPI-01=[INF-01]-[EFF-01]	Permit Requirement	11.0 (An.Avg.)		MGD						Continuous	Calculated
Flow	Sample Measurement										
PARM Code 50050 J Mon.Site No. PPI-01=[INF-01]-[EFF-01]	Permit Requirement	Report (Mo.Avg.)		MGD						Continuous	Calculated
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon.Site No. EFA-01	Permit Requirement				20.0 (An.Avg.)			mg/L		5 Days/Week	24-hr. FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 A Mon.Site No. EFA-01	Permit Requirement				30.0 (Mo.Avg.)	45.0 (Wk.Avg.)	60.0 (Max.)	mg/L		5 Days/Week	24-hr. FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 B Mon.Site No. EFB-01	Permit Requirement				5.0 (Max.)			mg/L		Daily	Grab
Turbidity	Sample Measurement										
PARM Code 00070 B Mon.Site No. EFB-01	Permit Requirement				Report (Max.)			NTU		Continuous	Meter

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here): _____

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Loxahatchee River Environmental Control District MONITORING GROUP R-001, including plant influent PERMIT NUMBER: **FL0034649**
 NUMBER:

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
pH	Sample Measurement										
PARM Code 00400 A Mon.Site No. EFA-01	Permit Requirement				6.0 (Min.)	8.5 (Max.)		SU		Continuous	Meter
Coliform, Fecal, % less than detection	Sample Measurement										
PARM Code 51005 A Mon.Site No. EFA-01	Permit Requirement				75 (Min.)			Percent		Daily	Grab
Coliform, Fecal	Sample Measurement										
PARM Code 74055 A Mon.Site No. EFA-01	Permit Requirement				25 (Max.)			#/100 mL		Daily	Grab
Total Residual Chlorine (For Disinfection)	Sample Measurement										
PARM Code 50060 A Mon.Site No. EFA-01	Permit Requirement				1.0 (Min.)			mg/L		Continuous	Meter
Nitrogen, Total	Sample Measurement										
PARM Code 00600 A Mon.Site No. EFA-01	Permit Requirement				Report (Max.)			mg/L		Weekly	24-hr. FPC
Phosphorus, Total (as P)	Sample Measurement										
PARM Code 00665 A Mon.Site No. EFA-01	Permit Requirement				Report (Max.)			mg/L		Weekly	24-hr. FPC
Flow	Sample Measurement										
PARM Code 50050 P Mon.Site No. INF-01	Permit Requirement	11.0 (An.Avg.)		MGD						Continuous	Meter
Flow	Sample Measurement										
PARM Code 50050 G Mon.Site No. INF-01	Permit Requirement	Report (Mo.Avg.)		MGD						Continuous	Meter
Percent Capacity, (TMADF/Permitted Capacity) x 100	Sample Measurement										
PARM Code 00180 P Mon.Site No. OTH-01	Permit Requirement				Report (Max.)			Minutes		Monthly	Calculated
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 G Mon.Site No. INF-02	Permit Requirement	Report (Max.)		mg/L						5 days/week	24-hr. FPC

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Loxahatchee River Environmental Control District MONITORING GROUP NUMBER: R-001, including plant influent PERMIT NUMBER: **FL0034649**

MONITORING PERIOD From: _____ To: _____

Solids, Total Suspended	Sample Measurement										
PARM Code 00530 G Mon.Site No. INF-02	Permit Requirement				Report (Max.)			mg/L		5 days/week	24-hr. FPC
Flow, (Concentrate)	Sample Measurement										
PARM Code 50050 P Mon.Site No. FLW-02	Permit Requirement	Report (Mo.Avg.)	3.0 MaxDaily	MGD						Continuous	Meter
Solids, Total Suspended, (Blend)	Sample Measurement										
PARM Code 00530 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			mg/L		Weekly	Grab
pH, (Blend)	Sample Measurement										
PARM Code 00400 1 Mon.Site No. EFF-05	Permit Requirement				Report (Min.)	Report (Max.)		SU		Weekly	Grab
Specific Conductance, (Blend)	Sample Measurement										
PARM Code 00095 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			umho/cm		Continuous	Meter
Fluoride, Total (as F), (Blend)	Sample Measurement										
PARM Code 00951 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			mg/L		Weekly	Grab
Blend Ratio	Sample Measurement										
PARM Code 51133 1 Mon.Site No. FLW-02	Permit Requirement	Report (Min.)		Ratio						Continuous	Calculated
Sodium Adsorption Ratio (SAR), (Blend)	Sample Measurement										
PARM Code 00931 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			Ratio		Weekly	Calculated
Sodium, Total Recoverable, (Blend)	Sample Measurement										
PARM Code 00923 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			mg/L		Weekly	Grab
Magnesium, Total Recoverable, (Blend)	Sample Measurement										
PARM Code 00921 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			mg/L		Weekly	Grab
Calcium, Total Recoverable, (Blend)	Sample Measurement										
PARM Code 00918 1 Mon.Site No. EFF-05	Permit Requirement				Report (Max.)			mg/L		Weekly	Grab

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: Loxahatchee River Environmental Control District MONITORING GROUP NUMBER: **R-001, including plant influent** PERMIT NUMBER: **FL0034649**

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Chloride (as Cl), (Blend)	Sample Measurement										
PARM Code 00940 1 Mon.Site No. EFF-05	Permit Requirement					Report (Day.Max.)		mg/L		Weekly	Grab
TSS using a TSS meter	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFB-01	Permit Requirement				Report (Max.)			mg/L		Continuous	Meter
Solids, Total Dissolved (TDS)	Sample Measurement										
PARM Code 70295 1 Mon. Site No. EFF-05	Permit Requirement				1,500 (Max.)			mg/L		Weekly	Grab
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Loxahatchee Environmental Control District
MAILING ADDRESS: 2500 Jupiter Park Drive
Jupiter, FL 33458

PERMIT NUMBER **FL0034649**

LIMIT: Final
CLASS SIZE: Major
REPORT: Monthly
GROUP: Domestic

FACILITY: **LRECD WWTF**
LOCATION: 2500 Jupiter Park Drive
Jupiter, FL 33458

MONITORING GROUP
NUMBER: U-001
MONITORING GROUP DESC: Underground injection well system (1 well).

COUNTY: Palm Beach

NO DISCHARGE FROM ☐
SITE:
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon.Site No. EFF-01	Permit Requirement	18.0 (Hr.Peak)	Report (Mo.Avg.)	MGD						Continuous	Meter
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 Y Mon.Site No. EFF-02	Permit Requirement				20.0 (An.Avg.)			mg/L		5 Days/Week	24-hr. FPC
BOD, Carbonaceous 5 day, 20C	Sample Measurement										
PARM Code 80082 1 Mon.Site No. EFF-02	Permit Requirement				30.0 (Mo.Avg.)	45.0 (Wk.Avg.)	60.0 (Max.)	mg/L		5 Days/Week	24-hr. FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon.Site No. EFF-02	Permit Requirement				20.0 (An.Avg.)			mg/L		5 Days/Week	24-hr. FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon.Site No. EFF-02	Permit Requirement				30.0 (Mo.Avg.)	45.0 (Wk.Avg.)	60.0 (Max.)	mg/L		5 Days/Week	24-hr. FPC
pH	Sample Measurement										
PARM Code 00400 1 Mon.Site No. EFF-02	Permit Requirement				6.0 (Min.)	8.5 (Max.)		SU		Continuous	Meter

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here): _____

DAILY SAMPLE RESULTS - PART B

PERMIT NUMBER **FL0034649**

Facility:

LRECD WWTF

Monitoring Period

From: _____ To: _____

Sampling Point(s): **EFA-01** (Eff. after chlorination)

	CBOD5 (mg/L), after chlorination	pH (Max), after chlorination	pH (Min), after chlorination	Fecal Coliform Bacteria (#/100 mL), after chlorin.	Fecal Coliform, % < detect. (Percent), after chlorin.	Enterococci (#/100 mL), after chlorination	Nitrogen, Total (mg/L), after chlorination	Phosphorus (mg/L), after chlorination	TRC (For Disinfect.) (mg/L), after chlorination		
Code	80082	00400	00400	74055	51005	31639	00600	00665	50060		
Mon. Site	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01	EFA-01		
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

DAILY SAMPLE RESULTS - PART B

PERMIT NUMBER **FL0034649**

Monitoring Period From: _____ To: _____

Facility:

LRECD WWTF

Sampling Point(s): **EFB-01** (Eff. after filtration & before chlor.),
EFD-01 (Eff after dechlor.), **EFF-01** (Meter @ injec. well) , and
EFF-02 (Screen before injec. well)

	TSS (mg/L), after filtration & before chlorin.	Turbidity (NTU), after filtration & before chlorin.	TSS using TSS meter (mg/L)	TRC (For Dechlor.) (mg/L), after dechlorin.	Flow (MGD), to Injection Well	CBOD5 (mg/L), to Injection Well	TSS (mg/L), to Injection Well	pH (Max), to Injection Well	pH (Min), to Injection Well
Code	00530	00070	00530	50060	50050	80082	00530	00400	00400
Mon. Site	EFB-01	EFB-01	EFB-01	EFD-01	EFF-01	EFF-02	EFF-02	EFF-02	EFF-02
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
Total									
Mo. Avg.									

PLANT STAFFING:

Day Shift Operator	Class: _____	Certificate No: _____	Name: _____
Evening Shift Operator	Class: _____	Certificate No: _____	Name: _____
Night Shift Operator	Class: _____	Certificate No: _____	Name: _____
Lead Operator	Class: _____	Certificate No: _____	Name: _____

DAILY SAMPLE RESULTS - PART B

PERMIT NUMBER **FL0034649**

Monitoring Period From: _____ To: _____

Facility:

LRECD WWTF

Sampling Point(s): **INF-01** (Inf. @ Parshall Flume), **INF-02** (Inf. @ common header before bar screen), **OTH-01** (Calc.), **PPI-01**=[**INF-01**]-[**EFF-01**] (Inf. to R-001), **STM-01** (Inf. to Abacoa MSSW), and **STM-03** (Discharge from Abacoa MSSW).

	Flow (MGD), Influent	CBOD5 (mg/L), Influent	TSS (mg/L), Influent	Percent Capa., (TMADF/Perm Capa.) x 100 (Percent)	Flow (MGD), Influent, to Reuse System R-001	Flow (MGD), Influent to Abacoa MSSW	Duration of Discharge (Minutes), from Abacoa MSSW	Overflow Use, Occurrences (Occ./Mo.), from Abacoa MSSW
Code	50050	80082	00530	00180	50050	50050	81381	74062
Mon. Site	INF-01	INF-02	INF-02	OTH-01	PPI-01=[INF-01]-[EFF-01]	STM-01	STM-03	STM-03
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
Total								
Mo. Avg.								

PLANT STAFFING:

Day Shift Operator Class: _____ Certificate No: _____ Name: _____

Evening Shift Operator Class: _____ Certificate No: _____ Name: _____

Night Shift Operator Class: _____ Certificate No: _____ Name: _____

Lead Operator Class: _____ Certificate No: _____ Name: _____

DAILY SAMPLE RESULTS - PART B

PERMIT NUMBER

FL0034649

Facility:

LRECD WWTF

Monitoring Period

From: _____ To: _____

Sampling Point(s): **EFF-05** (Concentrate/reclaimed water blend to R-001).

	Calcium, Total Recoverable (mg/L)	Chloride (as Cl) (mg/L)	Fluoride, Total (as F) (mg/L)	Magnesium, Total Recoverable (mg/L)	pH (Max)	pH (Min)	Sodium Adsorption Ratio (RATIO)	Sodium, Total Recoverable (mg/L)	TSS (mg/L)	Solids, Total Dissolved (TDS) (mg/L)	Specific Conductance (umho/cm)
Code	00918	00940	00951	00921	00400	00400	00931	00923	00530	70295	00095
Mon. Site	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05	EFF-05
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
Total											
Mo. Avg.											

DAILY SAMPLE RESULTS - PART B

PERMIT NUMBER **FL0034649**

Monitoring Period From: _____ To: _____

Facility:

LRECD WWTF

Sampling Point(s): **FLW-01** (Reclaim water to blend going to Reuse), **FLW-02** (Concentrate to blend going to Reuse), **FLW-03** (Blend going to Reuse)

	Flow (MGD), of Concentrate to Blend going to Reuse	Flow (MGD), of Blend to Reuse	Blend Ratio (RATIO), Effluent: Concentrate to Reuse				
Code	50050	50050	51133				
Mon. Site	FLW-02	FLW-03	FLW-01 & FLW-02				
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
Total							
Mo. Avg.							

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-01-RB
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Riverbend Background Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (yy/mm/dd)

COMMENTS AND EXPLANATION (Reference all attachments here)

GROUND WATER MONITORING WELL REPORT - PART D

County: Palm Beach
 Facility Name: LRECD WWTF
 Permit Number: FL0034649

Monitoring Well ID: MWC-02-RB
 Well Type: Compliance
 Description: Riverbend Compliance Monitoring Well-02

Monitoring Period From: _____ To: _____

Date Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-01-TEQ
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Tequesta CC Background Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-TEQ
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Tequesta CC Compliance Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	☐ Yes ☐ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-01-AC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Admiral's Cove Compliance Monitoring Well-01
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-02-AC
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Admiral's Cove Background Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-01-TC
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Turtle Creek Background Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-TC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Turtle Creek Compliance Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-01-JL
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Jonathan's Landing Background Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-JL
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Jonathan's Landing Compliance Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	☐ Yes ☐ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-01-JH
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Jupiter Hills Compliance Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-03-JH
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Jupiter Hills Background Monitoring Well-03
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-01-LC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Loxahatchee Club Compliance Monitor Well-01
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-LC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Loxahatchee Club Compliance Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-03-LC
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Loxahatchee Club Background Monitoring Well-03
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	☐ Yes ☐ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-04-LC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Loxahatchee Club Compliance Monitoring Well-04
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-01-IC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Indian Creek Compliance Monitoring Well-01
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-IC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Indian Creek Compliance Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-03-IC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Indian Creek Compliance Monitoring Well-03
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-04-IC
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Indian Creek Background Monitoring Well-04
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County: Palm Beach
 Facility Name: LRECD WWTF
 Permit Number: FL0034649

Monitoring Well ID: MWC-01-Ab
 Well Type: Compliance
 Description: Abacoa Compliance Monitoring Well-01

Monitoring Period From: _____ To: _____

Date Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County: Palm Beach
 Facility Name: LRECD WWTF
 Permit Number: FL0034649

Monitoring Well ID: MWC-02-Ab
 Well Type: Compliance
 Description: Abacoa Compliance Monitoring Well-02

Monitoring Period From: _____ To: _____

Date Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County: Palm Beach
 Facility Name: LRECD WWTF
 Permit Number: FL0034649

Monitoring Well ID: MWC-03-Ab
 Well Type: Compliance
 Description: Abacoa Compliance Monitoring Well-03

Monitoring Period From: _____ To: _____

Date Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		10	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		500	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		10	ug/L	Grab	Annually				
Chloride (as Cl)	00940		250	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		5	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		100	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		15	ug/L	Grab	Annually				
Coliform, Fecal	74055		4	#/100 mL	Grab	Annually				
pH	00400		6.0 to 8.5	SU	In-situ	Annually				
Sulfate, Total	00945		250	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County: Palm Beach
 Facility Name: LRECD WWTF
 Permit Number: FL0034649

Monitoring Well ID: MWB-04-Ab
 Well Type: Background
 Description: Abacoa Background Monitoring Well-04

Monitoring Period From: _____ To: _____

Date Sample Obtained: _____

Was the well purged before sampling? ☐ Yes ☐ No

Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-01-BC
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Bear's Club Background Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-BC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Bear's Club Compliance Monitoring Well-02
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-03-BC
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Bear's Club Compliance Monitoring Well-03
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No		Time Sample Obtained: _____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWB-01-JUP
Facility Name:	LRECD WWTF	Well Type:	Background
Permit Number:	FL0034649	Description:	Jupiter Country Club Background Monitoring Well-01
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained: _____	

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-02-JUP
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Jupiter Country Club Compliance Monitoring Well-02
Monitoring Period	From: _____ To: _____	Date Sample Obtained:	_____
Was the well purged before sampling?	☐ Yes ☐ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

GROUND WATER MONITORING WELL REPORT - PART D

County:	Palm Beach	Monitoring Well ID:	MWC-03-JUP
Facility Name:	LRECD WWTF	Well Type:	Compliance
Permit Number:	FL0034649	Description:	Jupiter Country Club Compliance Monitoring Well-03
Monitoring Period	From: _____	To: _____	Date Sample Obtained: _____
Was the well purged before sampling?	___ Yes ___ No	Time Sample Obtained:	_____

Parameter	PARM Code	Sample Measurement	Permit Requirement	Units	Sample Type	Monitoring Frequency	Detection Limits	Analysis Method	Sampling Equipment Used	Samples Filtered (L/F/N)
Water Level Relative to NGVD	82545		Report	Feet	In-situ	Annually				
Nitrogen, Nitrate, Total (as N)	00620		Report	mg/L	Grab	Annually				
Solids, Total Dissolved (TDS)	70295		Report	mg/L	Grab	Annually				
Arsenic, Total Recoverable	00978		Report	ug/L	Grab	Annually				
Chloride (as Cl)	00940		Report	mg/L	Grab	Annually				
Cadmium, Total Recoverable	01113		Report	ug/L	Grab	Annually				
Chromium, Total Recoverable	01118		Report	ug/L	Grab	Annually				
Lead, Total Recoverable	01114		Report	ug/L	Grab	Annually				
Coliform, Fecal	74055		Report	#/100 mL	Grab	Annually				
pH	00400		Report	SU	In-situ	Annually				
Sulfate, Total	00945		Report	mg/L	Grab	Annually				
Turbidity	00070		Report	NTU	Grab	Annually				

COMMENTS AND EXPLANATION (Reference all attachments here):

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions as well as the SUPPLEMENTAL INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION / INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION / INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the Permittee or authorized representative:

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

Add the results to get the Total and divide by the number of days in the month to get the Monthly Average.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.