Effluent Quality Assessment of City of Clearwater East WRF Pinellas County NPDES # FL0021865 Sampled January 26, 2026

Division of Environmental Assessment and Restoration
Florida Department of Environmental Protection
April 2026

DEP Laboratory, Biology Program
2600 Blair Stone Road, MS 6515
Tallahassee, FL 32399-2400
www.floridadep.gov

Contents

Summary of Results....3
Facility Overview....3
Methods....3
Results....6
Literature Cited....9
Appendix A. Explanations of Measurements....16
Appendix B. Chain of Custody....18
Appendix C. Chemical Analysis of Effluent....21

List of Tables

Table 1. Measured field parameters....10
Table 2. Analytical water chemistry, microbiological, and toxicological data....11
Table 3. Analytical metals data....13
Table 4. Algal Growth Potential (AGP)....14
Table 5. Detected Organic Constituents....15

List of Figures

Figure 1. Map of Facility and Discharge Location....5

Summary of Results

The effluent sample was not toxic to the marine organisms tested in the acute toxicity bioassays. The algal growth potential (AGP) and nutrient results suggest a potential for nutrient enrichment in freshwater but not in marine receiving waters. There were twenty organic constituents detected in the effluent grab sample.

Facility Overview

The City of Clearwater East WRF is an advanced wastewater treatment facility. The permit can be found in the DEP OCULUS, Document Management System. To access the permit directly, use this link and click the "Public OCULUS Login" button in the center of the webpage. (https://depedms.dep.state.fl.us:443/Oculus/servlet/shell?command=getEntity&[guid=38.1108850.1]&[profile=Permitting_Authorization]).

The effluent is intermittently discharged into Old Tampa Bay, a Class II Marine Water and Outstanding Florida Water [waterbody identification (WBID) 1558H] (Figure 1). The receiving water for this facility falls under the Estuary-Specific Numeric Interpretations of the Narrative Nutrient Criteria (NNC) for Old Tampa Bay within the Tampa Bay region. For this region, the NNC, expressed as annual load, are 0.23 tons/million cubic meters of water total phosphorus and 1.08 tons/million cubic meters of water total nitrogen; and, expressed as annual arithmetic mean, 9.3 µg/L chlorophyll *a* (Subparagraph 62-302.532(1) (b)1., F.A.C.). For Class II predominantly marine waters, the daily average dissolved oxygen (DO) saturation shall not be below 42 percent in more than 10 percent of the values (Subsection 62-302.533(2), F.A.C.). This fifth year inspection (FYI) event only provides single sample results. It should be noted that waterbody impairment assessments are based on longer-term data, and individual exceedances of a criterion do not indicate use impairment. http://ca.dep.state.fl.us/mapdirect/?focus=nutrientcriteria

Methods

Effluent grab and 24-hour flow proportioned composite samples were collected from monitoring site location EFA-01 (prior to dechlorination) and effluent grab samples for toxicity bioassays from EFD-01 (post-dechlorination) for outfall D-001 on January 26, 2026. Some analyte permit limits were for EFA-01, EFD-01 or EFB-01. Whole Effluent Toxicity was requested by the district to be run as acute freshwater test instead of permit-specified chronic freshwater test.

Samples were collected by Emmalise Hunter and Lauren Ballard (Southwest district). Analyses were performed by Eurofins Environmental Testing in Orlando, Benchmark EnviroAnalytical, Inc. in Palmetto, and DEP Laboratory in Tallahassee.

All field and laboratory methods followed DEP Standard Operating Procedures (see https://floridadep.gov/dear/quality-assurance/content/dep-sops and https://floridadep.gov/dear/florida-dep-laboratory/content/dep-laboratory-quality-assurance-manual-and-sops for details) and met DEP quality assurance/quality control standards (see

https://floridadep.gov/dear/quality-assurance). Explanations of specific methods and measurements can be found in Appendix A.

Class II Water Quality Criteria for Fresh and Marine Waters are found in Chapter 62-302, F.A.C. All references to Rule 62-302.530, F.A.C. are to the surface water quality criteria table with an effective date of 02/17/2016 and a notice identification number of 17115667.




Figure 1. Map of Facility and Discharge Location

Results

Physical and Chemical Parameters (See Table 1 and Appendices A, B, and C)

- All field measured effluent water quality parameters complied with Class II Water Quality Criteria for Marine Waters and effluent permit limits.

Analytical Water Chemistry (See Table 2 and Appendices A and C)

- All water chemistry analytes detected in the effluent grab and composite samples complied with Class II Water Quality Criteria for Marine Waters and effluent permit limits.

- Total ammonia nitrogen was detected in the blank.

- Total organic carbon was detected in the blank between the method detection limit (MDL) and the practical quantitation limit (PQL).

Microbiology (See Table 2 and Appendices A and C)

- Effluent enterococci and fecal coliform levels complied with Class II Water Quality Criteria for Marine Waters and effluent permit limits.

Toxicity Whole Effluent Test (See Table 2 and Appendices A and C)

- Tests were performed January 27 through January 31, 2026.

- The sample was aerated for 25 minutes at a rate of approximately 100 bubbles per minute to decrease the dissolved oxygen (DO) from 10.3 mg/L to 8.7 mg/L.

- Acute bioassay results are reported as the Concentration Lethal to 50% of the test organisms (LC50).

- In a 96-hour acute definitive test of 100% effluent, mortality of <20% provides confidence that the effluent meets the acute toxicity criterion of Florida's Surface Water Quality Standards (Paragraph 62-302.500(1)(a), F.A.C.). Mortality between 20 and 50% indicates low to moderate levels of toxicity, and further action may be required. Mortality of >50% indicates that the effluent fails to meet the minimum requirement to discharge to waters of the state (Paragraph 62-4.244(3)(a), F.A.C.).

- For the 96-hour acute definitive test, the calculated LC50 for the water flea, *Ceriodaphnia dubia*, was >100% effluent with 0% mortality in 100% sample. The calculated LC50 for the fish, *Pimephales promelas*, was >100% effluent with 0% mortality in 100% sample. The effluent sample was not toxic to either test, during the 96-hour acute definitive bioassays and therefore, complied with effluent permit limits.

- For more information or to obtain copies of the toxicity bench sheets, please contact the Biology Laboratory at 850-245-8177.

Metals (See Table 3 and Appendices A and C)

- Effluent metals complied with Class II Water Quality Criteria for Marine Waters and the effluent permit limit for EFD-01.

Algal Growth Potential (See Table 4 and Appendices A and C)

- The effluent Algal Growth Potential (AGP) was 6.01 mg dry wt/L of the freshwater unicellular green alga, *Raphidocelis subcapitata*. The effluent AGP result is less than the AGP range (6.10 to 20.0 mg dry wt/L) suggested to be representative of high productivity for freshwater (Miller et al. 1978). The analytical chemistry suggests that the effluent is nitrogen-limited (Miller et al. 1978).

- An aliquot of the effluent AGP sample was salinity adjusted from an apparent salinity of approximately 0.64 parts per thousand (ppth) to a salinity of approximately 7.1 ppth by the addition of artificial sea salts to meet the salinity requirements of the test species *Dunaliella tertiolecta*.

- The salinity adjusted effluent AGP was below detection. Raschke and Shultz (1987) determined that AGP values above 10.0 mg dry weight/L represent a "problem" threshold for marine receiving waters, implying nutrient enrichment. The analytical chemistry suggests that the effluent is nitrogen-limited (Miller et al. 1978).

- Differences greater than an order of magnitude between actual and predicted AGP values are considered sufficient evidence to warrant follow up testing with the algal growth inhibition bioassay. True algal growth inhibition can only be determined by performing an actual algal growth inhibition test. Should algal growth inhibition be suspected, the district should request that the algal growth inhibition test be performed as a follow-up to the inspection.

Organic Constituents (See Table 5 and Appendices A and C)

- Atrazine (herbicide), azoxystrobin (fungicide), boscalid (fungicide), chlorfenapyr (insecticide), diazepam (insecticide), fipronil desulfinyl (insecticide), fludioxonil (fungicide), fluxapyroxad (fungicide), loratadine (antihistamine), phenytoin (anti-seizure), propiconazole (fungicide), simazine (herbicide), sulfentrazone (herbicide), tebuconazole (fungicide), 2,6-dinitrotoluene (industrial pollutant), acetophenone (solvent), bromodichloromethane (solvent), bromoform (solvent), chloroform (industrial pollutant), and dibromochloromethane (industrial pollutant) were detected in the effluent grab sample.

- Acetophenone was detected in the blank between the MDL and PQL.

- The only single-sample effluent permit limit for organic constituents is to report dibromochloromethane from EFD-01.

- Six of the organic constituents were fungicides, three were herbicides, three were insecticides, three were solvents, three were industrial pollutants, one was an antihistamine, and one was an anti-seizure product.

Literature Cited

Miller, W. E., Greene, J. C., and Shiroyama, T. 1978. The *Selenastrum capricornutum* Printz algal assay bottle test. EPA600/9-78-018. U. S. EPA, Corvallis, Oregon. 126 p.

Raschke, R.L. and Schultz, D.A. 1987. The use of the algal growth potential test for data assessment. Journal Water Pollution Control Federation.

Stevenson, R. J. and Bahls, L. L. 1999. Periphyton protocols. Pp. 6.1-6.22 in: Rapid bioassessment protocols for use in wadeable streams and rivers. 2nd edition. By: M. T. Barbour, J. Gerritsen, B. D. Snyder and J. B. Stribling. EPA 841-B-99-002. U. S. Environmental Protection Agency, Office of Water, Washington, D. C.

USEPA. 1971. Algal Assay Procedure: Bottle Test. EPA950R71094 U. S. EPA, Corvallis, Oregon, 82 p.

USEPA. 1974. Marine Algal Assay Procedure: Bottle Test. EPA660375008 U. S. EPA, Corvallis, Oregon. 43 p.

USEPA. 2000. Nutrient Criteria Technical Guidance Manual – River and Streams. EPA-822-B-00-002.

Table 1. Measured field parameters

Effluent limits (for EFA-01 unless otherwise indicated), Class II Water Quality Criteria for Marine Waters, and field parameters

Parameter	Units	Class II Criteria	Effluent Permit Limits	Effluent EFD-01	Effluent EFA-01
Temperature	C	-	-	23.4	23.4
pH	SU	6.5 - 8.5	6.5 - 8.5 s	7.2	7.5
Specific Conductance	µmhos/cm	-	-	1,144	1,074
Salinity	ppth	-	-	0.6 c	0.5 c
Dissolved Oxygen	% saturation	≥ 42	-	109.1	107.4
Total Residual Chlorine (For Disinfection)	mg/L	-	≥ 1.0 s	-	2.3
Total Residual Chlorine (For Dechlorination)	mg/L	< 0.01	≤ 0.01 s (EFD-01)	< 0.01 U	-

A dash (-) indicates sample/measurement was not collected or criterion/limit does not exist.
c - Value is calculated.
s – Single sample
U - Material analyzed for but not detected; value reported is the method detection limit.

Table 2. Analytical water chemistry, microbiological, and toxicological data

Effluent limits (for EFA-01 unless otherwise indicated), Class II Water Quality Criteria for Marine Waters, and analytical water chemistry, microbiological, and toxicological data

Analyte	Units	Class III Criteria	Effluent Permit Limits	Effluent Composite	Effluent Grab
Ortho-phosphate	mg P/L	-	-	-	0.34
Total Phosphorus	mg P/L	-	Report sp	0.39	0.42
Total Ammonia Nitrogen[1]	mg N/L	-	-	-	0.028
Un-ionized Ammonia (calculated salinity)	mg N/L	-	-	-	< 0.02 c
Nitrate and Nitrite	mg N/L	-	-	1.7	0.61
Total Kjeldahl Nitrogen	mg N/L	-	-	0.75	0.85
Organic Nitrogen	mg N/L	-	-	-	0.82 c
Total Nitrogen	mg N/L	-	≤ 6.0 sp	2.5 c	1.46 c
Total Organic Carbon[2]	mg C/L	-	-	-	6.9
Chlorophyll *a* - Corrected	µg/L	≤ 9.3 g	-	-	0.52 U
Phaeophytin	µg/L	-	-	-	0.63 U
CBOD, 5 day, N - inhibited	mg/L	-	≤ 10.0 sp	4.9	-
Hardness	mg CaCO3/L	-	-	-	173 c
Total Suspended Solids	mg/L	-	≤ 10.0 sp	2 U	2 U
Turbidity	NTU	≤ 29 t	-	-	0.75 IA
Color (true)	PCU	-	-	-	3.3 I
Alkalinity	mg CaCO3/L	-	-	-	140 A
Chloride	mg Cl/L	-	-	-	200 A
Fluoride	mg F/L	≤ 1.5	-	-	0.17
Sulfate	mg SO4/L	-	-	-	50 A
Fecal Coliforms	cfu/100 mL	≤ 31 s	≤ 25 s	-	10 U
Escherichia coli	MPN/100 mL	-	-	-	10 U

Analyte	Units	Class III Criteria	Effluent Permit Limits	Effluent Composite	Effluent Grab
Enterococci	MPN/100 mL	≤ 130	≤ 130	-	10 U
Bioassay - Water flea *(Ceriodaphnia dubia)*	% effluent	-	≥ 100 s (EFD-01)	-	> 100 (EFD-01)
Bioassay – Fish *(Pimephales promelas)*	% effluent	-	≥ 100 s (EFD-01)	-	> 100 (EFD-01)

A dash (-) indicates sample/measurement was not collected or criterion/limit does not exist.
c - Value is calculated.
g - Value expressed as an annual arithmetic mean.
p - 24 hour flow proportioned composite
s - Single sample
t - Shall not exceed 29 NTUs above background.
A - Value reported is the mean of two or more determinations.
I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
U - Material analyzed for but not detected; value reported is the method detection limit.
1 - Analyte detected in the blank.
2 - Analyte detected in the blank between the laboratory MDL and the laboratory PQL.

Table 3. Analytical metals data

Effluent limits, Class II Water Quality Criteria for Marine Waters, and analytical metals data

Analyte	Units	Class III Criteria	Effluent Permit Limits	Effluent Grab
Aluminum	µg/L	≤ 1500	-	31
Arsenic	µg/L	≤ 50	-	1.65
Cadmium	µg/L	≤ 8.8	-	0.020 U
Calcium	mg/L	-	-	58.2
Chromium, Total [3]	µg/L	≤ 50	-	0.40 U
Copper	µg/L	≤ 3.7	≤ 3.7 (EFD-01)	1.43
Iron	µg/L	≤ 300	-	40 I
Lead	µg/L	≤ 8.5	-	0.20 U
Magnesium	mg/L	-	-	6.83
Nickel	µg/L	≤ 8.3	-	0.88 I
Potassium	mg/L	-	-	12.4
Selenium	µg/L	≤ 71	-	0.20 U
Silver	µg/L	≤ 2.3	-	0.010 U
Sodium	mg/L	-	-	147
Zinc	µg/L	≤ 86	-	16 I

A dash (-) indicates sample/measurement was not collected or criterion/limit does not exist.
I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
U - Material analyzed for but not detected; value reported is the method detection limit.
3 - Class II Marine Water Quality Criterion (62-302.530(19)(b), F.A.C.) is for chromium-VI.

Table 4. Algal Growth Potential (AGP)

Measured and predicted algal growth potential (AGP; mg dry weight/L) for total soluble inorganic nitrogen (TSIN), ortho-phosphate (OP), total nitrogen (TN) and total phosphorus (TP) limitation and ratios of nitrogen to phosphorus

Location	Test Species	AGP (measured)	Predicted AGP (TSIN) ± 20%	Predicted AGP (OP) ± 20%	Predicted AGP (TN) ± 20%	Predicted AGP (TP) ± 20%	Inorganic N:P ratio	Total N:P ratio
Effluent Grab	*Raphidocelis subcapitata*	6.01 A	24 ± 4.8	150 ± 29.2	56 ± 11	180 ± 36	1.9	3.5
Effluent Grab	*Dunaliella tertiolecta*	3.00 U *	not applicable [4]	not applicable [4]	not applicable [4]	not applicable [4]	1.9	3.5

* - Sample salinity adjusted to 7.1 ppth.

A - Value reported is the mean of two or more determinations.

U - Material analyzed for but not detected; value reported is the method detection limit.

4 - Predictions not applicable to marine matrix.

Table 5. Detected Organic Constituents

Effluent limits, Class II Water Quality Criteria for Marine Waters, and analytical organic and pesticide data

Analyte	Units	Class III Criteria	Effluent Permit Limits	Effluent Grab
Atrazine	ng/L	-	-	32
Azoxystrobin	ng/L	-	-	10 J
Boscalid	ng/L	-	-	1.3 IJ
Chlorfenapyr	ng/L	-	-	2.8
Diazepam	ng/L	-	-	0.93 IJ
Fipronil Desulfinyl	ng/L	-	-	0.13 I
Fludioxonil	ng/L	-	-	0.23 I
Fluxapyroxad	ng/L	-	-	0.74 I
Loratadine	ng/L	-	-	2.9 J
Phenytoin	ng/L	-	-	31 I
Propiconazole	ng/L	-	-	13
Simazine	ng/L	-	-	4.4 J
Sulfentrazone	ng/L	-	-	3.7 I
Tebuconazole	ng/L	-	-	8.2
2,6-Dinitrotoluene	µg/L	-	-	0.62 J
Bromodichloromethane	µg/L	-	-	69
Bromoform	µg/L	-	-	3.6
Chloroform	µg/L	-	-	100
Dibromochloromethane	µg/L	-	Report (EFD-01)	36

A dash (-) indicates sample/measurement was not collected or criterion/limit does not exist.
I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
J - Estimated value and/or the analysis did not meet established quality control criteria.
U - Material analyzed for but not detected; value reported is the method detection limit.

Appendix A. Explanations of Measurements

Biological assessments are prepared by DEP staff to provide information for review of NPDES permit renewal applications. Biological assessments, in conjunction with other information concerning the subject facility and its receiving-water body, are used to determine appropriate permit conditions. References to Rule 62-302.530, F.A.C., are to the currently applicable surface water quality criteria table with an effective date of 02/17/2016 and a notice identification number of 17115667.

- **Chemical Analyses of the Effluent**

  The effluent was analyzed for nutrients, metals, organic constituents (base, neutral, and acid extractables) and pesticides following DEP SOPs. The results from these analyses were compared with Water Quality Criteria (Chapter 62-302, F.A.C.) and facility permit limits.

- **Chlorophyll a Content**

  Chlorophyll a content is an estimate of algal biomass. High algal biomass implies nutrient stress (Stevenson and Bahls 1999) and may constitute exceedances of Subsection 62-302.530(47), F.A.C., Paragraph 62-302.530(48)(a) F.A.C. and/or Paragraph 62-302.530(48)(b) F.A.C.

- **Bacteriological Testing**

  High levels of fecal indicator bacteria may constitute an exceedance of Subsection 62-302.530(6) and/or facility permit limits. *Escherichia coli* results are based on Most Probable Number (MPN) and shall not exceed 410 in 10% or more of the samples during any 30-day period (62-302.530(6)(b), F.A.C.). *Enterococci* results are based on Most Probable Number (MPN) and shall not exceed 130 in 10% or more of the samples during any 30-day period (62-302.530(6)(c), F.A.C.). If fewer than 10 samples are taken within a month for a given location, the Ten Percent Threshold Value (TPTV) is assessed as a single sample maximum. The results for fecal coliform by membrane filtration method are often based on colony counts outside the acceptable range (B-qualifier). The dilutions performed on the sample did not yield results within the method acceptable range of 20- 60 colony forming units per plate. The B-qualifier does not affect data quality.

- **Toxicity Bioassays**

  Greater than 50% mortality in an acute toxicity test may constitute an exceedance of Paragraph 62-302.500(1)(a) and/or facility permit limits. A 25% inhibition concentration (IC25) is the effluent concentration causing a 25% reduction in a biological response such as biomass or reproduction when compared to a control population. An IC25 of less than 100% in a chronic test may constitute exceedances of Subsection 62-302.530(20), Subsection 62-302.530(62) and/or facility permit limits. A no observed effect concentration (NOEC) less than 100% effluent in a chronic test may constitute an exceedance of Subsection 62-302.530(62) and/or facility permit limits. Standard reference toxicant (SRT) tests are conducted monthly to ensure quality in toxicity testing.

- **Algal Growth Potential (AGP)**

  Algal growth potential (AGP) is a measure of nutrients available for algal growth (Miller et al. 1978; USEPA 1974). The AGP value is the peak growth of the alga within that 14-day period, recorded as mg dry weight/L. AGP. The protocol for marine waters (USEPA 1974) refers to the original 1971 Bottle Test procedure (USEPA 1971) for analysis interpretation. The 1971 Bottle Test was updated in 1978 (Miller et al. 1978). AGP results within the range 6.10 to 20.0 mg dry wt/L are suggested to be representative of high productivity for freshwaters (Miller et al. 1978). AGP values above 10.0 mg dry weight/L represent a "problem" threshold for marine receiving waters, implying nutrient enrichment (Raschke and Schultz 1987, personal communication). High AGP values may constitute exceedances of Subsection 62-302.530(47), F.A.C., Paragraph 62-302.530(48)(a), F.A.C. and/or Paragraph 62-302.530(48)(b), F.A.C.

  The concentration of nutrients in a water sample may be used to calculate the expected yield of AGP under the assumption that other required nutrients (e.g. silicon, micronutrients) are present in excess (Miller *et al*. 1978). The expected amount of production is calculated as 38 times the total soluble inorganic nitrogen (nitrate and nitrite plus ammonia) under nitrogen limitation or 430 times the ortho-phosphate (OP) concentration under phosphorus limitation with an error of ± 20%. When the ratio of nitrogen to phosphorus (N: P) is less than 10:1, nitrogen limitation of algal production is likely. When the N: P ratio is 20:1 or greater, phosphorus limitation is likely (USEPA 2000). For ratios in-between, co-limitation may occur. Production of lower biomass than expected may be evidence of growth inhibition related to toxic compounds present in the water sample tested and may constitute an exceedance of Subsection 62-302.530(62), F.A.C. If a nutrient value is non-detect, predicted AGP and N:P ratio is calculated using ½ the method detection limit (MDL) for the non-detect value.

- **Definition of Qualifiers** (Rule 62-160.700, F.A.C.)

  A - Value reported is the mean of two or more determinations.
  B - Results based on colony counts outside the acceptable range.
  I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit.
  J - Estimated value and/or the analysis did not meet established quality control criteria.
  K - Actual value is known to be less than value given.
  L - Actual value is known to be greater than value given.
  N - Presumptive evidence of presence of material.
  O - Sampled, but analysis lost or not performed.
  Q - Sample held beyond normal holding time.
  T - Value reported is less than the criterion of detection.
  U - Material was analyzed for but not detected. The reported value is the method detection limit for the sample analyzed.
  V - Analyte was detected in both sample and method blank.
  X - Too few individuals to calculate SCI value.
  Y - The laboratory analysis was from an unpreserved or improperly preserved sample. The data may not be accurate.
  Z - Colonies were too numerous to count (TNTC).

Appendix B. Chain of Custody

Request Number: RQ-2026-01-12-07

FYI3 Clearwater City of East AWWTP (FL0021865) DW MA

Customer: SW-DIST

Project ID: FYI3

Florida Department of Environmental Protection
Central Laboratory Submittal Form

Page 1 of 4
last revised Jan 25, 2018

Requester: Benjamin Nomann
Collected By: Emmalise Hunter, Lauren Ballard
Field Report Prepared By: Tallahassee
Sampling Agency: SWD-FDEP

Location: Clearwater East WRF EFD-01	☐ Comp ☒ Grab	Collection (comp begin or grab) Date 1/26/26 Time 10:17am	Eastern / Central	Composite end Date Time	Bottle Group(s) (See pg 2)	Field ID: EFD-01	Matrix (type, e.g., Salt, Fresh, etc): Fresh	Diss. Oxygen 9.28→10.1 ☐ mg/L ☐ % sat	Total Res. Chlorine (mg/L) 0.01	
WIN/STORET #	Temp (C) 23.4	pH 7.20	Sample Depth Point of discharge ☐ ft ☐ m	Sp. Conductance (umho/cm) 1144	A	Latitude ☐ dd ☐ dms	Longitude ☐ dd ☐ dms	Salinity (ppt) 0.57	Comments: Post dechlorination | Tox only -KK 2/24/26	
Location: Clearwater East WRF	☐ Comp ☒ Grab	Collection (comp begin or grab) Date 1/26/26 Time 10:57am	Eastern / Central	Composite end Date Time	Bottle Group(s)	Field ID: EFA-01	Matrix (type, e.g., Salt, Fresh, etc): Fresh	Diss. Oxygen 8.76→10.74 ☐ mg/L ☐ % sat	Total Res. Chlorine (mg/L) 2.29	
WIN/STORET #	Temp (C) 23.4	pH 7.49	Sample Depth Point of discharge ☐ ft ☐ m	Sp. Conductance (umho/cm) 1074	A	Latitude ☐ dd ☐ dms	Longitude ☐ dd ☐ dms	Salinity (ppt) 0.53	Comments: Pre dechlorination -KK 2/24/26	
Location: Clearwater East WRF	☒ Comp ☐ Grab	Collection (comp begin or grab) Date 1/25/26 Time 12:00am	Eastern / Central	Composite end Date 1/26/26 Time 12:00am	Bottle Group(s)	Field ID: EFA-01	Matrix (type, e.g., Salt, Fresh, etc): Fresh	Diss. Oxygen ☐ mg/L ☐ % sat	Total Res. Chlorine (mg/L)	
WIN/STORET #	Temp (C)	pH	Sample Depth ☐ ft ☐ m	Sp. Conductance (umho/cm)	B	Latitude ☐ dd ☐ dms	Longitude ☐ dd ☐ dms	Salinity (ppt)	Comments	
Location: Clearwater East WRF	☐ Comp ☒ Grab	Collection (comp begin or grab) Date 1/26/26 Time 11:03am	Eastern / Central	Composite end Date Time	Bottle Group(s)	Field ID: Field Blanks	Matrix (type, e.g., Salt, Fresh, etc): DI water	Diss. Oxygen ☐ mg/L ☐ % sat	Total Res. Chlorine (mg/L)	
WIN/STORET #	Temp (C)	pH	Sample Depth ☐ ft ☐ m	Sp. Conductance (umho/cm)	C	Latitude ☐ dd ☐ dms	Longitude ☐ dd ☐ dms	Salinity (ppt)	Comments: Bottle group D – trip blanks	

Relinquished By:	Date/Time	Shipping Method	Number of Coolers Shipped:	Received By:	Date/Time
Emmalise Hunter	1/26/26 15:22	FEDEX			01-27-26 9:03

TRIP-BLK 01/26/26

Jenni Cox 1.27.26 0924

Benchmark EnviroAnalytical, Inc. **E84167** 1711 Twelfth Street East Palmetto, FL 34221 (941) 723-9986 / (941) 723-6061 fax Sample Temperature checked upon receipt at BEA with Temperature Gun ID #258	**Benchmark EA South E85086** 1001 Corporate Avenue, Suite 102 North Port, FL 34289 (941) 625-3137 (941) 423-7336 fax Sample Temperature checked upon receipt at BEAS with Temperature Gun ID #7

Client Information: **FDEP**

Address: 13051 N. Telecom Parkway
Tampa FL 33604

Phone # 815-470-5878

Report to: benjamin.paswater@dep.state.fl.us + emmalise.c.hunter@floridaDEP.gov

Invoice to: FDEP Micro Overflow

PO#_____

Project Name: Clearwater East WRF RQ-2026-01-12-07

Laboratory Submission # db011064

Sample Name	Sample Type[1] / Sample Matrix[2]	Collection		Container			Preservative[4]	Parameters for Analysis	Laboratory Sample #
		Date	Time EH	Qty	Capacity	Type[3]			
SW EFD-01 ECQ, ENQ	G	1/26/26	~~10:13am~~ 12:25pm EH	1	250mL	P	tab & Ice	enterococci & e. coli	1
EFD-01 FC	G	1/26/26	10:34am EH 10:13am	1	250mL	P	tab & ICE	Fecal coliform	2
EFD-02 ECQ, ENQ	G	1/26/26	10:34am ~~10:13am~~ EH	1	250mL	P	tab & Ice	enterococci & e. coli	3
EFA-01 AT 6/4/26			10:34am						
			10:57 AM AT 6/4/26						

Notes:

1. "Sample Type" is used to indicate whether the sample was a grab (G) or whether it was a composite (C).
2. "Sample Matrix" is used to indicate whether the sample is being discharged to drinking water (DW), groundwater (GW), surface water (SW), fresh surface water (FSW), saline surface water (SSW), soil, sediment (SDMNT), or sludge (SLDG).
3. "Container Type" is used to indicate whether the container is plastic (P) or glass (G).
4. **Sample must be refrigerated or stored in wet ice after collection. The temperature during storage should be less than or equal to 6°C (42.8°F).**
5. Under "Preservative," list any preservatives that were added to the sample container. Lot Number of preservative used is specific to the bottles included in the kit. NaThio, H_2SO_4 and HNO_3 do not have expiration dates per the manufacturer.

Instructions:

1. Each bottle has a label identifying sample ID, premeasured preservative contained in the bottle, sample type, client ID, and parameters for analysis.
2. The following information should be added to each bottle label after collection with permanent black ink: date and time of collection, sampler's name or initials, and any field number or ID.
3. All bottles not containing preservative may be rinsed with appropriate sample prior to collection.
4. The client is responsible for documentation of the sampling event. Please note special sampling events on the sample custody form.
5. Sample kit has been created by BEA using new, certified bottles.

Laboratory Sample Acceptability:

pH <2 : ~~B~~ BEA Temperature:

BEAS Temperature:

	Collected / Relinquished By & Affiliation: (Print & Sign)	Date	Time	Received By& Affiliation: (Print & Sign)	Date	Time
1	Emmalise Hunter FDEP	1/26/26	12:28pm		1-26-26	1229
2	Relinquished By& Affiliation: (Print & Sign)	Date	Time	Received By& Affiliation: (Print & Sign)	Date	Time

STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
TASK ASSIGNMENT/NOTIFICATION FORM: LAB145

Contract Manager. Linda Allen/Devan Cobb (850)-245-8084 / (850) 245-8078
2600 Blair Stone Rd., MS 6512
Tallahassee, FL 32399-2400

Contractor: Eurofins Environmental Testing Southeast, LLC
5102 LaRoche Ave
Savannah, GA 31404
ATTN: Noel Savoie

DEP Approval By: Devan R. Cobb-Williams Contractor Approval By Noel D
Project Manager

Contractor Representatives Contacted Noel Savoie

Date: 12/19/2025
Means of Contact. Email

Task Assignment Number: OV712 Maximum Cost: **$41.50** Turnaround Time 5 BD

Sample Delivery Date. 1/27/2025

Project Name/Description:
RQ-2026-01-12-07;FY13 Clearwater City of East AWWTP (FL0021865) DW MA

Deliverable Number/ Parameter Group/ Method	**Sample Matrix**	**# of Samples**	**# of Containers**	**DEP ID #**	**Unit Cost**	**% Mark-up (if any)**	**Cost**
Quote/OV-CBOD-IN CBOD, nitrogen-mhibited 5210B-2011	W	1	1		$39.00		$39.00
217/Sample Disposal Fee:	1				$2 50		$2 50
Total Number of Containers Shipped:	1					**Total:**	**$41.50**

670-79258 Chain of Custody

QC Instructions.

Comments:

Samples released to Contract Lab by: Emmalise Hunter Date/Time: 1/26/26 14:47

Delivery Method: FEDEX Shipping Overnight

Samples Accepted by: JL E-ORL 11/11 Date/Time 1/27/26 1053

* **Please sign and return by email to** Linda.S.Allen@FloridaDEP.gov and **Devan.R.Cobb@dep.state.fl.us**

Page 14 of 27

2/19/2026 (Rev. 1)

Appendix C. Chemical Analysis of Effluent

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 12:00	Effluent Composite	Overflow	Carbonaceous Biochemical Oxygen Demand	4.9	mg/L	2.0	2.0
1/26/2026 12:00	Effluent Composite	Nutrients	TSS	2 U	mg/L	2.0	10
1/26/2026 12:00	Effluent Composite	Nutrients	Total-P	0.39	mg P/L	0.010	0.050
1/26/2026 12:00	Effluent Composite	Nutrients	Kjeldahl Nitrogen	0.75	mg N/L	0.080	0.20
1/26/2026 12:00	Effluent Composite	Nutrients	NO2NO3-N	1.7	mg N/L	0.030	0.10
1/26/2026 10:17	Effluent Grab	Toxicology	Bioassay-Acute-Def-FW-C.dubia, LC50	100 L	LC50		
1/26/2026 10:17	Effluent Grab	Toxicology	Bioassay-Acute-Def-FW-Fish, LC50	100 L	LC50		
1/26/2026 10:17	Effluent Grab	Nutrients	Specific Conductance	1144	µmhos/cm		
1/26/2026 10:17	Effluent Grab	Nutrients	Temperature	23.4	C		
1/26/2026 10:17	Effluent Grab	Nutrients	pH	7.20	SU		
1/26/2026 10:17	Effluent Grab	Nutrients	Dissolved Oxygen %Sat	109.1	%Sat		
1/26/2026 10:57	Effluent Grab	AGP/LN	Algal Growth Potential-Salinity Adjusted	3.00 U	mg DryWt/L	3.00	3.00
1/26/2026 10:57	Effluent Grab	AGP/LN	Algal Growth Potential	6.01 A	mg DryWt/L	0.300	0.900
1/26/2026 10:57	Effluent Grab	Chlorophyll/Grain Size/BOD	Chlorophyll-a, Corrected	0.52 U	µg/L	0.52	1.5
1/26/2026 10:57	Effluent Grab	Chlorophyll/Grain Size/BOD	Chlorophyll-a, Uncorrected	0.31 U	µg/L	0.31	0.92
1/26/2026 10:57	Effluent Grab	Chlorophyll/Grain Size/BOD	Phaeophytin-a	0.63 U	µg/L	0.63	1.9
1/26/2026 10:57	Effluent Grab	Overflow	Escherichia Coli-Quanti-Tray	10 U	MPN/100 mL	10	10
1/26/2026 10:57	Effluent Grab	Overflow	Fecal Coliforms-Membrane Filter	10 U	cfu/100 mL	10	10
1/26/2026 10:57	Effluent Grab	Overflow	Enterococci-Quanti-Tray	10 U	MPN/100 mL	10	10
1/26/2026 10:57	Effluent Grab	Metals	Silver	0.010 U	µg/L	0.010	0.040
1/26/2026 10:57	Effluent Grab	Metals	Sodium	147	mg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Metals	Cadmium	0.020 U	µg/L	0.020	0.080
1/26/2026 10:57	Effluent Grab	Metals	Selenium	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Metals	Lead	0.20 U	µg/L	0.20	0.40
1/26/2026 10:57	Effluent Grab	Metals	Zinc	16 I	µg/L	5.0	20
1/26/2026 10:57	Effluent Grab	Metals	Aluminum	31	µg/L	5.0	20
1/26/2026 10:57	Effluent Grab	Metals	Arsenic	1.65	µg/L	0.050	0.20
1/26/2026 10:57	Effluent Grab	Metals	Copper	1.43	µg/L	0.40	0.80
1/26/2026 10:57	Effluent Grab	Metals	Nickel	0.88 I	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Metals	Iron	40 I	µg/L	30	120
1/26/2026 10:57	Effluent Grab	Metals	Potassium	12.4	mg/L	0.30	1.2

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Metals	Calcium	58.2	mg/L	0.075	0.30
1/26/2026 10:57	Effluent Grab	Metals	Magnesium	6.83	mg/L	0.040	0.16
1/26/2026 10:57	Effluent Grab	Metals	Chromium	0.40 U	µg/L	0.40	1.6
1/26/2026 10:57	Effluent Grab	Nutrients	Color (true)	3.3 I	PCU	2.0	6.0
1/26/2026 10:57	Effluent Grab	Nutrients	Turbidity	0.75 IA	NTU	0.10	1.0
1/26/2026 10:57	Effluent Grab	Nutrients	Organic Carbon	6.9	mg C/L	0.50	1.0
1/26/2026 10:57	Effluent Grab	Nutrients	TSS	2 U	mg/L	2.0	10
1/26/2026 10:57	Effluent Grab	Nutrients	O-Phosphate-P	0.34	mg P/L	0.0080	0.020
1/26/2026 10:57	Effluent Grab	Nutrients	NO2NO3-N	0.61	mg N/L	0.015	0.050
1/26/2026 10:57	Effluent Grab	Nutrients	Total-P	0.42	mg P/L	0.010	0.050
1/26/2026 10:57	Effluent Grab	Nutrients	Ammonia-N	0.028	mg N/L	0.0020	0.0050
1/26/2026 10:57	Effluent Grab	Nutrients	Chloride	200 A	mg Cl/L	2.0	5.0
1/26/2026 10:57	Effluent Grab	Nutrients	Total Alkalinity	140 A	mg CaCO3/L	0.65	2.5
1/26/2026 10:57	Effluent Grab	Nutrients	Kjeldahl Nitrogen	0.85	mg N/L	0.080	0.20
1/26/2026 10:57	Effluent Grab	Nutrients	Sulfate	50 A	mg SO4/L	2.0	5.0
1/26/2026 10:57	Effluent Grab	Nutrients	Fluoride	0.17	mg F/L	0.025	0.10
1/26/2026 10:57	Effluent Grab	Pesticides	Caffeine	7.7 U	ng/L	7.7	38
1/26/2026 10:57	Effluent Grab	Pesticides	Diazepam	0.93 IJ	ng/L	0.41	2.0
1/26/2026 10:57	Effluent Grab	Pesticides	Fluazifop-P-butyl	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Loratadine	2.9 J	ng/L	0.31	1.5
1/26/2026 10:57	Effluent Grab	Pesticides	Metolachlor	0.77 U	ng/L	0.77	3.8
1/26/2026 10:57	Effluent Grab	Pesticides	Norflurazon	1.0 UJ	ng/L	1.0	5.1
1/26/2026 10:57	Effluent Grab	Pesticides	Parathion Ethyl	0.15 UJ	ng/L	0.15	0.77
1/26/2026 10:57	Effluent Grab	Pesticides	Prometryn	0.36 UJ	ng/L	0.36	1.8
1/26/2026 10:57	Effluent Grab	Pesticides	Sulfentrazone	3.7 I	ng/L	1.4	7.1
1/26/2026 10:57	Effluent Grab	Pesticides	Alachlor	0.41 UJ	ng/L	0.41	2.0
1/26/2026 10:57	Effluent Grab	Pesticides	Azinphos Methyl	3.1 UJ	ng/L	3.1	15
1/26/2026 10:57	Effluent Grab	Pesticides	Azoxystrobin	10 J	ng/L	0.41	2.0
1/26/2026 10:57	Effluent Grab	Pesticides	Coumaphos	1.1 UJ	ng/L	1.1	5.6
1/26/2026 10:57	Effluent Grab	Pesticides	Diazinon	0.13 UJ	ng/L	0.13	0.64
1/26/2026 10:57	Effluent Grab	Pesticides	Difenoconazole	0.61 U	ng/L	0.61	3.1
1/26/2026 10:57	Effluent Grab	Pesticides	Disulfoton	0.61 UJ	ng/L	0.61	3.1
1/26/2026 10:57	Effluent Grab	Pesticides	Flumioxazin	3.1 U	ng/L	3.1	15
1/26/2026 10:57	Effluent Grab	Pesticides	Fonofos	0.15 UJ	ng/L	0.15	0.77

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Pesticides	Methidathion	0.82 UJ	ng/L	0.82	4.1
1/26/2026 10:57	Effluent Grab	Pesticides	Metribuzin	0.41 U	ng/L	0.41	2.0
1/26/2026 10:57	Effluent Grab	Pesticides	Oxadiazon	0.36 U	ng/L	0.36	1.8
1/26/2026 10:57	Effluent Grab	Pesticides	Phenytoin	31 I	ng/L	12	61
1/26/2026 10:57	Effluent Grab	Pesticides	Tebuconazole	8.2	ng/L	1.4	7.1
1/26/2026 10:57	Effluent Grab	Pesticides	Atrazine	32	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Chlorpyrifos Ethyl	0.31 UJ	ng/L	0.31	1.5
1/26/2026 10:57	Effluent Grab	Pesticides	Fluxapyroxad	0.74 I	ng/L	0.26	1.3
1/26/2026 10:57	Effluent Grab	Pesticides	Imazalil	0.66 U	ng/L	0.66	3.3
1/26/2026 10:57	Effluent Grab	Pesticides	Naled	2.6 UJ	ng/L	2.6	13
1/26/2026 10:57	Effluent Grab	Pesticides	Mevinphos	1.0 UJ	ng/L	1.0	5.1
1/26/2026 10:57	Effluent Grab	Pesticides	Molinate	0.26 U	ng/L	0.26	1.3
1/26/2026 10:57	Effluent Grab	Pesticides	Pendimethalin	1.7 U	ng/L	1.7	8.7
1/26/2026 10:57	Effluent Grab	Pesticides	Prodiamine	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Propiconazole	13	ng/L	0.61	3.1
1/26/2026 10:57	Effluent Grab	Pesticides	Pyriproxyfen	0.26 U	ng/L	0.26	1.6
1/26/2026 10:57	Effluent Grab	Pesticides	Terbufos	0.20 UJ	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Thiobencarb	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Butylate	0.46 U	ng/L	0.46	2.3
1/26/2026 10:57	Effluent Grab	Pesticides	Carbophenothion	0.51 UJ	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Cyprodinil	0.20 U	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Dimethomorph	3.1 U	ng/L	3.1	15
1/26/2026 10:57	Effluent Grab	Pesticides	EPTC	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Ethion	0.31 UJ	ng/L	0.31	1.5
1/26/2026 10:57	Effluent Grab	Pesticides	Metalaxyl	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Ibuprofen	0.080 U	µg/L	0.080	0.32
1/26/2026 10:57	Effluent Grab	Pesticides	Naproxen	0.0080 U	µg/L	0.0080	0.032
1/26/2026 10:57	Effluent Grab	Pesticides	Acetochlor	0.20 U	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Chlorfenapyr	2.8	ng/L	0.31	1.5
1/26/2026 10:57	Effluent Grab	Pesticides	Chlorpyrifos Methyl	0.10 UJ	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Cyanazine	5.1 U	ng/L	5.1	26
1/26/2026 10:57	Effluent Grab	Pesticides	Ethoprop	0.13 UJ	ng/L	0.13	0.64
1/26/2026 10:57	Effluent Grab	Pesticides	Hexazinone	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Iprodione	0.51 U	ng/L	0.51	2.6

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Pesticides	Oxyfluorfen	0.20 U	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Phorate	0.26 UJ	ng/L	0.26	1.3
1/26/2026 10:57	Effluent Grab	Pesticides	Propanil	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Propargite	0.82 U	ng/L	0.82	4.1
1/26/2026 10:57	Effluent Grab	Pesticides	Simazine	4.4 J	ng/L	0.26	1.3
1/26/2026 10:57	Effluent Grab	Pesticides	Carfentrazone Ethyl	0.15 U	ng/L	0.15	0.77
1/26/2026 10:57	Effluent Grab	Pesticides	Dithiopyr	2.0 U	ng/L	2.0	10
1/26/2026 10:57	Effluent Grab	Pesticides	Fenamiphos	0.46 UJ	ng/L	0.46	2.3
1/26/2026 10:57	Effluent Grab	Pesticides	Fipronil	0.20 U	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Fipronil Desulfinyl	0.13 I	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Pyridaben	1.4 U	ng/L	1.4	7.1
1/26/2026 10:57	Effluent Grab	Pesticides	Stirophos	0.41 UJ	ng/L	0.41	3.3
1/26/2026 10:57	Effluent Grab	Pesticides	Trifloxystrobin	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Ametryn	2.6 UJ	ng/L	2.6	13
1/26/2026 10:57	Effluent Grab	Pesticides	Boscalid	1.3 IJ	ng/L	0.41	2.0
1/26/2026 10:57	Effluent Grab	Pesticides	Buprofezin	2.0 U	ng/L	2.0	10
1/26/2026 10:57	Effluent Grab	Pesticides	Fenbuconazole	0.51 U	ng/L	0.51	2.6
1/26/2026 10:57	Effluent Grab	Pesticides	Fipronil Sulfide	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Fludioxonil	0.23 I	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Fluopicolide	0.20 UJ	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Pronamide	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Pyraflufen Ethyl	0.31 U	ng/L	0.31	1.5
1/26/2026 10:57	Effluent Grab	Pesticides	Terbuthylazine	0.20 U	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Atrazine Desethyl	1.3 U	ng/L	1.3	6.6
1/26/2026 10:57	Effluent Grab	Pesticides	Bromacil	0.61 U	ng/L	0.61	3.1
1/26/2026 10:57	Effluent Grab	Pesticides	Demeton	3.6 UJ	ng/L	3.6	18
1/26/2026 10:57	Effluent Grab	Pesticides	Dimethenamid	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Etridiazole	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Fipronil Sulfone	0.26 UJ	ng/L	0.26	1.3
1/26/2026 10:57	Effluent Grab	Pesticides	Fluopyram	0.20 U	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Flutolanil	0.10 U	ng/L	0.10	0.51
1/26/2026 10:57	Effluent Grab	Pesticides	Malathion	0.36 UJ	ng/L	0.36	1.8
1/26/2026 10:57	Effluent Grab	Pesticides	Myclobutanil	0.36 U	ng/L	0.36	1.8
1/26/2026 10:57	Effluent Grab	Pesticides	Napropamide	0.71 U	ng/L	0.71	3.6

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Pesticides	Parathion Methyl	0.20 UJ	ng/L	0.20	1.0
1/26/2026 10:57	Effluent Grab	Pesticides	Prometon	3.1 U	ng/L	3.1	15
1/26/2026 10:57	Effluent Grab	Pesticides	Triadimefon	0.15 U	ng/L	0.15	0.77
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	4-Chloro-3-methylphenol	0.31 UJ	µg/L	0.31	1.2
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Hexachloroethane	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosodi-n-butylamine	0.51 UJ	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Nitrobenzene	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	o-Toluidine	0.41 UJ	µg/L	0.41	1.6
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Trichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,1,2-Trichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,1,1-Trichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,1,2,2-Tetrachloroethane	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,4-Dichlorobenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Chloromethane	2.0 U	µg/L	2.0	8.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Dibromochloromethane	36	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,6-Dichlorophenol	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	3,3'-Dichlorobenzidine	4.1 U	µg/L	4.1	16
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Fluoranthene	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Hexachlorobutadiene	0.072 UJ	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Hexachlorocyclopentadiene	0.20 UJ	µg/L	0.20	0.82
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Isophorone	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Isosafrole	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosodi-n-propylamine	0.12 U	µg/L	0.12	0.49
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosomethylethylamine	2.0 U	µg/L	2.0	8.2
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	m,p-Xylene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Methylene chloride	4.0 U	µg/L	4.0	16
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	o-Chlorotoluene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	o-Xylene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,2-Dichloropropane	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Chlorobenzene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Nitrophenol	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Aniline	1.2 UJ	µg/L	1.2	4.9
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bis(2-ethylhexyl)adipate	0.61 UJ	µg/L	0.61	2.5
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bis(2-ethylhexyl)phthalate	2.0 U	µg/L	2.0	8.2

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Diethyl phthalate	1.5 UJ	µg/L	1.5	6.1
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,4,5-Trichlorophenol	0.20 U	µg/L	0.20	0.82
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,6-Dinitrotoluene	0.62 J	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Hexachlorobenzene	0.061 U	µg/L	0.061	0.25
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosodimethylamine	2.6 U	µg/L	2.6	10
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Naphthalene	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Pentachloroethane	0.15 U	µg/L	0.15	0.61
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Hexanone	3.0 U	µg/L	3.0	12
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Acetone	5.0 U	µg/L	5.0	20
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,4-Dichlorophenol	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,4-Dinitrophenol	10 UJ	µg/L	10	41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bis(2-chloroethoxy)methane	0.082 U	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bis(2-chloroisopropyl)ether	0.082 U	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Di-n-octyl phthalate	1.0 UJ	µg/L	1.0	4.1
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	3-Methylcholanthrene	0.61 UJ	µg/L	0.61	2.5
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	4-Bromophenyl phenyl ether	0.072 U	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Tetrachloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Toluene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,1-Dichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,3,5-Trimethylbenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	cis-1,2-Dichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1-Methylphenanthrene	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,3,5-Trinitrobenzene	0.51 UJ	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Acetylaminofluorene	0.82 UJ	µg/L	0.82	3.3
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzidine	10 U	µg/L	10	41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Biphenyl	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Dimethyl phthalate	0.31 UJ	µg/L	0.31	1.2
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Fluorene	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosodiethylamine	0.41 U	µg/L	0.41	1.6
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosopyrrolidine	0.72 U	µg/L	0.72	2.9
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	trans-1,2-Dichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Trichlorofluoromethane	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Butanone	5.0 U	µg/L	5.0	20
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Carbon tetrachloride	0.20 U	µg/L	0.20	0.80

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Isopropylbenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Acetophenone	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzo(a)pyrene	0.082 U	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzo(b)fluoranthene	0.15 U	µg/L	0.15	0.61
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzyl alcohol	0.31 U	µg/L	0.31	1.2
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Chrysene	0.082 U	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Dibenzo(a,h)anthracene	0.51 UJ	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Dibenzofuran	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,6-Dimethylnaphthalene	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Dibenzothiophene	0.072 U	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	4-Chlorophenyl phenyl ether	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,4-Dimethylphenol	4.1 UJ	µg/L	4.1	16
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,4-Dinitrotoluene	0.15 UJ	µg/L	0.15	0.61
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1-Methylnaphthalene	0.15 UJ	µg/L	0.15	0.61
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,2,4-Trichlorobenzene	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,3-Dinitrobenzene	0.51 UJ	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Acenaphthene	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzo(g,h,i)perylene	0.20 UJ	µg/L	0.20	0.82
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzo(k)fluoranthene	0.072 U	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Butyl benzyl phthalate	0.51 UJ	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,4,6-Trichlorophenol	0.51 U	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Hexachloropropene	0.082 U	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosodiphenylamine/ Diphenylamine	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Phenanthrene	0.072 U	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Pyridine	4.1 U	µg/L	4.1	16
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,1-Dichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,2-Dichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	4-Methyl-2-Pentanone	3.0 U	µg/L	3.0	12
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Carbon disulfide	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Chloroethane	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Chlorophenol	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Azobenzene/1,2-Diphenylhydrazine	0.061 UJ	µg/L	0.061	0.25
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Carbazole	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Di-n-butyl phthalate	3.1 UJ	µg/L	3.1	12

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	m,p-Cresols	0.26 UJ	µg/L	0.26	1.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosopiperidine	0.072 UJ	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	o-Cresol	0.20 UJ	µg/L	0.20	0.82
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Pentachlorobenzene	0.061 UJ	µg/L	0.061	0.25
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Pentachloronitrobenzene	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Styrene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,2-Dichlorobenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bromoform	3.6	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bromomethane	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	cis-1,3-Dichloropropene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Methylnaphthalene	0.15 UJ	µg/L	0.15	0.61
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Nitroaniline	0.31 UJ	µg/L	0.31	1.2
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Acenaphthylene	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	7,12-Dimethylbenz(a)anthracene	0.051 UJ	µg/L	0.051	0.20
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Anthracene	0.061 U	µg/L	0.061	0.25
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bis(2-chloroethyl)ether	0.20 U	µg/L	0.20	0.82
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Dimethylaminoazobenzene	0.41 UJ	µg/L	0.41	1.6
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Ethyl methanesulfonate	2.6 U	µg/L	2.6	10
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Indeno(1,2,3-cd)pyrene	0.51 UJ	µg/L	0.51	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	N-Nitrosomorpholine	0.082 U	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Pentachlorophenol	2.0 UJ	µg/L	2.0	8.2
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Phenol	0.20 U	µg/L	0.20	0.82
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Pyrene	0.10 UJ	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Safrole	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Methyl-t-butyl ether	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	trans-1,3-Dichloropropene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Vinyl chloride	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,2,4-Trimethylbenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,3-Dichlorobenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Bromodichloromethane	69	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Chloroform	100	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Ethylbenzene	0.20 U	µg/L	0.20	0.80
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,3,4,6-Tetrachlorophenol	0.20 U	µg/L	0.20	0.82

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2,3,5-Trimethylnaphthalene	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	1,2,4,5-Tetrachlorobenzene	0.072 UJ	µg/L	0.072	0.29
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Chloronaphthalene	0.082 UJ	µg/L	0.082	0.33
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Methyl-4,6-dinitrophenol	3.1 UJ	µg/L	3.1	12
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	2-Picoline	0.61 UJ	µg/L	0.61	2.5
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	4-Nitrophenol	5.1 U	µg/L	5.1	20
1/26/2026 10:57	Effluent Grab	Priority Organic Pollutants	Benzo(a)anthracene	0.10 U	µg/L	0.10	0.41
1/26/2026 10:57	Effluent Grab	Nutrients	pH	7.49			
1/26/2026 10:57	Effluent Grab	Nutrients	Dissolved Oxygen %Sat	107.4	%Sat		
1/26/2026 10:57	Effluent Grab	Nutrients	Temperature	23.4	C		
1/26/2026 10:57	Effluent Grab	Nutrients	Specific Conductance	1074	µmhos/cm		
1/26/2026 11:03	Field Blank	Metals	Nickel	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Metals	Arsenic	0.050 U	µg/L	0.050	0.20
1/26/2026 11:03	Field Blank	Metals	Silver	0.010 U	µg/L	0.010	0.040
1/26/2026 11:03	Field Blank	Metals	Sodium	0.50 U	mg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Metals	Potassium	0.30 U	mg/L	0.30	1.2
1/26/2026 11:03	Field Blank	Metals	Lead	0.20 U	µg/L	0.20	0.40
1/26/2026 11:03	Field Blank	Metals	Zinc	5.0 U	µg/L	5.0	20
1/26/2026 11:03	Field Blank	Metals	Magnesium	0.040 U	mg/L	0.040	0.16
1/26/2026 11:03	Field Blank	Metals	Chromium	0.40 U	µg/L	0.40	1.6
1/26/2026 11:03	Field Blank	Metals	Cadmium	0.020 U	µg/L	0.020	0.080
1/26/2026 11:03	Field Blank	Metals	Aluminum	5.0 U	µg/L	5.0	20
1/26/2026 11:03	Field Blank	Metals	Iron	30 U	µg/L	30	120
1/26/2026 11:03	Field Blank	Metals	Copper	0.40 U	µg/L	0.40	0.80
1/26/2026 11:03	Field Blank	Metals	Selenium	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Metals	Calcium	0.075 U	mg/L	0.075	0.30
1/26/2026 11:03	Field Blank	Nutrients	Chloride	0.20 U	mg Cl/L	0.20	0.50
1/26/2026 11:03	Field Blank	Nutrients	Total Alkalinity	0.65 U	mg CaCO3/L	0.65	2.5
1/26/2026 11:03	Field Blank	Nutrients	O-Phosphate-P	0.004 U	mg P/L	0.0040	0.010
1/26/2026 11:03	Field Blank	Nutrients	Organic Carbon	0.57 I	mg C/L	0.50	1.0
1/26/2026 11:03	Field Blank	Nutrients	Turbidity	0.10 U	NTU	0.10	1.0
1/26/2026 11:03	Field Blank	Nutrients	Fluoride	0.025 U	mg F/L	0.025	0.10
1/26/2026 11:03	Field Blank	Nutrients	NO2NO3-N	0.003 U	mg N/L	0.0030	0.010
1/26/2026 11:03	Field Blank	Nutrients	Total-P	0.002 U	mg P/L	0.0020	0.0050

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Nutrients	Ammonia-N	0.006	mg N/L	0.0020	0.0050
1/26/2026 11:03	Field Blank	Nutrients	Sulfate	0.20 U	mg SO4/L	0.20	0.50
1/26/2026 11:03	Field Blank	Nutrients	Color (true)	2.0 U	PCU	2.0	6.0
1/26/2026 11:03	Field Blank	Nutrients	Kjeldahl Nitrogen	0.080 U	mg N/L	0.080	0.20
1/26/2026 11:03	Field Blank	Pesticides	Myclobutanil	0.36 U	ng/L	0.36	1.8
1/26/2026 11:03	Field Blank	Pesticides	Naled	2.6 U	ng/L	2.6	13
1/26/2026 11:03	Field Blank	Pesticides	Parathion Methyl	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Pendimethalin	1.7 U	ng/L	1.7	8.7
1/26/2026 11:03	Field Blank	Pesticides	Triadimefon	0.15 U	ng/L	0.15	0.77
1/26/2026 11:03	Field Blank	Pesticides	Atrazine	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Boscalid	0.41 U	ng/L	0.41	2.0
1/26/2026 11:03	Field Blank	Pesticides	Buprofezin	2.0 U	ng/L	2.0	10
1/26/2026 11:03	Field Blank	Pesticides	EPTC	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Etridiazole	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Naproxen	0.0080 U	µg/L	0.0080	0.032
1/26/2026 11:03	Field Blank	Pesticides	Oxadiazon	0.36 U	ng/L	0.36	1.8
1/26/2026 11:03	Field Blank	Pesticides	Prometon	3.1 U	ng/L	3.1	15
1/26/2026 11:03	Field Blank	Pesticides	Pronamide	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Thiobencarb	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Trifloxystrobin	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Bromacil	0.61 U	ng/L	0.61	3.1
1/26/2026 11:03	Field Blank	Pesticides	Carbophenothion	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Chlorfenapyr	0.31 U	ng/L	0.31	1.5
1/26/2026 11:03	Field Blank	Pesticides	Diazinon	0.13 U	ng/L	0.13	0.64
1/26/2026 11:03	Field Blank	Pesticides	Loratadine	0.31 U	ng/L	0.31	1.5
1/26/2026 11:03	Field Blank	Pesticides	Metolachlor	0.77 U	ng/L	0.77	3.8
1/26/2026 11:03	Field Blank	Pesticides	Norflurazon	1.0 U	ng/L	1.0	5.1
1/26/2026 11:03	Field Blank	Pesticides	Terbuthylazine	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Alachlor	0.41 U	ng/L	0.41	2.0
1/26/2026 11:03	Field Blank	Pesticides	Azoxystrobin	0.41 U	ng/L	0.41	2.0
1/26/2026 11:03	Field Blank	Pesticides	Diazepam	0.41 UJ	ng/L	0.41	2.0
1/26/2026 11:03	Field Blank	Pesticides	Flutolanil	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Fluxapyroxad	0.26 U	ng/L	0.26	1.3
1/26/2026 11:03	Field Blank	Pesticides	Ibuprofen	0.080 U	µg/L	0.080	0.32

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Pesticides	Metribuzin	0.41 U	ng/L	0.41	2.0
1/26/2026 11:03	Field Blank	Pesticides	Napropamide	0.72 U	ng/L	0.72	3.6
1/26/2026 11:03	Field Blank	Pesticides	Phorate	0.26 U	ng/L	0.26	1.3
1/26/2026 11:03	Field Blank	Pesticides	Prometryn	0.36 U	ng/L	0.36	1.8
1/26/2026 11:03	Field Blank	Pesticides	Propanil	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Pyraflufen Ethyl	0.31 U	ng/L	0.31	1.5
1/26/2026 11:03	Field Blank	Pesticides	Butylate	0.46 U	ng/L	0.46	2.3
1/26/2026 11:03	Field Blank	Pesticides	Chlorpyrifos Methyl	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Cyprodinil	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Disulfoton	0.61 U	ng/L	0.61	3.1
1/26/2026 11:03	Field Blank	Pesticides	Fipronil Sulfone	0.26 U	ng/L	0.26	1.3
1/26/2026 11:03	Field Blank	Pesticides	Fluopyram	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Fonofos	0.15 U	ng/L	0.15	0.77
1/26/2026 11:03	Field Blank	Pesticides	Iprodione	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Metalaxyl	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Parathion Ethyl	0.15 U	ng/L	0.15	0.77
1/26/2026 11:03	Field Blank	Pesticides	Oxyfluorfen	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Propargite	0.82 U	ng/L	0.82	4.1
1/26/2026 11:03	Field Blank	Pesticides	Ametryn	2.6 U	ng/L	2.6	13
1/26/2026 11:03	Field Blank	Pesticides	Carfentrazone Ethyl	0.15 U	ng/L	0.15	0.77
1/26/2026 11:03	Field Blank	Pesticides	Difenoconazole	0.61 U	ng/L	0.61	3.1
1/26/2026 11:03	Field Blank	Pesticides	Dithiopyr	2.0 U	ng/L	2.0	10
1/26/2026 11:03	Field Blank	Pesticides	Flumioxazin	3.1 U	ng/L	3.1	15
1/26/2026 11:03	Field Blank	Pesticides	Fluopicolide	0.20 UJ	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Hexazinone	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Malathion	0.36 UJ	ng/L	0.36	1.8
1/26/2026 11:03	Field Blank	Pesticides	Mevinphos	1.0 U	ng/L	1.0	5.1
1/26/2026 11:03	Field Blank	Pesticides	Molinate	0.26 U	ng/L	0.26	1.3
1/26/2026 11:03	Field Blank	Pesticides	Propiconazole	0.61 U	ng/L	0.61	3.1
1/26/2026 11:03	Field Blank	Pesticides	Sulfentrazone	1.4 U	ng/L	1.4	7.2
1/26/2026 11:03	Field Blank	Pesticides	Atrazine Desethyl	1.3 U	ng/L	1.3	6.7
1/26/2026 11:03	Field Blank	Pesticides	Caffeine	7.7 U	ng/L	7.7	38
1/26/2026 11:03	Field Blank	Pesticides	Demeton	3.6 U	ng/L	3.6	18
1/26/2026 11:03	Field Blank	Pesticides	Ethion	0.31 U	ng/L	0.31	1.5

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Pesticides	Fipronil Desulfinyl	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Fluazifop-P-butyl	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Imazalil	0.67 U	ng/L	0.67	3.3
1/26/2026 11:03	Field Blank	Pesticides	Methidathion	0.82 U	ng/L	0.82	4.1
1/26/2026 11:03	Field Blank	Pesticides	Prodiamine	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Pyridaben	1.4 U	ng/L	1.4	7.2
1/26/2026 11:03	Field Blank	Pesticides	Simazine	0.26 U	ng/L	0.26	1.3
1/26/2026 11:03	Field Blank	Pesticides	Stirophos	0.41 U	ng/L	0.41	3.3
1/26/2026 11:03	Field Blank	Pesticides	Acetochlor	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Azinphos Methyl	3.1 U	ng/L	3.1	15
1/26/2026 11:03	Field Blank	Pesticides	Coumaphos	1.1 U	ng/L	1.1	5.6
1/26/2026 11:03	Field Blank	Pesticides	Cyanazine	5.1 U	ng/L	5.1	26
1/26/2026 11:03	Field Blank	Pesticides	Dimethenamid	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Fipronil Sulfide	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Fludioxonil	0.10 U	ng/L	0.10	0.51
1/26/2026 11:03	Field Blank	Pesticides	Phenytoin	12 U	ng/L	12	61
1/26/2026 11:03	Field Blank	Pesticides	Pyriproxyfen	0.26 U	ng/L	0.26	1.6
1/26/2026 11:03	Field Blank	Pesticides	Tebuconazole	1.4 U	ng/L	1.4	7.2
1/26/2026 11:03	Field Blank	Pesticides	Terbufos	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Pesticides	Chlorpyrifos Ethyl	0.31 U	ng/L	0.31	1.5
1/26/2026 11:03	Field Blank	Pesticides	Dimethomorph	3.1 U	ng/L	3.1	15
1/26/2026 11:03	Field Blank	Pesticides	Ethoprop	0.13 U	ng/L	0.13	0.64
1/26/2026 11:03	Field Blank	Pesticides	Fenamiphos	0.46 U	ng/L	0.46	2.3
1/26/2026 11:03	Field Blank	Pesticides	Fenbuconazole	0.51 U	ng/L	0.51	2.6
1/26/2026 11:03	Field Blank	Pesticides	Fipronil	0.20 U	ng/L	0.20	1.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,6-Dinitrotoluene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	4-Bromophenyl phenyl ether	0.072 U	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	4-Chlorophenyl phenyl ether	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Aniline	1.2 UJ	µg/L	1.2	4.9
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzidine	10 U	µg/L	10	41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzo(g,h,i)perylene	0.21 UJ	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,2-Dichloropropane	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,2,4-Trimethylbenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzene	0.20 U	µg/L	0.20	0.80

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bromoform	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Methyl-t-butyl ether	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Methylene chloride	4.0 U	µg/L	4.0	16
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Chloroform	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Dibromochloromethane	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	o-Chlorotoluene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	o-Xylene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Styrene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Tetrachloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Vinyl chloride	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Chrysene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Diethyl phthalate	1.5 U	µg/L	1.5	6.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Fluoranthene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Pyridine	4.1 U	µg/L	4.1	16
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Safrole	0.082 UJ	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,2,4,5-Tetrachlorobenzene	0.072 UJ	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Nitroaniline	0.31 U	µg/L	0.31	1.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,6-Dimethylnaphthalene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzo(a)anthracene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,3,5-Trimethylbenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Carbon disulfide	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Chlorobenzene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Toluene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Hexachlorobutadiene	0.072 U	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Indeno(1,2,3-cd)pyrene	0.51 UJ	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	m,p-Cresols	0.26 U	µg/L	0.26	1.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosodi-n-propylamine	0.12 U	µg/L	0.12	0.49
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosodimethylamine	2.6 U	µg/L	2.6	10
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosomethylethylamine	2.1 U	µg/L	2.1	8.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosomorpholine	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	o-Cresol	0.21 U	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Chloronaphthalene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Picoline	0.62 U	µg/L	0.62	2.5
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,1-Dichloroethane	0.20 U	µg/L	0.20	0.80

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Ethylbenzene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Carbazole	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Dibenzothiophene	0.072 U	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Hexachlorocyclopentadiene	0.21 U	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Isosafrole	0.10 UJ	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosodiethylamine	0.41 U	µg/L	0.41	1.6
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosopyrrolidine	0.72 U	µg/L	0.72	2.9
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	o-Toluidine	0.41 UJ	µg/L	0.41	1.6
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1-Methylphenanthrene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,3-Dinitrobenzene	0.51 UJ	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,3,4,6-Tetrachlorophenol	0.21 U	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,3,5-Trimethylnaphthalene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,4,6-Trichlorophenol	0.51 U	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	3,3'-Dichlorobenzidine	4.1 U	µg/L	4.1	16
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	4-Chloro-3-methylphenol	0.31 UJ	µg/L	0.31	1.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Acetophenone	0.40 I	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzyl alcohol	0.31 U	µg/L	0.31	1.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,1,1-Trichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,2-Dichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,4-Dichlorobenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	cis-1,2-Dichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	trans-1,3-Dichloropropene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Trichlorofluoromethane	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bis(2-chloroisopropyl)ether	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Butyl benzyl phthalate	0.51 U	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Di-n-octyl phthalate	1.0 UJ	µg/L	1.0	4.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Dimethylaminoazobenzene	0.41 U	µg/L	0.41	1.6
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Isophorone	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Pentachloroethane	0.15 U	µg/L	0.15	0.62
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Pentachlorophenol	2.1 U	µg/L	2.1	8.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Phenanthrene	0.072 U	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Phenol	0.21 U	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,3,5-Trinitrobenzene	0.51 U	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bis(2-ethylhexyl)phthalate	2.1 U	µg/L	2.1	8.2

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Di-n-butyl phthalate	3.1 U	µg/L	3.1	12
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Fluorene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosodiphenylamine/ Diphenylamine	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Naphthalene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Pentachloronitrobenzene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Pyrene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1-Methylnaphthalene	0.15 UJ	µg/L	0.15	0.62
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,6-Dichlorophenol	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	3-Methylcholanthrene	0.62 U	µg/L	0.62	2.5
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Acenaphthylene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Anthracene	0.062 U	µg/L	0.062	0.25
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,1-Dichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,3-Dichlorobenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Butanone	5.0 U	µg/L	5.0	20
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Chloroethane	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bis(2-chloroethyl)ether	0.21 U	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Dibenzofuran	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Dimethyl phthalate	0.31 U	µg/L	0.31	1.2
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Hexachloropropene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosodi-n-butylamine	0.51 UJ	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,4-Dimethylphenol	4.1 U	µg/L	4.1	16
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	4-Nitrophenol	5.1 U	µg/L	5.1	21
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	7,12-Dimethylbenz(a)anthracene	0.051 UJ	µg/L	0.051	0.21
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Acenaphthene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Azobenzene/1,2-Diphenylhydrazine	0.062 U	µg/L	0.062	0.25
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,1,2,2-Tetrachloroethane	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,2-Dichlorobenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bromodichloromethane	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	cis-1,3-Dichloropropene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	trans-1,2-Dichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Trichloroethene	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Dibenzo(a,h)anthracene	0.51 UJ	µg/L	0.51	2.1
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Hexachloroethane	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Acetylaminofluorene	0.82 U	µg/L	0.82	3.3

Date Sampled	Site ID	Analysis Group	Component	Result	Units	MDL	PQL
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Chlorophenol	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Methyl-4,6-dinitrophenol	3.1 U	µg/L	3.1	12
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,4-Dinitrophenol	10 U	µg/L	10	41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,4,5-Trichlorophenol	0.21 U	µg/L	0.21	0.82
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Biphenyl	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Acetone	5.0 U	µg/L	5.0	20
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Chloromethane	2.0 U	µg/L	2.0	8.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Isopropylbenzene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	m,p-Xylene	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bis(2-chloroethoxy)methane	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bis(2-ethylhexyl)adipate	0.62 U	µg/L	0.62	2.5
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Ethyl methanesulfonate	2.6 U	µg/L	2.6	10
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Hexachlorobenzene	0.062 U	µg/L	0.062	0.25
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	N-Nitrosopiperidine	0.072 U	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Nitrobenzene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Pentachlorobenzene	0.062 U	µg/L	0.062	0.25
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,2,4-Trichlorobenzene	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Methylnaphthalene	0.15 UJ	µg/L	0.15	0.62
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Nitrophenol	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,4-Dichlorophenol	0.10 U	µg/L	0.10	0.41
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2,4-Dinitrotoluene	0.15 U	µg/L	0.15	0.62
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzo(a)pyrene	0.082 U	µg/L	0.082	0.33
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzo(b)fluoranthene	0.15 U	µg/L	0.15	0.62
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Benzo(k)fluoranthene	0.072 U	µg/L	0.072	0.29
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	1,1,2-Trichloroethane	0.20 U	µg/L	0.20	0.80
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	2-Hexanone	3.0 U	µg/L	3.0	12
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	4-Methyl-2-Pentanone	3.0 U	µg/L	3.0	12
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Bromomethane	0.50 U	µg/L	0.50	2.0
1/26/2026 11:03	Field Blank	Priority Organic Pollutants	Carbon tetrachloride	0.20 U	µg/L	0.20	0.80