

Effluent Quality Assessment

Beverly Beach Wastewater Treatment Facility

Flagler County

NPDES #FL0039756

Sampled June 15, 2009

September 2009

Biology Section
Bureau of Laboratories
Division of Environmental Assessment and Restoration

Quality Manual No. 870346G
NELAC Certification No. E31780

CONTENTS

Introduction

Methods

Results and Discussion

Literature Cited

Tables

Table 1	Effluent limits, Class III Marine Criteria and chemical data
Table 2	Chemical data from Influent, prior to treatment

Appendices

Appendix A	Chain of Custody
Appendix B	Bioassay Bench Sheets
Appendix C	SRT Bench Sheets and Statistical Analyses
Appendix D	Organism Receipt
Appendix E	Chemical Analyses of Effluent and Influent
Appendix F	Facility Summary, Effluent Limits, and Permit Violations Recorded on Discharge Monitoring Report
Appendix G	EPA End Sheet

Beverly Beach Wastewater Treatment Facility, 217 Starboard Drive, Beverly Beach, Flagler County, Florida, 32136. NPDES #FL0039756. Effluent grab samples for bioassay and chemical analyses and influent (prior to treatment) grab samples for metals analyses for this facility were collected on June 15, 2009.

Introduction

Beverly Beach Waste Water Treatment Facility (WWTF) is a domestic wastewater facility which uses the extended aeration activated sludge process to treat domestic wastewater. (See Appendix F for detailed facility information provided by Ed Jamro of FDEP Northeast District.)

Methods

Samples were collected from the EFD-1 NPDES sampling point for Outfall D-001 and the INF-1 NPDES sampling point for influent by Eesa Ali and Tom Kallemeyn (FDEP Northeast District) following DEP-SOP-001/01 FS 2400 Wastewater Sampling. All DEP SOPs are available on the web at: http://www.floridadep.org/labs/qa/sops.htm.

See Appendix A for the completed chain of custody form.

The 96-hour acute screening toxicity tests were performed following internal DEP SOPs TA07_01 and TA07_02. All internal DEP SOPs are available on the web at: http://www.floridadep.org/labs/cgi-bin/sop/biosop.asp.

Results and Discussion

Toxicity Test Results

Tests were performed June 16 - 20, 2009.

Ceriodaphnia dubia 96-hour acute screening bioassay – LC_{50} < 100%, 100% * mortality in 100% sample at 72 hours

Cyprinella leedsi 96-hour acute screening bioassay – LC_{50} > 100%, 30% * mortality in 100% sample at 96 hours

The bioassay samples were acutely toxic to the test organisms.

*NOTE: In an acute screening test of 100% effluent, mortality of <20% provides confidence that the effluent meets the acute toxicity criterion of Florida's Surface Water Quality Standards (Rule 62-302.500 (1) (a) 4, F.A.C.). Mortality between 20-50% indicates low to moderate levels of toxicity, and further action may be required. Mortality of >50% indicates that the effluent fails to meet the minimum requirement to discharge to waters of the state (Rule 62-4.244(3) (a), F.A.C.).

See Appendix B for bioassay bench sheets. See Appendix C for results of the last 20 standard reference toxicant (SRT) tests and the bench sheets and statistical analyses of the SRT tests that correspond to these facility tests. See Appendix D for test organism receipts.

Algal Growth Potential

A sample for Algal Growth Potential (AGP) analysis was not collected for this facility.

Chemistry Results

Total residual chlorine (0.08 mg/L) and total ammonia (2.81 mg N/L) were detected in the bioassay sample in the laboratory.

Samples were not collected for nutrient analyses.

Copper, lead, nickel, and zinc were detected in the effluent at levels that comply with Class III marine water quality criteria (62-302.530, F.A.C.). Arsenic was detected between the laboratory method detection limits (MDL) and practical quantitation limits (PQL). Dissolved oxygen (2.3 mg/L) in the effluent was less than both the Class III marine water criterion (≥ 4.0 mg/L, 62-302.500 (30), F.A.C.) and the permit limit (≥ 6.0 mg/L, NPDES# FL0039756) for dissolved oxygen. Total residual chlorine (0.08 mg/L) in the effluent as measured in the bioassay laboratory also exceeded both the Class III marine criterion and permit conditions for total residual chlorine (≤0.01 mg/L, 62-302.500 (18), F.A.C., and NPDES# FL0039756).

See Table 1 for results of analytes detected in the effluent, and corresponding limits. See Table 2 for results of analytes detected in the plant influent prior to treatment. See Appendix E for a complete list of chemical analyses performed.

Conclusion

The effluent sample collected from the EFD-1 for this facility on June 15, 2009, was acutely toxic to both test species during the 96-hour acute screening bioassays. Effluent water quality samples collected on June 15, 2009, violated water quality criterion and permit conditions for both dissolved oxygen and total residual chlorine.

Literature Cited

None

Table 1. Effluent limits, Class III Criteria for predominantly marine waters and chemical data for samples collected from the Beverly Beach WWTF on June 15, 2009.

Beverly Beach WWTF NPDES# FL0039756	Class III Criteria	Effluent Limits	Effluent	
Organic Constituents (µg/L)				
None Detected	-	-	None Detected	
Metals (µg/L unless otherwise noted)				
Aluminum	≤ 1,500	-	60	U
Arsenic	≤ 50	-	0.89	I
Cadmium	≤ 8.8	-	0.03	U
Calcium (mg/L)	-	-	56.4	
Chromium-III	-	-	0.3	U
Copper	≤ 3.7	≤ 3.7 s	3.04	
Iron	≤ 300	-	30	U
Lead	≤ 8.5	-	2.43	
Magnesium (mg/L)	-	-	11	
Mercury	≤ 0.025	Report	-	
Nickel	≤ 8.3	-	1.07	
Selenium	≤ 71	-	0.2	U
Silver	≤ 2.3	-	0.025	U
Zinc	≤ 86	≤ 86.0 s	39	
Nutrients (mg/L)				
Ortho-phosphate	-	Report	-	
Total Phosphorus	-	Report	-	
Total Ammonia	-	Report	-	
Un-ionized Ammonia	-	-	-	
Nitrate and Nitrite	-	Report	-	
Total Kjeldahl Nitrogen	-	Report	-	
Organic Nitrogen	-	Report	-	
Total Nitrogen	-	Report	-	
General Physical and Chemical Parameters				
Dissolved Oxygen (mg/L)	≥ 4.0	≥ 6.0	2.3	
pH (SU)	6.5 - 8.5	6.5 - 8.5	6.6	
Conductivity (µmhos/cm)	-	-	1,249	
Temperature (°C)	-	-	27.1	
Salinity	-	Report	≤ 0.59	c
Sample Depth (m)	-	-	0	
Total Residual Chlorine (mg/L)	≤ 0.01	≤ 0.01 s	0.08	£Q
Total Suspended Solids (mg/L)	-	≤ 10.0 s	-	
CBOD, 5 day (mg/L), N - inhibited	-	≤ 20.0 s	-	
Flow (MGD)	-	0.085	0.03	
Hardness (mg $CaCO_3$)	-	-	186.13	c

Value exceeds the Class III Water Quality Criteria or permit limits

c - Value is calculated

s - Single sample

I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit

U - Material analyzed for but not detected; value reported is the method detection limit

Q - Sample held beyond normal holding time

- If 10 or fewer samples are taken within a month, the single sample limit is 400 CFU (62-302.530(6), F.A.C.)

£ - Sample measured in Bioassay Laboratory

Table 2. Parameters taken on Influent prior to biological treatment at the Beverly Beach WWTF on June 15, 2009

Beverly Beach WWTF NPDES# FL0039756	Influent collected 6/15/2009 1010	Influent collected 6/15/2009 1020	Influent collected 6/15/2009 1030
Metals (µg/L unless otherwise noted)			
Aluminum	2,350	540	130 I
Arsenic	2.54	1.66	0.8 I
Cadmium	1.09	0.2	0.15
Calcium (mg/L)	125	38.5	58.1
Chromium-III	7.8	2.7	0.85 I
Copper	120	94.2	10.3
Iron	2,130	500	370
Lead	9.09	3.28	0.85
Magnesium (mg/L)	13.9	5.72	12.9
Mercury	-	-	-
Nickel	11.6	3.93	1.41
Selenium	2.69	0.92	0.36 I
Silver	1.03	0.16	0.13
Zinc	1,070	252	122

I - The reported value is between the laboratory method detection limit and the laboratory practical quantitation limit

Florida Department of Environmental Protection

Central Laboratory Sample Submittal Form

Event ID *

Request Number: RQ-2009-05-18-40
Beverly Beach WWTP

Requester: Jennifer Paris
Field Report Prepared By: EA
Collected By: EA / TK
Send Final Report To: Tom Kallemeyn
Sampling Agency: DEP

Customer: NE-DIST
Project ID: FYI3
PMAS: 1143

Lab ID *	Location: Beverly Beach WWTP final effluent			☐ Comp ☑ Grab	Collection (begin) Date 6/15/09 Time 1000 Eastern Central	Collection (end) Date Time Eastern Central	Bottle Group(s)**			
	Field ID			Tot Res Chlorine (mg/L)	Diss Oxygen (mg/L) 2.3	Storet Station Number	A			
	Matrix (Include type e.g. Salt, Fresh, etc): Effluent	Temp (C): 27.1	pH: 6.64	Sample Depth ☐ m ☐ ft: n/a	0.62	☐ Salinity (PPTh) ☑ Sp Conductance (umho/cm): 1249	NPDES Number			
	Latitude ° ' "	Longitude ° ' "		Comments: Post de chlor. Please check Cl before for test.						
Lab ID *	Location: Beverly Beach WWTP influent			☐ Comp ☑ Grab	Collection (begin) Date 6/15/09 Time ~~1000~~ Eastern Central	Collection (end) Date Time Eastern Central	Bottle Group(s)**			
	Field ID			Tot Res Chlorine (mg/L)	Diss Oxygen (mg/L)	Storet Station Number	C			
	Matrix (Include type e.g. Salt, Fresh, etc)	Temp (C)	pH	Sample Depth ☐ m ☐ ft		☐ Salinity (PPTh) ☐ Sp Conductance (umho/cm)	NPDES Number			
	Latitude ° ' "	Longitude ° ' "		Comments: ~~Inf~~ I II III 1010(I) 1020(II) 1030(III)						
Lab ID *	Location: Equipment Blank			☐ Comp ☑ Grab	Collection (begin) Date Time 1007 Eastern Central	Collection (end) Date ~~1007~~ Time Eastern Central	Bottle Group(s)**			
	Field ID			Tot Res Chlorine (mg/L)	Diss Oxygen (mg/L)	Storet Station Number	B			
	Matrix (Include type e.g. Salt, Fresh, etc)	Temp (C)	pH	Sample Depth ☐ m ☐ ft		☐ Salinity (PPTh) ☐ Sp Conductance (umho/cm)	NPDES Number			
	Latitude ° ' "	Longitude ° ' "		Comments						
Lab ID *	Location			☐ Comp ☐ Grab	Collection (begin) Date Time Eastern Central	Collection (end) Date Time Eastern Central	Bottle Group(s)**			
	Field ID			Tot Res Chlorine (mg/L)	Diss Oxygen (mg/L)	Storet Station Number				
	Matrix (Include type e.g. Salt, Fresh, etc)	Temp (C)	pH	Sample Depth ☐ m ☐ ft		☐ Salinity (PPTh) ☐ Sp Conductance (umho/cm)	NPDES Number			
	Latitude ° ' "	Longitude ° ' "		Comments						

Relinquished By:	Date/Time	Shipping Method:	Received By:	Date/Time	Relinquished By:	Date/Time	Received By:	Date/Time
E-Mi	6/15/09	Fed ex	[redacted]	6/16/09 09:30				

* Shaded Areas for Lab use only.

** Please see reverse side for Bottle Group information.

last revised October 1, 2003

2 bloom jugs mt 1007 6/16/09

FDEP Biology Laboratory - Acute Screen Bioassay Bench Sheets

Facility: Beverly Beach WWTP

Address: 217 Starboard Drive

City: Beverly Beach County: Flagler 32136

Contact/District: Ed Jamro / Northeast

NPDES Permit #: FL 0039756

LIMS Job #: TLH-2009-06-16-07 LIMS Sample #: 119428

Lims Data Entry: 7-1-09 MF Data Entry Verification: 7-2-09 BA

Sample Collection: Date: 6-15-09 Time: 1000

Hold Time Start: Date: 6-15-09 Time: 1000

Comments:

Instructions (for below): Circle appropriate wording. If yes is circled, complete blanks.

Test Type: Screen

Static / Static Renewal / Flow-through

Test Duration: 48 (96) Hours.

Test 1 validation: Test 1: SOP TA 07_01

Control survival ≥90%: (Yes) No

Temperature Range ≤3°C: (Yes) No

Test 2 validation: Test 2: SOP TA 07_02

Control survival ≥90%: (Yes) No

Temperature Range ≤3°C: (Yes) No

(√one)

Test 1 incubated in: [x] Incubator #: 2 [ ] Waterbath #: _____

Test 2 incubated in: [x] Incubator #: 2 [ ] Waterbath #: _____

Initial sample handling:

PH adjustment : yes (no) Initial pH: ____ NaOH N HCl N ____ Drops mL Final pH: ____

Aeration : (yes) no Initial DO: 10.9 mg/L Final DO: 7.1 mg/L Duration: 30 minutes Rate: ~100 bubbles/min

Salinity adjusted (Test 1): yes (no) Initial Salinity: _____ Final Salinity: _____ Salts Hypersaline brine

Salinity adjusted (Test 2): yes (no) Initial Salinity: _____ Final Salinity: _____ Salts Hypersaline brine

Dechlorination: yes (no) _____mL of 0.025N Sodium Thiosulfate per liter of sample. Final TRC: _____

Light Intensity : 50 - 100 ft. candles

Photoperiod : 16 light 8 dark

Temperature Range °C: (If used)

Incubator # 2 min 26.0 max 26.7 mean 26.4

Incubator # ____ min: _____ max: _____ mean: _____

Waterbath # ____ min _____ max _____ mean _____

Room B246 min 24.9 max 25.5 mean 25.2

Sample Validation:

Temperature: Shipped ≤6°C (Yes) No — IF Hand Delivered: Cooling (received °C < collected °C) Yes No

Holding Time: ≤36 Hours (Yes) No (Composite-end of collection; grab-when collected; 4 in 24 - time last sample collected)

Water Quality Parameters	Batch #	20% DMW	Well Water	Moderately Hard Water	Salt Water ASW NSW Test 1	Salt Water ASW NSW Test 2	Other:	Original Sample	Measured by	Verified by
		6-16-09	6-15-09							
Field Total Residual Cl_2 (mg/L):		N/A	N/A	N/A	N/A	N/A		Not Measured		MF
Lab Total Residual Cl_2 (mg/L):		<0.03	<0.03					0.08	AGR	JD
Alkalinity (mg/L as $CaCO_3$):		81	141					172	AGR	JD
Hardness (mg/L as $CaCO_3$):		79	129					177	AGR	JD
Total Ammonia (mg/L as N):		<0.17	<0.17					2.31	BA	JD
Conductivity: (µmhos) mmhos		0.174 JD (A)	0.277 JD					1.67	JD/BA	JD/MF
Salinity (ppth):		—	—					0.98	BA	JD

Investigators' Signatures

James Daniel

Amelia Rankin

Marshall Faircloth

Bruce Alexander


Loretta C. Wolfe

REVIEWER

(A) Corrected mmhos to mmhos JD by MF 7-2-09

V 1.6 7/8/08

Appendix B. (continued)



FDEP Biology Laboratory - Bioassay Survival Bench Sheet

LIMS Sample #: 1194428 Test #: 112 SOP#:TA 07 01 Test Started: Date 6.16.09 Time: 12:50

Organism/Batch/Age: C.dubia / 6-20-09 / <24hrs Test Ended: Date 6.20.09 Time: 1300

Chamber/Test Volume: 30 / 20 ml Diluent/ Batch: DMW / 6.16.09 Test Duration: 48 hr 96 hr

Food/Batch: [x] YCT 1-22-09 [x] P.sub 2-13-09

[ ] Artemia Lot#_____ Batch #: 0hr_____ 24hr_____ 48hr_____ 72hr_____

Feeding: [x] Prior to Test [x] Prior to Renewal [✓] 0 hr [ ] 24 hr [✓] 48 hr [ ] 72 hr

Concentration	Replicate	Chamber #	Test Hour 0 hr	24 hr	48 hr BR	48 hr AR	72 hr	96 hr
Ctl	A	A	5	5	5	5	5	
	B	B	5	5	5	5	5	
	C	C	5	5	5	5	5	
	D	D	5	5	5	5	5	
100%	A	A	5	5	4 10	4	0 4D	
	B	B	5	5	2 30	2	0 2D	
	C	C	5	5	1 40	1	0 1D	
	D	D	5	5	1 40	1	0 1D	

Loaded/Verified by: BA / MF Checked by: BA BA BA BA

m = missing d = dead BR/AR = Before/After Renewal

Test Results:

Screening Tests: Report LC50 as >100%, =100%, or <100%.

% mortality in 100% sample: 100% LC50: MF < 100 % 7-1-09

If Calculated: 95% CI_____ Method_____

Comments: Terminated at 72 hours. MF 7-2-09

V 2.3 7/15/2008

Substitue highest test concentration used if other than 100% (example: Ocean outfall tested at 30% concentration).

Page 000008

Appendix B. (continued)

FDEP Biology Laboratory - Bioassay Survival Bench Sheet

LIMS Sample #: 1194428 Test #: 2/2 SOP#:TA 07 02 Test Started: Date 6/6/09 Time: 1200

Organism/Batch/Age: C.leedsi / 6/6/09 / 13 days Test Ended: Date 6/8/09 Time: 1200

Chamber/Test Volume: 1000 / 500 ml Diluent/ Batch: Well / 6/15/09 Test Duration: 48 hr

Food/Batch: [ ] YCT [ ] P.sub

[X] Artemia Lot# 38138 Batch #: 0hr 7/9/09 24hr ___ 48hr 8/09 72hr ___

Feeding: [X] Prior to Test [X] Prior to Renewal [X] 0 hr [ ] 24 hr [X] 48 hr [ ] 72 hr

Concentration	Replicate	Chamber #	0 hr	24 hr	48 hr BR	48 hr AR	72 hr	96 hr
(+)	A	F1	5	5	5	5	5	5
	B	F2	5	5	5	5	5	5
	C	F3	5	5	5	5	5	5
	D	F4	5	5	5	5	5	5
100%	A	F5	5	3 2D	3	3	3	3
	B	F6	5	5	4 1D	4	4	4
	C	F7	5	5	3 2D	3	2 1D	2
	D	F8	5	5	5	5	5	5

Loaded/Verified by: [initials] Checked by: [initials]

m = missing d = dead BR/AR = Before/After Renewal

Comments:

Test Results:

Screening Tests: Report LC50 as >100%, =100%, or <100%.

% mortality in 100% sample: 30% LC50: >100%

If Calculated: 95% CI ______ Method ______

V 2.3 7/15/2008

Substitue highest test concentration used if other than 100% (example: Ocean outfall tested at 30% concentration).

Page 000009

Appendix B. (continued)

FDEP Biology Laboratory - Bioassay Parameter Bench Sheet

LIMS Sample # : 119442 8 mL Test #: 1 of 2

TEST SOP #: TA07_01 Test Species: ☑ Ceriodaphnia dubia ☐ Cyprinella leedsi ☐ Pimephales promelas

Test aerated: yes (no) (circle one) Check 1: ☐ Americamysis bahia ☐ Menidia beryllina ☐ Other:

Concentration CTL	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate	M	/	A	M	A	*
pH (S.U.)	8.0	/	8.4	8.0	7.8	
Temperature °C	24.0	/	24.5	25.1	24.7	
Dissolved Oxygen mg/L aerate if < 4	7.7	/	7.4	7.5	6.7	
Conductivity µmhos mmhos	0.174	/	0.191	0.177	0.186	
Salinity ppth	–	/	–	–	–	
(initials) Measured by:	BA	/	MF	MF	BA	
(initials) Recorded by:	BA		MF	MF	BA	

Comments: * Test Terminated @ 72 hours MF 8-25-09

Salinity only needs measuring if saltwater.

Concentration	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate						
pH (S.U.)						
Temperature °C						
Dissolved Oxygen mg/L aerate if < 4						
Conductivity µmhos mmhos						
Salinity ppth						
(initials) Measured by:						
(initials) Recorded by:						

Comments:

Concentration 100%	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate	M	/	A	M	A	*
pH (S.U.)	8.2	/	8.3	7.7	8.3	
Temperature °C	26.2	/	24.3	25.2	24.3	
Dissolved Oxygen mg/L aerate if < 4	7.1	/	7.0	7.9	6.8	
Conductivity µmhos mmhos	1.06	/	1.017	1.052	1.092	
Salinity ppth	–	/	–	–	–	
(initials) Measured by:	BA	/	MF	MF	BA	
(initials) Recorded by:	BA	/	MF	MF	BA	

Comments:

000010

Page

FDEP Biology Laboratory - Bioassay Parameter Bench Sheet

LIMS Sample # : 1194428 Test #: 2 of 2

TEST SOP #: TA07_02 Test Species: ☐ *Ceriodaphnia dubia* ☒ *Cyprinella leedsi* ☐ *Pimephales promelas*

Test aerated: yes (no) (circle one) Check 1: ☐ *Americamysis bahia* ☐ *Menidia beryllina* ☐ Other:_____

Concentration ctrl	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate	A	B	C	C	D	A
pH (S.U.)	7.9	8.3	8.3	7.9	8.1	8.1
Temperature °C	24.3	25.7	25.0	24.4	24.7	24.5
Dissolved Oxygen mg/L aerate if < 4	7.5	8.2	7.1	7.4	6.8	7.5
Conductivity (µmhos) mmhos	277	296	279	278	286	313
Salinity ppth	–	–	–	–	–	–
(initials) Measured by:	JS	[illegible]	[illegible]	BA	JS	JS
(initials) Recorded by:	JS	[illegible]	[illegible]	BA	JS	JS

Comments:

Concentration 100%	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate	A	B	C	C	D	A
pH (S.U.)	8.2	8.3	8.3	7.8	8.0	8.2
Temperature °C	25.9	25.7	25.1	24.2	24.6	24.7
Dissolved Oxygen mg/L aerate if < 4	7.6	7.7	6.4	7.3	6.6	7.1
Conductivity (µmhos) mmhos	1074	1051	1057	1039	1059	1080
Salinity ppth	–	–	–	–	–	–
(initials) Measured by:	JS	[illegible]	[illegible]	BA	JS	JS
(initials) Recorded by:	JS	[illegible]	[illegible]	BA	JS	JS

Comments:

Salinity only needs measuring if saltwater.

Concentration	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate						
pH (S.U.)						
Temperature °C						
Dissolved Oxygen mg/L aerate if < 4						
Conductivity µmhos mmhos						
Salinity ppth						
(initials) Measured by:						
(initials) Recorded by:						

Comments:

Concentration	0 Hr.	24 Hr.	48 Hr. before renewal	48 Hr. after renewal	72 Hr.	96 Hr.
Replicate						
pH (S.U.)						
Temperature °C						
Dissolved Oxygen mg/L aerate if < 4						
Conductivity µmhos mmhos						
Salinity ppth						
(initials) Measured by:						
(initials) Recorded by:						

Comments:

Appendix B. (continued)

Bioassay Instrument ID

Test ID: Beverly Beach WWTP Dates: 6-16-09 — 6-20-09

METER / DEVICE	ID	SOP	Parameter	Method	√used
YSI Model 58 Dissolved Oxygen Meter	90H018262	TA06_04	Dissolved Oxygen	SM 4500 O G	✓
Accumet AR-10 pH Meter	93312105	TA06_23	pH	SM 4500 H+	✓
Mettler-Toledo SevenMulti Conductivity Meter	SN 1225117049 Probe H04257	TA06_25	Conductivity	SM 2510 B	✓
			Salinity	SM 2520 B	✓
Denver Model 225 ISE with ammonia probe	SN K01377	TA06_17	Ammonia	SM 4500 NH3 F	✓
Thermometer (DO probe)	YSI 5750 SN 05J1720	TA06_05	Temperature	SM-2530B modified DEP SOP-001/01 FT1400	✓
Hach Pocket Colorimeter II	05050C026378	TA06_22	Total Residual Chlorine	EPA 330.5 SM 4500 CL G	✓
Alkalinity (Hach Kit)	No SN	TA06_08	Alkalinity	SM 2320 B	✓
Hardness (Hach Kit)	No SN	TA06_09	Hardness	SM 2340 C	✓
OHAUS Balance 250D	1125481084	TA06_21 TA06_27	Weight	-	N/A
S-Weights	BIO-S-WEIGHTS-01	NA	Balance check	-	N/A

SM-2530B modified to allow use of electronic and non-mercury filled thermometers.
Insert other device information in blank spaces(if used). Test ID = Facility or SRTs (acute SRT–Chronic SRT)

entered by M. Faulstich 7-2-09

V1.1 6/12/08 MF

PAGE

000012

Appendix C. SRT Bench Sheets and Statistical Analysis


Florida Department of Environmental Protection
Bureau of Laboratories

Standard Reference Toxicant (SRT) Test Data - 96-hour Acute Toxicity
Ceriodaphnia dubia (water flea) - Sodium Chloride (NaCl)

Date	LC50	Mean LC50	Std Dev	Lower Control Limit	Upper Control Limit
12/04/07	1.82	1.89	0.19	1.50	2.27
01/22/08	1.85	1.88	0.19	1.50	2.26
02/05/08	1.94	1.87	0.18	1.50	2.24
03/04/08	1.92	1.87	0.18	1.50	2.24
04/01/08	2.26	1.89	0.20	1.49	2.30
05/06/08	1.99	1.89	0.20	1.49	2.28
06/03/08	1.73	1.88	0.20	1.48	2.28
07/08/08	2.12	1.89	0.21	1.47	2.30
08/05/08	1.87	1.88	0.20	1.47	2.29
09/03/08	2.18	1.89	0.21	1.46	2.31
10/11/08	1.98	1.91	0.20	1.51	2.31
11/04/08	1.94	1.90	0.19	1.52	2.29
12/02/08	2.09	1.92	0.19	1.55	2.30
01/06/09	2.09	1.95	0.17	1.60	2.30
02/03/09	1.96	1.94	0.16	1.61	2.26
03/03/09	2.07	1.95	0.16	1.63	2.27
03/31/09	2.02	1.96	0.16	1.64	2.28
05/05/09	1.69	1.96	0.15	1.66	2.27
05/12/09	2.04	1.98	0.14	1.69	2.26
06/02/09	2.15	1.99	0.15	1.69	2.28

Lower Control Limit = mean - 2 * Std Dev
Upper Control Limit = mean + 2 * Std Dev

CV = 7.42
EPA reference 75th quartile CV = 29%



Appendix C. (continued)


Florida Department of Environmental Protection
Bureau of Laboratories

Standard Reference Toxicant (SRT) Test Data - 96-hour Acute Toxicity
Cyprinella leedsi (bannerfin shiner) - Sodium Chloride (NaCl)


Date	LC50	Mean LC50	Std Dev	Lower Control Limit	Upper Control Limit
12/04/07	7.35	8.19	0.47	7.25	9.11
01/08/08	8.11	8.17	0.47	7.24	9.11
02/05/08	8.66	8.17	0.47	7.25	9.09
03/04/08	7.57	8.16	0.47	7.21	9.10
04/01/08	8.24	8.18	0.46	7.27	9.10
05/15/08	7.96	8.14	0.51	7.12	9.15
06/03/08	8.21	8.15	0.51	7.14	9.16
07/08/08	7.81	8.12	0.51	7.10	9.14
08/05/08	7.76	8.07	0.48	7.10	9.04
09/03/08	8.01	8.09	0.47	7.14	9.03
10/11/08	7.45	8.06	0.49	7.08	9.05
11/04/08	8.30	8.04	0.47	7.10	8.98
12/02/08	8.14	8.03	0.47	7.10	8.97
01/06/09	8.28	8.03	0.46	7.10	8.95
02/03/09	8.09	8.04	0.46	7.12	8.96
03/03/09	8.06	8.06	0.45	7.16	8.96
03/31/09	9.04	8.07	0.46	7.15	8.98
04/08/09	8.09	8.05	0.45	7.15	8.96
05/05/09	8.11	8.02	0.43	7.17	8.87
06/02/09	8.52	8.08	0.41	7.27	8.90

Lower Confidence Limit = mean - 2 * Std Dev
Upper Confidence Limit = mean + 2 * Std Dev

CV = 5.05
EPA reference 75th quartile CV = 19%



Appendix C. (continued)



FDEP Biology Laboratory - Acute SRT Bench Sheet

Method from EPA-821-R-02-012 except *H. azteca*

Test Organism: (check one)
- ☐ *Americamysis bahia* — Method 2007.0 TA07.03
- ☐ *Menidia Beryllina* — Method 2006.0 TA07.04
- ☐ *Hyalella azteca* — Method 100.1 EPA-600-R-99-064
- ☑ *Ceriodaphnia dubia* — Method 2002.0 TA07.01
- ☐ *Cyprinella leedsi* — Method 2000.0 TA07.02
- ☐ *Pimephales promelas* — Method 2000.0 TA07.02

Test Type: ☐ non-renewal ☑ renewal

Test Page 1 of 2

Diluent/ Batch #: DMW / 5-18-09

Toxicant/ Batch#: NaCl /

Organism Batch: 19-09

Age: 24hrs

Test Beginning: Date: 6-2-09 Time: 13:25

Test Ending: Date: 6-6-09 Time: 1200

6-6-09 Prog unit

Water Quality Parameters:	Diluent	SOP	Initials
Total Residual Cl_2 (mg/L):	<.03	TA06_22	MF
Alkalinity (mg/L as $CaCO_3$):	83	TA06_08	BA
Hardness (mg.L as $CaCO_3$):	96	TA06_09	BA
Total Ammonia (mg/L as N):	<0.17	TA06_17	MF
Conductivity: ~~umhos~~ mmhos	0.181	TA06_25	JD
Salinity (ppth):	—	TA06_25	—

Food:	Batch
☑ YCT	j. 12-09
☑ *P. subcapitata*	2-13-09
☐ Artemia Lot #	

Artemia Batch:

0 hr:	
24 hr:	
48 hr:	
72 hr:	

Chamber size: 30 mL

Test volume: 20 mL per replicate

Concentrations prepared by: BA

Temperature Range °C (if used)

Test Incubated in: Incubator # 2 Waterbath # ____ Incubator # 2 min. 25.8 max. 26.7 mean 26.3

Light Intensity: 50-100 Ft. candles Waterbath # ___ min. ____ max. ____ mean ____

Photoperiod: 16 hours Light / 8 hours dark Room B246 min. 24.9 max. 26.0 mean 25.5

Feeding: √as needed
☑ Before test
☐ 0 hr
☑ 24 hr
☐ 48 hr
☐ 72 hr

all species 2 hrs prior to test

mysids daily

all species except *H. azteca* 2 hr prior to renewal

H. azteca 0 hr and 48 hr

Concentration µg/L mg/L g/L	Replicate	Chamber #	Test Hour 0 hr	24 hr	48 hr BR	48 hr AR	72 hr	96 hr
Control	A	A	5	5	5	5	5	5
	B	B	5	5	5	5	5	5
	C	C	5	5	5	5	5	5
	D	D	5	5	5	5	5	5
1.5	A	A	5	5	5	5	5	5
	B	B	5	5	5	5	5	5
	C	C	5	5	5	5	5	5
	D	D	5	5	5	5	5	5
2.0	A	A	5	5	4 (1)	4	3 (1)	2 (1)
	B	B	5	5	5	5	5	5
	C	C	5	5	4 (1)	4	4	4
	D	D	5	5	5	5	5	5
2.5	A	A	5	5	3 (2)	3	1 (2)	0 (1)
	B	B	5	3 (2)	2 (1)	2	0 (2)	—
	C	C	5	5	0 (5d)	0	—	—
	A	D	5	4 (1d)	1 (4d)	1	1	1
3.0	A	A	5	5	1 (4d)	1	0 (1)	—
	B	B	5	3 (2) (A)	—	—	—	—
	C	C	5	3 (2)	1 (4d)	1	0 (1)	—
	D	D	5	3 (2d)	1 (4d)	1	0 (1)	—
4.0	A	A	5	0 (5d)	0 (5d)	—	—	—
	B	B	5	2 (3d)	0 (5d)	—	—	—
	C	C	5	0 (5d)	0 (5d)	—	—	—
	D	D	5	0 (5d)	0 (5d)	—	—	—

H. azteca		
0 hr	Alk	Hrd
Well		
100%		
96 hr	Alk	Hrd
Well		
100%		

Organisms loaded by: BA Checked by: MF

Loading Verified by: MF AR = after renewal

m = missing d = dead BR = before renewal hr = hour

Investigators' Signatures

Marshall Faircloth

Amelia Rankin

Brett Alexander

Reviewer: Britta Wolfe

Comments: (A) spilled vial after counting ROC 6-05-09

(B) transcription error ROC 6-04-09

Method: TSK

Statistics: LC50	95% confidence intervals Lower	Upper
48 hour: 2.43	2.26	2.61
96 hour: 2.15	2.04	2.26

PAGE 00 059

Revised 7/15/2008 mf

Appendix C. (continued)

FDEP Biology Laboratory - Acute SRT Bench Sheet
0-96 hour parameters

Methods from EPA-821-R-02-012 except *H. azteca*

Test Page 2 of 2

Test Organism: (check one)
- ☐ *Americamysis bahia* Method 2007.0 TA07.03
- ☐ *Menidia Beryllina* Method 2006.0 TA07.04
- ☐ *Hyalella azteca* Method 100.1 EPA-600-R-99-064
- ☑ *Ceriodaphnia dubia* Method 2002.0 TA07.01
- ☐ *Cyprinella leedsi* Method 2000.0 TA07.02
- ☐ *Pimephales promelas* Method 2000.0 TA07.02

Test Beginning: Date: 6.2.09 Time: 1325
Test Ending: Date: 6.6.09 Time: 1200

Test Type: ☐ non-renewal ☑ renewal

hr = hour AR = after renewal BR = before renewal

Concentration µg/L mg/L g/L	Replicate	Test Hour	pH (SU)	Temperature (° C)	Dissolved Oxygen (mg/L)	Conductivity ☐ µmhos ☑ mmhos	Salinity (ppth)
Control		0 hr	7.8	24.6	7.2	0.181	—
		24 hr	—	—	—	—	—
		48 hr BR	8.0	24.2	6.7	0.276	
		48 hr AR	8.1	24.5	7.3	0.181	
		72 hr	—	—	—	—	
		96 hr	7.9	24.3	7.7	0.139	
1.5		0 hr	7.8	24.1	7.3	2.88	—
		24 hr	—	—	—	—	
		48 hr BR	8.0	24.2	6.7	3.06	
		48 hr AR	8.1	24.7	7.1	2.91	
		72 hr	—	—	—	—	
		96 hr	7.9	24.4	7.4	2.99	
2.0		0 hr	7.8	24.1	7.2	3.88	—
		24 hr	—	—	—	—	
		48 hr BR	8.0	24.2	6.8	4.55	
		48 hr AR	8.2	24.7	7.1	3.83	
		72 hr	—	—	—	—	
		96 hr	8.0	24.4	7.4	3.99	
3.5		0 hr	7.9	24.0	7.3	4.69	—
		24 hr	—	—	—	—	
		48 hr BR	8.0	24.2	6.9	5.50	
		48 hr AR	8.2	24.8	7.2	4.73	
		72 hr	—	—	—	—	
		96 hr	8.0	24.2	7.6	4.95	
3.0		0 hr	7.9	24.0	7.3	5.59	—
		24 hr	—	—	—	—	
		48 hr BR	8.1	24.2	6.9	6.47	
		48 hr AR	8.2	24.7	7.1	5.56	
	A	72 hr	8.1	24.4	7.1	5.65	
		96 hr					
4.0		0 hr	8.0	24.0	7.1	7.28	—
		24 hr	—	—	—	—	
		48 hr BR	8.1	24.2	6.9	8.83	
		48 hr AR					
		72 hr					
		96 hr					

Investigators Signatures: Amelia Rankin, James Daniel, Becca Albritton, Marshall Faircloth

Reviewed By: Loretta Wolf

Measured by:
- 0 hr: DA
- 24 hr: —
- 48 hr BR: ALR
- 48 hr AR: ALR
- 72 hr:
- 96 hr: DA


Measure/record salinity for marine tests

Comments:

PAGE 00 060

Revised 07/15/2008 MF

Appendix C. (continued)



FDEP Biology Laboratory - Acute SRT Bench Sheet

Method from EPA-821-R-02-012 except *H. azteca*

Test Organism: (check one)
- ☐ *Americamysis bahia* Method 2007.0 TA07.03
- ☐ *Menidia Beryllina* Method 2006.0 TA07.04
- ☐ *Hyalella azteca* Method 100.1 EPA-600-R-99-064
- ☐ *Ceriodaphnia dubia* Method 2002.0 TA07.01
- ☒ *Cyprinella leedsi* Method 2000.0 TA07.02
- ☐ *Pimephales promelas* Method 2000.0 TA07.02

Test Type: ☐ non-renewal ☒ renewal

Test Page 1 of 2

Diluent/ Batch #: well 1 6.1.09
Toxicant/ Batch#: NaCl 1 6.1.09
Organism Batch: 6.2.09 Age: 0 days
Test Beginning: Date: 6.2.09 Time: 1320
Test Ending: Date: 6.6.09 Time: 1400

Water Quality Parameters:	Diluent	SOP	Initials
Total Residual Cl_2 (mg/L):	0.03	TA05_22	CF
Alkalinity (mg/L as $CaCO_3$):	160	TA06_08	DS
Hardness (mg.L as $CaCO_3$):	153	TA06_09	DS
Total Ammonia (mg/L as N):	0.017	TA05_17	MF
Conductivity: ~~umhos~~ mmhos	0.277	TA06_25	JD
Salinity (ppth):	—	TA06_25	—

Food:	Batch
☐ YCT	
☐ *P. subcapitata*	
☑ Artemia Lot #	38438

Artemia Batch:
- 0 hr: 71-09
- 24 hr:
- 48 hr: 73-09
- 72 hr:

Chamber size: 1000 mL
Test volume: 500 mL per replicate

Concentrations prepared by: JD
Temperature Range °C:(if used)
Test Incubated in: Incubator # 2 Waterbath # ____ Incubator # 2 min. 25.8 max. 26.7 mean 26.3
Light Intensity: 50-100 Ft. candles Waterbath # ___ min. ____ max. ____ mean ____
Photoperiod: 16 hours Light / 8 hours dark Room B246 min. 24.9 max. 26.0 mean 25.5

Feeding: √as needed
- ☑ Before test
- ☐ 0 hr
- ☐ 24 hr
- ☑ 48 hr
- ☐ 72 hr

all species 2 hrs prior to test
mysids daily
all species except *H. azteca* 2 hr prior to renewal
H. azteca 0 hr and 48 hr

Concentration µg/L	mg/L	pH	Replicate	Chamber #	Test Hour 0 hr	24 hr	48 hr BR	48 hr AR	72 hr	96 hr
Control			A	D1	10	10	10	10	10	10
			B	D2	10	10	10	10	10	10
6			A	D3	10	10	10	10	10	10
			B	D4	10	10	10	10	10	10
7			A	D5	10	10	10	10	10	10
			B	D6	10	10	10	10	10	10
8			A	D7	10	10	10	10	10	10
			B	D8	10	8 2D	8	8	8	8
9			A	D9	10	1 4D	0 6D	—	—	—
			B	D10	10	3 7D	3	3	3	3
10			A	D11	10	0 8D	—	—	—	—
			B	D12	10	0 6D	—	—	—	—

H. azteca		
0 hr	Alk	Hrd
Well		
100%		
96 hr	Alk	Hrd
Well		
100%		

Organisms loaded by: JD Checked by: JD JD JD JD JD JD
Loading Verified by: DS AR = after renewal
m = missing d = dead BR = before renewal hr = hour

Investigators' Signatures
Reviewer: Mitta Wolfe

Comments:

Method: TSK

Statistics: LC50	95% confidence intervals Lower	Upper
48 hour: 8.52	8.31	8.73
96 hour: 8.52	8.31	8.73

PAGE 00 661

Revised 7/15/2008 mf

Appendix C. (continued)

FDEP Biology Laboratory - Acute SRT Bench Sheet
0-96 hour parameters

Methods from EPA-821-R-02-012 except *H. azteca*

Test Page 2 of 2

Test Organism: (check one)
- ☐ *Americamysis bahia* Method 2007.0 TA07.03
- ☐ *Menidia Beryllina* Method 2006.0 TA07.04
- ☐ *Hyalella azteca* Method 100.1 EPA-600-R-99-064
- ☐ *Ceriodaphnia dubia* Method 2002.0 TA07.01
- ☒ *Cyprinella leedsi* Method 2000.0 TA07.02
- ☐ *Pimephales promelas* Method 2000.0 TA07.02

Test Beginning: Date: 6.2.09 Time: 1210
Test Ending: Date: 6.6.09 Time: 1102

Test Type: ☐ non-renewal ☒ renewal

hr = hour AR = after renewal BR = before renewal

Concentration µg/L mg/L	Replicate	Test Hour	pH (SU)	Temperature (°C)	Dissolved Oxygen (mg/L)	Conductivity ☒ µmhos ☐ mmhos	Salinity (ppth)
Control	A	0 hr	7.6	24.0	7.4	0277	–
	B	24 hr	8.0	24.2	6.5	0.284	–
	A	48 hr BR	8.1	25.5	6.5	0.286	–
	A	48 hr AR	8.1	24.8	7.5	0.284	–
	B	72 hr	7.9	25.3	5.1	0.280	–
	A	96 hr	7.6	25.6	6.0	0.295	–
6	A	0 hr	7.6	24.0	7.7	11.30	–
	B	24 hr	8.0	24.1	6.6	11.08	–
	A	48 hr BR	8.1	25.3	6.3	10.89	–
	A	48 hr AR	8.0	24.6	7.1	11.04	–
	B	72 hr	7.9	25.5	4.7	11.1	–
	A	96 hr	7.7	25.6	5.4	11.4	–
7	A	0 hr	7.7	24.0	7.7	12.96	–
	B	24 hr	8.0	24.1	6.5	12.96	–
	A	48 hr BR	8.1	25.4	6.2	12.80	–
	A	48 hr AR	8.0	24.6	7.1	12.80	–
	B	72 hr	7.9	25.4	4.9	12.8	–
	A	96 hr	7.8	25.6	5.5	13.1	–
8	A	0 hr	7.8	24.0	7.7	14.66	–
	B	24 hr	8.0	24.0	6.5	14.69	–
	A	48 hr BR	8.1	25.2	6.2	14.18	–
	A	48 hr AR	8.0	24.6	7.0	14.12	–
	B	72 hr	8.0	25.4	5.4	14.2	–
	A	96 hr	7.9	25.5	5.8	14.5	–
9	A	0 hr	7.9	24.0	7.7	16.36	–
	B	24 hr	7.9	24.0	6.3 59	16.62	–
	A	48 hr BR	8.1	25.2	6.4	16.13	–
	A	48 hr AR	8.0	24.6	6.9	16.31	–
	B	72 hr	8.0	25.9	5.6	16.4	–
	A	96 hr	8.0	25.6	6.1	16.7	–
10	A	0 hr	7.8	24.0	7.6	17.96	–
	B	24 hr	7.5	24.8	5.3	17.64	–
–	–	48 hr BR	–	–	–	–	–
–	–	48 hr AR	–	–	–	–	–
–	–	72 hr	–	–	–	–	–
–	–	96 hr	–	–	–	–	–

Investigators Signatures
Jessica Dinzel
Charles Burt
Bruce Allsopp
Amelia Karlen
Marshall Faircloth
Reviewed By: Loretta Wolfe

Measured by:
0 hr:
24 hr:
48 hr BR:
48 hr AR:
72 hr:
96 hr:

Measure/record salinity for marine tests

Comments: A) transcription error KRG 03.09

PAGE 00 062

Revised 07/15/2008 MF

Appendix C. (continued)

***Ceriodaphnia dubia* Acute Standard Reference Toxicant Test**

DATE: 6-2-09 DURATION: 96 h TOXICANT: NaCl
SPECIES: *Ceriodaphnia dubia*

RAW DATA: Concentration (g/L)	Number Exposed	Mortalities
.00	20	0
1.50	20	0
2.00	20	4
2.50	20	19
3.00	15	15
4.00	20	20

SPEARMAN-KARBER TRIM: .00%

SPEARMAN-KARBER ESTIMATES: LC50: **2.15**
95% LOWER CONFIDENCE: 2.04
95% UPPER CONFIDENCE: 2.26

***Cyprinella leedsi* Acute Standard Reference Toxicant Test**

DATE: 6-2-09 DURATION: 96 h TOXICANT: NaCl
SPECIES: *Cyprinella leedsi*

RAW DATA: Concentration (g/L)	Number Exposed	Mortalities
.00	20	0
6.00	20	0
7.00	20	0
8.00	20	2
9.00	20	17
10.00	20	20

SPEARMAN-KARBER TRIM: .00%

SPEARMAN-KARBER ESTIMATES: LC50: **8.52**
95% LOWER CONFIDENCE: 8.31
95% UPPER CONFIDENCE: 8.73

Appendix D. Test Organism Receipts

MARINCO BIOASSAY LABORATORY
The Aquatic Toxicology Specialists

NELAP Certification # E84191

Organism Shipment Record

State of Florida Aquaculture Certificate Number AQ0668007

Date: 6/1/09

Shipped to: FDEP

P.O. No:

Species	Quantity	Age	Brood Number	Temp.	pH	Salinity
Mysidopsis bahia	150	4 DAYS	M2090528	25°C	7.9 s.u	20‰
Menidia beryllina	150	12 DAYS	SS090520	25°C	7.9 s.u.	20‰
						Hardness
Cyprinella leedsi	200	11 DAYS	FM090521	25°C	7.8 s.u	80 mg/L
Pimephales promelas	150	8 DAYS	FM090524	25°C	7.8 s.u	80 mg/L

Packed by:

Shipped Via: FedEx

Notes:

Thank you for your order.

4569 Samuel Street · Sarasota, FL 34233 · Tel: 941-925-3594 · Fax: 941-922-3874 · Web: www.biologylab.com

Appendix D. (continued)

MARINCO BIOASSAY LABORATORY
The Aquatic Toxicology Specialists

NELAP Certification # E84191

Organism Shipment Record

State of Florida Aquaculture Certificate Number AQ0668007

Date: 6/15/09

Shipped to: FL DEP

P.O. No:

Species	Quantity	Age	Brood Number	Temp.	pH	Salinity
Mysidopsis bahia	100	3 DAYS	MS090612	25°C	7.9 s.u	20‰
Menidia beryllina	100	12 DAYS	MS090603	25°C	7.9 s.u	20‰
						Hardness
Cyprinella leedsi	100	12 DAYS	CL090603	25°C	7.8 s.u	80mg/L
Pimephales promelas	350	<24 HRS	FM090614-1700	25°C	7.8 s.u	80mg/L

Packed by:

Shipped Via: FedEx

Notes:

Thank you for your order.

4569 Samuel Street · Sarasota, FL 34233 · Tel: 941-925-3594 · Fax: 941-922-3874 · Web: www.biologylab.com

Appendix E. Chemical Analyses performed on the effluent from the Beverly Beach Wastewater Treatment Facility Outfall D-001 and on influent (prior to treatment) into the facility, sampled on June 15, 2009.

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:00	EFFLUENT	Toxicology	Bioassay-Acute-Screen-FW-Fish, LC50	100	L	LC50		
6/15/2009 10:00	EFFLUENT	Toxicology	Bioassay-Acute-Screen-FW-C.dubia, LC50	100	K	LC50		
6/15/2009 10:00	EFFLUENT	Metals	Chromium	0.3	U	ug/L	0.3	1.2
6/15/2009 10:00	EFFLUENT	Metals	Copper	3.04		ug/L	0.5	0.5
6/15/2009 10:00	EFFLUENT	Metals	Magnesium	11		mg/L	0.04	0.16
6/15/2009 10:00	EFFLUENT	Metals	Arsenic	0.89	I	ug/L	0.25	1
6/15/2009 10:00	EFFLUENT	Metals	Aluminum	60	U	ug/L	60	240
6/15/2009 10:00	EFFLUENT	Metals	Cadmium	0.03	U	ug/L	0.03	0.12
6/15/2009 10:00	EFFLUENT	Metals	Silver	0.025	U	ug/L	0.025	0.1
6/15/2009 10:00	EFFLUENT	Metals	Selenium	0.2	U	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Metals	Zinc	39		ug/L	5	20
6/15/2009 10:00	EFFLUENT	Metals	Calcium	56.4		mg/L	0.075	0.3
6/15/2009 10:00	EFFLUENT	Metals	Iron	30	U	ug/L	30	120
6/15/2009 10:00	EFFLUENT	Metals	Nickel	1.07		ug/L	0.25	1
6/15/2009 10:00	EFFLUENT	Metals	Lead	2.43		ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Pesticides	DDT-p,p'	0.03	U	ug/L	0.03	0.12
6/15/2009 10:00	EFFLUENT	Pesticides	Gamma-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:00	EFFLUENT	Pesticides	Heptachlor Epoxide	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Methoxychlor	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Dieldrin	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Metalaxyl	0.25	U	ug/L	0.25	1
6/15/2009 10:00	EFFLUENT	Pesticides	Prometryn	0.15	UJ	ug/L	0.15	0.6
6/15/2009 10:00	EFFLUENT	Pesticides	DDD-p,p'	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Endosulfan II	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Toxaphene	0.75	U	ug/L	0.75	3
6/15/2009 10:00	EFFLUENT	Pesticides	Alpha-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:00	EFFLUENT	Pesticides	Endrin	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Heptachlor	0.01	U	ug/L	0.01	0.04
6/15/2009 10:00	EFFLUENT	Pesticides	Azinphos Methyl	0.2	UJ	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Pesticides	Bromacil	0.2	U	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Pesticides	Chlorpyrifos Ethyl	0.05	U	ug/L	0.05	0.2

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:00	EFFLUENT	Pesticides	Ethion	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Naled	0.8	U	ug/L	0.8	3.2
6/15/2009 10:00	EFFLUENT	Pesticides	Endrin Aldehyde	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Chlorpyrifos Methyl	0.1	U	ug/L	0.1	0.4
6/15/2009 10:00	EFFLUENT	Pesticides	Ethoprop	0.1	U	ug/L	0.1	0.4
6/15/2009 10:00	EFFLUENT	Pesticides	Fonofos	0.1	UJ	ug/L	0.1	0.4
6/15/2009 10:00	EFFLUENT	Pesticides	Malathion	0.15	U	ug/L	0.15	0.6
6/15/2009 10:00	EFFLUENT	Pesticides	Phorate	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Endosulfan I	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Metolachlor	0.5	UJ	ug/L	0.5	2
6/15/2009 10:00	EFFLUENT	Pesticides	Parathion Methyl	0.1	U	ug/L	0.1	0.4
6/15/2009 10:00	EFFLUENT	Pesticides	Simazine	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Aldrin	0.01	U	ug/L	0.01	0.04
6/15/2009 10:00	EFFLUENT	Pesticides	Hexazinone	0.1	U	ug/L	0.1	0.4
6/15/2009 10:00	EFFLUENT	Pesticides	DDE-p,p'	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Parathion Ethyl	0.15	U	ug/L	0.15	0.6
6/15/2009 10:00	EFFLUENT	Pesticides	Norflurazon	0.15	U	ug/L	0.15	0.6
6/15/2009 10:00	EFFLUENT	Pesticides	Metribuzin	0.1	U	ug/L	0.1	0.4
6/15/2009 10:00	EFFLUENT	Pesticides	Diazinon	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Butylate	0.2	UJ	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Pesticides	Ametryn	0.05	UJ	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Alachlor	0.6	UJ	ug/L	0.6	2.4
6/15/2009 10:00	EFFLUENT	Pesticides	Endosulfan Sulfate	0.02	U	ug/L	0.02	0.08
6/15/2009 10:00	EFFLUENT	Pesticides	Delta-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:00	EFFLUENT	Pesticides	Chlordane	0.2	U	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Pesticides	Beta-BHC	0.015	U	ug/L	0.015	0.06
6/15/2009 10:00	EFFLUENT	Pesticides	Mevinphos	0.2	U	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Pesticides	Atrazine	0.05	U	ug/L	0.05	0.2
6/15/2009 10:00	EFFLUENT	Pesticides	Fenamiphos	0.2	U	ug/L	0.2	0.8
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2-Methyl-4,6-dinitrophenol	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	4-Chloro-3-methylphenol	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	4-Nitrophenol	15	U	ug/L	15	59
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Butyl benzyl phthalate	4.9	U	ug/L	4.9	20
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Di-n-butyl phthalate	4.9	U	ug/L	4.9	20

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Pyrene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2,4-Dimethylphenol	9.9	U	ug/L	9.9	39
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2,4-Dinitrophenol	15	U	ug/L	15	59
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Benzo(a)anthracene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Benzo(k)fluoranthene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Chrysene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Diethyl phthalate	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Fluoranthene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Fluorene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	N-Nitrosodiphenylamine/ Diphenylamine	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Nitrobenzene	2	U	ug/L	2	7.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Benzidine	99	U	ug/L	99	390
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Benzo(b)fluoranthene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Bis(2-chloroisopropyl)ether	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Dimethyl phthalate	9.9	U	ug/L	9.9	39
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Hexachlorocyclopentadiene	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Indeno(1,2,3-cd)pyrene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	N-Nitrosodimethylamine	2	U	ug/L	2	7.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2,4-Dichlorophenol	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2-Chlorophenol	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	4-Bromophenyl phenyl ether	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Acenaphthylene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Anthracene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Phenol	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2,6-Dinitrotoluene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Pentachlorophenol	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	3,3'-Dichlorobenzidine	39	UJ	ug/L	39	160
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	4-Chlorophenyl phenyl ether	2	U	ug/L	2	7.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Benzo(a)pyrene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Bis(2-ethylhexyl)phthalate	15	U	ug/L	15	59
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Hexachloroethane	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2,4,6-Trichlorophenol	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2,4-Dinitrotoluene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2-Chloronaphthalene	0.99	U	ug/L	0.99	3.9

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Di-n-octyl phthalate	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Hexachlorobenzene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Hexachlorobutadiene	3	U	ug/L	3	12
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Naphthalene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	1,2,4-Trichlorobenzene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	2-Nitrophenol	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Acenaphthene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Benzo(g,h,i)perylene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Bis(2-chloroethoxy)methane	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Bis(2-chloroethyl)ether	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Dibenzo(a,h)anthracene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Isophorone	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	N-Nitrosodi-n-propylamine	2	U	ug/L	2	7.9
6/15/2009 10:00	EFFLUENT	Priority Organic Pollutants	Phenanthrene	0.99	U	ug/L	0.99	3.9
6/15/2009 10:00	EFFLUENT	Field Parameter	Temperature	27.1		C		
6/15/2009 10:00	EFFLUENT	Field Parameter	pH	6.64				
6/15/2009 10:00	EFFLUENT	Field Parameter	Dissolved Oxygen	2.3		mg/L		
6/15/2009 10:00	EFFLUENT	Field Parameter	Specific Conductance	1249		umhos/cm		
6/15/2009 10:07	Equip blk	Metals	Nickel	0.25	U	ug/L	0.25	1
6/15/2009 10:07	Equip blk	Metals	Chromium	0.3	U	ug/L	0.3	1.2
6/15/2009 10:07	Equip blk	Metals	Cadmium	0.03	U	ug/L	0.03	0.12
6/15/2009 10:07	Equip blk	Metals	Aluminum	60	U	ug/L	60	240
6/15/2009 10:07	Equip blk	Metals	Magnesium	0.04	U	mg/L	0.04	0.16
6/15/2009 10:07	Equip blk	Metals	Zinc	5	U	ug/L	5	20
6/15/2009 10:07	Equip blk	Metals	Silver	0.025	U	ug/L	0.025	0.1
6/15/2009 10:07	Equip blk	Metals	Copper	0.5	U	ug/L	0.5	0.5
6/15/2009 10:07	Equip blk	Metals	Selenium	0.2	U	ug/L	0.2	0.8
6/15/2009 10:07	Equip blk	Metals	Calcium	0.075	U	mg/L	0.075	0.3
6/15/2009 10:07	Equip blk	Metals	Arsenic	0.25	U	ug/L	0.25	1
6/15/2009 10:07	Equip blk	Metals	Iron	30	U	ug/L	30	120
6/15/2009 10:07	Equip blk	Metals	Lead	0.2	U	ug/L	0.2	0.8
6/15/2009 10:07	Equip blk	Pesticides	Endrin Aldehyde	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Gamma-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:07	Equip blk	Pesticides	Heptachlor Epoxide	0.021	U	ug/L	0.021	0.084

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:07	Equip blk	Pesticides	Alachlor	0.62	UJ	ug/L	0.62	2.5
6/15/2009 10:07	Equip blk	Pesticides	Atrazine	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Methoxychlor	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Ethion	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Malathion	0.15	U	ug/L	0.15	0.6
6/15/2009 10:07	Equip blk	Pesticides	Mevinphos	0.21	U	ug/L	0.21	0.84
6/15/2009 10:07	Equip blk	Pesticides	Parathion Methyl	0.1	U	ug/L	0.1	0.4
6/15/2009 10:07	Equip blk	Pesticides	Ethoprop	0.1	U	ug/L	0.1	0.4
6/15/2009 10:07	Equip blk	Pesticides	Simazine	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Diazinon	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Metribuzin	0.1	U	ug/L	0.1	0.4
6/15/2009 10:07	Equip blk	Pesticides	Naled	0.82	U	ug/L	0.82	3.3
6/15/2009 10:07	Equip blk	Pesticides	Parathion Ethyl	0.15	U	ug/L	0.15	0.6
6/15/2009 10:07	Equip blk	Pesticides	Phorate	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Endosulfan Sulfate	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Bromacil	0.21	U	ug/L	0.21	0.84
6/15/2009 10:07	Equip blk	Pesticides	Butylate	0.21	UJ	ug/L	0.21	0.84
6/15/2009 10:07	Equip blk	Pesticides	Fenamiphos	0.21	U	ug/L	0.21	0.84
6/15/2009 10:07	Equip blk	Pesticides	Alpha-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:07	Equip blk	Pesticides	Beta-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:07	Equip blk	Pesticides	DDD-p,p'	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Delta-BHC	0.01	U	ug/L	0.01	0.04
6/15/2009 10:07	Equip blk	Pesticides	Dieldrin	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Metalaxyl	0.26	U	ug/L	0.26	1
6/15/2009 10:07	Equip blk	Pesticides	Aldrin	0.01	U	ug/L	0.01	0.04
6/15/2009 10:07	Equip blk	Pesticides	Chlordane	0.21	U	ug/L	0.21	0.84
6/15/2009 10:07	Equip blk	Pesticides	DDE-p,p'	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Heptachlor	0.01	U	ug/L	0.01	0.04
6/15/2009 10:07	Equip blk	Pesticides	Endosulfan II	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Prometryn	0.15	UJ	ug/L	0.15	0.6
6/15/2009 10:07	Equip blk	Pesticides	Metolachlor	0.51	UJ	ug/L	0.51	2
6/15/2009 10:07	Equip blk	Pesticides	Fonofos	0.1	UJ	ug/L	0.1	0.4
6/15/2009 10:07	Equip blk	Pesticides	Endosulfan I	0.021	U	ug/L	0.021	0.084
6/15/2009 10:07	Equip blk	Pesticides	Norflurazon	0.15	U	ug/L	0.15	0.6

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:07	Equip blk	Pesticides	Chlorpyrifos Methyl	0.1	U	ug/L	0.1	0.4
6/15/2009 10:07	Equip blk	Pesticides	Chlorpyrifos Ethyl	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Toxaphene	0.77	U	ug/L	0.77	3.1
6/15/2009 10:07	Equip blk	Pesticides	Endrin	0.051	U	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	DDT-p,p'	0.031	U	ug/L	0.031	0.12
6/15/2009 10:07	Equip blk	Pesticides	Hexazinone	0.1	U	ug/L	0.1	0.4
6/15/2009 10:07	Equip blk	Pesticides	Ametryn	0.051	UJ	ug/L	0.051	0.2
6/15/2009 10:07	Equip blk	Pesticides	Azinphos Methyl	0.21	UJ	ug/L	0.21	0.84
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	3,3'-Dichlorobenzidine	40	UJ	ug/L	40	160
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	4-Chlorophenyl phenyl ether	2	U	ug/L	2	8
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Benzo(a)anthracene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Di-n-octyl phthalate	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Hexachlorobutadiene	3	U	ug/L	3	12
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Indeno(1,2,3-cd)pyrene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	N-Nitrosodi-n-propylamine	2	U	ug/L	2	8
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Phenanthrene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	1,2,4-Trichlorobenzene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	4-Chloro-3-methylphenol	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Acenaphthene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Bis(2-ethylhexyl)phthalate	15	U	ug/L	15	60
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Di-n-butyl phthalate	5	U	ug/L	5	20
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Diethyl phthalate	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Isophorone	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Anthracene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Benzo(a)pyrene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Benzo(k)fluoranthene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Chrysene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Dimethyl phthalate	10	U	ug/L	10	40
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Hexachlorobenzene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2,6-Dinitrotoluene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2-Methyl-4,6-dinitrophenol	3	U	ug/L	3	12
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Benzidine	100	U	ug/L	100	400
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	N-Nitrosodimethylamine	2	U	ug/L	2	8
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	N-Nitrosodiphenylamine/ Diphenylamine	3	U	ug/L	3	12

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Phenol	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2,4-Dichlorophenol	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2-Chloronaphthalene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2-Nitrophenol	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	4-Bromophenyl phenyl ether	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Acenaphthylene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Benzo(g,h,i)perylene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Bis(2-chloroethoxy)methane	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Dibenzo(a,h)anthracene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Pyrene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2,4,6-Trichlorophenol	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Benzo(b)fluoranthene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Bis(2-chloroethyl)ether	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Butyl benzyl phthalate	5	U	ug/L	5	20
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Hexachloroethane	3	U	ug/L	3	12
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Pentachlorophenol	3	U	ug/L	3	12
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2,4-Dimethylphenol	10	U	ug/L	10	40
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2,4-Dinitrotoluene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Bis(2-chloroisopropyl)ether	3	U	ug/L	3	12
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Hexachlorocyclopentadiene	3	U	ug/L	3	12
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2,4-Dinitrophenol	15	U	ug/L	15	60
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	2-Chlorophenol	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	4-Nitrophenol	15	U	ug/L	15	60
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Fluoranthene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Fluorene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Naphthalene	1	U	ug/L	1	4
6/15/2009 10:07	Equip blk	Priority Organic Pollutants	Nitrobenzene	2	U	ug/L	2	8
6/15/2009 10:10	IN FLUUENT- I	Metals	Lead	9.09		ug/L	0.2	0.8
6/15/2009 10:10	IN FLUUENT- I	Metals	Selenium	2.69		ug/L	0.2	0.8
6/15/2009 10:10	IN FLUUENT- I	Metals	Arsenic	2.54		ug/L	0.25	1
6/15/2009 10:10	IN FLUUENT- I	Metals	Copper	120		ug/L	0.5	0.5
6/15/2009 10:10	IN FLUUENT- I	Metals	Cadmium	1.09		ug/L	0.03	0.12
6/15/2009 10:10	IN FLUUENT- I	Metals	Zinc	1070		ug/L	5	20
6/15/2009 10:10	IN FLUUENT- I	Metals	Nickel	11.6		ug/L	0.25	1

Appendix E. (continued)

Date Sampled	Field ID	Analysis Group	Components	Result	Remarks	Units	MDL	PQL
6/15/2009 10:10	IN FLUUENT- I	Metals	Iron	2130		ug/L	30	120
6/15/2009 10:10	IN FLUUENT- I	Metals	Calcium	125		mg/L	0.075	0.3
6/15/2009 10:10	IN FLUUENT- I	Metals	Chromium	7.8		ug/L	0.3	1.2
6/15/2009 10:10	IN FLUUENT- I	Metals	Magnesium	13.9		mg/L	0.04	0.16
6/15/2009 10:10	IN FLUUENT- I	Metals	Aluminum	2350		ug/L	60	240
6/15/2009 10:10	IN FLUUENT- I	Metals	Silver	1.03		ug/L	0.025	0.1
6/15/2009 10:20	IN FLUUENT- II	Metals	Magnesium	5.72		mg/L	0.04	0.16
6/15/2009 10:20	IN FLUUENT- II	Metals	Iron	500		ug/L	30	120
6/15/2009 10:20	IN FLUUENT- II	Metals	Lead	3.28		ug/L	0.2	0.8
6/15/2009 10:20	IN FLUUENT- II	Metals	Arsenic	1.66		ug/L	0.25	1
6/15/2009 10:20	IN FLUUENT- II	Metals	Chromium	2.7		ug/L	0.3	1.2
6/15/2009 10:20	IN FLUUENT- II	Metals	Calcium	38.5		mg/L	0.075	0.3
6/15/2009 10:20	IN FLUUENT- II	Metals	Silver	0.16		ug/L	0.025	0.1
6/15/2009 10:20	IN FLUUENT- II	Metals	Selenium	0.92		ug/L	0.2	0.8
6/15/2009 10:20	IN FLUUENT- II	Metals	Zinc	252		ug/L	5	20
6/15/2009 10:20	IN FLUUENT- II	Metals	Copper	94.2		ug/L	0.5	0.5
6/15/2009 10:20	IN FLUUENT- II	Metals	Nickel	3.93		ug/L	0.25	1
6/15/2009 10:20	IN FLUUENT- II	Metals	Aluminum	540		ug/L	60	240
6/15/2009 10:20	IN FLUUENT- II	Metals	Cadmium	0.2		ug/L	0.03	0.12
6/15/2009 10:30	IN FLUUENT- III	Metals	Copper	10.3		ug/L	0.5	0.5
6/15/2009 10:30	IN FLUUENT- III	Metals	Selenium	0.36	I	ug/L	0.2	0.8
6/15/2009 10:30	IN FLUUENT- III	Metals	Magnesium	12.9		mg/L	0.04	0.16
6/15/2009 10:30	IN FLUUENT- III	Metals	Cadmium	0.15		ug/L	0.03	0.12
6/15/2009 10:30	IN FLUUENT- III	Metals	Calcium	58.1		mg/L	0.075	0.3
6/15/2009 10:30	IN FLUUENT- III	Metals	Arsenic	0.8	I	ug/L	0.25	1
6/15/2009 10:30	IN FLUUENT- III	Metals	Zinc	122		ug/L	5	20
6/15/2009 10:30	IN FLUUENT- III	Metals	Nickel	1.41		ug/L	0.25	1
6/15/2009 10:30	IN FLUUENT- III	Metals	Chromium	0.85	I	ug/L	0.3	1.2
6/15/2009 10:30	IN FLUUENT- III	Metals	Silver	0.13		ug/L	0.025	0.1
6/15/2009 10:30	IN FLUUENT- III	Metals	Aluminum	130	I	ug/L	60	240
6/15/2009 10:30	IN FLUUENT- III	Metals	Iron	370		ug/L	30	120
6/15/2009 10:30	IN FLUUENT- III	Metals	Lead	0.85		ug/L	0.2	0.8

Appendix F. Facility Summary, Effluent Limits, and Permit Violations Recorded on Discharge Monitoring Report

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009

State of Florida
Department of Environmental Protection
Facility Introduction & Summary

PART I: Information gathered prior to sampling event	
Prepared By: Ed Jamro	**Contact Number:** 904-807-3264
Facility Name (as it appears on permit): Beverly Beach WWTF	**Current Name:** same
NPDES Permit Number: FL0 039756	**Permit Expiration Date:** August 28, 2010
Physical Address: 217 Starboard Drive Beverly Beach, FL 32136	
District: Northeast	**County:** Flagler
Function of Facility: Facility treats domestic wastewater.	
Facility Type: Domestic Wastewater	**Permitted Capacity (MGD):** 0.085
Mean Flow for previous 12 months for all EXTERNAL outfalls listed in permit (list date range including months): **January 2008 through December 2008 mean flows @ 0.03_ MGD** **0.036 MGD in March 2008; 0.024 MGD in May, June & December 2008.**	
If applicable, Mean Flow for previous 12 months for REUSE outfall(s) (list date range including months): **NA**	
Description of type of Discharge: ☒ **Continuous** ☐ **Intermittent** ☐ **Seasonal** ☐ **Rainfall Dependent** ☐ **Other, please specify**	

Appendix F. (continued)

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009

Description of Sampling Location(s) - actual permit designation of permitted sampling point(s):
EFA-1 – Sample point immediately after disinfection and prior to dechlorination.
EFD-1 – Sample point after dechlorination and post aeration but prior to discharge to the ICWW.

SWU-1 –North of discharge – channel marker #3
SWD-1 –South of discharge – channel marker #7.

INF-1 – Influent, prior to biological treatment (cannot contain internal recycled streams)

Description of Permitted Outfall(s): (excerpted from current permit)

Surface Water Discharge:

An existing 0.085 MGD annual average daily flow (AADF) permitted discharge to the Intracoastal Waterway (Class III marine waters) at Discharge Location (D-001) which is approximately 15 feet in length and discharges at a depth of approximately 2.5 feet.

The point of discharge is located approximately at latitude 29 ° 31' 08" N, longitude 81 ° 09' 00" W.

Description of Treatment Process (if multiple discharge points, include a detailed map or diagram of facility):

An existing 0.085 million gallon per day (MGD) annual average daily flow permitted capacity wastewater treatment facility (WWTF) consisting of two plants that operate in parallel.

Plant Number One is an extended aeration activated sludge domestic wastewater treatment plant consisting of one pre-aeration tank (5,000 gallons), five aeration tanks (5,000 gallons each), two secondary clarifiers (6,200 gallons each), and two aerobic digesters (5,000 gallons each).

Plant Number Two is an extended aeration activated sludge plant consisting of one aeration basin (35,000 gallons), one secondary clarifier (10,100 gallons with 132 square feet surface area), and one aerobic digester (9,450 gallons).

The supernatant from the three (3) secondary clarifiers of the two plants are combined and sent to a two-cell sand filter (36 sq.ft. filtration media), one chlorine contact chamber (2,700 gallons), one dechlorination chamber, and a duplex effluent pump station with post aeration.

The final effluent is discharged to the Intracoastal Waterway.

PART I: Continued

List current Effluent Limits of Outfall(s) to be Sampled: This should include any AO or CO limits the facility may be under

1. **During the period beginning on the issuance date and lasting through the completion and placing into service the new WWTF, the permittee is authorized to discharge effluent from Outfall D-001 to Intracoastal Waterway. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.8:**
   The permittee is required to conduct in stream monitoring at SWU-1 and SWD-1 as shown below.

			Effluent Limitations			Monitoring Requirements			
Parameter	Units	Max/Min	Annual Average	Monthly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Flow to surface water	MGD	Maximum	0.215	Report	--	5 Days/Week	Meter	EFD-1	See Cond.I.A.3
BOD, Carbonaceous 5 day, 20C	MG/L	Maximum	10.0	10.0	20.0	Every Two Weeks	8-hr flow proportioned composite	EFD-1	
Solids, Total Suspended	MG/L	Maximum	5.0	5.0	10.0	Every Two Weeks	8-hr flow proportioned composite	EFD-1	
Coliform, Fecal	#/100ML	Maximum	See Permit Condition I.A.4.	Every Two Weeks	Grab	EFD-1			
pH	SU	Range			6.5 to 8.5	5 Days/Week	Grab or Meter	EFA-1	
Total Residual Chlorine (For Disinfection)	MG/L	Minimum			0.5	5 Days/Week	Grab	EFA-1	See Cond.I.A.5
Total Residual Chlorine (For Dechlorination)	MG/L	Maximum			0.01	Every Two Weeks	Grab	EFD-1	
Oxygen, Dissolved (DO)	MG/L	Minimum			6.0	5 Days/Week	Grab	EFD-1	
Total Recoverable Copper	µG/L	Maximum			3.7	Quarterly	8-hr flow proportioned composite	EFD-1	See Cond. VI.1
Total Recoverable Zinc	µG/L	Maximum			86.0	Quarterly	8-hr flow proportioned composite	EFD-1	See Cond. VI.1

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009

PART I: Continued

List current Effluent Limits of Outfall(s) to be Sampled: This should include any AO or CO limits the facility may be under

1. **During the period beginning on the issuance date and lasting through the completion and placing into service the new WWTF, the permittee is authorized to discharge effluent from Outfall D-001 to Intracoastal Waterway. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.8:**
   The permittee is required to conduct in stream monitoring at SWU-1 and SWD-1 as shown below.

			Effluent Limitations			Monitoring Requirements			
Parameter	Units	Max/Min	Annual Average	Monthly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Mercury, Total Recoverable	µG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Nitrogen, Total	MG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Nitrogen, Organic, Total (as N)	MG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Nitrogen, Total	LBS/DAY	Maximum			Report	Quarterly	Calculate	CAL-1	
Nitrite plus Nitrate, (as N)	MG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Nitrogen, Ammonia, Total (as N)	MG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Nitrogen, Kjeldahl, Total (as N)	MG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Salinity	PPT	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Phosphorus, Total (as P)	MG/L	Maximum			Report	Quarterly	8-hr flow proportioned composite	EFD-1	
Phosphorus, Total (as P)	LBS/DAY	Maximum			Report	Quarterly	Calculated	CAL-1	

PART I: Continued

List current Effluent Limits of Outfall(s) to be Sampled: This should include any AO or CO limits the facility may be under

1. **During the period beginning on the issuance date and lasting through the completion and placing into service the new WWTF, the permittee is authorized to discharge effluent from Outfall D-001 to Intracoastal Waterway. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with condition I.C.8:**
   The permittee is required to conduct in stream monitoring at SWU-1 and SWD-1 as shown below.

			Effluent Limitations			Monitoring Requirements			
Parameter	Units	Max/Min	Annual Average	Monthly Average	Single Sample	Monitoring Frequency	Sample Type	Monitoring Location Site Number	Notes
Phosphate, Ortho (as P)	MG/L	Maximum			Report	Quarterly	Grab and filtered immediately	EFD-1	
Flow through the WWTF before placing the new WWTF into service	MGD	Maximum	0.085	Report		5 Days/Week	Meter	INF-1	See Note 1 below
BOD, Carbonaceous 5 day, 20C before placing the new WWTF into service	MG/L	Maximum		Report		Every Two Weeks	Grab	INF-1	See Note 1 below
Solids, Total Suspended before placing the new WWTF into service	MG/L	Maximum		Report		Every Two Weeks	Grab	INF-1	See Note 1 below
Whole Effluent Toxicity	See Note 2 below							EFD-1	
Stream monitoring	See Note 3 below							SWU-1 SWD-1	

NOTES: 1. - Influent samples shall be collected so that they do not contain digester supernatant or return activated sludge, or any other plant process recycled waters. *[62-601.500(4)]*

2. **Acute Whole Effluent Toxicity Testing Program**
   The permittee shall comply with the following requirements to evaluate acute whole effluent toxicity

a. Effluent limitation

(1) Mortality less than or equal to 20% in the 100% effluent test concentration in any routine test shall constitute compliance with these permit conditions and Rules 62-302.200(1) and 62-302.500(1)(a) 4, F.A.C. Mortality of greater than 20% in the 100% effluent concentration in any test shall constitute unacceptable toxicity. The permittee shall conduct additional follow-up tests as described in I.A.9.c. below for any routine test for which unacceptable toxicity has been observed.

(2) Whole effluent acute toxicity shall not exceed, in any routine test, mortality of greater than 50% in the 100% effluent concentration or an LC50 less than 100% effluent in any additional follow-up test [Rule 62-302.200(1), Rule 62-302.500(1)(a) 4 and Rule 62-4.244(3)(a), F.A.C.]

b. Monitoring frequency

(1) Routine toxicity tests shall be conducted once every two months, the first starting within 60 days of permit issuance, and lasting for the duration of this permit unless a reduction in the frequency of monitoring is granted in writing by the Department.

(2) Upon completion of six consecutive, valid routine tests that demonstrate compliance with the effluent limitation specified in 9.a. (1) and (2) above, the permittee may send a written request to the Department for a reduction in testing frequency. The Department shall review this request within 45 days of receipt and approve or deny the request in writing. Materials submitted to the Department for review should include a summary of the data and the complete bioassay reports for all tests being considered. In no case shall the frequency of monitoring be reduced to less than annually. Requested reductions in monitoring frequency shall only become effective upon Department approval.

(3) If a test within the sequence of the six is deemed invalid, but is replaced by a repeat valid test initiated within seven days of the invalidation, the invalid test will not be counted against the requirement for six consecutive valid tests for the purpose of evaluating the reduction of monitoring frequency. If two or more invalidations occur, this provision does not apply.

c. Test Requirements

(1) Routine Tests: All routine tests shall be conducted using a control (0% effluent) and one test concentration of 100% final effluent.

(2) Additional Follow-up Tests, if required:

(a) If a routine test does not meet the acute toxicity limitation in I.A.9.a. (1) and (2) above, the permittee shall conduct three additional follow-up tests on each species that failed the test.

(b) The first additional follow-up test shall be conducted using a control (0% effluent) and a minimum of five dilutions: 100%, 50%, 25%, 12.5% and 6.25% effluent. The dilution series may be modified in the second and third test to more accurately bracket the toxicity, such that at least two dilutions above (not to exceed 100% effluent) and two dilutions below the target concentration and a control (0% effluent) are run. All test results shall be statistically analyzed according to the Appendices in EPA-821-R-02-012.

(c) The first test shall be initiated within two weeks of the end of the failed routine test. The remaining additional follow-up tests shall be conducted weekly thereafter until a total of three valid additional follow-up tests are completed.

(3) The permittee shall conduct 96-hour acute static renewal toxicity tests using the freshwater daphnid, *Ceriodaphnia dubia*, and the bannerfin shiner, *Cyprinella leedsi*, concurrently.

(4) All test species, procedures, and quality assurance criteria used shall be in accordance with Methods for Measuring Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, EPA-821-R-02-012. Any deviation of the bioassay procedures

outlined herein shall be submitted in writing to the Department for review and approval prior to use. In the event the above method is revised, the permittee shall conduct acute toxicity testing in accordance with the revised method.

(5) The control water and dilution water used will be moderately hard water as described in EPA-821-R-02-012, Table 7.

d. Sampling Requirements

(1) For routine and additional follow-up tests, an 8-hr flow-proportioned composite sample shall be collected at location EFD-1. The composite duration and the collection times of effluent sample shall be documented on the chain of custody sheet.

(2) Results for each additional test shall include the determination of LC50 values with 95% confidence limits.

e. Quality Assurance Requirements

(1) A standard reference toxicant (SRT) quality assurance (QA) acute toxicity test shall be conducted with each species used in the required toxicity tests either concurrently or no more than 30 days before the date of each routine or additional follow-up test conducted. The SRT-QA data shall be included in the bioassay reports for each companion routine or additional follow-up tests required.

(2) If the mortality in the control (0% effluent) exceeds 10% for either species in any test, the test for that species (including the control) shall invalidated and the test repeated.

(3) If 100% mortality occurs prior to the end of any test and control mortality is less than 10% at that time, that test (including the control) shall be terminated with the conclusion that the test fails and constitutes non-compliance.

(4) Additional follow-up tests shall be evaluated for acceptability based on the concentration-response relationship, as required by EPA-821-R-02-012, Section 12.2.6.2. and included in the bioassay reports.

f. Reporting Requirements

(1) Results from <u>all</u> required toxicity tests shall be entered on the Discharge Monitoring Report (DMR) as follows:

(a) Routine Test Results: If 50% or less mortality occurs for the test species, then " > 100%" should be entered on the DMR for that test species. If more than 50% mortality occurs for the test species, then " < 100%" should be entered.

(b) Additional Follow-up Test Results: Report the calculated LC50 value for that test species and the 95% confidence limits.

(2) A bioassay laboratory report for the routine test shall be prepared according to EPA-821-R-02-012, Section 12, Report Preparation and Test Review and mailed to the Department at the address below within 30 days of the completion of the test.

(3) For additional follow-up tests, a *single* bioassay laboratory report shall be prepared according to EPA-821-R-02-012, Section 12, and mailed within 45 days of completion of the third valid additional follow-up test. If any additional follow-up tests, or two consecutive routine tests, do not meet either the 20% or 50% mortality imitation specified in I.A.9.a. (1) and (2) above, the permittee shall contact the

Department within 30 days of the laboratory report submittal to discuss the corrective actions necessary to remedy the observed acute toxicity.

(4) All bioassay laboratory reports shall be mailed to:

Florida Department of Environmental Protection
Northeast District - Domestic Wastewater Section
7825 Baymeadows Way, Suite B-200
Jacksonville, Florida 32256-7590

3. The Permittee shall continue regular monitoring of the segment of the Intracoastal Waterway near the outfall, D-001, for maintaining data on the impact of the discharge to the water quality of the surface water body. The monitoring sites are described as follows:

Site Location	Describe Site
SWU-1	North of discharge - channel marker # 3
SWD-1	South of discharge - channel marker # 7

The permittee shall coordinate the specific site locations with the FDEP, Northeast District office. The parameters to be measured shall include the following:

1) DO, pH, temperature, specific conductivity, salinity
2) $CBOD_5$, NH_3, TKN, $NO_2 + NO_3$, Alkalinity, Total Phosphorous, Ortho-Phosphorus, chlorophyll-a
3) Tide stage, stream velocity

Metered parameters (DO, pH, temperature, conductivity, salinity) shall be sampled at the surface, mid-depth and at the bottom. Grab samples shall be taken at mid-depth at the specified locations. Ortho-phosphorous samples shall be filtered immediately after collection. Monitoring shall occur on a semi-annual basis. The sample shall be taken at the same time as a normal sampling event, as defined in I.A.1 above. The results of instream sampling shall be reported to on the discharge monitoring report (DMR) corresponding to the months in which the samples were taken. *[62-4.240(3)(c)]*

Appendix F. (continued)

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009

PART I: Continued

Receiving Waters: **Intracoastal Waterway**	**Classification (indicate whether fresh or marine):** **Class III Marine Waters**

Toxicity Test Requirements (routine and/or additional test language, test species, salinity adjustment, etc.):

See Note 2 on previous pages.

Administrative or Consent Orders (date executed, specific requirements, interim limit dates-if applicable, etc.):

N/A – old AO has expired. A new Consent Order has been drafted but not yet issued. The new CO addresses effluent copper and zinc concentrations and the schedule for rebuilding the WWTP.

Facility Mixing Zone Details (if applicable): NA

List Permit Violations (DMR data) and plant upsets that occurred at the plant within the last year:
For January 1, 2008 to February 28, 2009 (from PCS)

Date	Parameter and Units	Limit	Result
03-08	Total Copper, ug/l	3.7 ug/l (max)	5.77
04-08	Dissolved Oxygen, mg/l	6.0 mg/l (min)	5.0
04-08	Total Suspended Solids, mg/l	5.0 mg/l (max) month avg.	7.15
04-08	Total Suspended Solids, mg/l	10.0 mg/l (max)	12.3
04-08	Total Residual Chlorine, mg/l	0.01 mg/l (max)	0.09
04-08	Total Residual Chlorine, mg/l	0.5 mg/l (min)	0.44
04-08	pH – SU	6.5 SU (min)	6.0
05-08	pH – SU	6.5 SU (min)	6.0
05-08	Total Suspended Solids, mg/l	5.0 mg/l (max) monthly avg.	6.5
05-08	Total Suspended Solids, mg/l	10.0 mg/l (max)	12
05-08	C-BOD-5-day, mg/l	10.0 mg/l(max) monthly avg.	13.63
05-08	C-BOD-5-day, mg/l	20.0 mg/l (max)	22.45
09-08	Total Suspended Solids, mg/l	5.0 mg/l (max) monthly avg.	13.9
09-08	Total Suspended Solids, mg/l	10.0 mg/l (max)	26.8
09-08	Total Copper, ug/l	3.7 ug/l (max)	5.8
12-08	C-BOD-5-day, mg/l	20.0 mg/l (max)	23
12-08	Total Zinc, ug/l	86 ug/l	92
12-08	Total Copper, ug/l	3.7 ug/l (max)	4.7

Appendix F. (continued)

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009

Describe previous FYI and WQBEL study:
Last Biological Assessment sampling was done by FDEP on April 12, 1999.

Water Quality Based Effluent Limitation (WQBEL) – Permit Fact Sheet dated – 5/9/05 & Revised – 09/06.

- Monitoring frequencies and limitations are retained from the previous permit for "conventional" pollutants parameters (TSS, pH, and TRC(Chlorination and Dechlorination)).
- Comparisons of the water quality north (upstream) and south (downstream) of the discharge indicate no significant changes to water quality in terms of DO, CBOD5, and pH. The monitoring frequencies and limitations of CBOD5, DO, and pH will be retained as they are in the existing permit.
- Annual average and monthly Geo. Mean of fecal coliform from June 30, 2004 through March 31, 2005 were 26.6 and 45.0 / 100 mL, respectively. Although the total coliform of Intracoastal Waterway at Beverly Beach is on the planning list, based on the fecal coliform data reported, there is no evidence to show that the coliform in the effluent contributed to the total coliform of the waterbody. Therefore, the facility is not required to increase disinfection treatment level of the effluent before discharge to the Intracoastal Waterway. The limit of fecal coliform in the permit is established in accordance with Rule 62-600.440(4)(c), FAC.
- Although nutrients are on the planning list, the ambient water quality data upstream and downstream of the discharge indicates no significant change to water quality in term of nitrogen. In addition, even though the data suggests an increase in the amount of total phosphorus in the downstream sampling location, this has not been reflected in higher primary productivity in the receiving water as evidenced from the Chlorophyll a data. Moreover, the permittee plans to construct an AWT plant and cease discharge to the Intracoastal Waterway in favor of reuse of reclaimed water for irrigation of public-access areas. Nutrient limits are not recommended in the interim period.
- Results of the five sampling inspections at the facility between 2000 and 2003 showed that silver, lead, cadmium, and selenium did not exceed water quality standards.
- Department sampling inspection reports indicated that the concentrations of copper and zinc in the effluent samples exceeded the Class III marine water quality standards. An administrative order (AO 86 NE) is issued in conjunction with the permit to allow time for the facility to evaluate and consider options concerning the exceedances for total copper and zinc. The Department used the Reasonable Assurance Verification Workbook to establish the interims limits for total recoverable copper and total zinc in the AO 86. (Appendix A)
- The permittee shall continue testing for total recoverable mercury. Upon the completion of six (6) valid tests and the analytical results show that concentrations of the mercury in the effluent has not exceeded the surface water quality criteria limits, the permittee may petition the Department to reduce the monitoring frequency or remove the monitoring requirement of this parameter. *[62-4.240(3)(c),FAC]*
- Due to the fact that the discharge of Reverse Osmosis (RO) concentrate to the treatment facility was discontinued in 1999 when the RO water treatment facility serving the area was connected to the Palm Coast Utilities water distribution system, the facility is receiving 100% domestic wastewater (No industrial wastewater contributions). Monitoring for parameters such as total alpha, dissolved alpha, gross particle activity alpha, and radium 226 plus radium 228 are not necessary. Therefore, they are not required to be monitored in the new permit.
- The Permittee is required to conduct regular monitoring of the segment of the Intracoastal Waterway near the outfall for maintaining data on the impact of the discharge to the water quality of the surface water body which is a part of an on-going Water Quality Based Effluent Limitation (WQBEL) study for the Intracoastal Waterway . If a new WQBEL is developed for the facility which requires the effluent limit to be revised, the permittee shall be informed in writing by administrative notice.

- **In order to provide reasonable assurance that the discharge will not adversely affect the designated use of the receiving water, whole effluent toxicity testing is required.**

Appendix F. (continued)

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009

Describe previous or current Enforcement Actions (including WLs): **The current permit had an Administrative Order (AO-86-NE) that covered interim limits for copper and zinc. The Order "expired" in late 2007 and the system still does not consistently meet copper and zinc limits.** **A Warning Letter was issued on July 2, 2008 regarding non-compliance with the construction schedule for the upgraded WWTP.** **A Consent Order is currently in draft form to address the construction schedule, copper, and zinc issues.**
Describe any violations or problems noted in previous inspection: **Inspected on 8/18/08 and a Non-compliance letter was issued on 9/3/08 for security, backflow prevention, residuals, and compliance schedule issues.**
Discuss whether DMR trends within previous five years are improving or declining: - **No comments**
Additional Comments (this should include a trend of the Effluent, i.e. if the facility is now Reuse): **Permit modification was issued 12/29/08. The WWTP expansion is supposed to include a reuse system. Construction is scheduled to start by May 31, 2009.**

Appendix F. (continued)

BEVERLY BEACH WWTP – FL0039756 – APRIL-2009


PART II: Sampling Event Information	
Date(s) sample collected: May 18, 2009 (planned)	**Sampler(s):**
Temperature (Deg C):	**pH (SU):**
Dissolved Oxygen (mg/L):	**Conductivity (umhos/cm):**
Total Residual Chlorine (mg/L):	**Total Residual Chlorine - after Disinfection (mg/L):**
Method of Chlorination: Sodium Hypochlorite liquid	**Method of De-chlorination:** Sodium Bisulfite
Flow During Sample Collection for each outfall(MGD):	
Mean Flow for each outfall for previous 12 months based on sampling date (If samples are taken on more than one day, indicate Mean Flow for each day): Mean flow in past year is 0.03MGD.	
Describe Discharge during Sampling Event: ☐ Continuous ☐ Intermittent ☐ Seasonal ☐ Rainfall Dependent ☐ Other, please specify	
Describe any conditions, difficulties or abnormal events that occurred during the sample collection and any other additional comments here: Describe appearance of final effluent ---	

Page 12 of 12 02/06/09

Appendix G. EPA End Sheet


The Bioassay of Beverly Beach WWTP effluent sampled on June 15, 2009. NPDES #FL0039756.

Fill Out This Section For All Surface Water Discharger Inspections(CEI, CSI, CBI, PAI, XSI-RI Optional)



The Priority Pollutants Analysis of Beverly Beach WWTP effluent sampled on June 15, 2009. NPDES #FL0039756.

Fill Out This Section For All Surface Water Discharger Inspections(CEI, CSI, CBI, PAI, XSI-RI Optional)



Biological Analyses of Beverly Beach WWTP effluent sampled on June 15, 2009. NPDES #FL0039756.

Fill Out This Section For All Surface Water Discharger Inspections(CEI, CSI, CBI, PAI, XSI-RI Optional)

