


APPENDIX I
NPDES PERMIT No. FL0001562



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

In the Matter of an
Application for Permit by:

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Turkey Point Power Plant
9760 S.W. 344 Street
Florida City, FL 34428

DEP File # FL0001562-004-IW1N/NR
Miami-Dade County
Florida Power & Light Company

Attention: Mr. Terry O. Jones

NOTICE OF PERMIT

Enclosed is Permit Number FL0001562, issued under Section 403.0885, Florida Statutes and DEP Chapter 62-620, Florida Administrative Code, authorizing renewal of a "No Discharge" NPDES permit for internal discharge to an onsite closed-loop recirculating cooling canal system at the Turkey Point Power Plant located at 9670 S.W. 344 Street, Florida City, Miami-Dade County, Florida.

Any party to this order (permit) has the right to seek judicial review of the permit under section 120.68 of the Florida Statutes, by the filing of a Notice of Appeal under rule 9.110 of the Florida Rules of Appellate Procedure, with the Clerk of the Department of Environmental Protection, Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000 and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within thirty days after this notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION

Mimi Drew
Director
Division of Water Resource Management
2600 Blair Stone Road
Tallahassee, FL 32399-2400
(850) 245-8336

'More Protection Less Process'

FPL
Turkey Point Power Plant
Permit Number FL0001562

Page 2

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52, Florida Statutes, with the designated deputy clerk, receipt of which is hereby acknowledged.

G. Shultz 05-13-05
Clerk Date

Copies furnished to:

Roosevelt Childress, EPA
Chairman, Miami-Dade County Board of Commissioners
Tim Powell, P.E., DEP SED, West Palm Beach
Buck Owen, P.E., DEP Tallahassee
Betsy Hewitt, DEP Tallahassee (w/o enclosure)

SECOND AMENDMENT TO THE FACT SHEET

DATE: January 28, 2004

PERMIT NUMBER: FL0001562

PERMITTEE: Florida Power & Light Company
Turkey Point Power Plant

The following minor corrections have been made to the proposed permit. None of these corrections alter any of the discharge limitations monitoring requirements in the permit.

1. Permittee Comments

The Permittee requested the following minor corrections to the permit

Typographical errors in the Draft Permit: The Applicant pointed out several typographical errors by the Department which are not listed in the items below. The Department has corrected these errors, which were non-substantive and did not affect any permit limitations or monitoring requirements.

Condition 1A.6.&7. The Permittee pointed out that that previous permits did not include these conditions, which refer to floating foam and visible sheen on surface waters of the state due to discharge of wastewater. The Permittee noted that the conditions are not appropriate because the facility does not discharge to surface waters. The Department concurs, and notes that it included the conditions in error. The conditions have been deleted from the final permit

**STATE OF FLORIDA
INDUSTRIAL WASTEWATER FACILITY PERMIT**

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562 (Major)

PA FILE NUMBER:

FL0001562-004-IW1N

ISSUANCE DATE:

May 6, 2005

EXPIRATION DATE:

May 5, 2010

RESPONSIBLE AUTHORITY:

Mr. Terry O. Jones
Vice President

FACILITY:

FPL Turkey Point Power Plant
9760 S.W. 344 Street
Florida City, FL 33035
Dade County

Latitude: See Note Below Longitude: See Note Below

Note: Latitude and longitude are not shown at Permittee's request, for purposes of Homeland Security pursuant to federal regulations found at 18 CFR 388.113(c)(i) and (ii) and by Presidential Directive dated December 17, 2003.

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.) and applicable rules of the Florida Administrative Code (F.A.C.), and constitutes authorization to discharge to waters of the state under the National Pollutant Discharge Elimination System (NPDES). The above named permittee is hereby authorized to operate the facilities shown on the application and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

The facility consists of four steam-electric generating units: Two fossil fuel oil-fired units (Units 1&2) and two nuclear units (Units 3&4). Units 1&2 each have a continuous generating capability of 404 megawatts (MW), and Units 3&4 each have a continuous generating capability of 693 MW.

WASTEWATER TREATMENT:

Wastewater from the Turkey Point facility consists of a non-contact once-through condenser cooling water (OTCW), auxiliary equipment cooling water (AECW), low-volume waste (LVW), and stormwater. LVW consists of chemical treatment system wastewater, boiler blowdown, reverse osmosis concentrate, condensate polishing system backwash water, and other process wastestreams. Stormwater includes stormwater associated with industrial activity and stormwater not associated with industrial activity.

OTCW and AECW discharge to the facility's approximately 6,700 acre onsite closed loop cooling canal system. LVW, equipment area stormwater, and non-equipment area stormwater/drainage discharge either directly to the onsite closed loop cooling canal system or indirectly to the same system via solids settling basins and/or neutralization basin. The cooling canal system is not lined, and therefore, discharges to Class G-III groundwater. The cooling canal system does not discharge to surface waters of the state.

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010

EFFLUENT DISPOSAL:

Surface Water Discharge:

This permit does not authorize discharge to surface waters of the state.

Internal Outfalls:

This permit authorizes discharge from existing internal outfalls I-001 and I-002 to the facility's onsite closed loop cooling canal system.

Groundwater Discharge

This permit authorizes an existing discharge from the onsite closed loop cooling canal system to the surficial aquifer which is a Class G-III groundwater.

IN ACCORDANCE WITH: The limitations, monitoring requirements and other conditions as set forth in Part I through Part VIII on pages 3 through 14 of this permit.

PERMITTEE:

PERMIT NUMBER:

FL0001562

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

Issuance date: May 6, 2005
Expiration date: May 5, 2010

I. Effluent Limitations and Monitoring Requirements

A. Surface Water Discharges

1. This permit does not authorize discharge to surface waters of the state
2. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge non process wastewater consisting of non-contact once-through condenser cooling water (OTCW), non-contact auxiliary equipment cooling water (AECW), and other wastestreams (as indicated in the permit renewal application) from Internal Outfall I-001 to the onsite feeder canal within the facility's onsite closed loop cooling canal system. Such discharge shall be limited and monitored by the permittee as specified below:

Parameters (units)	Discharge Limitations			Monitoring Requirements		
	Maximum Daily Average	Daily Maximum	Daily Minimum	Monitoring Frequency	Sample Type	Sample Point
Temperature (F), Water (DEG.F)	--	Report	--	Monthly	Instantaneous	OUI-1
Solids, Total Suspended (MG/L)	--	Report	--	Quarterly	Grab	OUI-1
pH (SU)	--	Report	Report	Quarterly	Grab	OUI-1
Salinity (PPT)	--	Report	--	Quarterly	Grab	OUI-1
Specific Conductance (UMHO/CM)	--	Report	--	Quarterly	Grab	OUI-1
Copper, Total Recoverable (UG/L)	--	Report	--	Semiannually	Grab	OUI-1
Iron, Total Recoverable (MG/L)	--	Report	--	Semiannually	Grab	OUI-1
Zinc, Total Recoverable (UG/L)	--	Report	--	Semiannually	Grab	OUI-1

3. Effluent samples shall be taken at the monitoring site locations listed in permit condition I A 2. and as described below:

Sample Point	Description of Monitoring Location
OUI-1	Cooling water discharge prior to entering the feeder canal within the closed loop cooling canal system

PERMITTEE:

PERMIT NUMBER: FL0001562

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

Issuance date: May 6, 2005
Expiration date: May 5, 2010

4. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge process wastewater and stormwater from Internal Outfall I-002 into the facility's onsite closed loop cooling canal system. Such discharge shall be limited and monitored by the permittee as specified below:

Parameters (units)	Discharge Limitations			Monitoring Requirements		
	Monthly Average	Daily Maximum	Daily Minimum	Monitoring Frequency	Sample Type	Sample Point
Solids, Total Suspended (MG/L)	--	Report	--	Semiannually	Grab	OUI-2
PH (SU)	--	Report	Report	Monthly	Grab	OUI-2
Specific Conductance (UMHO/CM)	--	Report	--	Quarterly	Grab	OUI-2
Lead, Total Recoverable (UG/L)	--	Report	--	Semiannually	Grab	OUI-2
Oil and Grease (MG/L)	--	Report	--	Semiannually	Grab	OUI-2
Copper, Total Recoverable (UG/L)	--	Report	--	Semiannually	Grab	OUI-2
Zinc, Total Recoverable (UG/L)	--	Report	--	Semiannually	Grab	OUI-2

5. Effluent samples shall be taken at the monitoring site locations listed in permit condition I A 4. and as described below:

Sample Point	Description of Monitoring Location
OUI-2	discharge from the two solids settling basins or neutralization basin prior to mixing with water in the closed loop cooling canal system

B. Underground Injection Control Systems

1. This section is not applicable to this permit. Discharge by underground injection is regulated under permit UC-13-277655.

C. Land Application Systems

1. This section is not applicable to this facility.

D. Other Methods of Disposal or Recycling

1. There shall be no discharge of industrial wastewater from this facility to ground or surface waters, except as authorized by this permit.

E. Other Limitations and Monitoring and Reporting Requirements

1. Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Southeast District Office Discharge Monitoring Reports (DMRs) in accordance

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010

with the frequencies specified by the REPORT type (i.e., monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type on DMR	Monitoring Period	DMR Due Date
Monthly or Toxicity	first day of month – last day of month	28 th day of following month
Quarterly	January 1 – March 31	April 28
	April 1 – June 30	July 28
	July 1 – September 30	October 28
	October 1 – December 31	January 28
Semiannual	January 1 – June 30	July 28
	July 1 – December 31	January 28
Annual	January 1 – December 31	January 28

DMRs shall be submitted for each required monitoring period including months of no discharge.

The permittee shall make copies of the attached DMR form(s) and shall submit the completed DMR form(s) to the Department's Southeast District Office at the address specified in Permit Condition I.E.2.

- Unless specified otherwise in this permit, all reports and notifications required by this permit, including twenty-four hour notifications, shall be submitted to or reported to the Southeast District Office at the address specified below:

Southeast District Office
400 North Congress, Suite 200
West Palm Beach, FL 33401-3303
Phone Number - (561) 681-6702

- All reports and other information shall be signed in accordance with requirements of Rule 62-620.305, F.A.C.
- The permittee shall provide safe access points for obtaining representative samples which are required by this permit.
- If there is no discharge from the facility on a day scheduled for sampling, the sample shall be collected on the day of the next discharge.
- Bypasses subject to General Conditions VIII.20 and VIII.22 shall be monitored or estimated daily, or as approved by the Department for flow and other parameters required for the specific outfall that is bypassed. Monitoring results shall be reported to the Department.
- There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid.
- This permit authorizes the use of the following biocides, or their generic equivalents, in various closed cooling water systems without limitations or monitoring; NALCO 7338, NALCO 7330, NALCO 7348, BULAB 6001/6002, BETZ POWERLINE 3610. The Permittee shall notify the Department if there is a discharge of any of these products into the closed cycle cooling canal system in other than de-minimus amounts which contain concentrations of active ingredients above the MDLs for those ingredients.

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010

- 9 A permit revision from the Department shall be required prior to the use of any biocide or chemical additive, which may be toxic to aquatic life, (except as authorized elsewhere in this permit) in the cooling water system or any other portion of the industrial wastewater system. The permit revision request shall include:

- a. Name and general composition of biocide or chemical
- b. Frequencies of use
- c. Quantities to be used
- d. Proposed effluent concentrations
- e. Acute and/or chronic toxicity data (laboratory reports shall be prepared according to Section 12 of EPA document no. EPA/600/4-90/027 entitled, Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters for Freshwater and Marine Organisms, or most current addition.)
- f. Product data sheet
- g. Product label

The Department shall review the above information to determine if a major or minor permit revision is necessary. Discharge associated with the use of such biocide or chemical is not authorized without prior authorization by the Department. Permit revisions shall be processed in accordance with the requirements of Chapter 62-620, F.A.C.

10. Discharge of any product registered under the Federal Insecticide, Fungicide, and Rodenticide Act to any waste stream which ultimately may be released to waters of the State is prohibited unless specifically authorized elsewhere in this permit. This requirement is not applicable to products used for lawn and agricultural purposes or to the use of herbicides if used in accordance with labeled instructions and any applicable State permit.

11. Hydrazine and Monoethanolamine (EIA) Monitoring Requirements

- a) Discharge of hydrazine, carbonylhydrazide, dimethylamine, and monoethanolamine (EIA) in the boiler or steam generator blowdown is authorized without limitation or monitoring requirements.
- b) Hydrazine from plant layup water during overhauls and/or refueling outages shall be measured at the outlet from the unit being serviced. Sampling shall be once per day of discharge by grab sample at the maximum expected concentration. Results of sampling will be submitted to the Department upon request. To determine the hydrazine concentration being discharged to the cooling canal system, the following equation shall be used:

$$\frac{(B/S) \text{ Blowdown Flow} \times (B/S) \text{ Hydrazine Concentration}}{\text{Once-through Cooling Water Flow}} = \text{Hydrazine concentration at the closed cycle cooling canal system}$$

Where (B/S) refers to boiler or steam generator

In the event that any value exceeds 3.4 mg/l, the permittee shall immediately modify its release pattern and resample. The Department's Southeast District office will be notified of the situation within five days.

12. Molybdate, Tolytriazole, and Nitrite Discharge Requirements

The discharge of molybdate, tolytriazole, and nitrite to the closed cycle recirculating cooling canal system during maintenance of the auxiliary closed water system is allowed without limitations and monitoring requirements.

13. Non-discharging/Closed Loop Vehicle Wash Recycle System Requirements

- a) No discharge of recycle system wastewater, including filter backwash water, is authorized to surface water or to ground water

PERMITTEE:

Florida Power & Light Company
9760 S W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010

- b) The rainwater diversion system shall be operated in accordance with the facility's Best Management Practice Procedure as indicated on amended drawing No. 297-036, Alternate No. 6, signed and sealed 4/23/99.
 - c) A placard shall be conspicuously posted in the area of the non-discharging/closed loop recycle equipment which indicates the proper operation of the rainwater diversion system i.e. TRUCK WASH RAINWATER VALVE OPERATING PROCEDURE as indicated on amended drawing No. 297-036 Alternate No. 6, signed and sealed 4/23/99.
 - d) Spent process wastewater shall be disposed of at a Department permitted wastewater treatment facility which is capable of treating the wastewater
 - e) Any oil collected from the oil/water separator shall be disposed by a licensed used oil recycler in accordance with Florida Administrative Code 62-710 or otherwise recycled on site through Department approved methods and procedures.
 - f) Any accidental discharge to ground water or surface water shall be reported to the Southeast District office.
14. Notwithstanding any other requirements of this "No Discharge" permit, the permittee shall comply with all applicable provisions of the Final Judgement dated September 10, 1971, in Civil Action Number 70-328-CA issued by the U.S. District Judge C. Clyde Atkins of the Southern District of Florida.

II. Industrial Sludge Management Requirements

A. Basic Management Requirements

- 1. Sludge or other solids generated from the facility shall be reused, reclaimed, or otherwise disposed of in accordance with the requirements of Chapter 62-701, F.A.C.
- 2. The permittee shall keep records at the facility of the amount of sludge or residuals disposed, transported, or incinerated. If a person other than the permittee is responsible for sludge transporting, disposal, or incineration, the permittee shall also keep the following records:
 - a. name, address and telephone number of any transporter, and any manifests or bill of lading used;
 - b. name and location of the site of disposal, treatment or incineration;
 - c. name, address, and telephone number of the entity responsible for the disposal, treatment, or incineration site

III. Ground Water Monitoring Requirements

- 1. This section is not applicable to this facility.

IV. Other Land Application Requirements

- 1. The Permittee's discharge to ground water shall not cause a violation of the minimum criteria for ground water specified in Rule 62-520.400, F.A.C. and 62-520.430, F.A.C.

PERMITTEE:

PERMIT NUMBER:

FL0001562

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

Issuance date: May 6, 2005
Expiration date: May 5, 2010

V. Operation and Maintenance Requirements

A. Operation of Treatment and Disposal Facilities

1. The permittee shall ensure that the operation of this facility is as described in the application and supporting documents.
2. The operation of the pollution control facilities described in this permit shall be under the supervision of a person who is qualified by formal training and/or practical experience in the field of water pollution control.

B. Record keeping Requirements:

1. The permittee shall maintain the following records on the site of the permitted facility and make them available for inspection:
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports, other than those required in items a. and f. of this section, required by the permit for at least three years from the date the report was prepared, unless otherwise specified by Department rule;
 - c. Records of all data, including reports and documents used to complete the application for the permit for at least three years from the date the application was filed, unless otherwise specified by Department rule;
 - d. A copy of the current permit;
 - e. A copy of any required record drawings;
 - f. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date on the logs or schedule.

VI. Schedules

1. The permittee shall achieve compliance with the other conditions of this permit as follows:

Operational level attained	Issuance Date of permit
----------------------------	-------------------------

2. No later than 14 calendar days following a date identified in the above schedule(s) of compliance, the permittee shall submit either a report of progress or, in the case of specific actions being required by an identified date, a written notice of compliance or noncompliance. In the latter case, the notice shall include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirement.

VII. Other Specific Conditions

A. Specific Conditions Applicable to All Permits

1. Drawings, plans, documents or specifications submitted by the permittee, not attached hereto, but retained on file at the Southeast District Office, are made a part hereof.

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER: FL0001562

Issuance date: May 6, 2005
Expiration date: May 5, 2010

2. Where required by Chapter 471 (P.E.) or Chapter 492 (P.G.) Florida Statutes, applicable portions of reports to be submitted under this permit, shall be signed and sealed by the professional(s) who prepared them.
3. This permit satisfies Industrial Wastewater program permitting requirements only and does not authorize operation of this facility prior to obtaining any other permits required by local, state or federal agencies.

B. Specific Conditions Related to Construction

1. This section is not applicable to this facility.

C. Duty to Reapply

1. The permittee shall submit an application to renew this permit at least 180 days before the expiration date of this permit.
2. The permittee shall apply for renewal of this permit on the appropriate form listed in Rule 62-620.910, F.A.C., and in the manner established in Chapter 62-620, F.A.C., and the Department of Environmental Protection Guide to Wastewater Permitting including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C.
3. An application filed in accordance with subsections 1. and 2. of this part shall be considered timely and sufficient. When an application for renewal of a permit is timely and sufficient, the existing permit shall not expire until the Department has taken final action on the application for renewal or until the last day for seeking judicial review of the agency order or a later date fixed by order of the reviewing court.
4. The late submittal of a renewal application shall be considered timely and sufficient for the purpose of extending the effectiveness of the expiring permit only if it is submitted and made complete before the expiration date.

D. Specific Conditions Related to Existing Manufacturing, Commercial, Mining, and Silviculture Wastewater Facilities or Activities

1. Existing manufacturing, commercial, mining, and silvicultural wastewater facilities or activities that discharge into surface waters shall notify the Department as soon as they know or have reason to believe:
 - a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following levels
 - (1) One hundred micrograms per liter,
 - (2) Two hundred micrograms per liter for acrolein and acrylonitrile; five hundred micrograms per liter for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter for antimony, or
 - (3) Five times the maximum concentration value reported for that pollutant in the permit application
 - b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following levels
 - (1) Five hundred micrograms per liter,
 - (2) One milligram per liter for antimony, or
 - (3) Ten times the maximum concentration value reported for that pollutant in the permit application.

E. Reopener Clause

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010

1. The permit shall be revised, or alternatively, revoked and reissued in accordance with the provisions contained in Rules 62-620.325 and 62-620.345 F.A.C., if applicable, or to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2) and 307(a)(2) of the Clean Water Act (the Act), as amended, if the effluent standards, limitations, or water quality standards so issued or approved:
 - a. Contains different conditions or is otherwise more stringent than any condition in the permit/or;
 - b. Controls any pollutant not addressed in the permit.

The permit as revised or reissued under this paragraph shall contain any other requirements then applicable.

2. The permit may be reopened to adjust effluent limitations or monitoring requirements should future Water Quality Based Effluent Limitation determinations, water quality studies, DEP approved changes in water quality standards, or other information show a need for a different limitation or monitoring requirement.
3. The Department may develop a Total Maximum Daily Load (TMDL) during the life of the permit. Once a TMDL has been established and adopted by rule, the Department shall revise this permit to incorporate the final findings of the TMDL.

VIII. General Conditions

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, F.S. Any permit noncompliance constitutes a violation of Chapter 403, F.S., and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1), F.A.C.]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2), F.A.C.]
3. As provided in Subsection 403.087(6), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringements of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3), F.A.C.]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4), F.A.C.]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not be

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER: FL0001562

Issuance date: May 6, 2005
Expiration date: May 5, 2010

a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit [62-620.610(5), F.A.C.]

6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit [62-620.610(6), F.A.C.]
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit [62-620.610(7), F.A.C.]
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [62-620.610(8), F.A.C.]
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.[62-620.610(9), F.A.C.]
10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, Florida Statutes, or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. [62-620.610(10), F.A.C.]
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. [62-620.610(11), F.A.C.]
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. [62-620.610(12), F.A.C.]
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. [62-620.610(13), F.A.C.]

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER: FL0001562

Issuance date: May 6, 2005
Expiration date: May 5, 2010

14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the Department approves the transfer [62-620.610(14), F.A.C.]
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. [62-620.610(15), F.A.C.]
16. The permittee shall apply for a revision to the Department permit in accordance with Rule 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Wastewater Permitting at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. [62-620.610(16), F.A.C.]
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance[62-620.610(17), F.A.C.]
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10)
 - b. If the permittee monitors any contaminate more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health (DOH) under Chapter 64E-1, F.A.C., where such certification is required by Rule 62-160.300(4), F.A.C. The laboratory must be certified for any specific method and analyte combination that is used to comply with this permit. For domestic wastewater facilities, the on-site test procedures specified in Rule 62-160.300(4), F.A.C., shall be performed by a laboratory certified test for those parameters or under the direction of an operator certified under Chapter 62-602, F.A.C.
 - e. Fields activities including on-site tests and sample collection, whether performed by a laboratory or a certified operator, must follow the applicable procedures described in DEP-SOP-001/01 (January 2002). Alternate field procedures and laboratory methods may be used where they have been approved according to the requirements of Rules 62-160.220, 62-160.330, and 62-160.600, F.A.C. [62-620.610(18), F.A.C.]
19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. [62-620.610(19), F.A.C.]
20. The permittee shall report to the Department's Southeast District Office any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010

the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.

a. The following shall be included as information which must be reported within 24 hours under this condition:

- (1) Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
- (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
- (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
- (4) Any unauthorized discharge to surface or ground waters.

b. Oral reports as required by this subsection shall be provided as follows:

- (1) For unauthorized releases or spills of untreated or treated wastewater reported pursuant to subparagraph a 4 that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the Department by calling the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.
- (2) Oral reports, not otherwise required to be provided pursuant to subparagraph b(1) above, shall be provided to Department's Southeast District Office within 24 hours from the time the permittee becomes aware of the circumstances.

c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department's Southeast District Office shall waive the written report.

[62-620.610(20), F.A.C.]

21. The permittee shall report all instances of noncompliance not reported under Conditions VIII. 18 and 19 of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Condition VIII. 20. of this permit. [62-620.610(21), F.A.C.]

22. Bypass Provisions.

a. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:

- (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
- (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
- (3) The permittee submitted notices as required under Condition VIII.22 b. of this permit.

PERMITTEE:

Florida Power & Light Company
9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER:

FL0001562

Issuance date:

May 6, 2005

Expiration date:

May 5, 2010


- b. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Condition VIII 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- c. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Condition VIII 22 a (1) through (3) of this permit.
- d. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of Condition VIII 22 a. through c. of this permit.
[62-620.610(22), F.A.C.]

23. Upset Provisions

- a. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The permittee submitted notice of the upset as required in Condition VIII 20. of this permit; and
 - (4) The permittee complied with any remedial measures required under Condition VIII 5. of this permit
- b. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.
- c. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review
[62-620.610(23), F.A.C.]

Executed in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION



Mimi A. Drew
Director, Division of Water Resource Management
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
(850) 245-8592

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551 , 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Florida Power & Light Company
MAILING ADDRESS: 9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER FL0001562

LIMIT: Final
CLASS SIZE: Major

REPORT: Monthly
GROUP: Industrial

FACILITY: FPL Turkey Point Power Plant
LOCATION: 9760 S.W. 344 Street
Florida City, FL 33035

MONITORING GROUP NUMBER: I-001
MONITORING GROUP DESC: non-contact once through condenser cooling water

COUNTY: Dade

NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Temperature (F), Water	Sample Measurement										
PARM Code 00011 P Mon. Site No. OUL-1	Permit Requirement					Report (Day Max.)		DEG.F		Monthly	Instantaneous
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551 , 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Florida Power & Light Company
MAILING ADDRESS: 9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER

FL0001562

LIMIT:
CLASS SIZE:

Final
Major

REPORT:
GROUP:

Quarterly
Industrial

FACILITY: FPL Turkey Point Power Plant
LOCATION: 9760 S.W. 344 Street
Florida City, FL 33035

MONITORING GROUP NUMBER: I-001

MONITORING GROUP DESC: non-contact once through condenser cooling water

COUNTY: Dade

NO DISCHARGE FROM SITE: ☐

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 P Mon. Site No. OUI-1	Permit Requirement					Report (Day.Max.)		MGL		Quarterly	Grab
pH	Sample Measurement										
PARM Code 00400 P Mon. Site No. OUI-1	Permit Requirement					Report (Day.Min.)	Report (Day.Max.)	SU		Quarterly	Grab
Salinity	Sample Measurement										
PARM Code 00480 P Mon. Site No. OUI-1	Permit Requirement						Report (Day.Max.)	PPT		Quarterly	Grab
Specific Conductance	Sample Measurement										
PARM Code 00095 P Mon. Site No. OUI-1	Permit Requirement						Report (Day.Max.)	UMHO/CM		Quarterly	Grab
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551 , 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Florida Power & Light Company
MAILING ADDRESS: 9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER FL0001562

LIMIT: Final
CLASS SIZE: Major

REPORT: Semiannual
GROUP: Industrial

FACILITY: FPL Turkey Point Power Plant
LOCATION: 9760 S.W. 344 Street
Florida City, FL 33035

MONITORING GROUP NUMBER: I-001
MONITORING GROUP DESC: non-contact once through condenser cooling water

COUNTY: Dade

NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Copper, Total Recoverable	Sample Measurement							
PARM Code 01119 P Mon. Site No. OUI-1	Permit Requirement			Report (Day Max.)	UG/L		Semiannually	Grab
Iron, Total Recoverable	Sample Measurement							
PARM Code 00980 P Mon. Site No. OUI-1	Permit Requirement			Report (Day Max.)	MG/L		Semiannually	Grab
Zinc, Total Recoverable	Sample Measurement							
PARM Code 01094 P Mon. Site No. OUI-1	Permit Requirement			Report (Day Max.)	UG/L		Semiannually	Grab
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551 , 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Florida Power & Light Company
MAILING ADDRESS: 9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER FL0001562

LIMIT: Final
CLASS SIZE: Major

REPORT: Monthly
GROUP: Industrial

FACILITY: FPL Turkey Point Power Plant
LOCATION: 9760 S.W. 344 Street
Florida City, FL 33035

MONITORING GROUP NUMBER: I-002
MONITORING GROUP DESC: low volume wastewater (LVW) and equipment area stormwater discharged

COUNTY: Dade

NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
pH	Sample Measurement							
PARM Code 00400 P Mon. Site No. OUI-002	Permit Requirement			Report (Day/Min.)	Report (Day/Max.)	SU	Monthly	Grab
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							
	Sample Measurement							
	Permit Requirement							

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551 , 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Florida Power & Light Company
MAILING ADDRESS: 9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER FL0001562

LIMIT: Final
CLASS SIZE: Major

REPORT: Quarterly
GROUP: Industrial

FACILITY: FPL Turkey Point Power Plant
LOCATION: 9760 S.W. 344 Street
Florida City, FL 33035

MONITORING GROUP NUMBER: I-002
MONITORING GROUP DESC: low volume wastewater (LVW) and equipment area stormwater discharged

COUNTY: Dade

NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Specific Conductance	Sample Measurement										
PARM Code 00095 P Mon. Site No. OUI-002	Permit Requirement					Report (Day/Max.)		UMHO/CM		Quarterly	Grab
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										
	Sample Measurement										
	Permit Requirement										

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: Florida Power & Light Company
MAILING ADDRESS: 9760 S.W. 344 Street
Florida City, FL 33035

PERMIT NUMBER FL0001562

LIMIT: Final
CLASS SIZE: Major

REPORT: Semiannual
GROUP: Industrial

FACILITY: FPL Turkey Point Power Plant
LOCATION: 9760 S.W. 344 Street
Florida City, FL 33035

MONITORING GROUP NUMBER: I-002
MONITORING GROUP DESC: low volume wastewater (LVW) and equipment area stormwater discharged

COUNTY: Dade

NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Solids, Total Suspended	Sample Measurement							
PARM Code 00530 P Mon. Site No. OUI-002	Permit Requirement			Report (Day Max.)	MG/L		Semiannually	Grab
Lead, Total Recoverable	Sample Measurement							
PARM Code 01114 P Mon. Site No. OUI-002	Permit Requirement			Report (Day Max.)	UG/L		Semiannually	Grab
Oil and Grease	Sample Measurement							
PARM Code 00536 P Mon. Site No. OUI-002	Permit Requirement			Report (Day Max.)	MG/L		Semiannually	Grab
Copper, Total Recoverable	Sample Measurement							
PARM Code 01119 P Mon. Site No. OUI-002	Permit Requirement			Report (Day Max.)	UG/L		Semiannually	Grab
Zinc, Total Recoverable	Sample Measurement							
PARM Code 01094 P Mon. Site No. OUI-002	Permit Requirement			Report (Day Max.)	UG/L		Semiannually	Grab
	Sample Measurement							
	Permit Requirement							

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (YY/MM/DD)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions as well as the SUPPLEMENTAL INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.910(10), F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

Add the results to get the Total and divide by the number of days in the month to get the Monthly Average.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.