

BEFORE THE GOVERNOR AND CABINET
OF THE STATE OF FLORIDA

DECEMBER
32/81

In Re: FLORIDA POWER & LIGHT)
COMPANY PALATKA STATION (PUTNAM PLANT),)
MODIFICATION OF CONDITIONS OF)
CERTIFICATION NO. PPS-74-01.)
_____)

The following persons were present and participated in the
disposition of this matter:

Honorable Bob Graham
Governor

Honorable George Firestone
Secretary of State

Honorable Jim Smith
Attorney General

Honorable Gerald A. Lewis
Comptroller

Honorable Bill Gunter
Treasurer and Insurance Commissioner

Honorable Ralph D. Turlinton
Commissioner of Education

Honorable Doyle Conner
Commissioner of Agriculture

MODIFICATION OF CERTIFICATION

BY THE GOVERNOR AND CABINET:

The Governor and Cabinet, sitting as the Siting Board,
having reviewed the Proposed Agreement (attached hereto and
incorporated as Exhibit 1) and being otherwise fully advised
herein, it is

ORDERED:

1. The Agreement of the parties is approved in accordance
with Section 403.516(2), Florida Statutes.

2. Conditions Nos. 1, 2, 4 and 5 of the Site Certification
for Florida Power and Light Company's Putnam Plant are hereby
modified to read as follows:

1. Fuel consumed should not contain more
than 0.7% sulfur nor should stack
emissions exceed those specified in
Florida Administrative Code Rule
17-2.600(6).

2. Stack Height: (no change)

Wind Restriction: (no change)

Wind Monitoring: The permittee
shall measure wind velocity and wind
direction at hourly intervals in the

only for those hours during which either unit of the plant operates on oil. Wind data for the hours during which oil was burned during each month or, if applicable, a statement that no oil was burned during that month, shall be reported to the Northeast District Manager of the Department by the last day of each month following the reporting period. Wind velocity and direction measurements required by this paragraph shall be made in accordance with recognized methods and procedures.

4. The permittee shall install and operate continuous monitoring devices on one of the paired exhaust stacks for the following: Opacity, Nitrogen Oxides. Records of such monitoring shall be available for inspection.

5. The permittee shall install and operate continuously for a 24-hour period every six days, two ambient air, West-Gaeke, monitoring devices for sulfur dioxide and two suspended particulate sampling devices. The location of these ambient air samplers shall be determined by consultation with the Northeast District Manager of the Department. The data collected will be reported to the Northeast District Manager quarterly by the last day of each month following the reporting period utilizing the SAROAD or other mutually acceptable format.

3. Condition No. 32 is hereby added to the Site Certification for Florida Power & Light Company's Putnam Plant, to read as follows:

32. Modification of Conditions

The conditions of this certification may be modified in the following manner:

- A. The Board pursuant to 403.516(1), F.S., hereby delegates to the Secretary the authority to modify, after notice and opportunity for hearing, any conditions pertaining to air and water monitoring and sampling, variances, or exceptions to water quality standards.
- B. All other modifications shall be made in accordance with Section 403.516, Florida Statutes.

DONE AND ENTERED this 22 day of March 1984, in Tallahassee, Florida, pursuant to the vote of the Governor and

Cabinet sitting as the Siting Board at a duly constituted Cabinet meeting on February 21, 1984.

BY THE GOVERNOR AND CABINET
SITTING AS THE SITING BOARD:

Bob Graham
Governor

Copies furnished to:

Peter C. Cunningham, Esquire
Mary F. Clark, Esquire, DCA
Kenneth Morris, Putnam County
Susan Clark, Esquire, PSC
J. Alan Cox, Esquire, DER

FILING AND ACKNOWLEDGEMENT

FILED, on this date, pursuant to S120.52 (9),
Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Chris Vance 3/19/84
Clerk Date