

Worley, Jay A. - Director, Environmental Programs

From: Baxter, John E.
Sent: Tuesday, May 19, 2009 4:03 PM
To: 'marc.harris@dep.state.fl.us'; 'Long, Melissa M.'
Cc: Worley, Jay A. - Director, Environmental Programs; Kofler, Bruce W. - Mgr. Environmental Compliance
Subject: St Johns River Power Park - DBA Approval

Marc/Melissa,

Reference is made to the letter we submitted to the Department on May 12th to add dibasic acid to the flue gas desulphurization system at SJRPP. Below is additional information we'd like included in our submittal regarding the prior approval. If you have any questions, please let us know. Thanks.

Thanks,
John Baxter
(904) 665-5359, Office
(904) 219-0921, Mobile

-----Original Message-----

From: Hatcher, Michael [mailto:Michael.Hatcher@dep.state.fl.us]
Sent: Friday, March 19, 2004 9:48 AM
To: Kofler, Bruce W.
Subject: St Johns River Power Park

Bruce,

This is to confirm our conversation this morning regarding the previous minor permit revision application that was submitted to the Department on September 3, 2003 and subsequently approved January 9, 2004. As was previously discussed with JEA staff at the time of submittal of the minor permit revision application the use of the Adipic/Di-basic acid in the FGD process does not require a revision of the facility's wastewater permit. The information on the characteristics and use of the Adipic/Di-basic acid that was provided along with minor permit revision application has been placed in the permit file for this facility.

Thanks,

Michael Hatcher, P.E.
Power Plant Permitting
Industrial Wastewater Section
850-245-8593
SC 205-8593