

Regeneration Log (Concurrent Series)

Date: 1-6-06

Time: 1400

Run length: 214,000 - 18000 = _____ gallons

Service Water pressure: 92 psi Temp. 72 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #		
					60°	70°	80°	83°				
1	SA	BW	15	60	50	57	66	68	56	110		
2	SA	Settle	3	60								
3	SC	BW	10	59	75	87	97	101	87	97		
4	PA	BW	15	59	50	57	62	64	57	53	Hydrometer	
5	PC	BW	15	59	120	140	153	158	140	36	Target	Actual
6a	SA	3% NaOH	29	60		10			10	155	1.0417	
6b	SA to PA	3% NaOH	66	60		10			10	155	1.0417	1.042
6c	SA to PA	SR	32	60		20			20	156		Total: 1590
6d	PC	Settle	3	60		0						
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.008
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.018
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	1.031
6h	SC to PC	SR	8	59		85			85	191		Total: 2975
6i	PC	FR	16	59		165			165	29		3120
7	PA	FR	22	60		165			165	49		
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82		
9	SC	FR	17	60		165			165	91		
10	SA	FR	14/CT-3 < 500	60		165			165	103		
11	Rinse Recycle		13/CT-5 < 200	60		165			125	116		
12	Mandatory Recycle		10			165			125	116		
	Service					150				122		

3% = 1.0215

5% = 1.0417

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: Acid 2 mins

Dump ph: 10

Notes:

Regeneration Log (Concurrent Series)

Date: 1-11-06

Time: 2200

Run length: 214,000 - 20,000 = 194,000 gallons

Service Water pressure: 82 psi Temp. 72 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target				Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			3%= 1.0215		5%=1.0417	
1	SA	BW	15	60	50	57	66	68	58	110				
2	SA	Settle	3	60					—					
3	SC	BW	10	59	75	87	97	101	86	97				
4	PA	BW	15	59	50	57	62	64	56	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	140	36	Target	Actual	Target	Actual
6a	SA	3% NaOH	29	60		10			10	155	1.0417	1.040	290	300
6b	SA to PA	3% NaOH	66	60		10			10	155	1.0417	1.040	950	980
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1590
6d	PC	Settle	3	60		0			0					
6e	SC to PC	1.5% Acid	12	59		85			86	191/206	1.0084	1.010	1020	1130
6f	SC to PC	3.0% Acid	9	59		85			86	191/207	1.0184	1.018	1785	1910
6g	SC to PC	5.0% Acid	6	59		85			86	191/208	1.0317	1.020	2295	2310
6h	SC to PC	SR	8	59		85			86	191		Total:	2975	3120
6i	PC	FR	16	59		165			164	29				
7	PA	FR	22	60		165			167	49				
8	PC to PA	Recycle	30/CT-1 <20	60		165			160	82				
9	SC	FR	17	60		165			168	91				
10	SA	FR	14/CT-3 <500	60		165			168	103				
11	Rinse Recycle		13/CT-5 <200	60		165			168	116				
12	Mandatory Recycle		10			165			168	116				
	Service					150				122				

Caustic Pump # A

Setting: 400

Caustic Temp. 170

Target = 49° C or 120° F

Caustic Pump # A

Setting: 400

Caustic Temp. 170

Target = 49° C or 120° F

Neutralization Basin pH: 9.6

Corrections: 1 min. acid

Dump ph: 5.80

Notes:

Regeneration Log (Concurrent Series)

Date: 2-28-06

Time: 1530

Run length: 214,000 - 19000 = 195000 gallons

Service Water pressure: psi Temp. 74 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	60	110				
2	SA	Settle	3	60								3%= 1.0215		
3	SC	BW	10	59	75	87	97	101	88	97		5%=1.0417		
4	PA	BW	15	59	50	57	62	64	60	53	Hydrometer	Dilution Water		
5	PC	BW	15	59	120	140	153	158	146	36	Target	Actual	Target	Actual
6a	SA	3% NaOH	29	60		10			12	155	1.0417	1.060	290	379
6b	SA to PA	3% NaOH	66	60		10			12	155	1.0417	1.040	950	1001
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1625
6d	PC	Settle	3	60		0			0					1710
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.012	1020	1140
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.016	1785	1921
6g	SC to PC	5.0% Acid	6	59		85			55	191/208	1.0317	1.021	2295	2338
6h	SC to PC	SR	8	59		85			86	191		Total:	2975	3144
6i	PC	FR	16	59		165			164	29				3090
7	PA	FR	22	60		165			165	49				
8	PC to PA	Recycle	30/CT-1 ≤ 20 ✓	60		165			164	82				
9	SC	FR	17 ✓	60		165			165	91	250 ✓	Caustic Pump #	P51A	
10	SA	FR	14/CT-3 ≤ 5 ✓	60		165			163	103		Setting:	400	
11	Rinse Recycle		13/CT-5 ≤ 2 ✓	60		165			124	116		Caustic Temp.	124°F	
12	Mandatory Recycle		10			165			124	116		Target =	49° C or 120° F	
	Service					150			NO	122				

Neutralization Basin pH: 11.4

Corrections: 3 MINS, Acid

Dump ph: 7

Notes: After Regen Nant's Basin was approx. 2/3 full. (High odor of faeces)
Initial pH of N/Basin High.

over
② 275 1/4 171/2 Jemini tank

Regeneration Log (Concurrent Series)

Date: 3-3-06

Time: 0240

Run length: $214,000 - 18,000 = 196,000$ gallons

Service Water pressure: 90 psi Temp. 74 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #		
					60°	70°	80°	83°				
1	SA	BW	15	60	50	57	65	68	60	110		
2	SA	Settle	3	60								
3	SC	BW	10	59	75	87	97	101	90	97		
4	PA	BW	15	59	50	57	62	64	60	53	Hydrometer	
5	PC	BW	15	59	120	140	153	158	145	36	Target	Actual
6a	SA	3% NaOH	29	60		10			10	155	1.0417	—
6b	SA to PA	3% NaOH	66	60		10			10	155	1.0417	
6c	SA to PA	SR	32	60		20			20	156		Total: 1590
6d	PC	Settle	3	60		0						
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.010
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.020
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	
6h	SC to PC	SR	8	59		85			85	191		Total: 2975
6i	PC	FR	16	59		165			165	29		
7	PA	FR	22	60		165			164	49		
8	PC to PA	Recycle	30/CT-1 < 20	60		165			162	82		
9	SC	FR	17	60		165			164	91		
10	SA	FR	14/CT-3 < 500	60		165			164	103		
11	Rinse Recycle		13/CT-5 < 200	60		165			130	116		
12	Mandatory Recycle		10			165			130	116		
	Service					150				122		

3% = 1.0215

5% = 1.0417

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.8

Corrections: NONE

Dump ph: 7.8

Notes:

Regeneration Log (Concurrent Series)

Date: 03-15-06

Time: 09:15

Run length: 214,000 - 52K = 162000 gallons

Service Water pressure: 94 psi Temp. 97 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM/Target											
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #	
1	SA	BW	15	60	50	57	66	68	60	110	
2	SA	Settle	3	60					✓		
3	SC	BW	10	59	75	87	97	101	93	97	
4	PA	BW	15	59	50	57	62	64	60	53	
5	PC	BW	15	59	120	140	153	158	145	36	
6a	SA	5% NaOH	29	60	10				10	155	
6b	SA to PA	5% NaOH	66	60	10				10	155	
6c	SA to PA	SR	32	60	20				20	156	
6d	PC	Settle	3	60	0				✓		
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	
6h	SC to PC	SR	8	59	85				85	191	
6i	PC	FR	16	59	165				165	29	
7	PA	FR	22	60	165				165	49	
8	PC to PA	Recycle	30/CT-1 < 20	60	165				160	82	
9	SC	FR	17	60	165				165	91	
10	SA	FR	14/CT-3 < 100	60	165				165	103	
11	Rinse Recycle			13/CT-5 < 2.00	60	165				125	116
12	Mandatory Recycle			10		165				116	
	Service					150				122	

3%= 1.0215
5%=1.0417

Hydrometer

Dilution Water

Target	Actual	Target	Actual
1.0417	1.0	290	280
1.0417	1.042	950	920
	Total:	1590	

100 MINUTES * ✓ - Prolong 2 min
✓ Prolong 5 MINUTES
✓ 4 MINUTES

Caustic Pump # 5A

Setting: 400

Caustic Temp. 120 ° F

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections:

Dump ph:

Notes: Chain Valve & P2 Seized up. Will not turn/budge/move.

⑧ Unit failed to go into mandatory recycle on start.

C91 Tekko. started visit in Managua then switched to

Auto & it worked.

Regeneration Log (Concurrent Series)

Date: 3-17-06
 Time: 0415
 Run length: 214,000 - 30K = 184K gallons
 Service Water pressure: 94 psi Temp. 78 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	60	110
2	SA	Settle	3	60					✓	
3	SC	BW	10	59	75	87	97	101	94	97
4	PA	BW	15	59	50	57	62	64	60	53
5	PC	BW	15	59	120	140	153	158	160	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0				—	
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116
12	Mandatory Recycle		10		165				165	116
	Service				150				150	122

3% = 1.0215
 5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	280
1.0417	1.042	950	
Total:		1590	
1.0084	1.0075	1020	1050
1.0184	1.018	1785	
1.0317	1.3	2295	2262
Total:		2975	

Caustic Pump # _____

Setting: _____

Caustic Temp. _____

Target = 49° C or 120° F

Neutralization Basin pH: 8

Corrections: _____

Dump ph: 8

Notes: _____

Regeneration Log (Concurrent Series)

Date: 3-20-04

Time: 1653

Run length: $214,000 - 22,000 = 192,000$ gallons

Service Water pressure: 92 psi Temp. 76 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	40	110				
2	SA	Settle	3	60							3%= 1.0215			
3	SC	BW	10	59	75	87	97	101	87	97	5%=1.0417			
4	PA	BW	15	59	50	57	62	64	60	53	Hydrometer	Dilution Water		
5	PC	BW	15	59	120	140	153	158	144	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60		10			10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60		10			10	155	1.0417	1.040	950	
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1610
6d	PC	Settle	3	60		0								
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.009	1020	
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	1.0310	2295	
6h	SC to PC	SR	8	59		85			85	191		Total:	2975	3130
6i	PC	FR	16	59		165			165	29				
7	PA	FR	22	60		165			164	49				
8	PC to PA	Recycle	30/CT-1 < 20	60		165			159	82				
9	SC	FR	17	60		165			165	91				
10	SA	FR	14/CT-3 < 100	60		165			165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60		165			124	116				
12	Mandatory Recycle		10			165			124	116				
	Service					150			123	122				

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.4

Corrections: None

Dump ph: 8.4

Notes:

Regeneration Log (Concurrent Series)

Date: 3/23/06
 Time: 1115
 Run length: 214,000 - 26,000 = 188,000 gallons
 Service Water pressure: 90 psi Temp. 75 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	67	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53
5	PC	BW	15	59	120	140	153	158	<u>145</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0				<u>0</u>	
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	22	60	165				<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>160</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60	165					<u>175</u>	116
12	Mandatory Recycle		10		165				<u>175</u>	116
	Service				150					122

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.040</u>	290	
1.0417	<u>1.041</u>	950	
	Total:	1590	
1.0084	<u>1.012</u>	1020	
1.0184	<u>1.020</u>	1785	
1.0317		2295	
	Total:	2975	

Caustic Pump # 5B
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 8.0
 Corrections: 30 sec ACID
 Dump ph: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 4/12/06
 Time: 07:13
 Run length: 214,000 - 29,000 = 185,000 gallons
 Service Water pressure: 88 psi Temp. 77 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>61</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>92</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>59</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>146</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417	<u>1.041</u>	290	
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>1.041</u>	950	
6c	SA to PA	SR	32	60	20				<u>20</u>	156	Total:		1590	
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>1.008</u>	1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>1.018</u>	1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317	<u>1.030</u>	2295	
6h	SC to PC	SR	8	59	85				<u>85</u>	191	Total:		2975	
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	22	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>160</u>	82				
9	SC	FR	17	60	165				<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>123</u>	116				
12	Mandatory Recycle		10		165				<u>123</u>	116				
	Service				150					122				

Caustic Pump # 5A
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 8.9
 Corrections: 30 sec
 Dump pH: 7.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 4-17-06

Time: 16 40

Run length: $214,000 - 7,000 = 207,000$ gallons

Service Water pressure: 86 psi Temp. 77 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM Target														
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #				
1	SA	BW	15	60	50	57	66	68	59	110				
2	SA	Settle	3	60					—				3%= 1.0215	
3	SC	BW	10	59	75	87	97	101	90	97			5%=1.0417	
4	PA	BW	15	59	50	57	62	64	58	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	140	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417	—	290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.0400	950	
6c	SA to PA	SR	32	60	20					156		Total:	1590	1630
6d	PC	Settle	3	60	0				—					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.0080	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.0190	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.0300	2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3270
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165					49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165					82				
9	SC	FR	17	60	165					91				
10	SA	FR	14/CT-3 < 100	60	165					103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116				
12	Mandatory Recycle		10		165					116				
	Service				150				145	122	2445			

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Başın pH: 9.5

Corrections: Yes

Dump ph: 7.5

Notes: SUPER - SMOOTH

[illegible]

Regeneration Log (Concurrent Series)

Date: 7/19/06

Time: 0700

Run length: 214,000 - 30,000 = 184,000 gallons

Service Water pressure: 94 psi Temp. 80 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM Target										Actual	RSV #						
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	3%= 1.0215			5%=1.0417					
1	SA	BW	15	60	50	57	66	68			66			110			
2	SA	Settle	3	60													
3	SC	BW	10	59	75	87	97	101	97	97							
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer			Dilution Water			
5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual			
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290				
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417		950				
6c	SA to PA	SR	32	60	20				20	156		Total:	1590				
6d	PC	Settle	3	60	0												
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084		1020				
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184		1785				
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317		2295				
6h	SC to PC	SR	8	59	85				85	191		Total:	2975				
6i	PC	FR	16	59	165				165	29							
7	PA	FR	22	60	165				165	49							
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82							
9	SC	FR	17	60	165				165	91							
10	SA	FR	14/CT-3 < 100	60	165				165	103							
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116							
12	Mandatory Recycle		10		165					116							
	Service				150					122							

Caustic Pump # 13

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 1 min ACID
Dump pH: 8.0

Notes:

Caustic Pump # 15

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 4/22/06

Time: 08:10

Run length: $214,000 - 27,000 = 187,000$ gallons

Service Water pressure: 86 psi Temp. 70 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0				0	
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				160	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 400	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116
12	Mandatory Recycle		10		165				125	116
	Service				150					122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.041	950	
	Total:	1590	
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
	Total:	2975	

Caustic Pump # A

Setting: 400

Caustic Temp. 119

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: 20 Dec

Dump ph: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 4/27/06

Time: 10:03

Run length: 214,000 - 20,000 = 194,000 gallons

Service Water pressure: 86 psi Temp. 78 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°				Hydrometer		Dilution Water	
1	SA	BW	15	60	50	57	66	68	64	110					
2	SA	Settle	3	60											
3	SC	BW	10	59	75	87	97	101	95	97					
4	PA	BW	15	59	50	57	62	64	60	53					
5	PC	BW	15	59	120	140	153	158	150	36		Target	Actual	Target	Actual
6a	SA	3% NaOH	29	60		10			10	155	1.0417			290	
6b	SA to PA	3% NaOH	66	60		10			10	155	1.0417			950	
6c	SA to PA	SR	32	60		20			20	156		Total:		1590	
6d	PC	Settle	3	60		0									
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.008		1020	
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.018		1785	
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	1.031		2295	
6h	SC to PC	SR	8	59		85			85	191		Total:		2975	3110
6i	PC	FR	16	59		165			165	29					
7	PA	FR	22:00	60		165			165	49					
8	PC to PA	Recycle	30/CT-1 <20	60		165			163	82					
9	SC	FR	17:50	60		165			165	91					
10	SA	FR	14/CT-3 <500	60		165			165	103					
11	Rinse Recycle		13:07.5 <200	60		165			125	116					
12	Mandatory Recycle		10			165			125	116					
	Service					150				122					

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5.5

Corrections: 1 min Caust

Dump pH: 6.5

Notes:

Regeneration Log (Concurrent Series)

Date: 5/5/06
Time: 11:55

Run length: 214,000 - 19000 = _____ gallons
Service Water pressure: 100 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>95</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>151</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417			
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417			
6c	SA to PA	SR	32	60	20				<u>20</u>	156	<u>1.041</u>	Total:	1590	<u>15</u>
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>1.010</u>	1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>1.018</u>	1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317	<u>1.031</u>	2295	<u>2270</u>
6h	SC to PC	SR	8	59	85				<u>85</u>	191		Total:	2975	<u>3140</u>
6i	PC	FR	16	59	165				<u>167</u>	29				
7	PA	FR	22	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>160</u>	82				
9	SC	FR	17	60	165				<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116				
12	Mandatory Recycle		10		165				<u>Reset</u>	116				
	Service				150				<u>140</u>	122				

Caustic Pump # 5A
Setting: 400
Caustic Temp. 125
Target = 49° C or 120° F

Neutralization Basin pH: 5
Corrections: 6 min caustic
Dump ph: 7.0

Notes: program STOP on Fast Rinse.
Had to Reboot system - P/A - Reset to 19.9K
plc
5/4/06
5/0

D. Aviles. 2245

(C) MONTRE

Regeneration Log (Concurrent Series)

Date: 05-14-06
 Time: 10:44 *Regeneration of Anion(s)*
 Run length: 214,000 - gallons
 Service Water pressure: 95 psi Temp. 78 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Repeat caustic application / Regen of Anion(s)

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68		110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101		97				
4	PA	BW	15	59	50	57	62	64		53				
5	PC	BW	15	59	120	140	153	158		36				
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417		950	
6c	SA to PA	SR	32	60	20				20	156	Total:		1590	
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85					191/206	1.0084		1020	
6f	SC to PC	3.0% Acid	9	59	85					191/207	1.0184		1785	
6g	SC to PC	5.0% Acid	8	59	85					191/208	1.0317		2295	
6h	SC to PC	SR	8	59	85					191	Total:		2975	
6i	PC	FR	16	59	165					29				
7	PA	FR	22	60	165				164	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				163	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116				
12	Mandatory Recycle				165					116				
	Service				150					122				

Caustic Pump # 5B

Setting: 400

Caustic Temp. 120° F

Target = 49° C or 120° F

Neutralization Basin pH: 10+
 Corrections: 5 min acid
 Dump pH: 7

Notes: Did not go to step # 11 and gave a Rinse to waste conductivity High alarm.

Regeneration Log (Concurrent Series)

Date: 5/2/06

Time: 0915

Run length: 214,000 - = gallons

Service Water pressure: 100 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			160	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
	Total:	1590	
1.0084	1.008	1020	
1.0184	1.019	1785	
1.0317	1.032	2295	
	Total:	2975	

Caustic Pump # 13

Setting: 1100

Caustic Temp. 121


Target = 49° C or 120° F

Neutralization Basin pH: 5.0

Corrections: Caustic for 5 min

Dump pH: 6.5

Notes: _____



Regeneration Log (Concurrent Series)

Date: 5-31-06

Time: 1335

Run length: $214,000 - 63,000 = 151,000$ gallons

Service Water pressure: 84 psi Temp. 82 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target					
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	63	53
5	PC	BW	15	59	120	140	153	158	155	36
6a	SA	5% NaOH	29	60	10				9	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				84	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				130	116
12	Mandatory Recycle		10		165				130	116
	Service				150					122

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	No Flow	290	280
1.0417	1.042	950	950
Total:		1590	1560
Total:		2975	3120

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5.5

Corrections: Added Canonic

Dump ph: 7.0

Notes: _____

...Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 06-04-06

Time: 15:15

Run length: 214,000 - 24000 = 190,000 gallons

Service Water pressure: 196 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			✓	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			11	82
9	SC	FR	17	60		165			11	91
10	SA	FR	14/CT-3 < 5	60		165			11	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			11	116
12	Mandatory Recycle		10			165			11	116
	Service	175				150			150	122

3%= 1.0215	
5%= 1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	
1.0417	1.0415	950	
	Total:	1590	
	Total:	2975	

Caustic Pump # 5A

Setting: 250/400

Caustic Temp. 120°F

Target = 49° C or 120° F

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.042</u>	290	
1.0417	<u>1.0415</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.0175</u>	1785	
1.0317	<u>1.03</u>	2295	
	Total:	2975	

Caustic Pump # 5A
Setting: 250/400
Caustic Temp. 120°F
Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: 0

Dump ph: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 6-8-06

Time: 0022

Run length: 214,000 - 18000 = 195,000 gallons

Service Water pressure: 93 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	<u>67</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>125</u>	116
12	Mandatory Recycle		10			165			<u>125</u>	116
	Service					150				122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	<u>320</u>
1.0417	<u>1.041</u>	950	<u>980</u>
	Total:	1590	<u>1650</u>
1.0084	<u>1.008</u>	1020	<u>1020</u>
1.0184	<u>1.018</u>	1785	<u>1900</u>
1.0317	<u>1.031</u>	2295	<u>2420</u>
	Total:	2975	<u>3110</u>

Caustic Pump # A
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections:

Dump ph: 8.0

Notes:

Regeneration Log (Concurrent Series)

Date: 4/11/06

Time: _____

Run length: 214,000 - 25,000 = 189,000 gallons

Service Water pressure: 93 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	68	68	<u>67</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>152</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417	—	290	
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>1.041</u>	950	
6c	SA to PA	SR	32	60	20				<u>20</u>	156				
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>1.008</u>	1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>1.018</u>	1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317	<u>1.031</u>	2295	
6h	SC to PC	SR	8	59	85				<u>85</u>	191				
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	22	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82				
9	SC	FR	17	60	165				<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60	165					103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116				
12	Mandatory Recycle		10		165					116				
	Service				150					122				

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	
1.0417	<u>1.041</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.031</u>	2295	
	Total:	2975	

Caustic Pump # 3
Setting: 250/400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: _____

Dump pH: 8.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 6-14-15-66

Time: 0015

Run length: 214,000 - 51,000 = _____ gallons

Service Water pressure: 86 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>68</u>	110
2	SA	Settle	3	60					<u>✓</u>	
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>158</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0			<u>✓</u>	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>130</u>	116
12	Mandatory Recycle		10			165			<u>130</u>	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	<u>300</u>
1.0417	<u>1.04</u>	950	<u>960</u>
	Total:	1590	
1.0084	<u>1.008</u>	1020	<u>1020</u>
1.0184	<u>1.018</u>	1785	<u>1850</u>
1.0317	<u>1.030</u>	2295	<u>2300</u>
	Total:	2975	<u>3060</u>

Caustic Pump # A

Setting: 220/400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 3 MIN ACID
Dump pH: 7.0

Notes: _____

[Handwritten signature]

Regeneration Log (Concurrent Series)

Date: 6/18/06

Time: 0730

Run length: $214,000 - 14,000 = 200,000$ gallons

Service Water pressure: 99 psi Temp. 80 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	151	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle			13/CT-5 < 2.00	60		165		160	116
12	Mandatory Recycle			10			165		160	116
	Service						150			122

$$3\% = 1.0215$$
 $5\% = 1.0417$

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.041	950	
	Total:	1590	
			1610
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
	Total:	2975	3120

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: add and for 30 sec.

Dump ph: 7-0

Notes:



Regeneration Log (Concurrent Series)

Date: 6/20/06

Time: 1353

Run length: 214,000 - 14,000 = 200,000 gallons

Service Water pressure: 93 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	67	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0				—	
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				164	29
7	PA	FR	22	60	165				164	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				164	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116
12	Mandatory Recycle		10		165				125	116
	Service				150					122

3%= 1.0215	
5%=1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.041	950	
	Total:	1590	
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
	Total:	2975	

Caustic Pump # A

Setting: 250/400

Caustic Temp. 120

Target = 49° C or 120° F

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.041</u>	950	
Total:		1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.031</u>	2295	
Total:		2975	

Caustic Pump # A

Setting: 250/400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: None

Dump pH: 8.0

Notes:

Regeneration Log (Concurrent Series)

Date: 6-23-06

Time: 1457

Run length: 214,000 - 22000 = _____ gallons

Service Water pressure: 99 psi Temp. 84 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>68</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>100</u>	97
4	PA	BW	15	59	50	57	62	64	<u>64</u>	53
5	PC	BW	15	59	120	140	153	158	<u>158</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>125</u>	116
12	Mandatory Recycle		10			165			<u>125</u>	116
	Service					150				122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.0417</u>	950	
	Total:	1590	<u>1610</u>
1.0084	<u>1.0084</u>	1020	
1.0184	<u>1.0184</u>	1785	
1.0317	<u>1.0317</u>	2295	
	Total:	2975	<u>3190</u>

Caustic Pump # A

Setting: 700

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.0

Corrections: _____

Dump ph: 6.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 6-26-6

Time: 14:45

Run length: 214,000 - 147000 = 64 gallons

Service Water pressure: 98 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60					✓	
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			✓	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	16	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			125	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.04	290	
1.0417	1.04	950	
	Total:	1590	
1.0084	1.008	1020	
1.0184	1.019	1785	
1.0317	1.03	2295	
	Total:	2975	

Caustic Pump # 5B
Setting: 400
Caustic Temp. 120°F
Target = 49° C or 120° F

Neutralization Basin pH: 8
Corrections: None
Dump pH: 8

Notes: _____

24300
2430
445.50
2164.80
4329.60

Regeneration Log (Concurrent Series)

Date: 6-30-06

Time: 0036

Run length: 214,000 - 18,000 = 196,000 gallons

Service Water pressure: 88 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	163	158	<u>152</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>164</u>	82
9	SC	FR	17	60		165			<u>166</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>163</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>126</u>	116
12	Mandatory Recycle		10			165			<u>126</u>	116
	Service					150				122

3%=1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.043</u>	290	<u>300</u>
1.0417	<u>1.043</u>	950	<u>970</u>
Total:		1590	<u>1620</u>
Total:		2975	<u>3160</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 1 min acid

Dump pH: 8.0

Notes:

Regeneration Log (Concurrent Series)

Date: 7/2/06

Time: 1700

Run length: 214,000 - 23 = 191000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			125	116
12	Mandatory Recycle		10			165			125	116
	Service					150				122

3%= 1.0215	
5%= 1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	280
1.0417	1.041	950	
	Total:	1590	1580
1.0084	1.085	1020	1110
1.0184	1.190	1785	
1.0317	1.031	2295	
	Total:	2975	3050

Caustic Pump # A

Setting: 400

Caustic Temp. 119

Target = 49° C or 120° F

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
		290	<u>280</u>
		950	
	Total:	1590	<u>1580</u>
	Total:	2975	<u>3050</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 119

Target = 49° C or 120° F

Neutralization Basin pH: _____

Corrections: _____

Dump pH: 8.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 7/5/66

Time: 17:15

Run length: 214,000 - 31 = 183,000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	3%= 1.0215			5%=1.0417	Hydrometer		Dilution Water
1	SA	BW	15	60	50	57	66	68	65	110					
2	SA	Settle	3	60											
3	SC	BW	10	59	75	87	97	101	96	97					
4	PA	BW	15	59	50	57	62	64	61	53	Hydrometer		Dilution Water		
5	PC	BW	15	59	120	140	153	158	152	36	Target	Actual	Target	Actual	
6a	SA	5% NaOH	29	60		10			10	155	1.0417		290		
6b	SA to PA	5% NaOH	66	60		10			10	155	1.0417	1.0417	950		
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1580	
6d	PC	Settle	3	60		0									
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.0084	1020		
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.0184	1785		
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	1.0317	2295		
6h	SC to PC	SR	8	59		85			85	191		Total:	2975	3100	
6i	PC	FR	16	59		165			165	29					
7	PA	FR	22	60		165			165	49					
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82					
9	SC	FR	17	60		165			165	91					
10	SA	FR	14/CT-3 < 100	60		165			165	103					
11	Rinse Recycle		13/CT-5 < 2.00	60		165			160	116					
12	Mandatory Recycle		10			165			160	116					
	Service					150				122					

Caustic Pump # 13

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Caustic Pump # 13

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: _____

Dump pH: _____

Notes: _____



Regeneration Log (Concurrent Series)

Date: 7/8/06
Time: 1422

Run length: 214,000 - 25,000 = 189,000 gallons
Service Water pressure: 86 psi Temp. 80 degrees F
A

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°				3%= 1.0215		5%=1.0417	
1	SA	BW	15	60	50	57	66	68	66	110					
2	SA	Settle	3	60											
3	SC	BW	10	59	75	87	97	101	97	97					
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water		
5	PC	BW	15	59	120	140	153	158	152	36	Target	Actual	Target	Actual	
6a	SA	5% NaOH	29	60		10			10	155	1.0417		290		
6b	SA to PA	5% NaOH	66	60		10			10	155	1.0417		950		
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1640	
6d	PC	Settle	3	60		0			0						
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084		1020		
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184		1785		
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317		2295		
6h	SC to PC	SR	8	59		85			85	191		Total:	2975	3080	
6i	PC	FR	16	59		165			165	29					
7	PA	FR	22	60		165			165	49					
8	PC to PA	Recycle	30/CT-1 < 20	60		165			1	82					
9	SC	FR	17	60		165			1	91					
10	SA	FR	14/CT-3 < 100	60		165			1	103					
11	Rinse Recycle		13/CT-5 < 2.00	60		165			126	116					
12	Mandatory Recycle		10			165			126	116					
	Service					150				122					

Caustic Pump # _____

Setting: _____

Caustic Temp. _____

Target = 49° C or 120° F

Caustic Pump # _____

Setting: _____

Caustic Temp. _____

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 1 MIN ACID

Dump ph: 8.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 7/10/06
 Time: 1628
 Run length: 214,000 - 148K = _____ gallons
 Service Water pressure: 91 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

GPM Target													
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #			
1	SA	BW	15	60	50	57	66	68	66	110			
2	SA	Settle	3	60									3%= 1.0215
3	SC	BW	10	59	75	87	97	101	98	97			5%=1.0417
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water
5	PC	BW	15	59	120	140	153	158	152	36	Target	Actual	Target Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1041	950
6c	SA to PA	SR	32	60	20					156	Total:		1590
6d	PC	Settle	3	60	0								
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1031	2295
6h	SC to PC	SR	8	59	85				85	191	Total:		2975 3080
6i	PC	FR	16	59	165				165	29			
7	PA	FR	22	60	165				165	49			+8
8	PC to PA	Recycle	30/CT-1 < 20	60	165				162	82			
9	SC	FR	17	60	165				165	91			+3
10	SA	FR	14/CT-3 < 100	60	165				165	103			+5
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116			B
12	Mandatory Recycle		10		165					116			
	Service				150					122			

Caustic Pump # B
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 10.8
 Corrections: 3 minutes Acid 4 min caustic
 Dump ph: 6.8

Notes: to much acid had to use caustic
RAISE ph. to Dump.

Resin changed on cation

Regeneration Log (Concurrent Series)

Date: 7/7/

Time: 1350

Run length: 214,000 - 137K = _____ gallons

Service Water pressure: 90 psi Temp. 74 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM Target											
Step	Vessel	Process	Time	Add.	60°	70°	80°	85°	Actual	RSV #	
1	SA	BW	15	60	50	57	66	68	66	110	
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101	98	97	
4	PA	BW	15	59	50	57	62	64	62	53	
5	PC	BW	15	59	120	140	153	158	153	36	
6a	SA	5% NaOH	29	60		10			10	155	
6b	SA to PA	5% NaOH	66	60		10			10	155	
6c	SA to PA	SR	32	60		20			20	156	
6d	PC	Settle	3	60		0					
6e	SC to PC	1.5% Acid	12	59		85			74	191/206	
6f	SC to PC	3.0% Acid	9	59		85			74	191/207	
6g	SC to PC	5.0% Acid	6	59		85			74	191/208	
6h	SC to PC	SR	8	59		85			74	191	
6i	PC	FR	16	59		165			165	29	
7	PA	FR	22	60		165			165	49	
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82	
9	SC	FR	17	60		165			165	91	
10	SA	FR	14/CT-3 < 100	60		165			165	103	
11	Rinse Recycle		13/CT-5 < 2.00	60		165			126	116	
12	Mandatory Recycle		10			165				116	
	Service					150				122	

3%= 1.0215	
5%=1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1040	950	
Total:		1590	1660

48
+5
+5

LOW

Caustic Pump # B

Setting: 400

Caustic Temp. 170

Target = 49° C or 120° F

Neutralization Basin pH: 9.5

Corrections: 2 mins Acid

Dump ph: 7.0

Notes:

Low flow on Acid

Regeneration Log (Concurrent Series)

Date: 7/12/06

Time: 1670

Run length: 214,000 - 70,100 = 144,000 gallons

Service Water pressure: 87 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

WAS NOT MONITORED
** NO FLOW THROUGH SAND POINT (CAUSTIC WAS FLOWING)*

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>64</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0			<u>0</u>	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>164</u>	49
8	PC to PA	Recycle 30/CT-1 < 20	60			165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR 14/CT-3 < 100	60			165			<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>125</u>	116
12	Mandatory Recycle		10			165			<u>125</u>	116
	Service					150			<u>145</u>	122

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<i>*</i>	950	
Total:		1590	<u>1600</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.017</u>	1785	
1.0317	<u>1.033</u>	2295	
Total:		2975	<u>3330</u>

Caustic Pump # A
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 9.5
Corrections: Acid 2 min
Dump pH: 7.5

Notes: CT 4 conductivity High fast rinse recycle

Regeneration Log (Concurrent Series)

Date: 7/16/06

Time: 1900

Run length: $214,000 - 33,000 = 181,000$ gallons

Service Water pressure: 85 psi Temp. 87 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			162	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			124	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	
1.0417	1.041	950	
	Total:	1590	1600

	Total:	2975	3110
--	--------	------	------

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5.0

Corrections: ADD CAUSTIC 4 min

Dump ph: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 7/20/06

Time: 13:30

Run length: 214,000 - 4000 = 210,000 gallons

Service Water pressure: 95 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	87	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16 ¹⁵	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				160	116
12	Mandatory Recycle		10		165					116
	Service				150					122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0417	950	
Total:		1590	1610
1.0084	1.0084	1020	
1.0184	1.0184	1785	
1.0317	1.0317	2295	
Total:		2975	3160

Caustic Pump # 1

Setting: 400

Caustic Temp. 121


Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: _____

Dump ph: _____

Notes: _____



Regeneration Log (Concurrent Series)

Date: 7-23-06

Time: 1255
$$\text{Run length: } 214,000 - \frac{7,000}{1} = \underline{207,000} \text{ gallons}$$

Service Water pressure: 92 psi Temp. 84 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target														
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #				
1	SA	BW	15	60	50	57	66	68	68	110				
2	SA	Settle	3	60					✓				3%= 1.0215	
3	SC	BW	10	59	75	87	97	101	101	97			5%=1.0417	
4	PA	BW	15	59	50	57	62	64	64	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	158	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417	1.042	290	290
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.042	950	950
6c	SA to PA	SR	32	60	20				20	156			Total:	1590
6d	PC	Settle	3	60	0				-					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.009	1020	1140
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	1900
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.032	2295	2480
6h	SC to PC	SR	8	59	85				85	191			Total:	2975
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				120	116				
12	Mandatory Recycle		10		165				120	116				
	Service				150					122				

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.5
Corrections: NONE
Dump pH: 6.5

Notes: Prolonged Step 11 by 30 mins.

Regeneration Log (Concurrent Series)

Date: 07/31/06

Time: 0900

Run length: 214,000 - 86 = 214000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

RSV Rate Control Valve

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	28	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			125	116
12	Mandatory Recycle		10			165			125	116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	300
1.0417	1.042	950	980
	Total:	1590	1610
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
	Total:	2975	3170

Caustic Pump # 5A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	<u>300</u>
1.0417	<u>1.042</u>	950	<u>980</u>
	Total:	1590	<u>1610</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.032</u>	2295	
	Total:	2975	<u>3170</u>

Caustic Pump # 5A
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 8.0
Corrections: caustic & MIDS
Dump ph: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 8-2-06
 Time: 0240
 Run length: 214,000 - 214 = _____ gallons
 Service Water pressure: 48 psi Temp. 82 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	67	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	101	97
4	PA	BW	15	59	50	57	62	64	64	53
5	PC	BW	15	59	120	140	153	159	158	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	28	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			166	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			168	116
12	Mandatory Recycle		10			165			166	116
	Service					150				122

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0411	950	
	Total:	1590	1660

+2

Caustic Pump # A
 Setting: 460
 Caustic Temp. 124
 Target = 49° C or 120° F


3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.041</u>	950	
	Total:	1590	<u>1660</u>
1.0084	<u>1.008</u>	1020	<u>940</u>
1.0184	<u>1.018</u>	1785	<u>1900</u>
1.0317	<u>1.031</u>	2295	<u>1990</u>
	Total:	2975	<u>3110</u>

Caustic Pump # A
 Setting: 460
 Caustic Temp. 124
 Target = 49° C or 120° F

Neutralization Basin pH: 6.5
 Corrections: 2
 Dump ph: _____

Notes: I/s @ 0741



Regeneration Log (Concurrent Series)

Date: 08/03/06

Time: 11:00

Run length: 214,000 - 14000 = 200000 gallons

Service Water pressure: 92 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target					
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	22	60	165				<u>165</u>	49
8	PC to PA	Recycle	<u>30/CT-1</u> < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	<u>14/CT-3</u> < 100	60	165				<u>165</u>	103
11	Rinse Recycle		<u>13/CT-5</u> < 2.00	60	165				<u>125</u>	116
12	Mandatory Recycle		10		165				<u>125</u>	116
	Service				150					122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	<u>320</u>
1.0417	<u>1.042</u>	950	<u>970</u>
Total:		1590	<u>1640</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5.5
Corrections: equatic 4mins.
Dump ph: 7.0

Notes:

I/S @ 1615

Regeneration Log (Concurrent Series)

Date: 08/06/06
Time: 1230

Run length: 214,000 - 12 = 202,000 gallons
Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°							
1	SA	BW	15	60	50	57	66	68	66	110					
2	SA	Settle	3	60								3%= 1.0215			
3	SC	BW	10	59	75	87	97	101	97	97		5%=1.0417			
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water		
5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual	
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	3300	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.0417	950	1060	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1730	
6d	PC	Settle	3	60	0										
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.0088	1020	1140	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	1920	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.0317	2295	2440	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3130	
6i	PC	FR	16	59	165				165	29					
7	PA	FR	28	60	165				165	49					
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82					
9	SC	FR	17	60	165				165	91					
10	SA	FR	14/CT-3 < 100	60	165				165	103					
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116					
12	Mandatory Recycle		10		165				125	116					
	Service				150					122					

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Caustic Pump # A
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 6.5
Corrections: _____
Dump ph: _____

Notes: _____

Regeneration Log (Concurrent Series)

Date: 08/09/06

Time: 1306

Run length: 214,000 - 11000 = 203000 gallons

Service Water pressure: 90 psi Temp. 88 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM Target											
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #	
1	SA	BW	15	60	50	57	66	68	68	110	
2	SA	Settle	3	60							3%= 1.0215
3	SC	BW	10	59	75	87	97	101	101	97	5%=1.0417
4	PA	BW	15	59	50	57	62	64	64	53	Hydrometer
5	PC	BW	15	59	120	140	153	158	158	36	Dilution Water
6a	SA	5% NaOH	29	60	10				10	155	Target
6b	SA to PA	5% NaOH	66	60	10				10	155	Actual
6c	SA to PA	SR	32	60	20				20	156	Target
6d	PC	Settle	3	60	0						Actual
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	Target
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	Actual
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	Target
6h	SC to PC	SR	8	59	85				85	191	Actual
6i	PC	FR	16	59	165				165	29	Total:
7	PA	FR	23	60	165				165	49	
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82	
9	SC	FR	17	60	165				165	91	
10	SA	FR	14/CT-3 < 100	60	165				165	103	
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116	
12	Mandatory Recycle		10		165				125	116	
	Service				150					122	

Caustic Pump # SA

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.0

Corrections:

Dump ph: 65

Notes:

Caustic Pump # 5A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

313

Service Water pressure: 90 psi Temp. 87 degrees F

GPM Target	
------------	--

Caustic Pump # 3
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Notes: _____

Regeneration Log (Concurrent Series)

Date: 08/18/06

Time: 0830

Run length: $214,000 - 49,000 = 165,000$ gallons

Service Water pressure: 92 psi Temp. 87 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target												
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #		
1	SA	BW	15	60	50	57	66	68	68	110		
2	SA	Settle	3	60							3%= 1.0215	
3	SC	BW	10	59	75	87	97	101	101	97	5%=1.0417	
4	PA	BW	15	59	50	57	62	64	64	53	Hydrometer	
5	PC	BW	15	59	120	140	153	158	158	36	Dilution Water	
6a	SA	5% NaOH	29	60	10				10	155	Target	Actual
6b	SA to PA	5% NaOH	66	60	10				10	155	Target	Actual
6c	SA to PA	SR	32	60	20				20	156	Target	Actual
6d	PC	Settle	3	60	0						Target	Actual
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.032
6h	SC to PC	SR	8	59	85				85	191	Total:	1590
6i	PC	FR	16	59	165				165	29	Total:	1640
7	PA	FR	22	60	165				165	49		
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82		
9	SC	FR	17	60	165				165	91		
10	SA	FR	14/CT-3 < 100	60	165				165	103		
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116		
12	Mandatory Recycle		10		165				125	116		
	Service				150					122		

Caustic Pump #	A
Setting:	400
Caustic Temp.	120
Target =	49° C or 120° F

Neutralization Basin pH: 6.8

Corrections:

Dump ph: 6.0

Notes:

Regeneration Log (Concurrent Series)

Date: 08/13/06

Time: 0800

Run length: 214,000 - 12000 = 202000 gallons

Service Water pressure: 94 psi Temp. 87 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>68</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>101</u>	97
4	PA	BW	15	59	50	57	62	64	<u>64</u>	53
5	PC	BW	15	59	120	140	153	158	<u>158</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	<u>28</u>	60	165				<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>125</u>	116
12	Mandatory Recycle		10		165				<u>125</u>	116
	Service				150					122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	<u>320</u>
1.0417	<u>1.042</u>	950	<u>990</u>
	Total:	1590	<u>1630</u>
1.0084	<u>1.008</u>	1020	<u>1140</u>
1.0184	<u>1.018</u>	1785	<u>1930</u>
1.0317	<u>1.032</u>	2295	<u>2450</u>
	Total:	2975	<u>3150</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: _____

Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 08/25/06

Time: 2:25

Run length: 214,000 - 15000 = 199000 gallons

Service Water pressure: 100 psi Temp. 82 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	69	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	101	97
4	PA	BW	15	59	50	57	62	64	64	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116
12	Mandatory Recycle		10		165				165	116
	Service				150					122

3%=1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
		290	
		950	
		Total: 1590	1600
		1020	
		1785	
		2295	
		Total: 2975	3150

Caustic Pump # B

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections:

Dump pH: 6.5

Notes:



Regeneration Log (Concurrent Series)

Date: 9-16-06
 Time: 0300
 Run length: 214,000 - 110K = 200K gallons
 Service Water pressure: 92 psi Temp. 82 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0				—	
6e	SC to PC	1.5% Acid	12	59	85				88	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				↓	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				↓	82
9	SC	FR	17	60	165				↓	91
10	SA	FR	14/CT-3 < 100	60	165				122	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				↓	116
12	Mandatory Recycle		10		165				↓	116
	Service				150				148	122

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.040	950	
	Total:	1590	1146
1.0084	1.008	1020	
1.0184	1.019	1785	
1.0317	1.031	2295	
	Total:	2975	3100

Caustic Pump # B
 Setting: 400
 Caustic Temp. 118° F
 Target = 49° C or 120° F

Neutralization Basin pH: 04
 Corrections: none
 Dump ph: 7.4

Notes: _____

Regeneration Log (Concurrent Series)

Date: 9/19/06

Time: 12:36

Run length: 214,000 - 17,000 = 200,000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	61	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			162	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 400	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			123	116
12	Mandatory Recycle		10			165			123	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.0440	290	
1.0417	1.041	950	
Total:		1590	
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
Total:		2975	

Caustic Pump # A

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 5.5
Corrections: 3 min Caustic
Dump pH: 6.5

Notes: _____

1406
1500
1532

1559
1630
1647
1704
1721

Regeneration Log (Concurrent Series)

Date: 09-24-06

Time: 12:36

Run length: $214,000 - 12,000 = 202$ gallons

Service Water pressure: 97 psi Temp. 88°F degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60					✓	
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			✓	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20 ✓	60		165			165	82
9	SC	FR	58.17 ✓	60		165			165	91
10	SA	FR	14/CT-3 < 5 ✓	60		165			165	VWO 103
11	Rinse Recycle		13/CT-5 < 2.00 ✓	60		165			120	116
12	Mandatory Recycle		10			165			120	116
	Service					150				122

 $3\% = 1.0215$
$$5\% = 1.0417$$

Hydrometer	Dilution Water
------------	----------------

Target	Actual	Target	Actual
--------	--------	--------	--------

Target	Actual	Target	Actual
PAVE	143	200	

0417	1.042	290	
------	-------	-----	--

.0417	1.04%	950	
-------	-------	-----	--

Total:	1590
--------	------

1000

0084	1000	1020	
	1000		

0184	11012	1785	
------	-------	------	--

0317	1032	2295	
------	------	------	--

Total	2975
-------	------

	Total.	2975	
--	--------	------	--

[illegible]

+ 8 mins. Prolong to 15:50

At 4 miles along to 16:30 H

50

Caustic Pump # 5 ft

Setting: ^{250/}400

Selling,

DE

Caustic Temp. 120'

Target = 49° C or 120° F

Neutralization Basin pH: 5.0

Corrections: Add caustic c:

Dump ph: 0v5

Notes: _____

1. The first step is to identify the problem or question that needs to be answered. This involves understanding the context and the specific requirements of the task.

1350+66

 $+1450+6$
$$= 1456.$$

Regeneration Log (Concurrent Series)

Date: 09/27/06
Time: 1434
Run length: 214,000 - 8000 = 206000 Gallons
Service Water pressure: 96 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15 ✓	60	50	57	66	68	66	110
2	SA	Settle	3 326	60					✓	
3	SC	BW	10 ✓	59	75	87	97	101	97 ✓	97
4	PA	BW	15 ✓	59	50	57	62	64	62 ✓	53
5	PC	BW	15 ✓	59	120	140	153	158	150	36
6a	SA	5% NaOH	29 ✓	60		10			10	155
6b	SA to PA	5% NaOH	66 ✓	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12 ✓	59		85			85	191/206
6f	SC to PC	3.0% Acid	9 ✓	59		85			85	191/207
6g	SC to PC	5.0% Acid	6 ✓	59		85			85	191/208
6h	SC to PC	SR	8 ✓	59		85			85	191
6i	PC	FR	16 ✓	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			165	116
12	Mandatory Recycle		10			165			165	116
	Service					150			120	122

3%= 1.0215

5%= 1.0417

Hydrometer Dilution Water

Target	Actual	Target	Actual
1.0417	1.042	290	
1.0417	1.042	950	
Total:		1590	
1.0084	1.008	1020	
1.0184	1.02	1785	
1.0317	1.032	2295	
Total:		2975	

Caustic Pump # 5B

Setting: 250
400

Caustic Temp. 120 °F

Target = 49° C or 120° F

Neutralization Basin pH: 3.5
Corrections: 10 min caustic
Dump pH: 6.4

Notes: _____

Caustic Pump # 5B
Setting: 250
Caustic Temp. 120 °F
Target = 49° C or 120° F

1840
5th

$$\begin{array}{r} 46 \\ 46 \\ \hline 112 \end{array} \quad \begin{array}{r} 52 \\ 32 \\ \hline 84 \\ 60 \\ 24 \end{array}$$

$$\begin{array}{r} 60 \\ 52 \\ \hline 112 \end{array}$$

$$16:52 - 17:24$$

Regeneration Log (Concurrent Series)

Date: Oct 1, 06
 Time: 0230
 Run length: 214,000 - 8000 = 206,000 gallons
 Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	✓15	60	50	57	66	68	66	110				
2	SA	Settle	3	60					—	—				
3	SC	BW	✓10	59	75	87	97	101	98	97				
4	PA	BW	✓15	59	50	57	62	64	62	53				
5	PC	BW	✓15	59	120	140	153	158	153	36				
6a	SA	5% NaOH	✓29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	✓66	60	10				10	155	1.0417	1.0%	950	
6c	SA to PA	SR	✓32	60	20				20	156				
6d	PC	Settle	3	60	0				—	—				
6e	SC to PC	1.5% Acid	✓12	59	85				87	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	✓9	59	85				85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	✓6	59	85				85	191/208	1.0317	1.032	2295	
6h	SC to PC	SR	✓8	59	85				85	191				
6i	PC	FR	✓16	59	165				165	29				
7	PA	FR	27 22 ✓	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20 ✓	60	165				165	82				
9	SC	FR	17 ✓	60	165				165	91				
10	SA	FR	14/CT-3 < 100 ✓	60	165				160	103				
11	Rinse Recycle		13/CT-5 < 2.00 ✓	60	165				120	116				
12	Mandatory Recycle		10		165				120	116				
	Service				150					122				

Caustic Pump # B
 Setting: 400
 Caustic Temp. 120°F
 Target = 49° C or 120° F

Neutralization Basin pH: OK
 Corrections: N/A
 Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10-3-06

Time: 2200

Run length: 214,000 - 0 = 214,000 gallons

Service Water pressure: 178 psi Temp. 78 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			
1	SA	BW	15	60	50	57	66	68	60	110	
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101	88	97	
4	PA	BW	15	59	50	57	62	64	60	53	
5	PC	BW	15	59	120	140	153	158	150	36	
6a	SA	5% NaOH	29	60	10				10	155	
6b	SA to PA	5% NaOH	66	60	10				10	155	
6c	SA to PA	SR	32	60	20				20	156	
6d	PC	Settle	3	60	0				-		
6e	SC to PC	1.5% Acid	12	59	85				88	191/206	
6f	SC to PC	3.0% Acid	9	59	85				88	191/207	
6g	SC to PC	5.0% Acid	6	59	85				88	191/208	
6h	SC to PC	SR	8	59	85				88	191	
6i	PC	FR	16	59	165				166	29	
7	PA	FR	22	60	165				166	49	
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82	
9	SC	FR	17	60	165				165	91	
10	SA	FR	14/CT-3 < 100	60	165				145	103	
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116	
12	Mandatory Recycle		10		165				165	116	
	Service				150				150	122	

3%= 1.0215	
5%= 1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0417	950	
	Total:	1590	
1.0084	1.0085	1020	
1.0184	1.0184	1785	
1.0317	1.032	2295	
	Total:	2975	3100

Caustic Pump # B

Setting: 400

Caustic Temp. 122

Target = 49° C or 120° F

Neutralization Basin pH: 7.4

Corrections: N/A

Dump pH: 6.5

Notes:

Regeneration Log (Concurrent Series)

Date: 10/3/06

Time: 1905

Run length: 214,000 - 23,000 = _____ gallons

Service Water pressure: 93 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			158	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			122	116
12	Mandatory Recycle		10			165			122	116
	Service					150				122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	
1.0417	—	950	
	Total:	1590	
1.0084	—	1020	
1.0184	—	1785	
1.0317	—	2295	
	Total:	2975	

Caustic Pump # B

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 6.3

Corrections: none

Dump ph: 6.3

Notes: Hydrometer is Broken

Regeneration Log (Concurrent Series)

Date: 10/9/66

Time: 0200

Run length: $214,000 - 6,000 = 208,000$ gallons

Service Water pressure: 84 psi Temp. 73 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM Target												
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #		
1	SA	BW	15	60	50	57	66	68	64	110		
2	SA	Settle	3	60							3%= 1.0215	
3	SC	BW	10	59	75	87	97	101	87	97	5%=1.0417	
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer	
5	PC	BW	15	59	120	140	153	158	150	36	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417	290
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	950
6c	SA to PA	SR	32	60	20				20	156	Total:	1590
6d	PC	Settle	3	60	0				-			1680
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1020
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1785
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	2295
6h	SC to PC	SR	8	59	85				85	191	Total:	2975
6i	PC	FR	16	59	165				165	29	Caustic Pump # _____	
7	PA	FR	22	60	165				165	49	Setting: _____	
8	PC to PA	Recycle	30/CT-1 < 20	60	165					82	Caustic Temp. _____	
9	SC	FR	17	60	165					91	Target = 49° C or 120° F	
10	SA	FR	14/CT-3 < 100	60	165					103		
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116		
12	Mandatory Recycle		10		165					116		
	Service				150					122		

Neutralization Basin pH: 7.0

Corrections: _____ N/A

Dump ph: 7.0

Notes: _____

Caustic Pump # _____

Setting:_____

Caustic Temp. _____

Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 10-18-06

Time: 1330

Run length: 214,000 - 2 = 212000 gallons

Service Water pressure: 84 psi Temp. 72 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>105</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>90</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>150</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>1.042</u>	950	
6c	SA to PA	SR	32	60	20				<u>20</u>	156		Total:	1590	<u>1200</u>
6d	PC	Settle	3	60	0				<u>-</u>					<u>16400</u>
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084		1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184		1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317		2295	
6h	SC to PC	SR	8	59	85				<u>86</u>	191		Total:	2975	<u>3170</u>
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	22	60	165				<u>160</u>	49				
8	PC to PA	Recycle	<u>30/CT-1</u> < 20	60	165				<u>160</u>	82				
9	SC	FR	17	60	165				<u>162</u>	91				
10	SA	FR	<u>14/CT-3</u> < 100	60	165				<u>162</u>	103				
11	Rinse Recycle		<u>13/CT-5</u> < 2.00	60	165				<u>162</u>	116				
12	Mandatory Recycle		10		165				<u>162</u>	116				
	Service				150					122				

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.042</u>	950	
	Total:	1590	<u>1200</u>
			<u>16400</u>
		1020	
		1785	
		2295	
	Total:	2975	<u>3170</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 100°F

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: N/A

Dump pH: 7

Notes:

Regeneration Log (Concurrent Series)

✓ - in progress stage
X - completed stage

Date: 10-11-06

Time: 18:48

Run length: 214,000 - 12,000 = 202,000 gallons

Service Water pressure: 86 psi Temp. 80° degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Activity
Duration

1848: 1 minute Delay PSD

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15 ✓	60	50	57	66	68	66 ✓	110
2	SA	Settle	26 mins 3 ✓	60					26 mins ✓	
3	SC	BW	10 ✓	59	75	87	97	101	97 ✓	97
4	PA	BW	15 ✓	59	50	57	62	64	62 ✓	53
5	PC	BW	15 ✓	59	120	140	153	158	153 ✓	36
6a	SA	5% NaOH	29 ✓	60		10			10 ✓	155
6b	SA to PA	5% NaOH	66 ✓	60		10			10 ✓	155
6c	SA to PA	SR	32 ✓	60		20			20 ✓	156
6d	PC	+ Settle	3 ✓	60	59	0			— ✓	
6e	SC to PC	1.5% Acid	12 ✓	59		85			85 ✓	191/206
6f	SC to PC	3.0% Acid	9 ✓	59		85			85 ✓	191/207
6g	SC to PC	5.0% Acid	6 ✓	59		85			85 ✓	191/208
6h	SC to PC	SR	8 ✓	59		85			85 ✓	191
6i	PC	FR	16 ✓	59		165			165 ✓	29
7	PA	FR	28 mins 22 ✓	60		165			165 ✓	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160 ✓	82
9	SC	FR	17	60		165			165 ✓	91
10	SA	FR	14/CT-3 < 4005	60		165			165 ✓	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			123 ✓	116
12	Mandatory Recycle		10			165			122 ✓	116
	Service					150				122

ACID
3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	
1.0417	1.042	950	
Total:		1590	
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
Total:		2975	

Actual time 28 mins. Not 22 - without any prolong.

Prolong 6 mins Caustic Pump # 5A

Setting: 250/400

Caustic Temp. 120°F

Target = 49° C or 120° F

Neutralization Basin pH: 5

Corrections: Add Caustic 5 MINS.

Dump pH: 6.0

Notes:

NB Found VLV #91 closed.

* N.B This (duration) time was actually 28 mins. not 22.5

Defect -
Super.
informal

Acid (dilute) sample line. No Flow thru VLV # CWT D BU 200
(1/2" Stainless line). Dilute Acid flow thru 2 3/4" to 3" line good.
Not having (Mistake) to VLV ADV-55 (caustic) to PA out.
for PA - caustic Application not poor/dull
PC inlet valve ADV-22 fair open.

Regeneration Log (Concurrent Series)

Date: 10/14/06Time: 2620Run length: 214,000 - 0700 = 207000 gallonsService Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155				
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155				
6c	SA to PA	SR	32	60	20				<u>20</u>	156				
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>1.008</u>	1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>1.018</u>	1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317	<u>1.032</u>	2295	
6h	SC to PC	SR	8	59	85				<u>85</u>	191				
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	22	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82				
9	SC	FR	17	60	165				<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>125</u>	116				
12	Mandatory Recycle		10		165				<u>125</u>	116				
	Service				150					122				

3% = 1.0215
 5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.042</u>	950	
Total:		1590	<u>1650</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.032</u>	2295	
Total:		2975	<u>3110</u>

Caustic Pump # ASetting: 400Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections: _____

Dump pH: 6.6

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10-20-06

Time: 1412

Run length: 214,000 - 11,000 = 203,000 gallons

Service Water pressure: 97 psi Temp. 78° degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

1412-1413 delay

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60					-	
3	SC	BW	10	59	75	87	97	101	95	97
4	PA	BW	15	59	50	57	62	64	61	53
5	PC	BW	15	59	120	140	153	158	151	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	59	0				0	
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				162	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100°	60	165					103
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116
12	Mandatory Recycle		10		165					116
	Service				150					122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	
1.0417	1.042	950	
	Total:	1590	
1.0084	1.0085	1020	
1.0184	1.02	1785	
1.0317	1.03	2295	
	Total:	2975	

Actual Time = 28 min
+ Prolong 1 minute.

Caustic Pump # B
Setting: 250/400
Caustic Temp. 120°F
Target = 49° C or 120° F

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	
1.0417	1.042	950	
Total:		1590	
Total:		2975	

Actual Time = 28 min Not 220

Prolong 1 minute

Caustic Pump # B

Setting: 250/400

Caustic Temp. 120°F

Target = 49° C or 120° F

Neutralization Basin pH: 5.0

Corrections:

Dump ph: 7.0

Notes: Add caustic for 6 min.

Regeneration Log (Concurrent Series)

Date: 10/27/06

Time: _____

Run length: 214,000 - 71000 = 143000 gallons

Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Hydrometer broken.

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			124	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
4.0417		290	
1.0417		950	
Total:		1590	1630
Total:		2975	3190

FF/R stuck. MANUAL operation

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

*Step 7
Timer ended
unit would not get
out of FAST Rinse
mode.
DID FAST Rinse*

Neutralization Basin pH: 5.5

Corrections: 3 minutes

Dump pH: 7.0

Notes: _____

*Recycle
in Recycle mode
Reset switch Back to
Auto, FAST Rinse Reset*

Regeneration Log (Concurrent Series)

Date: 10/30/06

Time: 11:00

Run length: 214,000 - 11000 = 203,000 gallons

Service Water pressure: 76 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>149</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417	<u>Broken</u>	290	
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>meter</u>	950	
6c	SA to PA	SR	32	60	20				<u>20</u>	156				
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>meter</u>	1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>broke</u>	1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317		2295	
6h	SC to PC	SR	8	59	85				<u>85</u>	191				
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	22	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>154</u>	82				
9	SC	FR	17	60	165				<u>155</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>150</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>152</u>	116				
12	Mandatory Recycle		10		165					116				
	Service				150					122				

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>Broken</u>	290	
1.0417	<u>meter</u>	950	
		Total:	<u>1590</u>
1.0084	<u>meter</u>	1020	
1.0184	<u>broke</u>	1785	
1.0317		2295	
		Total:	<u>2975</u>
			<u>3190</u>

Caustic Pump # 13

Setting: 450

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 7.5

Corrections: _____

Dump ph: 7.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 11/01/06
Time: 1230

Run length: 214,000 - 21000 = 193000 gallons
Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	66	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	97	97				
4	PA	BW	15	59	50	57	62	64	62	53				
5	PC	BW	15	59	120	140	153	158	153	36				
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417		950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1620
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084		1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184		1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317		2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3190
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				150	116				
12	Mandatory Recycle		10		165				125	116				
	Service				150					122				

Caustic Pump # B
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 6.5
Corrections: _____
Dump ph: 6.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 11/5/06
 Time: 1850
 Run length: 214,000 - 23 = _____ gallons
 Service Water pressure: 92 psi Temp. 78 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

ON 60 S COUNTED UP
 NOT IN EL

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			122	116
12	Mandatory Recycle		10			165			122	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	
1.0417	4	950	
Total:		1590	1760
Total:		2975	3150

Caustic Pump # A

Setting: 460

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections:

Dump ph: 6.5

Notes:

Regeneration Log (Concurrent Series)

Date: 11-7-06

Time: 20:00

Run length: 214,000 - 25000 = _____ gallons

Service Water pressure: 92 psi Temp. 76 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

1947 2002
2002 2005
2005 2015
2016 2031
2030

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	50	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			122	116
12	Mandatory Recycle		10			165			122	116
	Service					150				122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	
1.0417	1.04	950	
	Total:	1590	1670
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.030	2295	
	Total:	2975	3090

Caustic Pump # A

Setting: 400

Caustic Temp. 122

Target = 49° C or 120° F

Neutralization Basin pH: 6.7

Corrections: NONE

Dump ph: 6.7

Notes: _____

TOTAL CL

BEFORE 1.89

AFTER 0.00

Regeneration Log (Concurrent Series)

Date: 11/9/06
 Time: 1900
 Run length: 214,000 - 214,000 = 27,000 gallons
 Service Water pressure: 80 psi Temp. 76 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	60	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	87	97				
4	PA	BW	15	59	50	57	62	64	62	53				
5	PC	BW	15	59	120	140	153	158	153	36				
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	310
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.04	950	1050
6c	SA to PA	SR	32	60	20				20	156	Total:		1590	1650
6d	PC	Settle	3	60	0				0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	1030
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	1900
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.032	2295	2320
6h	SC to PC	SR	8	59	85				85	191	Total:		2975	3110
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				160	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116				
12	Mandatory Recycle		10		165				125	116				
	Service				150				150	122				

Caustic Pump # A
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 7.9
 Corrections: NONE
 Dump pH: 7.7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 11-21-06

Time: 0830

Run length: 214,000 - 21K = _____ gallons

Service Water pressure: 90 psi Temp. 75 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	65	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	96	97				
4	PA	BW	15	59	50	57	62	64	62	53				
5	PC	BW	15	59	120	140	153	158	153	36				
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.042	950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1650
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.030	2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3120
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22 ²⁸	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				160	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 400 ⁵	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116				
12	Mandatory Recycle		10		165					116				
	Service				150					122				

Caustic Pump # A

Setting: .400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.8

Corrections: _____

Dump pH: 6.8

Notes: _____
