

Regeneration Log (Concurrent Series)

Date: 12/23/2007

Time: 1900

Run length: 214,000 - 24000 = 190,000 gallons

Service Water pressure: 92 psi Temp. 74 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #		
					60°	70°	80°	83°			3% = 1.0215	5% = 1.0417
1	SA	BW	15	60	50	57	66	68	62	110		
2	SA	Settle	3	60					92	97		
3	SC	BW	10	59	75	87	97	101	60	53	Hydrometer	
4	PA	BW	15	59	50	57	62	64	145	36	Target	Actual
5	PC	BW	15	59	120	140	153	158	10	155	1.0417	
6a	SA	5% NaOH	29	60		10			10	155	1.0417	
6b	SA to PA	5% NaOH	66	60		10			20	156		
6c	SA to PA	SR	32	60		20					Total:	1590
6d	PC	Settle	3	60		0			85	191/206	1.0084	1.008
6e	SC to PC	1.5% Acid	12	59		85			85	191/207	1.0184	1.018
6f	SC to PC	3.0% Acid	9	59		85			85	191/208	1.0317	1.030
6g	SC to PC	5.0% Acid	6	59		85			85	191		
6h	SC to PC	SR	8	59		85			160	29		
6i	PC	FR	16	59		165			160	49		
7	PA	FR	22	60		165			160	82		
8	PC to PA	Recycle	30/CT-1 < 20	60		165			150	91		
9	SC	FR	17	60		165			150	103		
10	SA	FR	14/CT-3 < 100	60		165			134	116		
11	Rinse Recycle		13/CT-5 < 2.00	60		165			134	116		
12	Mandatory Recycle		10			165			134	122		
	Service					150						

Caustic Pump # A

Setting: 400

Caustic Temp. 120°F

Target = 49° C or 120° F

Neutralization Basin pH: 8.2

Corrections: None

Dump pH: 8.2

Notes:

Regeneration Log (Concurrent Series)

Date: 12/18/07

Time: 1205

Run length: 214,000 - 22000 = 192000 gallons

Service Water pressure: 92 psi Temp. 77 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	60	110
2	SA	Settle	3	60					40	97
3	SC	BW	10	59	75	87	97	101	60	53
4	PA	BW	15	59	50	57	62	64	145	36
5	PC	BW	15	59	120	140	153	158	10	155
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			20	156
6c	SA to PA	SR	32	60			0			
6d	PC	Settle	3	60					85	191/206
6e	SC to PC	1.5% Acid	12	59		85			85	191/207
6f	SC to PC	3.0% Acid	9	59		85			85	191/208
6g	SC to PC	5.0% Acid	6	59		85			85	191
6h	SC to PC	SR	8	59		85			165	29
6i	PC	FR	16	59		165			165	49
7	PA	FR	22	60		165			165	82
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	91
9	SC	FR	17	60		165			160	103
10	SA	FR	14/CT-3 < 100	60		165			150	116
11	Rinse Recycle			13/CT-5 < 2.00	60		165		150	116
12	Mandatory Recycle			10			150			122
	Service									

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
		Total: 1590	1580
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
		Total: 2975	3080

Caustic Pump # 5B
Setting: 400
Caustic Temp. 120°F
Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: Acid 3 mins
Dump ph: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 12-13-07
 Time: 0915
 Run length: 214,000 - 21K = 193K gallons
 Service Water pressure: 80 psi Temp. 82 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	60	68	106	110
2	SA	Settle	3	60					97	97
3	SC	BW	10	59	75	87	97	101	62	53
4	PA	BW	15	59	50	57	62	64	153	36
5	PC	BW	15	59	120	140	153	158	10	155
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			20	156
6c	SA to PA	SR	32	60		20				
6d	PC	Settle	3	60		0			85	191/206
6e	SC to PC	1.5% Acid	12	59		85			85	191/207
6f	SC to PC	3.0% Acid	9	59		85			85	191/208
6g	SC to PC	5.0% Acid	6	59		85			85	191
6h	SC to PC	SR	8	59		85			165	29
6i	PC	FR	16	59		165			165	49
7	PA	FR	22	60		165			165	82
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	91
9	SC	FR	17	60		165			165	103
10	SA	FR	14/CT-3 < 100	60		165			165	116
11	Rinse Recycle			13/CT-5 < 2.00	60		165		165	116
12	Mandatory Recycle			10			165		150	122
	Service									

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.040	290	
1.0417	1.041	950	
	Total:	1590	
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.03	2295	
	Total:	2975	

Caustic Pump # B
 Setting: 400
 Caustic Temp. 122
 Target = 49° C or 120° F

Neutralization Basin pH: 8
 Corrections: NONE
 Dump pH: 8

Notes:

Regeneration Log (Concurrent Series)

Date: 12-9-07

Time: 1904

Run length: 214,000 - 32,000 = 182,000 gallons

Service Water pressure: 84 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #		
					60°	70°	80°	83°				
1	SA	BW	15	60	50	57	66	68	66	110		
2	SA	Settle	3	60					94	97		
3	SC	BW	10	59	75	87	97	101	41	53		
4	PA	BW	15	59	50	57	62	64	144	36		
5	PC	BW	15	59	120	140	153	158	10	155		
6a	SA	3% NaOH	29	60		10			10	155		
6b	SA to PA	3% NaOH	66	60		10			10	155		
6c	SA to PA	SR	32	60		20			20	156		
6d	PC	Settle	3	60		0						
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1020
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1785
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	2295
6h	SC to PC	SR	8	59		85			85	191		
6i	PC	FR	16	59		165			145	29		
7	PA	FR	28	60		165			165	49		
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82		
9	SC	FR	17	60		165			165	91		
10	SA	FR	14/CT-3 < 100	60		165			165	103		
11	Rinse Recycle		13/CT-5 < 2.00	60		165			140	116		
12	Mandatory Recycle		10			165			135	116		
	Service					150			140	122		

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
	Total:	1590	1590
		1020	
		1785	
		2295	
	Total:	2975	3070

Caustic Pump # B
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: Acid - 3 mins
Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 12-5-07

Time: 1328

Run length: 214,000 - 19,000 = 195,000 gallons

Service Water pressure: 87 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	64	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	3% NaOH	29	60		10			10	155
6b	SA to PA	3% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			0	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	28	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			140	116
12	Mandatory Recycle		10			165			135	116
	Service					150			142	122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0400	950	
	Total:	1590	1590
1.0084	1.0080	1020	
1.0184	1.0190	1785	
1.0317	1.0310	2295	
	Total:	2975	3080

Caustic Pump # B
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 6.6

Corrections:

Dump pH: 6.6

Notes:

Updated 7/25/06

Regeneration Log (Concurrent Series)

Date: 12-01-07
 Time: 22:10 ~ 21:10
 Run length: 214,000 - 8 = 206,000 gallons
 Service Water pressure: 96 psi Temp. 76 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

GPM Target										Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			
1	SA	BW	15	60	50	57	66	68		60	110
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101		92	97
4	PA	BW	15	59	50	57	62	64		60	53
5	PC	BW	15	59	120	140	153	158		146	36
6a	SA	5% NaOH	29	60		10				10	155
6b	SA to PA	5% NaOH	66	60		10				10	155
6c	SA to PA	SR	32	60		20				20	156
6d	PC	Settle	3	60		0					
6e	SC to PC	1.5% Acid	12	59		85				85	191/206
6f	SC to PC	3.0% Acid	9	59		85				85	191/207
6g	SC to PC	5.0% Acid	6	59		85				85	191/208
6h	SC to PC	SR	8	59		85				85	191
6i	PC	FR	16	59		165				165	29
7	PA	FR	22	60		165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165				164	82
9	SC	FR	17	60		165				165	91
10	SA	FR	14/CT-3 < 100	60		165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165				140	116
12	Mandatory Recycle		10			165				135	116
	Service					150					122

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	1590
		1020	
		1785	
		2295	
Total:		2975	3060

Caustic Pump # 5B
 Setting: 400 / 250
 Caustic Temp. 120° F
 Target = 49° C or 120° F

Neutralization Basin pH: 7
 Corrections: None
 Dump pH: 7

Notes: _____

VO

Regeneration Log (Concurrent Series)

Date: 9/8/08
 Time: 18:36
 Run length: 214,000 - 22,000 = 192,000 gallons
 Service Water pressure: 92 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60					98	97
3	SC	BW	10	59	75	87	97	101	60	53
4	PA	BW	15	59	50	57	62	64	153	36
5	PC	BW	15	59	120	140	153	158	10	155
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			20	156
6c	SA to PA	SR	32	60		20				
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle			13/CT-5 < 2.00	60		165		125	116
12	Mandatory Recycle			10			165		125	116
	Service						150			122

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.042	950	
	Total:	1590	1660
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
	Total:	2975	3100

Caustic Pump # A
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 7.5
 Corrections:
 Dump pH: 7.5

Notes:

Regeneration Log (Concurrent Series)

Time: 13:15

Time: 13:15
Run length: 214,000 - 10000 = _____ gallons
Service Water pressure: 99 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	60	53
5	PC	BW	15	59	120	140	163	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			145	91
10	SA	FR	14/CT-3 < 100	60		165			145	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			145	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
	Total:	1590	1640
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
	Total:	2975	3050

Caustic Pump # PA
 Setting: 400
 Caustic Temp. 120°F
 Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: adjusted and for 2 min.
Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 9-1-07
 Time: 1905
 Run length: 214,000 - 35,000 = 179,000 gallons
 Service Water pressure: 84 psi Temp. 84 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	68	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	101	97
4	PA	BW	15	59	50	57	62	64	64	53
5	PC	BW	15	59	120	140	153	158	158	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			165	116
12	Mandatory Recycle		10			165			140	116
	Service					150			136	122

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	310
1.0417	1.042	950	970
Total:		1590	1690
1.0084	1.010	1020	1160
1.0184	1.020	1785	1920
1.0317	1.031	2295	2390
Total:		2975	3140

< 100, mho

< 50, mho Caustic Pump # A

< 5, mho Setting: 400

Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 9.0
 Corrections: 1 min Acid
 Dump pH: 6.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 8/30/07

Time: 1907

Run length: 214,000 - 9000 = 205,000 gallons

Service Water pressure: 84 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
X 1	SA	BW	15	60	50	57	66	68	66	110
X 2	SA	Settle	3	60						
X 3	SC	BW	10	59	75	87	97	101	96	97
X 4	PA	BW	15	59	50	57	62	64	62	53
X 5	PC	BW	15	59	120	140	153	158	152	36
X 6a	SA	5% NaOH	29	60		10			10	155
X 6b	SA to PA	5% NaOH	66	60		10			10	155
X 6c	SA to PA	SR	32	60		20			20	156
X 6d	PC	Settle	3	60		0				
X 6e	SC to PC	1.5% Acid	12	59		85			85	191/206
X 6f	SC to PC	3.0% Acid	9	59		85			85	191/207
X 6g	SC to PC	5.0% Acid	6	59		85			85	191/208
X 6h	SC to PC	SR	8	59		85			85	191
X 6i	PC	FR	16	59		165			165	29
X 7	PA	FR	22	60		165			165	49
X 8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
X 9	SC	FR	17	60		165			165	91
X 10	SA	FR	14/CT-3 < 100	60		165			144	103
X 11	Rinse Recycle		13/CT-5 < 2.00	60		165			144	116
X 12	Mandatory Recycle		10			165			138	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	1640
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
Total:		2975	3120

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections:

Dump pH: 7.0

Notes:

2 min acid

Regeneration Log (Concurrent Series)

Date: 9-3-07

Time: 2030

Run length: 214,000 - 14000 = 200,000 gallons

Service Water pressure: 84 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

2102 - delay

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
2103-2118	1	SA	BW	15	60	50	57	66	66	110
2118-2144	2	SA	Settle	3	60					
2119-2129	3	SC	BW	10	59	75	87	97	97	97
2129-2144	4	PA	BW	15	59	50	57	62	62	53
2144-2159	5	PC	BW	15	59	120	140	153	153	36
2144-2214	6a	SA	5% NaOH	29	60		10		10	155
2214-2322	6b	SA to PA	5% NaOH	66	60		10		10	155
2320-2352	6c	SA to PA	SR	32	60		20		20	156
2159-2203	6d	PC	Settle	3	60		0			
2203-2215	6e	SC to PC	1.5% Acid	12	59		85		85	191/208
2215-2224	6f	SC to PC	3.0% Acid	9	59		85		85	191/208
2224-2230	6g	SC to PC	5.0% Acid	6	59		85		85	191/208
2230-2238	6h	SC to PC	SR	8	59		85		85	191
2238-2254	6i	PC	FR	16	59		165		165	29
2254-0013	7	PA	FR	22	60		165		165	49
0013-0054	8	PC to PA	Recycle	30/CT-1 < 20	60		165		165	82
0054-0111	9	SC	FR	17	60		165		165	91
0111-0134	10	SA	FR	14/CT-3 < 100	60		165		165	103
0134-0149	11	Rinse Recycle	13/CT-5 < 2.00	60			165		145	116
0149	12	Mandatory Recycle		10			165		145	116
		Service					150		138	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.042	290	290
1.0417	1.042	950	950
Total:		1590	1590
1.0084	1.0084	1020	1130
1.0184	1.018	1785	1910
1.0317	1.032	2295	2320
Total:		2975	3120

Caustic Pump # 5B

Setting: 250/400

Caustic Temp. 1200 F.

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: 2 min caustic

Dump pH: 6

Notes:

Regeneration Log (Concurrent Series)

Date: 8/16/07

Time: 6:30

Run length: 214,000 - 1000 = 213000 gallons

Service Water pressure: 102 psi Temp. 67.5 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			160	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			140	116
12	Mandatory Recycle		10			165				116
	Service					150				122


3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	1690
1.0084	1.010	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
Total:		2975	3180

Caustic Pump # B
Setting: 400
Caustic Temp. 120°F
Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: Add acid for 3 min.
Dump pH: 7.0

Notes: _____



Regeneration Log (Concurrent Series)

Date: 8-18-07

Time: 0122

Run length: 214,000 - 26,000 gallons
Service Water pressure: 81 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	< 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			159	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			160	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.0410	290	
1.0417	1.0410	950	
Total:		1590	1580
1.0084	1.00	1020	1230
1.0184	1.018	1785	1980
1.0317	1.031	2295	2490
Total:		2975	3080

Caustic Pump # P-5A

Setting: _____

Caustic Temp. _____

Target = 49° C or 120° F

Neutralization Basin pH: 5
Corrections: caustic
Dump pH: 8

Notes: _____

1612
22
1634

Regeneration Log (Concurrent Series)

Date: 8-26-07
 Time: 26:00
 Run length: 214,000 - 7k = 207,000 gallons
 Service Water pressure: 88 psi Temp: 82 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	95	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			16	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			0	-
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			160	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			160	116
12	Mandatory Recycle		10			165			160	116
	Service					150			140	122

3%=1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.047	290	
1.0417	1.048	950	
Total:		1590	1596
1.0084	1.008	1020	
1.0184	1.0184	1785	
1.0317	1.032	2295	
Total:		2975	3009

Caustic Pump # B
 Setting: 400
 Caustic Temp. 122°F
 Target = 49° C or 120° F

Neutralization Basin pH: 7
 Corrections: N/A
 Dump pH: 7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 8/24/07

Time: 1930

Run length: 214,000 - 1060 = 213000 gallons

Service Water pressure: 99 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20				156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			160	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			160	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
	Total:	1590	1590
1.0084	1.009	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
	Total:	2975	3050

Caustic Pump # B

Setting: 1200

Caustic Temp. 120° F


Target = 49° C or 120° F

Neutralization Basin pH: 6.0

Corrections:

Dump pH: 6.0

Notes:



Regeneration Log (Concurrent Series)

Date: 9/16/07

Time: _____

Run length: 214,000 - 16000 = 198000 gallons

Service Water pressure: 98 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	57	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	3% NaOH	29	60	10				10	155
6b	SA to PA	3% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	28	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116
12	Mandatory Recycle		10		165					116
	Service				150					122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
	Total:	1590	1640
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
	Total:	2975	3050

Caustic Pump # A


Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6-0
Corrections: Add acid for 1 min
Dump pH: 7-0

Notes: _____



Regeneration Log (Concurrent Series)

Date: 9/12/07

Time: 2050

Run length: 214,000 - 19000 = 195000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>98</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>155</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>150</u>	116
12	Mandatory Recycle		10			165			<u>130</u>	116
	Service					150			<u>150</u>	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	<u>1.04</u>	950	
Total:		1590	<u>1700</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.033</u>	2295	
Total:		2975	<u>3140</u>

Caustic Pump # 400 A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: 3 min Acid

Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 9-11-07

Time: 1545

Time: 1543 11 1984 gallons

Run length: 214,000 - 16A - 170A gallons
 42 psi Temp 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	60	53
5	PC	BW	15	59	120	140	155	158	150	36
6a	SA	3% NaOH	29	60	10				10	155
6b	SA to PA	3% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85					191/206
6f	SC to PC	3.0% Acid	9	59	85					191/207
6g	SC to PC	5.0% Acid	6	59	85					191/208
6h	SC to PC	SR	8	59	85					191
6i	PC	FR	16	59	165					29
7	PA	FR	28	60	165					49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				163	91
10	SA	FR	14/CT-3 < 100	60	165				160	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116
12	Mandatory Recycle		10		165					116
	Service				150					122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	315
1.0417	1.041	950	985
Total:		1590	1690

18:58

Caustic Pump # 5A

Setting: _____

Caustic Temp. _____

Target = 49° C or 120° F

Neutralization Basin pH: 9
Corrections: 1.5 MINS Acid.
Dump pH: 7.0

Notes: 20:40 Making H_2O . 09-11-07

Regeneration Log (Concurrent Series)

Date: 9/10/07

Time: 2:35

Time: 2:35
Run length: 214,000 - $\frac{21,000}{8.2} = 193,000$ gallons
Temp 30 degree

Run length: 214,000 - 2,000 - 1,100 gallons
Service Water pressure: 82 psi Temp. 70 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	53	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	3% NaOH	29	60	10				10	155
6b	SA to PA	3% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85					191/206
6f	SC to PC	3.0% Acid	9	59	85					191/207
6g	SC to PC	5.0% Acid	6	59	85					191/208
6h	SC to PC	SR	8	59	85					191
6i	PC	FR	16	59	165					29
7	PA	FR	28	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116
12	Mandatory Recycle		10		165				140	116
	Service				150					122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	310
1.0417	1.042	950	990
	Total:	1590	1590
		1020	
		1785	
		2295	
	Total:	2975	3080

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Caustic Pump # A

Setting: 400

Caustic Temp. 170

Target = 49° C or 120° F

Neutralization Basin pH: 8

Corrections: None

Dump ph: 8

Notes: Readings not logged due to lack of personnel/unit sp's/
unit dedication

Regeneration Log (Concurrent Series)

Date: 09/18/07
 Time: 2020
 Run length: 214,000 - 13000 = 201000 gallons
 Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

					GPM Target				Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	66	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	97	97				
4	PA	BW	15	59	50	57	62	64	62	53				
5	PC	BW	15	59	120	140	153	158	153	36				
6a	SA	3% NaOH	29	60	10				10	155				
6b	SA to PA	3% NaOH	66	60	10				10	155				
6c	SA to PA	SR	32	60	20				20	156				
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.031	2295	
6h	SC to PC	SR	8	59	85				85	191				
6i	PC	FR	16	59	165				165	29				
7	PA	FR	28	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				150	91				
10	SA	FR	14/CT-3 < 100	60	165				150	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116				
12	Mandatory Recycle		10		165				140	116				
	Service				150					122				

3%=1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.042	950	
Total:		1590	1630

Caustic Pump # B
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 1
 Corrections: _____
 Dump pH: 1.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 11-28-97

Time: 2104

Run length: 214,000 - 21,000 = 193 gallons

Service Water pressure: 7 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60					✓	
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			✓	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			165	116
12	Mandatory Recycle		10			165			165	116
	Service					150			149	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.040	290	280
1.0417	1.041	950	880
Total:		1590	
Total:		2975	2990

Caustic Pump # P-5A

Setting: 760

Caustic Temp.: 120

Target = 49° C or 120° F

Neutralization Basin pH: 8

Corrections: N/A

Dump pH: 8

Notes:

Regeneration Log (Concurrent Series)

Date: 11/27/07
 Time: 0200
 Run length: 214,000 - 4000 = 210000 gallons
 Service Water pressure: 77 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	63	53
5	PC	BW	15	59	120	140	153	158	150	36
6a	SA	3% NaOH	29	60	10				10	155
6b	SA to PA	3% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0				0	
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	28	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165					91
10	SA	FR	14/CT-3 < 100	60	165					103
11	Rinse Recycle		13/CT-5 < 2.00	60	165					116
12	Mandatory Recycle		10		165				135	116
	Service				150				130	122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.042	950	
Total:		1590	
1.0084	1.008	1020	
1.0184	1.02	1785	
1.0317	1.03	2295	
Total:		2975	

543 Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 4.0
 Corrections: 5 min Caustic
 Dump ph: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 11/11/00

Time: 1300

Run length: 214 000 = 8 = 206K gallons

Service Water pressure: 06 psi Temp. 76 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	58	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	87	97
4	PA	BW	15	59	50	57	62	64	60	53
5	PC	BW	15	59	120	140	153	158	146	36
6a	SA	3% NaOH	29	60	10				110	155
6b	SA to PA	3% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				82	191/206
6f	SC to PC	3.0% Acid	9	59	85				84	191/207
6g	SC to PC	5.0% Acid	6	59	85				83	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				162	29
7	PA	FR	28	60	165				163	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				162	82
9	SC	FR	17	60	165				163	91
10	SA	FR	14/CT-3 < 100	60	165				163	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				162	116
12	Mandatory Recycle		10		165				163	116
	Service				150					122

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	10042	950	
Total:		1590	1585

Caustic Pump # A
 Setting: 400
 Caustic Temp. 1200
 Target = 49° C or 120° F

Neutralization Basin pH: 7.5

Corrections: None

Dump ph: 7.5

Notes:

Regeneration Log (Concurrent Series)

Date: 11-17-07

Time: 1954

Run length: 214,000 - 7,000 = 207,000 gallons

Service Water pressure: 87 psi Temp. 67 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
2120	1	SA	BW	15	60	50	57	66	57	110
	2	SA	Settle	3	60					
2136	3	SC	BW	10	59	75	87	97	87	97
2146	4	PA	BW	15	59	50	57	62	59	53
	5	PC	BW	15	59	120	140	153	140	36
2200	6a	SA	3% NaOH	29	60		10		10	155
	6b	SA to PA	3% NaOH	66	60		10		10	155
	6c	SA to PA	SR	32	60		20		20	156
	6d	PC	Settle	3	60		0		0	
	6e	SC to PC	1.5% Acid	12	59		85		85	191/206
	6f	SC to PC	3.0% Acid	9	59		85		85	191/207
	6g	SC to PC	5.0% Acid	6	59		85		85	191/208
	6h	SC to PC	SR	8	59		85		85	191
	6i	PC	FR	16	59		165		165	29
	7	PA	FR	28	60		165		165	49
	8	PC to PA	Recycle	30/CT-1 < 20	60		165		165	82
	9	SC	FR	17	60		165		165	91
	10	SA	FR	14/CT-3 < 100	60		165		165	103
	11	Rinse Recycle		13/CT-5 < 2.00	60		165		165	116
	12	Mandatory Recycle		10			165		165	116
		Service					150		198	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.040	950	
Total:		1590	1580
Total:		2975	3000

Caustic Pump # B

Setting: 406

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.0
Corrections: none
Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 11/9/07

Time: 0837

Run length: 214,000 - 8000 = 206,000 gallons

Service Water pressure: 79 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target				Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	65	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	96	97				
4	PA	BW	15	59	50	57	62	64	61	53				
5	PC	BW	15	59	120	140	153	158	152	36				
6a	SA	3% NaOH	29	60	10				10	155	1.0417	N/A	290	
6b	SA to PA	3% NaOH	66	60	10				10	155	1.0417		950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1530
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	129
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.031	2295	190
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3110
6i	PC	FR	16	59	165				164	29				
7	PA	FR	28	60	165				164	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				158	82				
9	SC	FR	17	60	165				160	91				
10	SA	FR	14/CT-3 < 100	60	165				160	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116				
12	Mandatory Recycle		10		165					116				
	Service				150					122				

3%= 1.0215

5%= 1.0417

Hydrometer

Dilution Water

Target

Actual

Target

Actual

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
	Total:	1590	1530
1.0084	1.008	1020	
1.0184	1.018	1785	129
1.0317	1.031	2295	190
	Total:	2975	3110

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 3

Corrections: 6 min NaOH

Dump ph: 7.0

Notes: ✓

Regeneration Log (Concurrent Series)

Date: 11/5/07

Time: 1035

Run length: 214,000 - 6,000 = 208,000 gallons

Service Water pressure: 88 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	64	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	61	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	3% NaOH	29	60		10			10	155
6b	SA to PA	3% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
7e	SC to PC	1.5% Acid	12	59		85			85	191/206
7f	SC to PC	3.0% Acid	9	59		85			85	191/207
7g	SC to PC	5.0% Acid	6	59		85			85	191/208
7h	SC to PC	SR	8	59		85			85	191
8i	PC	FR	16	59		165			165	29
8j	PA	FR	28	60		165			165	49
8k	PC to PA	Recycle	30/CT-1 < 20	60		165			159	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100-5	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			137	116
12	Mandatory Recycle		10			165			137	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0411	950	
Total:		1590	1580
Total:		2975	3120

Caustic Pump # A

Setting: 400

Caustic Temp. 119

Target = 49° C or 120° F

Neutralization Basin pH: 4.0

Corrections: 2 min Caustic

Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 10/30/07

Time: 0022

Run length: 214,000 - 3000 = 211000 gallons

Service Water pressure: 92 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target				Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	65	110				
2	SA	Settle	3	60							3%= 1.0215			
3	SC	BW	10	59	75	87	97	101	96	97	5%=1.0417			
4	PA	BW	15	59	50	57	62	64	61	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual
6a	SA	3% NaOH	29	60	10				10	155	1.0417	N/A	290	320
6b	SA to PA	3% NaOH	66	60	10				10	155	1.0417	1.041	950	
6c	SA to PA	SR	32	60	20				20	156	Total:		1590	
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	1130
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	1900
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.031	2295	2420
6h	SC to PC	SR	8	59	85				85	191	Total:		2975	3130
6i	PC	FR	16	59	165				164	29				
7	PA	FR	28	60	165				150	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				164	82				
9	SC	FR	17	60	165				163	91				
10	SA	FR	14/CT-3 < 100	60	165				163	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				137	116				
12	Mandatory Recycle		10		165				137	116				
	Service				150					122				

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 3
Corrections: 3 min caustic
Dump ph: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10/27/07

Time: 0520

Run length: 214,000 - 14000 = 200,00 gallons

Service Water pressure: 91 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>163</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>136</u>	116
12	Mandatory Recycle		10			165			<u>136</u>	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
	Total:	1590	<u>1620</u>
1.0084	1.008	1020	
1.0184	1.020	1785	
1.0317	1.032	2295	
	Total:	2975	<u>3060</u>

Caustic Pump # 81

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: _____

Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10/26/07

Time: 2330

Run length: 214,000 - 15000 = 199000 gallons

Service Water pressure: 98 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	64	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	3% NaOH	29	60	10				10	155
6b	SA to PA	3% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	28	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				160	91
10	SA	FR	14/CT-3 < 100	60	165				145	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				145	116
12	Mandatory Recycle		10		165					116
	Service				150					122

3% = 1.0215
 5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0411	950	
Total:		1590	1700
1.0084	1.0084	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
Total:		2975	3120

Caustic Pump # 8
 Setting: 400
 Caustic Temp. 170°F
 Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: _____

Dump ph: 4-0


Notes:

Caustic Pump # 3

Setting: 4.50

Caustic Temp. 170°F

Target = 49° C or 120° F



Regeneration Log (Concurrent Series)

Date: 10/22/07

Time: 0900

Run length: 214,000 - 23000 = 191000 gallons

Service Water pressure: _____ psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>162</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>160</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>168</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>140</u>	116
12	Mandatory Recycle		10			165			<u>140</u>	116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	<u>1.042</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.032</u>	2295	
	Total:	2975	<u>3100</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7

Corrections: NONE

Dump pH: 7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10-20-07

Time: 0015

Run length: 214,000 - 20,000 = 194,000 gallons

Service Water pressure: 91 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target				Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60					0	
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	3% NaOH	29	60		10			10	155
6b	SA to PA	3% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			0	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	28	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			140	116
12	Mandatory Recycle		10			165			140	116
	Service					150			139	122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0410	950	
	Total:	1590	1620
1.0084	1.0080	1020	
1.0184	1.0180	1785	
1.0317	1.0300	2295	
	Total:	2975	3130

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 2 min. Acid

Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10/7/07

Time: 1900

Run length: $214,000 - 16,000 = 198,000$ gallons

Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target						RSV Rate Set Points			
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #				
1	SA	BW	15	60	50	57	66	68	65	110				
2	SA	Settle	3	60							3%= 1.0215			
3	SC	BW	10	59	75	87	97	101	96	97	5%=1.0417			
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual
6a	SA	3% NaOH	29	60	10				10	155	1.0417	N/A	290	
6b	SA to PA	3% NaOH	66	60	10				10	155	1.0417		950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1620
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.019	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.032	2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3120
6i	PC	FR	16	59	165				165	29	Caustic Pump # <u>A</u> Setting: <u>400</u> Caustic Temp <u>120</u> Target = 49° C or 120° F			
7	PA	FR	28	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				145	91				
10	SA	FR	14/CT-3 < 100	60	165				160	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116				
12	Mandatory Recycle		10		165				140	116				
	Service				150				137	122				

Neutralization Basin pH: 9.0

Corrections: 1 MIN ACID

Dump ph: 7.5

Notes:

Caustic Pump # A

Setting: 400

Caustic Temp 120

Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 10-15-07

Time: 1936

Run length: 214,000 - 23000 = 191000 gallons

Service Water pressure: 90 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

1937
START

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	3% NaOH	29	60		10			10	155
6b	SA to PA	3% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	28	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			163	82
9	SC	FR	17	60		165			143	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			196	116
12	Mandatory Recycle		10			165			140	116
	Service					150			138	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.041	950	
Total:		1590	1530
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
Total:		2975	3100

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: 0

Dump pH: 8.0

Notes:

Regeneration Log (Concurrent Series)

Date: 10/13/07

Time: 0001

Run length: 214,000 - 25000 = 189,000 gallons

Service Water pressure: 90 psi Temp: 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>140</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>140</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>140</u>	116
12	Mandatory Recycle		10			165			<u>140</u>	116
	Service					150			<u>138</u>	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
	Total:	1590	<u>1630</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.019</u>	1785	
1.0317	<u>1.032</u>	2295	
	Total:	2975	<u>3080</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.5

Corrections: _____

Dump pH: 8.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10-10-07

Time: 1629

Run length: 214,000 - 23000 = 191000 gallons

Service Water pressure: 88 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20				156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>165</u>	116
12	Mandatory Recycle		10			165			<u>165</u>	116
	Service					150			<u>140</u>	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	<u>370</u>
1.0417	<u>1.041</u>	950	
Total:		1590	
1.0084	<u>1.008</u>	1020	<u>1420</u>
1.0184	<u>1.018</u>	1785	<u>1890</u>
1.0317	<u>1.031</u>	2295	<u>2400</u>
Total:		2975	

Caustic Pump # 15

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.5

Corrections: ---

Dump ph: 9.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10/7/07

Time: 1500

Run length: 214,000 - 31,000 = _____ gallons

Service Water pressure: 90 psi Temp 50 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>154</u>	36
6a	SA	3% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	3% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	28	60	165				<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>145</u>	91
10	SA	FR	14/CT-3 < 100	60	165				<u>145</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>145</u>	116
12	Mandatory Recycle		10		165				<u>145</u>	116
	Service				150				<u>140</u>	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
Total:		1590	<u>1660</u>
Total:		2975	<u>3170</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 2 ml ACID

Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 10-4-07

Time: 0836

Run length: 214,000 - 26,000 = 188,000 gallons

Service Water pressure: 89 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0			<u>0</u>	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>164</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>145</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>145</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>145</u>	116
12	Mandatory Recycle		10			165			<u>165</u>	116
	Service					150			<u>150</u>	122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	<u>1.0417</u>	950	
	Total:	1590	<u>1660</u>
1.0084	<u>1.0080</u>	1020	
1.0184	<u>1.0170</u>	1785	
1.0317	<u>1.0300</u>	2295	
	Total:	2975	<u>3200</u>

Caustic Pump # A

Setting: 480

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 2 min Acid

Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 10-2-07

Time: 1930

Run length: 214,000 - 27,000 = 187,000 gallons

Service Water pressure: 78 psi Temp. 86 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	3%= 1.0215			5%=1.0417			
1932	1	SA	BW	15	60	50	57	66	68	66	110				
1947	2	SA	Settle	3	60					—					
1948	3	SC	BW	10	59	75	87	97	101	97	97				
1958	4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water	
2013	5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual
2014	6a	SA	3% NaOH	29	60	10				10	155	1.0417	N/A	290	580
2108	6b	SA to PA	3% NaOH	66	60	10?				10	155	1.0417	1.040	950	1250
	6c	SA to PA	SR	32	60	20				20	156	Total:		1590	1890
	6d	PC	Settle	3	60	0				—					
	6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	1150
	6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.017	1785	1940
	6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.030	2295	2480
	6h	SC to PC	SR	8	59	85				85	191	Total:		2975	3190
	6i	PC	FR	16	59	165				165	29				
2246	7	PA	FR	28	60	165				165	49				
2308	8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
2345	9	SC	FR	17	60	165				165	91				
0013	10	SA	FR	14/CT-3 < 100	60	165				165	103				
0040	11	Rinse Recycle		13/CT-5 < 2.00	60	165				136	116				
	12	Mandatory Recycle		10		165				136	116				
		Service				150					122				

Caustic Pump # A

Setting: 400

Caustic Temp. 120°

Target = 49° C or 120° F

Caustic Pump # A

Setting: 400

Caustic Temp. 120°

Target = 49° C or 120° F

Neutralization Basin pH: 9
Corrections: 1.5 min Acid

Dump pH: 7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 9/30/07

Time: 0800

Run length: 214,000 - 20000 = 194000 gallons

Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36				
6a	SA	3% NaOH	29	60	10				<u>10</u>	155	1.0417	N/A	290	
6b	SA to PA	3% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>1.0417</u>	950	
6c	SA to PA	SR	32	60	20				<u>20</u>	156		Total:	1590	<u>1640</u>
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084		1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184		1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317		2295	
6h	SC to PC	SR	8	59	85				<u>85</u>	191		Total:	2975	<u>3210</u>
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	28	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>160</u>	82				
9	SC	FR	17	60	165				<u>150</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>150</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>140</u>	116				
12	Mandatory Recycle		10		165				<u>140</u>	116				
	Service				150				<u>—</u>	122				

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 9.0 - 1.1 = 7.9
Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 9-24-07

Time: 1929

Run length: 214,000 - 26000 = 188000 gallons

Service Water pressure: 84 psi Temp. 83 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>151</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>164</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>136</u>	116
12	Mandatory Recycle		10			165			<u>140</u>	116
	Service					150				122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	<u>340</u>
1.0417	<u>1.041</u>	950	
	Total:	1590	<u>1670</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.031</u>	2295	
	Total:	2975	<u>3160</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 2 mins Acid

Dump pH: 7.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 9/23/07
 Time: 2022
 Run length: 214,000 - 20,000 = 194,000 gallons
 Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60					-	
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53
5	PC	BW	15	59	120	140	153	158	<u>155</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		<u>165</u>			<u>135</u>	116
12	Mandatory Recycle		10			<u>165</u>			<u>140</u>	116
	Service					<u>150</u>	13		<u>135</u>	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
	N/A	290	
		950	<u>1041</u>
	Total:	1590	<u>2230</u>
	Total:	2975	<u>3090</u>

Caustic Pump # 5A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0
 Corrections: 2 min Acid - 1 min Caustic
 Dump pH: 7.0

Notes: 0234 in service

Regeneration Log (Concurrent Series)

Date: 9-20-07

Time: 2156

Run length: 214,000 - 12,000 = 202,000 gallons

Service Water pressure: 87 psi Temp. 83 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	94	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	3% NaOH	29	60		10			10	155
6b	SA to PA	3% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			0	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	28	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	14/CT-3 < 100	60		165			165	91
10	SA	FR	13/CT-5 < 2.00	60		165			165	103
11	Rinse Recycle			60		165			165	116
12	Mandatory Recycle		10			165			165	116
	Service					150			150	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0400	950	
	Total:	1590	1690
	Total:	2975	3130

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: 2 min Acid

Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 6-26-07

Time: 2038

Run length: 214,000 - 25000 = 189,000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #	
					60°	70°	80°	83°			
2109	1	SA	BW	15	60	50	57	66	68	44	110
2124	2	SA	Settle	3	60						
2127	3	SC	BW	10	59	75	87	97	101	96	97
2135	4	PA	BW	15	59	50	57	62	64	62	53
2150	5	PC	BW	15	59	120	140	153	158	153	36
2150	6a	SA	3% NaOH	29	60		10			10	155
2151	6b	SA to PA	3% NaOH	66	60		10			10	155
	6c	SA to PA	SR	32	60		20			20	156
	6d	PC	Settle	3	60		0			0	
2210	6e	SC to PC	1.5% Acid	12	59		85			85	191/206
2222	6f	SC to PC	3.0% Acid	9	59		85			85	191/207
2231	6g	SC to PC	5.0% Acid	6	59		85			85	191/208
2237	6h	SC to PC	SR	8	59		85			85	191
2245	6i	PC	FR	16	59		165			165	29
0000	7	PA	FR	28	60		165			165	49
0024	8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
0057	9	SC	FR	17	60		165			165	91
0133	10	SA	FR	14/CT-3 < 100	60		165			165	103
	11	Rinse Recycle	13/CT-5 < 2.00	60			165			165	116
	12	Mandatory Recycle		10			165			165	116
		Service					150			1	122

3%= 1.0215			
5%=1.0417			
Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0410	950	
	Total:	1590	1640
1.0084	1.0080	1020	
1.0184	1.0180	1785	
1.0317	1.0290	2295	
	Total:	2975	3270

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417	1.0410	950	
	Total:	1590	1640
1.0084	1.0080	1020	
1.0184	1.0180	1785	
1.0317	1.0290	2295	
	Total:	2975	3270

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 2 min 9.0

Dump pH: 6.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 9/28/07

Time: 0710

Run length: 214,000 - 33000 = 181000 gallons

Service Water pressure: 78 psi Temp. 78 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>63</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	3% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	3% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0			<u>0</u>	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	28	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165				91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>165</u>	116
12	Mandatory Recycle		10			165			<u>143</u>	116
	Service					150				122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	
1.0417		950	
	Total:	1590	
	Total:	2975	<u>2450</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 170

Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 12 min ACID
Dump pH: 7.4

Notes: _____

Regeneration Log (Concurrent Series)

Date: 9/8/07
Time: 1836

Time: 1836

Run length: $214,000 - 22,000 = 192,000$ gallons

Service Water pressure: 89 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60					—	
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	60	53
5	PC	BW	15	59	120	140	153	158	150	36
6a	SA	3% NaOH	29	60		10			10	155
6b	SA to PA	3% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			—	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	34	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			150	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			136	116
12	Mandatory Recycle		10			165			137	116
	Service					150				122

3%= 1.0215
 5%=1.0417

Hydrometer Dilution Water

Target	Actual	Target	Actual
1.0417	N/A	290	300
1.0417	1.044	950	950
Total:		1590	1570
Total:		2975	3060

2130
 2152
 2226
 2243
 2303
 2316

Caustic Pump # B
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: 0

Dump ph: 8.0

Notes: prolong #10

3 Shift MS

Regeneration Log (Concurrent Series)

Date: 8/24/07

Time: 22:50

Run length: 214,000 - 4000 = 210,000 gallons

Service Water pressure: 98 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	158	158		36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			160	91
10	SA	FR	14/CT-3 < 100	60		165			140	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			140	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
	Total:	1590	1610
1.0084	1.008	1020	
1.0184	1.019	1785	
1.0317	1.032	2295	
	Total:	2975	3060

Caustic Pump # A

Setting: 400

Caustic Temp. 121


Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections:

Dump pH: 7.0

Notes:



Regeneration Log (Concurrent Series)

Date: 8-14-07

Time: 1245

Run length: 214,000 - 12000 = 202000 gallons

Service Water pressure: 87 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>63</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>163</u>	91
10	SA	FR	14/CT-3 < 100	60		165				103
11	Rinse Recycle	13/CT-5 < 2.00	60			165				116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.041</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.031</u>	2295	
	Total:	2975	

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5.0

Corrections: 3 mins CAUSTIC

Dump pH: 6.5

Notes:

Regeneration Log (Concurrent Series)

Date: 08-11-07

Time: 2031

Time: 20.31
Run length: $214,000 - \frac{24,000}{8.2} = \frac{190,000}{\text{Temp } 800^\circ \text{F degree}}$ gallons

Run length: 214,000 - 29,000 - 170,000 gallons
Service Water pressure: 9.2 psi Temp. 80°F degrees F

2031 - delay - 2032

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #		
					60°	70°	80°	83°				
1	SA	BW	15	60	50	57	66	68	66	110	✓	
2	SA	Settle	3	60							✓	3% = 1.0215
3	SC	BW	10	59	75	87	97	101	97	97	✓	5% = 1.0417
4	PA	BW	15	59	50	57	62	64	62	53	✓	Hydrometer
5	PC	BW	15	59	120	140	153	158	153	36	✓	Dilution Water
6a	SA	5% NaOH	29	60		10			10	✓	155	1.0417
6b	SA to PA	5% NaOH	66	60		10			10	✓	155	1.0417
6c	SA to PA	SR	32	60		20			20	✓	156	
6d	PC	Settle	3	60		0						
6e	SC to PC	1.5% Acid	12	59		85			85	✓	191/206	1.0084
6f	SC to PC	3.0% Acid	9	59		85			85	✓	191/207	1.0184
6g	SC to PC	5.0% Acid	6	59		85			85	✓	191/208	1.0317
6h	SC to PC	SR	8	59		85			85	✓	191	
6i	PC	FR	16	59		165			165	✓	29	
7	PA	FR	22	60		165			165	✓	49	
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	✓	82	
9	SC	FR	17	60		165			165	✓	91	
10	SA	FR	14/CT-3 < 100	60		165			120	✓	103	
11	Rinse Recycle		13/CT-5 < 2.00	60		165			125	✓	116	
12	Mandatory Recycle		10	10		165					116	
	Service					150					122	

3% = 1.0215
 5% = 1.0417

Total: 1590 1590

Total: 2975 3120

prolong 11 MINS
 prolong 23 MINS
 NONE

Caustic Pump # 5D
 Setting: 250/400
 Caustic Temp. 120°F
 Target = 49°C or 120°F

Neutralization Basin pH: 5.0

Corrections: 3 mins caustic

Dump ph: 7.0

Dump ph: 7.0

Notes: (2) Reduced flow due to falling degasifier lvl falling.

3 470

11-21

Regeneration Log (Concurrent Series)

Date: 8/9/07
 Time: 2230
 Run length: 214,000 - 20 = 194 gallons
 Service Water pressure: 90 psi Temp: 86 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	100	97
4	PA	BW	15	59	50	57	62	64	53	53
5	PC	BW	15	59	120	140	153	158	160	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			155	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			130	116
12	Mandatory Recycle		10			165			140	116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.041	950	
	Total:	1590	
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.030	2295	
	Total:	2975	

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.5
 Corrections: NONE REQUIRED
 Dump pH: 2.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 08-07-07

Time: 07:31

Run length: 214,000 - 19,000 = 195,000 gallons

Service Water pressure: 92 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60					✓	
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	53	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			✓	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			137	116
12	Mandatory Recycle		10			165			137	116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.041	290	310
1.0417	1.042	950	960
Total:		1590	1610
Total:		2975	3140

Less than 100 meq/l - Prolong 9.0 min.
Prolong for 1.0 min.
Caustic Pump # 2 ft
Setting: 250/400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 3 min 10 sec
Dump pH: 6.5

Notes: _____

5 3/4 hr

317-627 - Regeneration Log (Concurrent Series)

Date: 8-2-07

Time: 2:00
Run length: 214,000 - 21,000 = 193,000 gallons
Service Water pressure: 92 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			145	116
12	Mandatory Recycle		10			165			145	116
	Service					150			150	122

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.040	290	320
1.0417	1.041	950	970
Total:		1590	1610
Total:		2975	3130

Caustic Pump # P-58
Setting: _____
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 9
Corrections: Sum Added Acid
Dump pH: 7.0

Notes: _____

2255
22
2277

2255
22
2277
23(17)

Regeneration Log (Concurrent Series)

Date: 7-31-07

Time: 1903

Run length: 214,000 - 56,000 = 158,000 gallons

Service Water pressure: 90 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target				Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	44	110				
2	SA	Settle	3	60					2		3%=1.0215			
3	SC	BW	10	59	75	87	97	101	97	97	5%=1.0417			
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	154	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60		10			10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60		10			10	155	1.0417	1.0408	950	
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1630
6d	PC	Settle	3	60		0			0					
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.0190	1785	
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	1.0300	2295	
6h	SC to PC	SR	8	59		85			85	191		Total:	2975	3070
6i	PC	FR	16	59		165			161	29				
7	PA	FR	22	60		165			165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82	Caustic Pump # <u>A</u>			
9	SC	FR	17	60		165			165	91	Setting: <u>400</u>			
10	SA	FR	14/CT-3 < 100	60		165			165	103	Caustic Temp. <u>120</u>			
11	Rinse Recycle			13/CT-5 < 2.00	60		165		165	116	Target = 49° C or 120° F			
12	Mandatory Recycle			10			165		160	116				
	Service					150			153	122				

Caustic Pump # A
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: none

Dump pH: 7.0

Notes:

(3% acid now working)

Regeneration Log (Concurrent Series)

Date: 7-28-07

Time: 2314

Run length: 214,000 - 7,000 = 207,000 gallons

Service Water pressure: 91 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	98	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			0	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			88	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			163	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			164	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			140	116
12	Mandatory Recycle		10			165			140	116
	Service					150			152	122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0400	950	
	Total:	1590	1660
1.0084	1.010	1020	
1.0184	No acid	1785	
1.0317	1.028	2295	
	Total:	2975	3070

Caustic Pump # A
Setting: 400
Caustic Temp. 121
Target = 49° C or 120° F

Neutralization Basin pH: 10
Corrections: 5ml acid
Dump pH: 7.5

Notes: 3.0 acid valve did not open w.o. written

Regeneration Log (Concurrent Series)

Date: 7-22-07
 Time: 1:16 pm
 Run length: 214,000 - 33,000 = 213,967 gallons
 Service Water pressure: 92 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			165	116
12	Mandatory Recycle		10			165			165	116
	Service					150				122

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.041	290	380
1.0417	1.040	950	990
Total:		1590	1630

Caustic Pump # P-5A
 Setting: _____
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 10.0
 Corrections: Acid 3 m.v.
 Dump pH: 6.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 7-20-07
 Time: 1402
 Run length: 214,000 - 35,000 = _____ gallons
 Service Water pressure: 92 psi Temp. 86 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	93°		
1	SA	BW	15	60	50	57	66	68	<u>68</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>100</u>	97
4	PA	BW	15	59	50	57	62	64	<u>63</u>	53
5	PC	BW	15	59	120	140	153	155	<u>154</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	22	60	165				<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60		165				<u>140</u>	116
12	Mandatory Recycle		10		165				<u>140</u>	116
	Service				150					122

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	<u>300</u>
1.0417	<u>1.041</u>	950	<u>960</u>
	Total:	1590	<u>1630</u>

Caustic Pump # 13
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 10+
 Corrections: 900 10 mins
 Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 7/18/07
 Time: 0010 2100
 Run length: 214,000 - 193000 = 193000 gallons
 Service Water pressure: 88 psi Temp. 83 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

GPM Target										Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			
1	SA	BW	15	60	50	57	66	68	68	110	
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101	100	97	
4	PA	BW	15	59	50	57	62	64	62	53	
5	PC	BW	15	59	120	140	153	158	155	36	
6a	SA	5% NaOH	29	60	10				10	155	
6b	SA to PA	5% NaOH	66	60	10				10	155	
6c	SA to PA	SR	32	60	20				20	156	
6d	PC	Settle	3	60	0						
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	
6h	SC to PC	SR	8	59	85				85	191	
6i	PC	FR	16	59	165				165	29	
7	PA	FR	22	60	165				165	49	
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82	
9	SC	FR	17	60	165				165	91	
10	SA	FR	14/CT-3 < 100	60	165				165	103	
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116	
12	Mandatory Recycle		10		165				140	116	
	Service				150					122	

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	320
1.0417	1.041	950	970
	Total:	1590	1640

Caustic Pump # B
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

3%= 1.0215
 5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	320
1.0417	1.041	950	970
	Total:	1590	1640
1.0084	1.008	1020	1110
1.0184	1.016	1785	2000
1.0317	1.03	2295	2390
	Total:	2975	3070

Caustic Pump # B
 Setting: 400
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 9.5
 Corrections: 6 min Acid
 Dump pH: 7.5

Notes: _____

124-230
 230302
 305

1.25-134

204
 324

402-419

Regeneration Log (Concurrent Series)

Date: 7-16-07

Time: 1325

Run length: 214,000 - 7000 = 207000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target				Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	67	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	61	53
5	PC	BW	15	59	120	140	153	158	151	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				147	116
12	Mandatory Recycle		10		165					116
	Service				150					122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0411	950	
Total:		1590	1620
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
Total:		2975	3100

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: 0

Dump pH: 8.0

Notes:

Regeneration Log (Concurrent Series)

Date: 7/13/07

Time: 1915

Run length: 214,000 - 214K = 0 gallons

Service Water pressure: 91 psi Temp. 86 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	68	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	100	97
4	PA	BW	15	59	50	57	62	64	64	53
5	PC	BW	15	59	120	140	153	158	160	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			155	116
12	Mandatory Recycle		10			165			165	116
	Service					150			150	122

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0411	950	
	Total:	1590	
1.0084	1.01	1020	
1.0184	1.018	1785	
1.0317	1.030	2295	
	Total:	2975	

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5

Corrections:

Dump pH: 20

Notes:

4 MIN CAUSTIC

Regeneration Log (Concurrent Series)

Date: 7/11/07

Time: 11:00

Run length: 214,000 - 0 = 214,000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20					156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116
12	Mandatory Recycle		10		165				140	116
	Service				150					122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.042	950	
Total:		1590	1630
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
Total:		2975	3110

Caustic Pump # A

Setting: 400

Caustic Temp. 120°F

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: _____

Dump pH: _____

Notes: _____

Regeneration Log (Concurrent Series)

Date: 7-9-07

Time: 0045

Run length: 214,000 - 0 = 214,000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>140</u>	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	<u>1630</u>
		1020	
		1785	
		2295	
Total:		2975	<u>3120</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 5

Corrections: 4 mins caustic

Dump ph: 6.5

Notes:

Regeneration Log (Concurrent Series)

Date: 07/06/07

Time: 0845

Run length: 214,000 - 0 = 214000 gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			
1	SA	BW	15	60	50	57	66	68	66	110	
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101	97	97	
4	PA	BW	15	59	50	57	62	64	62	53	
5	PC	BW	15	59	120	140	153	158	153	36	
6a	SA	5% NaOH	29	60	10				10	155	
6b	SA to PA	5% NaOH	66	60	10				10	155	
6c	SA to PA	SR	32	60	20				20	156	
6d	PC	Settle	3	60	0						
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	
6h	SC to PC	SR	8	59	85				85	191	
6i	PC	FR	16	59	165				165	29	
7	PA	FR	22	60	165				165	49	
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82	
9	SC	FR	17	60	165				165	91	
10	SA	FR	14/CT-3 < 100	60	165				165	103	
11	Rinse Recycle		13/CT-5 < 2.00	60	165				140	116	
12	Mandatory Recycle		10		165				140	116	
	Service				150					122	

3%= 1.0215
 5%=1.0417

Hydrometer
Dilution Water

Target
Actual
Target
Actual

Total: 1590

1640

Total: 2975

3090

Caustic Pump # 5A
 Setting: 400
 Caustic Temp. 120°F
 Target = 49° C or 120° F

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.042</u>	950	
	Total:	1590	<u>1640</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.032</u>	2295	
	Total:	2975	<u>3090</u>

Caustic Pump # 5A

Setting: 400

Caustic Temp. 120°F

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections:

Dump ph: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 7-3-07
 Time: 0050
 Run length: 214,000 - 27,000 = _____ gallons
 Service Water pressure: 78 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>90</u>	97
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53
5	PC	BW	15	59	120	140	153	158	<u>156</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>86</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>86</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>160</u>	29
7	PA	FR	22	60	165				<u>145</u>	49
8	PC to PA	Recycle	^{30/CT-1} < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	^{14/CT-3} < 100	60	165					103
11	Rinse Recycle		^{13/CT-5} < 2.00	60	165				<u>140</u>	116
12	Mandatory Recycle		10		165				<u>141</u>	116
	Service				150				<u>181</u>	122

3% = 1.0215
 5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	<u>290</u>
1.0417	—	950	<u>960</u>
	Total:	1590	<u>1595</u>
1.0084	—	1020	<u>1020</u>
1.0184	—	1785	<u>1790</u>
1.0317	—	2295	
	Total:	2975	

Caustic Pump # P-54
 Setting: 400
 Caustic Temp. 121°F
 Target = 49° C or 120° F

Neutralization Basin pH: 7
 Corrections: N/A
 Dump ph: 7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 6-27-07

Time: 0810

Run length: 214,000 - 24000 = _____ gallons

Service Water pressure: _____ psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	65	110				
2	SA	Settle	3	60					-	-				
3	SC	BW	10	59	75	87	97	101	100	97				
4	PA	BW	15	59	50	57	62	64	60	53				
5	PC	BW	15	59	120	140	153	158	155	36				
6a	SA	5% NaOH	29	60	10				10	155	1.0417	1.041	290	320
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.041	950	940
6c	SA to PA	SR	32	60	20				20	156	Total:		1590	1720
6d	PC	Settle	3	60	0				0	-				
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.009	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.017	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.031	2295	
6h	SC to PC	SR	8	59	85				85	191	Total:		2975	3150
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				166	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				145	116				
12	Mandatory Recycle		10		165				155	116				
	Service				150				138	122				

Caustic Pump # P-5A

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: 1 min Acid

Dump ph: 7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 6-23-07

Time: 1330

Run length: 214,000 - 22k = _____ gallons

Service Water pressure: 80 psi Temp. 53 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			
1	SA	BW	15	60	50	57	66	68	68	110	
2	SA	Settle	3	60					-		
3	SC	BW	10	59	75	87	97	101	100	97	
4	PA	BW	15	59	50	57	62	64	64	53	
5	PC	BW	15	59	120	140	153	158	150	36	
6a	SA	5% NaOH	29	60	10				10	155	
6b	SA to PA	5% NaOH	66	60	10				10	155	
6c	SA to PA	SR	32	60	20				20	156	
6d	PC	Settle	3	60	0				0		
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	
6h	SC to PC	SR	8	59	85				85	191	
6i	PC	FR	16	59	165				160	29	
7	PA	FR	22	60	165				160	49	
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82	
9	SC	FR	17	60	165				165	91	
10	SA	FR	14/CT-3 < 100	60	165				165	103	
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116	
12	Mandatory Recycle		10		165				165	116	
	Service				150				150	122	

3%= 1.0215	
5%=1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.041	290	
1.0417	1.041	950	
	Total:	1590	
1.0084	1.018	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
	Total:	2975	

Caustic Pump # P-5B

Setting: 400

Caustic Temp. 121°F

Target = 49° C or 120° F

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.041</u>	290	
1.0417	<u>1.041</u>	950	
	Total:	1590	
1.0084	<u>1.118</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.032</u>	2295	
	Total:	2975	

Caustic Pump # P-5B

Setting: 400

Caustic Temp. 121°F

Target = 49° C or 120° F

Neutralization Basin pH: 7

Corrections: 7

Dump pH: 7

Notes:

Regeneration Log (Concurrent Series)

Date: 6/20/67

Time: _____

Run length: 214,000 - 13000 = 201000 gallons

Service Water pressure: 98 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

					GPM Target					
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				162	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				155	82
9	SC	FR	17	60	165				164	91
10	SA	FR	14/CT-3 < 100	60	165				155	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				133	116
12	Mandatory Recycle		10		165				132	116
	Service				150				13	122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
		290	
		950	
	Total:	1590	1600
		1020	
		1785	
		2295	
	Total:	2975	3080

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: _____

Dump pH: 7.0

Notes: _____

1840

1846

1913

1906

2 min acid

Regeneration Log (Concurrent Series)

Date: 6-10-07

Time: 2350

Run length: 214,000 - 7k = 214k gallons

Service Water pressure: 9 psi Temp. 82 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>156</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>140</u>	116
12	Mandatory Recycle		10			165			<u>140</u>	116
	Service					150				122

3%=1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.042</u>	290	<u>310</u>
1.0417	<u>1.042</u>	950	<u>990</u>
	Total:	1590	<u>1660</u>
1.0084	<u>1.009</u>	1020	<u>1110</u>
1.0184	<u>1.019</u>	1785	<u>1880</u>
1.0317	<u>1.032</u>	2295	<u>2390</u>
	Total:	2975	<u>3080</u>

Caustic Pump # A
Setting: 400
Caustic Temp. 120°
Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections:

Dump pH: 8

Notes:

1 min acid

Regeneration Log (Concurrent Series)

Date: 6-22-07
 Time: 0130
 Run length: 214,000 - 16,000 = 198,000 gallons
 Service Water pressure: 92 psi Temp: 82 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	65	68	<u>67</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>64</u>	53
5	PC	BW	15	59	120	140	153	158	<u>156</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>164</u>	29
7	PA	FR	22	60		165			<u>166</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>157</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>134</u>	116
12	Mandatory Recycle		10			165			<u>120</u>	116
	Service					150			<u>11</u>	122

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.041</u>	290	<u>290</u>
1.0417	<u>1.041</u>	950	<u>980</u>
Total:		1590	<u>1270</u>
1.0084	<u>1.008</u>	1020	<u>1020</u>
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.031</u>	2295	
Total:		2975	<u>3110</u>

Caustic Pump # B
 Setting: 400
 Caustic Temp. 122°
 Target = 49° C or 120° F

Neutralization Basin pH: 9.0
 Corrections: 2 minutes ACID
 Dump pH: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 6-8-07

Time: 1:10

Run length: 214,000 - 17K = _____ gallons
Service Water pressure: 80 psi Temp. 84 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	100	97
4	PA	BW	15	59	50	57	62	64	65	53
5	PC	BW	15	59	120	140	153	158	160	36
6a	SA	5% NaOH	29	60		10			11	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60	<u>P3°</u>	20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			86	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			86	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			160	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			160	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			155	116
12	Mandatory Recycle		10			165			150	116
	Service					150			150	122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.04	290	290
1.0417	1.04	950	980
	Total:	1590	1600
1.0084	1.085	1020	1020
1.0184	1.018	1785	1790
1.0317	1.031	2295	2290
	Total:	2975	2986

Caustic Pump # P-5A

Setting: 10°

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 7.5

Corrections: _____

Dump pH: 7.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 6/16/07
 Time: 1230
 Run length: 214,000 - 10000 = 204000 gallons
 Service Water pressure: 90 psi Temp 82 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	68	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	68	64	62	53
5	PC	BW	15	59	120	140	153	158	152	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			165	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.042	950	980
	Total:	1590	1650
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.030	2295	2200
	Total:	2975	3100

Caustic Pump # A

Setting: 400

Caustic Temp. NO

Target = 49° C or 120° F

Neutralization Basin pH: 8

Corrections:

Dump pH: 7

Notes:

1 MW ACID

Regeneration Log (Concurrent Series)

Date: 6-11-07

Time: 0858

Run length: 214,000 - 16,000 = 198,000 gallons

Service Water pressure: 93 psi Temp. 78 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target											
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #	
1	SA	BW	15	60	50	57	66	68	65	110	
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101	96	97	
4	PA	BW	15	59	50	57	62	64	62	53	
5	PC	BW	15	59	120	140	153	158	153	36	
6a	SA	5% NaOH	29	60		10			10	155	
6b	SA to PA	5% NaOH	66	60		10			10	155	
6c	SA to PA	SR	32	60		20			20	156	
6d	PC	Settle	3	60		0					
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	
6h	SC to PC	SR	8	59		85			85	191	
6i	PC	FR	16	59		165			164	29	
7	PA	FR	22	60		165			164	49	
8	PC to PA	Recycle	30/CT-1 < 20	60		165			163	82	
9	SC	FR	17	60		165			164	91	
10	SA	FR	14/CT-3 < 100	60		165			165	103	
11	Rinse Recycle		13/CT-5 < 2.00	60		165			142	116	
12	Mandatory Recycle		10			165			140	116	
	Service					150			159	122	

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0430	950	
	Total:	1590	1660
1.0084	1.0100	1020	
1.0184	1.0170	1785	
1.0317	1.0310	2295	
	Total:	2975	3070

Caustic Pump # A
Setting: 400
Caustic Temp. 121
Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 4 min. Acid
Dump ph: 7.0

Notes: address 59 now works - still
fixing address 60

Regeneration Log (Concurrent Series)

Date: 6/8/07

Time: 0310

Run length: 214,000 - 16,000 = _____ gallons

Service Water pressure: 90 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°			
1	SA	BW	15	60	50	57	66	68		66	110
2	SA	Settle	3	60							
3	SC	BW	10	59	75	87	97	101		97	97
4	PA	BW	15	59	50	57	62	64		61	53
5	PC	BW	15	59	120	140	153	158		153	36
6a	SA	5% NaOH	29	60		10				10	155
6b	SA to PA	5% NaOH	66	60		10				10	155
6c	SA to PA	SR	32	60		20				20	156
6d	PC	Settle	3	60		0					
6e	SC to PC	1.5% Acid	12	59		85				85	191/206
6f	SC to PC	3.0% Acid	9	59		85				85	191/207
6g	SC to PC	5.0% Acid	6	59		85				85	191/208
6h	SC to PC	SR	8	59		85				85	191
6i	PC	FR	16	59		165				165	29
7	PA	FR	22.00	60		165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165				165	82
9	SC	FR	17	60		165				165	91
10	SA	FR	14/CT-3 < 100	60		165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165				140	116
12	Mandatory Recycle		10			165				140	116
	Service					150				✓	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.04	950	
Total:		1590	1670
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.031	2295	
Total:		2975	3130

Caustic Pump # A

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 7.5

Corrections: _____

Dump pH: 7.5

Notes: _____

0319

335

345

400

401

431

536

419

431

440

446

454

Regeneration Log (Concurrent Series)

Date: 6/6/67

Time: 2:30

Run length: $214,000 - 130,000 = 84,000$ gallons

Service Water pressure: 98 psi Temp. 80 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA^- =Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

GPM Target											
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #	
1	SA	BW	15	60	50	57	66	68	66	110	
2	SA	Settle	3	60							3%= 1.0215
3	SC	BW	10	59	75	87	97	101	97		5%=1.0417
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer
5	PC	BW	15	59	120	140	153	158	151	36	Dilution Water
6a	SA	5% NaOH	29	60	10				10	155	Target
6b	SA to PA	5% NaOH	66	60	10				10	155	Actual
6c	SA to PA	SR	32	60	20				20	156	Target
6d	PC	Settle	3	60	0						Actual
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317
6h	SC to PC	SR	8	59	85				85	191	Total:
6i	PC	FR	16	59	165				165	29	2975
7	PA	FR	22	60	165				165	49	3030
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82	
9	SC	FR	17	60	165/145				165/145	91	
10	SA	FR	14/CT-3 < 100	60	165/145				145	103	
11	Rinse Recycle		13/CT-5 < 2.00	60	165				135	116	
12	Mandatory Recycle		10		165					116	
	Service				150					122	

Caustic Pump # 13

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections:

Dump ph: 7.0


Notes: Reset valves # 91 & 103 to flow 145 gpm.

Caustic Pump # 13

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F



Regeneration Log (Concurrent Series)

Date: 6/4/07
 Time: 1254
 Run length: 214,000 - 31,000 = 183,000 gallons
 Service Water pressure: 91 psi Temp. 81 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	154	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			154	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			160	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			120	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215	
5%=1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
	Total:	1590	1670
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.030	2295	
	Total:	2975	3200

Caustic Pump # 13

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

100% Recycle

3%= 1.0215
 5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	<u>1570</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.030</u>	2295	
Total:		2975	<u>3200</u>

Caustic Pump # B
 Setting: 410
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 9
 Corrections: 2 min ACID
 Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 6-2-07

Time: 1829

Run length: 214,000 - 23,000 = 191,000 gallons

Service Water pressure: 92 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	151	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0			0	
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			154	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			120	116
12	Mandatory Recycle		10			165			120	116
	Service					150			124	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0400	950	
	Total:	1590	1710
1.0084	1.0080	1020	
1.0184	1.0174	1785	
1.0317	1.0310	2295	
	Total:	2975	3130

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: 4 min - acid

Dump pH: 6.0

Notes: Degasifier level went low during Fast rinse steps.

Regeneration Log (Concurrent Series)

Date: 5/31/07

Time: 915

Run length: 214,000 - 22,000 = 192,000 gallons

Service Water pressure: 88 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										Actual	RSV #				
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	3%= 1.0215			5%=1.0417	Hydrometer		Dilution Water
1	SA	BW	15	60	50	57	66	68	66	110					
2	SA	Settle	3	60											
3	SC	BW	10	59	75	87	97	101	96	97					
4	PA	BW	15	59	50	57	62	64	61	53					
5	PC	BW	15	59	120	140	153	158	152	36	Target	Actual	Target	Actual	
6a	SA	5% NaOH	29	60		10			10	155	1.0417	1.03	290		
6b	SA to PA	5% NaOH	66	60		10			10	155	1.0417	1.041	950	951	
6c	SA to PA	SR	32	60		20			20	156		Total:	1590	1620	
6d	PC	Settle	3	60		0									
6e	SC to PC	1.5% Acid	12	59		85			85	191/206	1.0084	1.008	1020		
6f	SC to PC	3.0% Acid	9	59		85			85	191/207	1.0184	1.018	1785		
6g	SC to PC	5.0% Acid	6	59		85			85	191/208	1.0317	1.031	2295	3110	
6h	SC to PC	SR	8	59		85			85	191		Total:	2975	3110	
6i	PC	FR	16	59		165			165	29					
7	PA	FR	22	60		165			164	49					
8	PC to PA	Recycle	30/CT-1 < 20	60		165			153	82					
9	SC	FR	.17	60		165			163	91					
10	SA	FR	14/CT-3 < 100	60		165			165	103					
11	Rinse Recycle		13/CT-5 < 2.00	60		165			120	116					
12	Mandatory Recycle		10			165			120	116					
	Service					150				122					

Caustic Pump #	A
Setting:	400
Caustic Temp.	121
Target =	49° C or 120° F

Caustic Pump # A

Setting: 400

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections:

Dump ph: 8.0

Notes:

2 min acid

Regeneration Log (Concurrent Series)

Date: 5-3-07

Time: 2100

Run length: 214,000 - 0 = 21400 gallons

Service Water pressure: 87 psi Temp. 70 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>40</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>158</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>165</u>	116
12	Mandatory Recycle		10			165			<u>165</u>	116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.041</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.030</u>	2295	
	Total:	2975	

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7

Corrections: 0

Dump pH: 7

Notes:

Regeneration Log (Concurrent Series)

Date: 4/26/07

Time: 08:00

Run length: $214,000 - 5000 = 209,000$ gallons

Service Water pressure: 98 psi Temp. degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target														
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #				
1	SA	BW	15	60	50	57	66	68	66	1:10				
2	SA	Settle	3	60							3%= 1.0215			
3	SC	BW	10	59	75	87	97	101	95	97	5%=1.0417			
4	PA	BW	15	59	50	57	62	64	59	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	145	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.0417	950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1650
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.0084	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.0184	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.0317	2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3130
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				162	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116				
12	Mandatory Recycle		10		165				145	116				
	Service				150					122				

Caustic Pump # 13

Setting: 200

Caustic Temp. 120


Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections:

Dump ph: 6.5

Notes:



Regeneration Log (Concurrent Series)

Date: 4/24/07

Time: 0845

Run length: 214,000 - 0 = 214000 gallons

Service Water pressure: _____ psi Temp. 76 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>90</u>	97
4	PA	BW	15	59	50	57	62	64	<u>57</u>	53
5	PC	BW	15	59	120	140	153	158	<u>145</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>10</u>	156
6d	PC	Settle	3	60		0			<u>20</u>	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	<u>30/CT-1</u> < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>162</u>	91
10	SA	FR	<u>14/CT-3</u> < 100	60		165			<u>165</u>	103
11	Rinse Recycle	<u>13/CT-5</u> < 2.00	60			165			<u>160</u>	116
12	Mandatory Recycle		10			165			<u>160</u>	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.041	290	
1.0417	1.041	950	
Total:		1590	<u>1650</u>
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.032	2295	
Total:		2975	<u>3090</u>

Caustic Pump # A

Setting: 450

Caustic Temp. 120°


Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections: _____

Dump pH: 6.5

Notes: _____



Regeneration Log (Concurrent Series)

Date: 4-14-07

Time: 2005

Run length: 214,000 - 3,000 = 211,000 gallons

Service Water pressure: 88 psi Temp. 82 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>101</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>64</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>160</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417		290	<u>300</u>
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>1.04</u>	950	<u>960</u>
6c	SA to PA	SR	32	60	20				<u>20</u>	156				
6d	PC	Settle	3	60	0				<u>✓</u>					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>1.008</u>	1020	<u>1080</u>
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>1.020</u>	1785	<u>1840</u>
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317	<u>1.032</u>	2295	<u>2350</u>
6h	SC to PC	SR	8	59	85				<u>85</u>	191				
6i	PC	FR	16	59	165				<u>165</u>	29				
7	PA	FR	22	60	165				<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82				
9	SC	FR	17	60	165				<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>120</u>	116				
12	Mandatory Recycle		10		165					116				
	Service				150					122				

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.04</u>	290	<u>300</u>
1.0417	<u>1.04</u>	950	<u>960</u>
Total:		1590	<u>1610</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7

Corrections: —

Dump pH: 7

Notes: _____

Regeneration Log (Concurrent Series)

Date: 4/11/07

Time: 1700

Run length: 214,000 - 0 = 214000 gallons

Service Water pressure: 85 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53
5	PC	BW	15	59	120	140	153	158	<u>150</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>170</u>	116
12	Mandatory Recycle		10			165			<u>170</u>	116
	Service					150				122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	<u>1600</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.031</u>	2295	
Total:		2975	<u>3090</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections:

Dump pH: 6.5

Notes:

Regeneration Log (Concurrent Series)

Date: 4-8-07

Time: 2020

Run length: 214,000 - 2 = 214000 gallons

Service Water pressure: 86 psi Temp. 87 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	15 22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				158*	82
9	SC	FR	15 17	60	165				165	91
10	SA	FR	15 4/CT-3 < 100	60	165				165	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				120	116
12	Mandatory Recycle		10		165				120	116
	Service				150					122

3%= 1.0215	
5%=1.0417	

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.0417	290	310
1.0417	1.041	950	970
	Total:	1590	1660
1.0084	1.008	1020	1140
1.0184	1.018	1785	1910
1.0317	1.031	2295	2550
	Total:	2975	3170

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.0417</u>	290	<u>310</u>
1.0417	<u>1.041</u>	950	<u>970</u>
	Total:	1590	<u>1660</u>
1.0084	<u>1.008</u>	1020	<u>1140</u>
1.0184	<u>1.018</u>	1785	<u>1910</u>
1.0317	<u>1.031</u>	2295	<u>2550</u>
	Total:	2975	<u>3170</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 6.5 12.8

Corrections: 7 min

Dump ph: 6.5 7.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 4/3/07
Time: 0058

Run length: 214,000 - 9000 = 205000 gallons
Service Water pressure: 84 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>97</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	22	60	165				<u>165</u>	49
8	PC to PA	Recycle	^{30/CT-1} < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	^{14/CT-3} < 100	60	165				<u>165</u>	103
11	Rinse Recycle		^{13/CT-5} < 2.00	60	165				<u>125</u>	116
12	Mandatory Recycle		10		165				<u>125</u>	116
	Service				150					122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	<u>1640</u>
Total:		2975	<u>3150</u>

Caustic Pump # 5B
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 7.0
Corrections: _____
Dump pH: 7.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 3-30-07

Time: 19:00

Run length: 214,000 - 9,000 = 205,000 gallons

Service Water pressure: 82 psi Temp. 82 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>66</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>21</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>167</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>165</u>	116
12	Mandatory Recycle		10			165			<u>165</u>	116
	Service					150				122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.041</u>	290	<u>290</u>
1.0417	<u>1.041</u>	950	<u>1000</u>
Total:		1590	<u>2100</u>
1.0084	<u>1.007</u>	1020	<u>1100</u>
1.0184	<u>1.017</u>	1785	<u>1875</u>
1.0317	<u>1.031</u>	2295	<u>2375</u>
Total:		2975	<u>3085</u>

Caustic Pump # 5A

Setting: 400

Caustic Temp. 120°

Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: NONE

Dump ph: 8.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 3-25-07

Time: 1812

Run length: 214,000 - 21000 = 193000 gallons

Service Water pressure: 86 psi Temp. 76 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1813-1828	1	SA	BW	15	60	50	57	66	66	110
1828-1853	2	SA	Settle	25	60					
1853-1879	3	SC	BW	10	59	75	87	97	95	97
1879-1854	4	PA	BW	15	59	50	57	62	64	53
1854-1909	5	PC	BW	15	59	120	140	153	148	36
1909-1924	6a	SA	5% NaOH	29	60		10		10	155
1924-2030	6b	SA to PA	5% NaOH	66	60		10		10	155
2030-2107	6c	SA to PA	SR	32	60		20		20	156
2107-1912	6d	PC	Settle	3	60		0			
1912-1926	6e	SC to PC	1.5% Acid	12	59		85		85	191/206
1926-1935	6f	SC to PC	3.0% Acid	9	59		85		85	191/207
1935-1941	6g	SC to PC	5.0% Acid	6	59		85		85	191/208
1941-1949	6h	SC to PC	SR	8	59		85		85	191
1949-2005	6i	PC	FR	16	59		165		165	29
2005-2102	7	PA	FR	22	60		165		165	49
2102-2200	8	PC to PA	Recycle	30/CT-1 <20	60		165		150	82
2200-2241	9	SC	FR	49	60		165		165	91
2241-2254	10	SA	FR	14/CT-3 <5	60		165		165	103
2254-2307	11	Rinse Recycle	13/CT-5 <2.00	60			165		160	116
2307-2317	12	Mandatory Recycle	10				165		160	116
2317-2607	Service		0025 hrs		150					122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.004	290	290
1.0417	1.002	950	1040
Total:		1590	1620
Total:		2975	3130

Prolog 12 MINS.

82 Valve Needs Servicing? Sticks

prolog 18 MINS

Caustic Pump # A

Setting: 400

Caustic Temp. 120°F

Target = 49° C or 120° F

low de-gasifier h. h. Ah.
Reduced flow to 140 GPM
for correction.

Neutralization Basin pH: 7.5

Corrections: None

Dump pH: 7.5

Notes: Low de-gas h.l. shut down. 2317. Manually (with hose)
fill degasifier with Jensen H₂O to clear low fuel.
re-started.

Jensen in Service back @ 0025 hrs. Making H₂O

41
23
18

Regeneration Log (Concurrent Series)

Date: 3-27-07

Time: 20:30

Run length: 214,000 - 15,000 = 199,000 gallons

Service Water pressure: 83 psi Temp. 83 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	64	53
5	PC	BW	15	59	120	140	153	158	156	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			86	191/206
6f	SC to PC	3.0% Acid	9	59		85			86	191/207
6g	SC to PC	5.0% Acid	6	59		85			86	191/208
6h	SC to PC	SR	8	59		85			86	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 15	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			121	116
12	Mandatory Recycle					165				116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.04	290	
1.0417	1.04	950	1050
Total:		1590	1720
Total:		2975	3170

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.1

Corrections: None

Dump pH: 7.1

Notes: _____

Regeneration Log (Concurrent Series)

Date: 3/24/07

Time: 0230

Run length: 214,000 - 28000 = 194000 gallons

Service Water pressure: 140 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	63	53
5	PC	BW	15	59	120	140	153	158	150	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			84	191
6i	PC	FR	16	59		165			163	29
7	PA	FR	22	60		165			160	49
* 8	PC to PA	Recycle	30/CT-1 < 20	60		165			160	82
9	SC	FR	17	60		165			160	91
10	SA	FR	14/CT-3 < 100	60		165			140	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			140	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.042	950	
Total:		1590	1700
1.0084	1.008	1020	
1.0184	1.018	1785	
1.0317	1.034	2295	
Total:		2975	3310

Caustic Pump # A

Setting: 100

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 10.5

Corrections: Add acid 2.5 min

Dump ph: 6.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 3-15-07

Time: 000

Run length: $214,000 - 29,000 = 185,000$ gallons

Service Water pressure: 87 psi Temp. 80 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

RSV Rate Set Value

GPM Target

Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	63	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			162	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			164	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			120	116
12	Mandatory Recycle		10			165			145	116
	Service					150			152	122

3%= 1.0215

5%= 1.0417

Hydrometer

Dilution Water

Target

Actual

Target

Actual

1.0417

290

1.0417

1.0390

950

Total:

1590

1640

1.0084

1.0080

1020

1.0184

1.0170

1785

1.0317

1.0290

2295

Total:

2975

3120

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 11.4
Corrections: 5 min - acid
Dump pH: 7.8

Notes: _____

Caustic Pump # B

Setting: 4.00

Caustic Temp. 120

Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 3-10-07

Time: 650

Run length: 214,000 - 20,000 = 194,000 gallons

Service Water pressure: 86 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target											RSV Rate Set Valve			
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #	3% = 1.0215		5% = 1.0417	
1	SA	BW	15	60	50	57	66	68		110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101		97				
4	PA	BW	15	59	50	57	62	64	56	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	140	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417	1.041	950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1650
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.031	2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3040
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				125	116				
12	Mandatory Recycle		10		165				125	116				
	Service				150				120	122				

Caustic Pump # B
 Setting: 100
 Caustic Temp. 120
 Target = 49° C or 120° F

Neutralization Basin pH: 10.9

Corrections:

Corrections: 4 m/v ACID

Notes:

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

1720

Regeneration Log (Concurrent Series)

Date: 5-11-67

Time: 1330

Run length: 214,000 - 6K = 208K gallons

Service Water pressure: 86 psi Temp. 80 degrees F

PC=Primary Cation

PA=Primary Anion

SC=Secondary Cation

SA=Secondary Anion

BW=Back Wash

SR=Slow Rinse

FR=Fast Rinse

RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36
6a	SA	5% NaOH	29	60	10				<u>10</u>	155
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155
6c	SA to PA	SR	32	60	20				<u>20</u>	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208
6h	SC to PC	SR	8	59	85				<u>85</u>	191
6i	PC	FR	16	59	165				<u>165</u>	29
7	PA	FR	22	60	165				<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>165</u>	82
9	SC	FR	17	60	165				<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60	165				<u>162</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60		165				<u>163</u>	116
12	Mandatory Recycle		10		165				<u>163</u>	116
	Service				150					122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.046</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.030</u>	2295	
	Total:	2975	

Caustic Pump # A

Setting: 400

Caustic Temp. 120°

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections:

Dump ph: 7.0

None

Notes:

Regeneration Log (Concurrent Series)

Date: 5/24/07

Time: 1620

Run length: 214,000 - 21,000 = 193,000 gallons

Service Water pressure: 91 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	96	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	151	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20				156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165				49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			165	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			165	116
12	Mandatory Recycle		10			165			165	116
	Service					150			150	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	N/A	290	310
1.0417	1.04	950	
	Total:	1590	
1.0084	1.008	1020	1120
1.0184	1.018	1785	2050
1.0317	3.1031	2295	2450
	Total:	2975	

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.6

Corrections: None

Dump pH: 7.2

Notes:

Regeneration Log (Concurrent Series)

Date: 22 May 07

Time: 1550

Run length: 214,000 - 15,000 = 199,000 gallons

Service Water pressure: 80 psi Temp. 84 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>67</u>	110
2	SA	Settle	3	60					—	
3	SC	BW	10	59	75	87	97	101	<u>101</u>	97
4	PA	BW	15	59	50	57	62	64	<u>64</u>	53
5	PC	BW	15	59	120	140	153	158	<u>156</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0			—	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165				116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215
5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.041</u>	290	<u>300</u>
1.0417	<u>1.041</u>	950	<u>970</u>
Total:		1590	<u>1630</u>
1.0084	<u>1.009</u>	1020	<u>1060</u>
1.0184	<u>1.017</u>	1785	<u>1810</u>
1.0317	<u>1.030</u>	2295	<u>2390</u>
Total:		2975	<u>3090</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 170°

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: 1 1/2 mins Acid

Dump pH: 8

Notes:

Regeneration Log (Concurrent Series)

Date: 20 Feb 1967

Time: 10 30 Am

Ruin length: $214,000 - 11000 = 203000$ gallons

Service Water pressure: 90 psi Temp. 79 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target														
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #				
1	SA	BW	15	60	50	57	66	68	66	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	97	97				
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417		950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	2300
6d	PC	Settle	3	60	0				0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317	1.031	2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3090
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				165	91				
10	SA	FR	14/CT-3 < 100	60	165				165	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				120	116				
12	Mandatory Recycle		10		165				118	116				
	Service				150					122				

3% = 1.0215
5% = 1.0417

Hydrometer
Dilution Water

Target
Actual
Target
Actual

1.0417
1.0417
Total: 1590
2300

1.0084
1.0184
1.0317
Total: 2975
3090

50
needs adjustment
Caustic Pump # B
Setting: 100
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 10 105 minutes of ACID
Corrections: _____
Dump pH: 7

Dump ph: 7
Notes: value 82 need adjustment.

Caustic Pump # B
Setting: ~~120~~ 100
Caustic Temp. 120
Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 3/17/07

Time: 1400

Run length: 214,000 - 8000 = 206 000 gallons

Service Water pressure: 88 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target														
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #				
1	SA	BW	15	60	50	57	66	68	66	110				
2	SA	Settle	3	60							3%= 1.0215			
3	SC	BW	10	59	75	87	97	101	97	97	5%=1.0417			
4	PA	BW	15	59	50	57	62	64	62	53	Hydrometer		Dilution Water	
5	PC	BW	15	59	120	140	153	158	153	36	Target	Actual	Target	Actual
6a	SA	5% NaOH	29	60	10				10	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				10	155	1.0417		950	
6c	SA to PA	SR	32	60	20				20	156		Total:	1590	1630
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				85	191/206	1.0084	1.008	1020	
6f	SC to PC	3.0% Acid	9	59	85				85	191/207	1.0184	1.018	1785	
6g	SC to PC	5.0% Acid	6	59	85				85	191/208	1.0317		2295	
6h	SC to PC	SR	8	59	85				85	191		Total:	2975	3110
6i	PC	FR	16	59	165				165	29				
7	PA	FR	22	60	165				165	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				165	82				
9	SC	FR	17	60	165				165	91	Caustic Pump # <u>5B</u>			
10	SA	FR	14/CT-3 < 100	60	165				165	103	Setting: <u>400</u>			
11	Rinse Recycle		13/CT-5 < 2.00	60	165				165	116	Caustic Temp. <u>120</u>			
12	Mandatory Recycle		10		165				165	116	Target = 49° C or 120° F			
	Service				150					122				

Neutralization Basin pH: 7.0

Corrections:

Dump ph: 7.0

Notes:

Caustic Pump # 7

Setting: 430

Caustic Temp. 120

Target = 49° C or 120° F

Regeneration Log (Concurrent Series)

Date: 5/26/07

Time: 1750

Run length: 214,000 - 16,000 = 198,000 gallons

Service Water pressure: 97 psi Temp. _____ degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>66</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>96</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>153</u>	36				
6a	SA	5% NaOH	29	60	10				<u>10</u>	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60	10				<u>10</u>	155	1.0417	<u>1.04</u>	950	
6c	SA to PA	SR	32	60	20				<u>20</u>	156	Total:		1590	<u>1190</u>
6d	PC	Settle	3	60	0									
6e	SC to PC	1.5% Acid	12	59	85				<u>85</u>	191/206	1.0084	<u>1.008</u>	1020	
6f	SC to PC	3.0% Acid	9	59	85				<u>85</u>	191/207	1.0184	<u>1.018</u>	1785	
6g	SC to PC	5.0% Acid	6	59	85				<u>85</u>	191/208	1.0317	<u>1.030</u>	2295	
6h	SC to PC	SR	8	59	85				<u>165</u>	191	Total:		2975	<u>3080</u>
6i	PC	FR	16	59	165				<u>115</u>	29				
7	PA	FR	22	60	165				<u>155</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60	165				<u>160</u>	82				
9	SC	FR	17	60	165				<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60	165				<u>165</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60	165				<u>120</u>	116				
12	Mandatory Recycle		10		165				<u>118</u>	116				
	Service				150					122				

Caustic Pump # 13

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9

Corrections: 1.5 min acid

Dump pH: 7.5

Notes: _____

Regeneration Log (Concurrent Series)

Date: 3-8-67

Time: 0024

Run length: 214,000 - 19,000 = 195,000 gallons

Service Water pressure: 89 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	65	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	55/62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0				0	
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				162	29
7	PA	FR	22	60	165				163	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				160	82
9	SC	FR	17	60	165				161	91
10	SA	FR	14/CT-3 < 100	60	165				152	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				155	116
12	Mandatory Recycle		10		165				138	116
	Service				150				151	122

3%= 1.0215
5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.240	950	
	Total:	1590	1610
1.0084	1.0080	1020	
1.0184	1.019	1785	
1.0317	1.034	2295	
	Total:	2975	3100

Caustic Pump # B

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 9.0
Corrections: 2 min acid
Dump pH: 6.0

Notes: _____

Caustic Pump # 7
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Monday

Time: 05:37 PM = 17 37

Service Water pressure: 100 psi Temp. 74 degrees F

Demineralizer
Check

1:37-1752 →
1752-1818 →
1753-1803 →
1803-1818 →
1818-1833 →
1818-1847 →
1848-1854 →

833 →

1905
1912
2005
2055
2124
2141
2200
2224

Caustic Pump # 5B
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Corrections:

Dump ph: 7.8

Notes:

Neutralization Basin pH: 9.4
Corrections: 2.5 minutes Acid
Dump pH: 6.8
Notes: STEP 8 not getting 165 GPM
chain valve wide open!

Regeneration Log (Concurrent Series)

Date: 3/2/07

Time: 0100

Run length: 214,000 - 2000 = 212000 gallons

Service Water pressure: 84 psi Temp. 74 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>60</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>90</u>	97
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53
5	PC	BW	15	59	120	140	153	158	<u>148</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>120</u>	116
12	Mandatory Recycle		10			165			<u>120</u>	116
	Service					150			<u>124</u>	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.040</u>	950	
Total:		1590	<u>1620</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.019</u>	1785	
1.0317	<u>1.030</u>	2295	
Total:		2975	<u>3080</u>

Caustic Pump # A

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections: 0

Dump ph: 7.0

Notes:

Regeneration Log (Concurrent Series)

Date: 2/26/07

Time: 2000

Run length: 214,000 - 7000 = 207,000 gallons

Service Water pressure: 86 psi Temp. 76 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #				
					60°	70°	80°	83°						
1	SA	BW	15	60	50	57	66	68	<u>60</u>	110				
2	SA	Settle	3	60										
3	SC	BW	10	59	75	87	97	101	<u>90</u>	97				
4	PA	BW	15	59	50	57	62	64	<u>60</u>	53				
5	PC	BW	15	59	120	140	153	158	<u>147</u>	36				
6a	SA	5% NaOH	29	60					<u>10</u>	155	1.0417		290	
6b	SA to PA	5% NaOH	66	60					<u>10</u>	155	1.0417	<u>1.041</u>	950	
6c	SA to PA	SR	32	60					<u>20</u>	156				
6d	PC	Settle	3	60					<u>0</u>					
6e	SC to PC	1.5% Acid	12	59					<u>85</u>	191/206	1.0084	<u>1.008</u>	1020	
6f	SC to PC	3.0% Acid	9	59					<u>85</u>	191/207	1.0184	<u>1.019</u>	1785	
6g	SC to PC	5.0% Acid	6	59					<u>85</u>	191/208	1.0317	<u>1.032</u>	2295	
6h	SC to PC	SR	8	59					<u>85</u>	191				
6i	PC	FR	16	59					<u>165</u>	29				
7	PA	FR	22	60					<u>165</u>	49				
8	PC to PA	Recycle	30/CT-1 < 20	60					<u>156</u>	82				
9	SC	FR	17	60					<u>165</u>	91				
10	SA	FR	14/CT-3 < 100	60					<u>165</u>	103				
11	Rinse Recycle		13/CT-5 < 2.00	60					<u>120</u>	116				
12	Mandatory Recycle		10						<u>120</u>	116				
	Service								<u>150</u>	122				

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
		290	
		950	
	Total:	1590	<u>1230</u>
	Total:	2975	<u>3030</u>

Caustic Pump # 15
Setting: 400
Caustic Temp. 120
Target = 49° C or 120° F

Neutralization Basin pH: 8.0

Corrections: _____

Dump pH: 8.0

Notes: _____

Regeneration Log (Concurrent Series)

Date: 02-21-07

Time: 20:13

Run length: 214,000 - 11,000 = 203,000 gallons

Service Water pressure: 95 psi Temp. 72 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve
FRR

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
2040-2055	1	SA	BW	15	60	50	57	66	68	110
2055-2110	2	SA	Settle	3 ⁵⁵	60					
2110-2125	3	SC	BW	10	59	75	87	97	101	97
2125-2140	4	PA	BW	15	59	50	57	62	64	53
2140-2155	5	PC	BW	15	59	120	140	153	158	36
2155-2210	6a	SA	5% NaOH	29	60		10		10	155
2210-2225	6b	SA to PA	5% NaOH	66	60		10		10	155
2225-2240	6c	SA to PA	SR	32	60		20		20	156
2240-2255	6d	PC	Settle	3	60		0		✓3	
2255-2310	6e	SC to PC	1.5% Acid	12	59		85		85	191/206
2310-2325	6f	SC to PC	3.0% Acid	9	59		85		85	191/207
2325-2340	6g	SC to PC	5.0% Acid	6	59		85		85	191/208
2340-2355	6h	SC to PC	SR	8	59		85		85	191
2355-2410	6i	PC	FR	16	59		165		165	29
2410-2425	7	PA	FR	22	60		165		165	49
2425-2440	8	PC to PA	FR Recycle	30/CT-1 < 20	60		165		155	(82)
2440-2455	9	SC	FR	25/CT-1 17	60		165		165	91
2455-2510	10	SA	FR R	14/CT-3 < 100.5	60		165		165	103
2510-2525	11	Rinse Recycle		13/CT-5 < 2.00	60		165		120	116
2525-2540	12	Mandatory Recycle					165		120	116
2540-2555		Service					150			122

3% = 1.0215
5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	1.0412	290	—
1.0417	1.0412	950	—
Total:		1590	1600
Total:		2975	3120

Probing (P) 10 min
P+1 min
P+2 min

Caustic Pump # B

Setting: 400

Caustic Temp. 120°F

Target = 49° C or 120° F

Neutralization Basin pH: 6.5

Corrections: 14/17

Dump pH: 6.5

Notes: * Chain Valve # PC Seized/Bound up. Would not budge.

ACW
GCW
C
G
Rinse Temp
Time
Time
Forward
Backward

Regeneration Log (Concurrent Series)

Date: 2/17/07

Time: 1400

Run length: 214,000 - 12800 = 202,000 gallons

Service Water pressure: 70 psi Temp. 70 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>60</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>89</u>	97
4	PA	BW	15	59	50	57	62	64	<u>58</u>	53
5	PC	BW	15	59	120	140	153	158	<u>140</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 16.5	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>120</u>	116
12	Mandatory Recycle		10			165			<u>120</u>	116
	Service					150			<u>144</u>	122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.04</u>	950	
Total:		1590	<u>1630</u>
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.018</u>	1785	
1.0317	<u>1.03</u>	2295	
Total:		2975	<u>3100</u>

Caustic Pump # A

Setting: 700

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 3.2

Corrections:

Dump ph: 6.8

Notes:

1600 - 12" 22" H2O 350000 CL

Regeneration Log (Concurrent Series)

Date: 1-30-07

Time: 1952

Run length: 214,000 - 11000 = 203,000 gallons

Service Water pressure: 93 psi Temp. 71 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>60</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>86</u>	97
4	PA	BW	15	59	50	57	62	64	<u>54</u>	53
5	PC	BW	15	59	120	140	153	158	<u>140</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>163</u>	29
7	PA	FR	22	60		165			<u>164</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>154</u>	82
9	SC	FR	17	60		165			<u>165</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			<u>120</u>	116
12	Mandatory Recycle		10			165			<u>120</u>	116
	Service					150				122

3%= 1.0215

5%= 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
		290	
1.0417	<u>1.041</u>	950	<u>980</u>
Total:		1590	<u>1640</u>
Total:		2975	<u>3100</u>

Caustic Pump # B

Setting: 400

Caustic Temp. 120°

Target = 49° C or 120° F

Neutralization Basin pH: 8.1

Corrections:

Dump ph: 8.1

Notes: _____

Regeneration Log (Concurrent Series)

Date: 1/27/07

Time: 0800

Run length: 214,000 - 24,000 = 190,000 gallons

Service Water pressure: 99 psi Temp. 77 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	58	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	88	97
4	PA	BW	15	59	50	57	62	64	57	53
5	PC	BW	15	59	120	140	153	158	140	36
6a	SA	5% NaOH	29	60	10				10	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				83	191/206
6f	SC to PC	3.0% Acid	9	59	85				83	191/207
6g	SC to PC	5.0% Acid	6	59	85				83	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				160	29
7	PA	FR	22	60	165				156	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				156	82
9	SC	FR	17	60	165				155	91
10	SA	FR	14/CT-3 < 100	60	165				160	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				160	116
12	Mandatory Recycle		10		165					116
	Service				150					122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
	Total:	1590	1640
1.0084	1.008	1020	
1.0184	1.019	1785	
1.0317	1.031	2295	
	Total:	2975	3040

Caustic Pump # 13

Setting: 400

Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 7.0

Corrections:

Dump ph: _____

Notes:

Notes: Timer is not working
ct-u meter is ~~bad~~



Regeneration Log (Concurrent Series)

Date: 2/8/07

Time: 6:00

Run length: 214,000 - 7090 = 207000 gallons

Service Water pressure: 100 psi Temp. 70 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

GPM Target										
Step	Vessel	Process	Time	Add.	60°	70°	80°	83°	Actual	RSV #
1	SA	BW	15	60	50	57	66	68	56	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	86	97
4	PA	BW	15	59	50	57	62	64	57	53
5	PC	BW	15	59	120	140	153	158	140	36
6a	SA	5% NaOH	29	60	10				16	155
6b	SA to PA	5% NaOH	66	60	10				10	155
6c	SA to PA	SR	32	60	20				20	156
6d	PC	Settle	3	60	0					
6e	SC to PC	1.5% Acid	12	59	85				85	191/206
6f	SC to PC	3.0% Acid	9	59	85				85	191/207
6g	SC to PC	5.0% Acid	6	59	85				85	191/208
6h	SC to PC	SR	8	59	85				85	191
6i	PC	FR	16	59	165				165	29
7	PA	FR	22	60	165				165	49
8	PC to PA	Recycle	30/CT-1 < 20	60	165				156	82
9	SC	FR	17	60	165				165	91
10	SA	FR	14/CT-3 < 100	60	165				170	103
11	Rinse Recycle		13/CT-5 < 2.00	60	165				170	116
12	Mandatory Recycle		10		165					116
	Service				150					122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417		950	
Total:		1590	1610
Total:		2975	3100

Caustic Pump # B

Setting: 100

Caustic Temp. 121

Target = 49° C or 120° F

Neutralization Basin pH: 9.0

Corrections: _____

Dump pH: _____

Notes: _____

Regeneration Log (Concurrent Series)

Date: 1/21/07

Time: 1900

Run length: 214,000 - 17000 = 197000 gallons

Service Water pressure: 93 psi Temp. 81 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>65</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>95</u>	97
4	PA	BW	15	59	50	57	62	64	<u>62</u>	53
5	PC	BW	15	59	120	140	153	158	<u>154</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>21</u>	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>84</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>84</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>167</u>	29
7	PA	FR	<u>28:22</u>	60		165			<u>166</u>	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			<u>160</u>	82
9	SC	FR	17	60		165			<u>160</u>	91
10	SA	FR	14/CT-3 < 100	60		165			<u>165</u>	103
11	Rinse Recycle	13/CT-5 < 2.00	60			165			<u>123</u>	116
12	Mandatory Recycle		10			165				116
	Service					150				122

3%= 1.0215

5%=1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	<u>1.043</u>	950	
	Total:	1590	
1.0084	<u>1.008</u>	1020	
1.0184	<u>1.019</u>	1785	
1.0317	<u>1.033</u>	2295	
	Total:	2975	

Caustic Pump # A

Setting: 400

Caustic Temp. 122

Target = 49° C or 120° F

Neutralization Basin pH: 7.1

Corrections: 0

Dump pH: 7.1

Notes:

Regeneration Log (Concurrent Series)

Date: 01/16/07
Time: 0945

Run length: 214,000 - 18000 = 196000 gallons
Service Water pressure: 94 psi Temp. 80 degrees F

PC=Primary Cation
PA=Primary Anion
SC=Secondary Cation
SA=Secondary Anion
BW=Back Wash
SR=Slow Rinse
FR=Fast Rinse
RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	66	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	97	97
4	PA	BW	15	59	50	57	62	64	62	53
5	PC	BW	15	59	120	140	153	158	153	36
6a	SA	5% NaOH	29	60		10			10	155
6b	SA to PA	5% NaOH	66	60		10			10	155
6c	SA to PA	SR	32	60		20			20	156
6d	PC	Settle	3	60		0				
6e	SC to PC	1.5% Acid	12	59		85			85	191/206
6f	SC to PC	3.0% Acid	9	59		85			85	191/207
6g	SC to PC	5.0% Acid	6	59		85			85	191/208
6h	SC to PC	SR	8	59		85			85	191
6i	PC	FR	16	59		165			165	29
7	PA	FR	22	60		165			165	49
8	PC to PA	Recycle	30/CT-1 < 20	60		165			161	82
9	SC	FR	17	60		165			165	91
10	SA	FR	14/CT-3 < 100	60		165			165	103
11	Rinse Recycle		13/CT-5 < 2.00	60		165			125	116
12	Mandatory Recycle		10			165			123	116
	Service					150			120	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417		290	
1.0417	1.0417	950	
Total:		1590	1640
Total:		2975	3060

Caustic Pump # SB
Setting: 400
Caustic Temp. 120°F
Target = 49° C or 120° F

Neutralization Basin pH: 4.0
Corrections: Caustic 2 min
Dump pH: 6.5

Notes:

1628

Regeneration Log (Concurrent Series)

Date: 1-4-07Time: 1314Run length: 214,000 - 18,000 = 196,000 gallonsService Water pressure: 93 psi Temp. 80 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
1	SA	BW	15	60	50	57	66	68	<u>64</u>	110
2	SA	Settle	3	60						
3	SC	BW	10	59	75	87	97	101	<u>94</u>	97
4	PA	BW	15	59	50	57	62	64	<u>42</u>	53
5	PC	BW	15	59	120	140	153	158	<u>142</u>	36
6a	SA	5% NaOH	29	60		10			<u>10</u>	155
6b	SA to PA	5% NaOH	66	60		10			<u>10</u>	155
6c	SA to PA	SR	32	60		20			<u>20</u>	156
6d	PC	Settle	3	60		0			<u>0</u>	
6e	SC to PC	1.5% Acid	12	59		85			<u>85</u>	191/206
6f	SC to PC	3.0% Acid	9	59		85			<u>85</u>	191/207
6g	SC to PC	5.0% Acid	6	59		85			<u>85</u>	191/208
6h	SC to PC	SR	8	59		85			<u>85</u>	191
6i	PC	FR	16	59		165			<u>165</u>	29
7	PA	FR	22	60		165			<u>165</u>	49
8	PC to PA	Recycle	30/CT-1 <20	60		165			<u>165</u>	82
9	SC	FR	17	60		165			<u>164</u>	91
10	SA	FR	14/CT-3 <100	60		165			<u>164</u>	103
11	Rinse Recycle	13/CT-5 <2.00	60			165			<u>125</u>	116
12	Mandatory Recycle		10			165			<u>125</u>	116
	Service					150			<u>155</u>	122

3% = 1.0215

5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	<u>1.0439</u>	290	
1.0417	<u>1.0430</u>	950	
	Total:	1590	<u>1620</u>
1.0084	<u>1.0280</u>	1020	
1.0184	<u>1.0180</u>	1785	
1.0317	<u>1.0300</u>	2295	
	Total:	2975	<u>3120</u>

Caustic Pump # BSetting: 400Caustic Temp. 120

Target = 49° C or 120° F

Neutralization Basin pH: 10.2Corrections: 5 min acidDump pH: 8.3Notes: Nils + M. M. at controls

① ②

Regeneration Log (Concurrent Series)

Date: 1/3/07
 Time: 1243
 Run length: 214,000 - 12000 = 202,000 gallons
 Service Water pressure: 94 psi Temp. 70 degrees F

PC=Primary Cation
 PA=Primary Anion
 SC=Secondary Cation
 SA=Secondary Anion
 BW=Back Wash
 SR=Slow Rinse
 FR=Fast Rinse
 RSV=Rate Set Valve

Step	Vessel	Process	Time	Add.	GPM Target				Actual	RSV #
					60°	70°	80°	83°		
X 1	SA	BW	15	60	50	57	66	68	56	110
X 2	SA	Settle	3	60						
X 3	SC	BW	10	59	75	87	97	101	86	97
X 4	PA	BW	15	59	50	57	62	64	57	53
X 5	PC	BW	15	59	120	140	153	158	140	36
X 6a	SA	5% NaOH	29	60		10			10	155
X 6b	SA to PA	5% NaOH	66	60		10			10	155
X 6c	SA to PA	SR	32	60		20			20	156
X 6d	PC	Settle	3	60		0				
X 6e	SC to PC	1.5% Acid	12	59		85			85	191/206
X 6f	SC to PC	3.0% Acid	9	59		85			85	191/207
X 6g	SC to PC	5.0% Acid	6	59		85			85	191/208
X 6h	SC to PC	SR	8	59		85			85	191
X 6i	PC	FR	16	59		165			165	29
X 7	PA	FR	22	60		165			164	49
X 8	PC to PA	Recycle 30/CT-1 < 20		60		165			158	82
X 9	SC	FR	17	60		165			165	91
X 10	SA	FR 14/CT-3 < 100-15		60		165			165	103
X 11	Rinse Recycle			60		165			119	116
X 12	Mandatory Recycle		10			165			120	116
	Service					150				122

3% = 1.0215
 5% = 1.0417

Hydrometer		Dilution Water	
Target	Actual	Target	Actual
1.0417	—	290	
1.0417	1.040	950	
Total:		1590	1640
Total:		2975	3100

Caustic Pump # A
 Setting: _____
 Caustic Temp. _____
 Target = 49° C or 120° F

Neutralization Basin pH: 4.0

Corrections: _____

Dump pH: 7.5

Notes: CAUSTIC 3 MIN

1358
 1359
 1409
 1424
 1425
 1454
 1600
 1450
 1455
 1505
 1510
 1518
 1633
 1700
 1727
 1744
 1758