

Appendix I

NPDES Permit No. FL0001503



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

NOTICE OF PERMIT

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

In the Matter of an
Application for Permit by:

Florida Power & Light Company (FP&L)
Mr. Dwayne Harper
Plant General Manager
4300 SW 42nd Avenue
Fort Lauderdale, FL 33314

PA File No. FL0001503-003-IW1S
Broward County
Lauderdale Power Plant
NPDES Permit No. FL0001503

Enclosed is Permit Number FL0001503 to Florida Power & Light Company (FP&L), 700 Universe Blvd., Juno Beach, Florida, 33408 to operate wastewater treatment and effluent disposal facilities for Units 4 and 5 of the Lauderdale Power Plant located in Broward County, Florida, issued under Section 403.0885, Florida Statutes and DEP Rule 62-620, Florida Administrative Code.

Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any.

Any party to this order (permit) has the right to seek judicial review of the permit under Section 120.68, Florida Statutes, by the filing of a Notice of Appeal under Rules 9.110 and 9.190, Florida Rules of Appellate Procedure, with the Clerk of the Department of Environmental Protection, Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida 32399-3000 and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate district court of appeal. The notice of appeal must be filed within thirty days after this notice is filed with the clerk of the Department.

Executed in Tallahassee, Florida.

DEPARTMENT OF
ENVIRONMENTAL PROTECTION

JUN 24 2010

SITING COORDINATION

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION

Janet G. Llewellyn

Director

Division of Water Resource Management

Florida Power & Light Company
Lauderdale Plant

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF PERMIT and all copies were mailed before the close of business on 06-23-10 to the listed persons.

[Clerk Stamp]

FILING AND ACKNOWLEDGMENT

FILED, on this date, under Section 120.52 (9), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

A. Shields 06-23-10
(Clerk) (Date)

Copies furnished to:

Copies furnished by certified mail to:

Chief, NPDES Permitting Section, EPA Region 4, Atlanta, GA
Chairman, Board of Broward County Commissioners
Ron Mezich, FWC Tallahassee
U.S. Fish & Wildlife Service

Copies furnished by First Class mail to:

Andy Flajole, FP&L

Copies furnished by intradepartmental mail to:

Mike Halpin, P.E., DEP Tallahassee
Justin Wolfe, Esq., DEP Tallahassee
Tim Powel, P.E., DEP West Palm Beach
Michael Hambor, DEP West Palm Beach



Florida Department of Environmental Protection

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Michael W. Sole
Secretary

STATE OF FLORIDA INDUSTRIAL WASTEWATER FACILITY PERMIT

PERMITTEE:

Florida Power & Light Company
700 Universe Boulevard
Juno Beach, FL 33408

PERMIT NUMBER: FL0001503-003 (Major)

FILE NUMBER: FL0001503-003-IW1S

ISSUANCE DATE: June 25, 2010

EXPIRATION DATE: June 24, 2015

RESPONSIBLE OFFICIAL:

Mr. Timothy Panoff
4300 SW 42nd Avenue
Fort Lauderdale, FL 33314

FACILITY:

FPL - Lauderdale Power Plant
4300 SW 42nd Avenue
Fort Lauderdale, FL 33314
Broward County
Latitude: 26°4' 7.38" N Longitude: 80°11' 56.76" W

This permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and applicable rules of the Florida Administrative Code (F.A.C.) and constitutes authorization to discharge to waters of the state under the National Pollutant Discharge Elimination System. This permit does not constitute authorization to discharge wastewater other than as expressly stated in this permit. The above named permittee is hereby authorized to operate the facilities in accordance with the documents attached hereto and specifically described as follows:

FACILITY DESCRIPTION:

The facility is an electric generating plant with a total nameplate rating of 1,874 megawatts (MW). The existing facility consists of two combined-cycle generating units (Units 4 and 5), two banks of twelve simple-cycle gas turbine units, and eight fuel storage tanks. Each combined-cycle unit consists of two combustion turbines (CT) which each exhaust through a separate heat recovery steam generator (HRSG). Each HRSG converts the heat from the CT exhaust into steam. The steam produced from the two HRSG units drives one single-reheat turbine generator. Each combined-cycle unit has a net summer continuous capability of 430 megawatts (MW). Each bank of simple-cycle gas turbines has a net capability of 504 MW.

Units 4 and 5 have a condenser once-through cooling water (OTCW) system and an auxiliary equipment cooling water (AECW) system that uses water from the Dania Cutoff Canal, a coastal marine waterbody. Plant intake screens consist of bar (coarse) screens, traveling screens and a floating trash boom. Screen wash water and debris removed from the screens flow together through intake structure troughs which discharge into a trash bucket that traps the debris and allows the wash water to return to the Dania Cutoff Canal. The open cooling water circulating pumps discharge into a common header which routes the water through three closed cooling water heat exchangers. The cooling water is then released to the discharge canal via two (one per each unit) 24-inch reinforced plastic discharge pipes. The plant's discharge canal discharges into an on-site once-through cooling pond. After passing through the cooling pond the water passes under State Road 84 and discharges via Outfall D-001 into the South Fork of the New River (Class III marine).

WASTEWATER TREATMENT:

Boiler blowdown, metal cleaning wastes, and pretreated oily waste streams are treated in the plant's wastewater treatment system prior to discharge to the discharge canal. Additional wastewater treatment includes chlorination with chlorine gas, sodium hypochlorite, or similar chlorination compounds for once-through cooling water and auxiliary-equipment cooling

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

water; pH-adjustment (if necessary) of reverse osmosis reject-water, and neutralization of demineralizer-regeneration water. These wastewaters are discharged to the discharge canal, which in turn discharges into an on-site, once-through cooling pond. The once-through cooling pond discharges from Outfall D-001 through a culvert to the South Fork of New River, a Class III Marine surface water body. Additional permitted surface water discharges include stormwater through Outfall D-00B1 and intake-screen wastewater and strainer backwash water from Outfall D-009. Outfalls D-00B1 and D-009 discharge into the Dania Cutoff Canal.

REUSE OR DISPOSAL:

Surface Water Discharge D-001: An existing 332 MGD annual average daily flow (AADF) discharge to the South Fork of New River (WBID 3277A), Class III Marine waters, from **Outfall D-001**, via a culvert at the downstream end of the once-through cooling pond system. The point of discharge is located approximately at latitude 26° 05' 09" N, longitude 80° 10' 55" W.

Surface Water Discharge D-00B1: An existing storm water discharge to Dania Cutoff Canal (WBID 3277E), Class III Marine Waters. The point of discharge is located approximately at latitude 26° 4' 5" N, longitude 80° 11' 44" W.

Surface Water Discharge D-009: An existing intake screen washwater and strainer backwash water discharge from **Outfall D-009** to Dania Cutoff Canal (WBID 3277E), Class III Marine waters. The point of discharge is located approximately at latitude 26° 04' 05" N, longitude 80° 11' 58" W.

Internal Outfall I-012: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-013: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-015: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-1B2: An existing permitted stormwater discharge to the discharge canal to the cooling pond.

Internal Outfall I-01E: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-11A: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-11B: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-16A: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-1B3: An existing permitted stormwater discharge to the discharge canal to the cooling pond

Internal Outfall I-16B: An existing permitted discharge to the discharge canal to the cooling pond.

Internal Outfall I-01D: An existing permitted discharge to the discharge canal to the cooling pond.

IN ACCORDANCE WITH: The limitations, monitoring requirements and other conditions set forth in this Cover Sheet and Part I through Part IX on pages 1 through 29 of this permit.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

I. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Surface Water Discharges

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Cooling Pond Discharge from Outfall D-001 to South Fork New River. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max Max	Report Report 380	Daily Maximum Monthly Average Annual Average	Daily	Calculated	EFF-3	
Temperature, Water	Deg F	Max Max	101.1 99.0	Daily Maximum Monthly Average	Continuous	Recorder	EFF-3	June -Sept
		Max Max	99.0 96.0	Daily Maximum Monthly Average				October -May
Solids, Total Dissolved (TDS)	mg/L	Max Max	Report Report	Daily Maximum Monthly Average	Bi-monthly	Grab	EFF-3	
pH	s.u.	Min Max	6.5 8.5	Daily Minimum Daily Maximum	Bi-monthly	Grab	EFF-3	
Chronic Whole Effluent Toxicity, 7-Day IC25 (Mysidopsis bahia)	percent	Min	100	Single Sample	Quarterly	Grab	EFF-3	
Chronic Whole Effluent Toxicity, 7-Day IC25 (Menidia beryllina)	percent	Min	100	Single Sample	Quarterly	Grab	EFF-3	

2. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.A.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-3	The point of discharge from the cooling pond prior to entering the South Fork New River.
INT-7	Facility intake screens

3. The permittee shall comply with the following requirements to evaluate chronic whole effluent toxicity of the discharge from outfall D-001.
 - a. Effluent Limitation
 - (1) In any routine or additional follow-up test for chronic whole effluent toxicity, the 25 percent inhibition concentration (IC25) shall not be less than 100% effluent. [Rules 62-302.530(61) and 62-4.241(1)(b), F.A.C.]
 - (2) For acute whole effluent toxicity, the 96-hour LC50 shall not be less than 100% effluent in any test. Acute toxicity testing is not required except as provided in 3.g.(4). [Rule 62-302.500(1)(a)4. and 62-4.241(1)(a), F.A.C.]

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

b. Monitoring Frequency

- (1) Routine toxicity tests shall be conducted once every three months, the first starting within 60 days of the issuance date of this permit and lasting for the duration of this permit.
- (2) Upon completion of four consecutive, valid routine tests that demonstrate compliance with the effluent limitation in 3.a.(1) above, the permittee may submit a written request to the Department for a reduction in monitoring frequency to once every six months. The request shall include a summary of the data and the complete bioassay laboratory reports for each test used to demonstrate compliance. The Department shall act on the request within 45 days of receipt. Reductions in monitoring shall only become effective upon the Department's written confirmation that the facility has completed four consecutive valid routine tests that demonstrate compliance with the effluent limitation in 3.a.(1) above.
- (3) If a test within the sequence of the four is deemed invalid based on the acceptance criteria in EPA-821-R-02-014, but is replaced by a repeat valid test initiated within 21 days after the last day of the invalid test, the invalid test will not be counted against the requirement for four consecutive valid tests for the purpose of evaluating the reduction of monitoring frequency.

c. Sampling Requirements

- (1) For each routine test or additional follow-up test conducted, a total of three grab samples of final effluent shall be collected and used in accordance with the sampling protocol discussed in EPA-821-R-02-014, Section 8.
- (2) The first sample shall be used to initiate the test. The remaining two samples shall be collected according to the protocol and used as renewal solutions on Day 3 (48 hours) and Day 5 (96 hours) of the test.
- (3) Samples for routine and additional follow-up tests shall not be collected on the same day.

d. Test Requirements

- (1) Routine Tests: All routine tests shall be conducted using a control (0% effluent) and a minimum of five test dilutions: **100%, 50%, 25%, 12.5%, and 6.25%** final effluent.
- (2) The permittee shall conduct 7-day survival and growth chronic toxicity tests with a mysid shrimp, **Americamysis (Mysidopsis) bahia**, Survival, Growth and Fecundity Test, and an inland silverside, **Menidia beryllina**, Larval Survival and Growth Test, concurrently.
- (3) All test species, procedures and quality assurance criteria used shall be in accordance with Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Saltwater Organisms, 4th ed., EPA-821-R-02-014. Any deviation of the bioassay procedures outlined herein shall be submitted in writing to the Department for review and approval prior to use. In the event the above method is revised, the permittee shall conduct chronic toxicity testing in accordance with the revised method.
- (4) The control water and dilution water used shall be artificial sea salts as described in EPA-821-R-02-014, Section 7.2. The test salinity shall be determined as follows:
 - (a) For the **Americamysis bahia** bioassays, the effluent shall be adjusted to a salinity of 20 parts per thousand (ppt). The salinity of the control/dilution water (0% effluent) shall be 20 ppt. If the salinity of the effluent is greater than 20 ppt, no salinity adjustment shall be made to the effluent and the test shall be run at the effluent salinity. The salinity of the control/dilution water shall match the salinity of the effluent.
 - (b) For the **Menidia beryllina** bioassays, the effluent shall be adjusted to 5 ppt. The salinity of the control/dilution water (0% effluent) shall be 5 ppt. If the salinity of the effluent is greater than 5 ppt, no salinity adjustment shall be made to the effluent and the test shall be run at the effluent salinity. The salinity of the control/dilution water shall match the salinity of the effluent.
 - (c) If the salinity of the effluent requires adjustment, a salinity adjustment control should be prepared and included with each bioassay. The salinity adjustment control is intended to identify toxicity resulting from adjusting the effluent salinity with artificial sea salts. To prepare the salinity adjustment control, dilute the control/dilution water to the salinity of the effluent and adjust the salinity of the salinity adjustment control at the same time and to the same salinity that the salinity of the effluent is adjusted using the same artificial sea salts.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

e. Quality Assurance Requirements

- (1) A standard reference toxicant (SRT) quality assurance (QA) chronic toxicity test shall be conducted with each species used in the required toxicity tests either concurrently or initiated no more than 30 days before the date of each routine or additional follow-up test conducted. Additionally, the SRT test must be conducted concurrently if the test organisms are obtained from outside the test laboratory unless the test organism supplier provides control chart data from at least the last five monthly chronic toxicity tests using the same reference toxicant and test conditions. If the organism supplier provides the required SRT data, the organism supplier's SRT data and the test laboratory's monthly SRT-QA data shall be included in the reports for each companion routine or additional follow-up test required.
- (2) If the mortality in the control (0% effluent) exceeds 20% for either species in any test or any test does not meet "test acceptability criteria", the test for that species (including the control) shall be invalidated and the test repeated. Test acceptability criteria for each species are defined in EPA-821-R-02-014, Section 14.12 (*Americamysis bahia*) and Section 13.12 (*Menidia beryllina*). The repeat test shall begin within 21 days after the last day of the invalid test.
- (3) If 100% mortality occurs in all effluent concentrations prior to the end of any test and the control mortality is less than 20% at that time, the test (including the control) shall be terminated with the conclusion that the test fails and constitutes non-compliance.
- (4) Additional follow-up tests shall be evaluated for acceptability based on the observed dose-response relationship as required by EPA-821-R-02-014, Section 10.2.6., and the evaluation shall be included with the bioassay laboratory reports.

f. Reporting Requirements

- (1) Results from all required tests shall be reported on the Discharge Monitoring Report (DMR) as follows:
 - (a) Routine and Additional Follow-up Test Results: The calculated IC25 for each test species shall be entered on the DMR.
- (2) A bioassay laboratory report for each routine test shall be prepared according to EPA-821-R-02-014, Section 10, Report Preparation and Test Review, and mailed to the Department at the address below within 30 days after the last day of the test.
- (3) For additional follow-up tests, a single bioassay laboratory report shall be prepared according to EPA-821-R-02-014, Section 10, and mailed within 30 days after the last day of the second valid additional follow-up test.
- (4) Data for invalid tests shall be included in the bioassay laboratory report for the repeat test.
- (5) The same bioassay data shall not be reported as the results of more than one test.
- (6) All bioassay laboratory reports shall be sent to:
Florida Department of Environmental Protection
Tallahassee Office
2600 Blair Stone Road, M.S. 3545
Tallahassee, Florida 32399-2400

g. Test Failures

- (1) A test fails when the test results do not meet the limits in 3.a.(1).
- (2) Additional Follow-up Tests:
 - (a) If a routine test does not meet the chronic toxicity limitation in 3.a.(1) above, the permittee shall notify the Department at the address above within 21 days after the last day of the failed routine test and conduct two additional follow-up tests according to 3.d. on each species that failed the test on each species that failed the test in accordance with 3.d.
 - (b) The first test shall be initiated within 28 days after the last day of the failed routine test. The remaining additional follow-up tests shall be conducted weekly thereafter until a total of two valid additional follow-up tests are completed.
 - (c) The first additional follow-up test shall be conducted using a control (0% effluent) and a minimum of five dilutions: 100%, 50%, 25%, 12.5%, and 6.25% effluent. The permittee may modify the dilution series in the second additional follow-up test to more accurately bracket the toxicity such that at least two dilutions above and two dilutions below the target concentration and a control (0% effluent) are run. All test results shall be statistically analyzed according to the Appendices in EPA-821-R-02-014.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

- (3) In the event of three valid test failures (whether routine or additional follow-up tests) within a 12-month period, the permittee shall notify the Department within 21 days after the last day of the third test failure.
 - (a) The permittee shall submit a plan for correction of the effluent toxicity within 60 days after the last day of the third test failure.
 - (b) The Department shall review and approve the plan before initiation.
 - (c) The plan shall be initiated within 30 days following the Department's written approval of the plan.
 - (d) Progress reports shall be submitted quarterly to the Department at the address above.
 - (e) During the implementation of the plan, the permittee shall conduct quarterly routine whole effluent toxicity tests in accordance with 3.d. Additional follow-up tests are not required while the plan is in progress. Following completion or termination of the plan, the frequency of monitoring for routine and additional follow-up tests shall return to the schedule established in 3.b.(1). If a routine test is invalid according to the acceptance criteria in EPA-821-R-02-014, a repeat test shall be initiated within 21 days after the last day of the invalid routine test.
 - (f) Upon completion of four consecutive, valid routine tests that demonstrate compliance with the effluent limitation in 3.a.(1) above, the permittee may submit a written request to the Department to terminate the plan. The plan shall be terminated upon written verification by the Department that the facility has passed at least four consecutive valid routine whole effluent toxicity tests. If a test within the sequence of the four is deemed invalid, but is replaced by a repeat valid test initiated within 21 days after the last day of the invalid test, the invalid test will not be counted against the requirement for four consecutive valid tests for the purpose of terminating the plan.
- (4) If chronic toxicity test results indicate greater than 50% mortality within 96 hours in an effluent concentration equal to or less than the effluent concentration specified as the acute toxicity limit in 3.a.(2), the Department may revise this permit to require acute definitive whole effluent toxicity testing.
- (5) The additional follow-up testing and the plan do not preclude the Department taking enforcement action for acute or chronic whole effluent toxicity permit limit violations.

[62-4.241, 62-620.620(3)]

4. The permittee shall maintain current intake traveling screen practices so as to assure that the screens are cycled at least twice during each 24 hours of continuous operation unless precluded by repair or maintenance requirements. The intake through-screen velocity shall be maintained at current levels such that existing maximum velocity is not exceeded.
5. The permittee shall develop a plan in accordance with the schedule in Condition VI.4 to help return live fish, shellfish, and other aquatic organisms collected or trapped on the intake screens to their natural habitat. All other material shall be removed from the intake screens and disposed of in accordance with all existing Federal, State, and/or local laws and regulations that apply to waste disposal. Such material shall not be returned to the receiving waters.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

6. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge stormwater from Outfall D-0B1 to Dania Cut-Off Canal. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max	Report	Daily Maximum	Weekly, when discharging	Calculated	EFF-8	See Condition I.A.9
Solids, Total Suspended	mg/L	Max	50.0	Daily Maximum	Weekly, when discharging	Grab	EFF-8	See Condition I.A.9
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Weekly, when discharging	Grab	EFF-8	

7. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.A.6 and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-8	Stormwater runoff discharge from Outfall D-00B1 prior to entering the Dania Cutoff Canal.

8. Discharge of intake screen washwater and strainer backwash via Outfall D-009 to the Dania Cutoff Canal is permitted without limitation or monitoring requirements, except that there shall be no discharge of floating solids or visible foam in other than trace amount and no discharge of a visible oil sheen at any time.
9. Monitoring is not required if a discharge results from rainfall in excess of the 10-year, 24-hour rainfall event.
10. The discharge shall not contain components that settle to form putrescent deposits or float as debris, scum, oil, or other matter. [62-302.500(1)(a)]

B. Internal Outfalls

1. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Demineralizer Regeneration Wastewater from I-012 to the discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition .C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitori ng Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Per batch of process	Calculated	EFF-12	
Oil and Grease	mg/L	Max Max	15.0 20.0	Monthly Average Daily Maximum	Weekly, when discharging	Grab	EFF-12	
Solids, Total Suspended	mg/L	Max Max	30 100	Monthly Average Daily Maximum	Weekly, when discharging	Grab	EFF-12	
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Weekly, when discharging	Grab	EFF-12	

PERMITTEE: Florida Power & Light
 FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
 ISSUANCE DATE: June 25, 2010
 EXPIRATION DATE: June 24, 2015

2. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.1. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-12	Demineralizer regeneration wastewater discharge prior to entering the discharge canal.

3. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Wastewater treatment system effluent from I-013 to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Recording Flow Meter with Totalizer	EFF-13	
Oil and Grease	mg/L	Max Max	15 20	Monthly Average Daily Maximum	Bi-monthly	Grab	EFF-13	
Solids, Total Suspended	mg/L	Max Max	30.0 100.0	Monthly Average Daily Maximum	Bi-monthly	Grab	EFF-13	
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Monthly	Grab	EFF-13	

4. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.3. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-13	Wastewater treatment system effluent discharge of low volume waste (not including metal cleaning waste) prior to entering the discharge canal.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

5. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge metal cleaning wastewater¹ from I-015 to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow, Total Volume	Mgal	Max Max	Report Report	Daily Maximum Monthly Total	Continuous, when discharging	Recording Flow Meter with Totalizer ²	EFF-14	See Condition I.B.7
Copper, Total Recoverable	mg/L	Max	1.0	Daily Maximum	Per batch of process ³	24-hr Composite ⁴	EFF-14	See Condition I.B.8
Iron, Total Recoverable	mg/L	Max	1.0	Daily Maximum	Per batch of process ³	24-hr Composite ⁴	EFF-14	See Condition I.B.8
Oil and Grease	mg/L	Max	15.0	Daily Maximum	Per batch of process ³	24-hr Composite ⁴	EFF-14	
Solids, Total Suspended	mg/L	Max	30	Daily Maximum	Per batch of process ³	24-hr Composite ⁴	EFF-14	

6. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.5. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-14	Wastewater treatment system effluent discharge of metal cleaning waste prior to entering the discharge canal.

7. The volume of metal cleaning waste generated during boiler chemical cleaning shall also be reported.
8. For wastes resulting from the evaporation of spent boiler chemical cleaning wastes, the quantities of total iron and total copper shall not exceed the quantity determined by multiplying the volume of spent boiler chemical cleaning waste evaporated times 1.0 mg/l.

¹ Metal cleaning waste may be batch treated separately from other waste-streams and discharged from the wastewater treatment system to the discharge canal through the same Outfall (I-13) from which treated low volume waste is discharged. However, the discharge outfall for treated metal cleaning waste shall be designated as Outfall I-015 for the purpose of identifying the discharge and establishing effluent limitation and monitoring requirements.

² Flow meters shall be calibrated at least once a year in accordance with the manufacturer's recommendations. Calibration records shall be maintained on-site in accordance with Section V.2 of this permit.

³ or once per day, whichever is more frequent.

⁴ Shall be defined as a composite of samples taken at the beginning, middle, and end of discharge period.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

9. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge stormwater from I-1B2 and I-1B3 to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

Effluent Limitations					Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max	Report	Daily Maximum	Weekly, when discharging	Calculated	EFF-9 EFF-10	See condition I.B.11
Solids, Total Suspended	mg/L	Max	50.0	Daily Maximum	Weekly, when discharging	Grab	EFF-9 EFF-10	See condition I.B.11
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Weekly, when discharging	Grab	EFF-9 EFF-10	

10. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.9. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-9	Stormwater runoff discharge from Outfalls I-01B2 prior to entering the onsite canal.
EFF-10	Stormwater runoff discharge from Outfalls I-01B3 prior to entering the onsite canal.

11. Monitoring is not required if a discharge results from rainfall in excess of the 10-year, 24-hour rainfall event.

12. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge reverse osmosis reject water from I-01E to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

Effluent Limitations					Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Weekly	Calculated	EFF-11	
Oil and Grease	mg/L	Max Max	15.0 20.0	Monthly Average Daily Maximum	Bi-monthly; every 2 months	Grab	EFF-11	
Solids, Total Suspended	mg/L	Max Max	30.0 100.0	Annual Average Daily Maximum	Weekly	8-hour flow proportioned composite	EFF-11	

13. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.12. and as described below:

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

Monitoring Site Number	Description of Monitoring Site
EFF-11	Reverse Osmosis reject wastewater prior to entering the discharge canal.

14. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Unit 4 once-through cooling water and auxiliary equipment cooling water from I-11A to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/ Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Calculated	INT-1	
Temperature, Water	Deg F	Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Meter	EFF-1	See Condition I.B.17
		Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Meter	INT-1	See Condition I.B.17
Temperature Rise (ΔT), Water	Deg F	Max Max	13.2 Report	Monthly Average Daily Maximum	Daily	Calculated	EFF-1	
Oxidants, Total Residual	mg/L	Max Max	0.20 0.20	Daily Maximum Monthly Average	Weekly	Multiple Grab	EFF-1	See Condition I.B.16
Chlorination Duration (AECW)	min	Max	1440	Daily Maximum	Daily	Calculated	INT-3	
Chlorination Duration (OTCW)	min	Max	120	Daily Maximum	Daily	Calculated	INT-5	
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Weekly	Grab	EFF-4	See Condition I.B.18

15. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.14 and as described below:

Monitoring Site Number	Description of Monitoring Site
INT-1	OTCW intake for Unit 4
EFF-1	OTCW discharge for Units 4.
INT-3	Point of chlorine addition for AECW for Unit 4
INT-5	Point of chlorine addition for OTCW for Units 4.
EFF-4	A location after combination of once-through cooling water from Units 4 and/or 5 with Outfalls I-16, I-01E and/or I-012, as appropriate but prior to entering the cooling pond or mixing with any other waste stream.

16. Total Residual Oxidants (TRO) means the value obtained using the amperometric titration method for total residual chlorine or the Hach model 19300 or equivalent). Testing for TRO by titration shall be conducted

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

according to either the low-level amperometric method, or the DPD calorimetric method as specified in section 4500-CI E. or 4500 CI G., respectively, Standard Methods for the examination of Water and Waste water, 18th Edition (or most current edition).

The permittee shall collect samples when chlorine is in use. TRO monitoring requirements for either Unit 4 or 5 are not applicable for any week in which chlorine is not added to that unit. No more than one unit shall discharge total residual oxidant at any one time.

Multiple grabs for TRO shall be defined as once per five minutes during TRO discharge periods of 30 minutes or less and once per 15 minutes for periods exceeding 30 minutes with no less than four analyses during the period of TRO discharge (sampling shall be continued until the end of the TRO discharge).

17. The permittee shall maintain and operate continuous recording temperature devices at the intake, the condenser outlet, and point of discharge from the cooling pond to monitor compliance with thermal limits.
18. The pH shall be monitored once per day during periods when all OTCW and AECW pumps are off-line and wastewaters from Outfalls I-16, I-01E and/or I-012 are being discharged.
19. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Unit 5 once-through cooling water and auxiliary equipment cooling water from I-11B to Discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Calculated	INT-2	
Temperature (F), Water	Deg F	Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Meter	EFF-2	See Condition I.B.17
Temperature (F), Water	Deg F	Max Max	Report Report	Daily Maximum Monthly Average	Continuous	Meter	INT-2	See Condition I.B.17
Temp. Diff. between Intake and Discharge	Deg F	Max Max	13.2 Report	Monthly Average Daily Maximum	Daily	Calculated	EFF-2	
Oxidants, Total Residual	mg/L	Max	0.20 0.20	Daily Maximum Monthly Average	Weekly	Multiple Grab	EFF-2	See Condition I.B.16
Chlorination Duration (AECW)	min	Max	1440	Daily Maximum	Daily	Meter	INT-4	
Chlorination Duration (OTCW)	min	Max	120	Daily Maximum	Daily	Meter	INT-6	
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Weekly	Grab	EFF-4	See Condition I.B.18

20. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.19. and as described below:

Monitoring Site Number	Description of Monitoring Site
INT-2	OTCW intake for Unit 5.
EFF-2	OTCW for Unit 5

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

INT-4	Point of chlorine addition for AECW for Unit 5
INT-6	Point of chlorine addition for OTCW for Unit 5
EFF-4	A location after combination of once-through cooling water from Units 4 and/or 5 with Outfalls I-16, I-01E and/or I-012, as appropriate but prior to entering the cooling pond or mixing with any other waste stream.

21. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Unit 4 Heat Recovery Steam Generator (HRSG) boiler blowdown from I-16A to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Monthly	Calculated	EFF-5	
Oil and Grease	mg/L	Max Max	15.0 20.0	Monthly Average Daily Maximum	Monthly	Grab	EFF-5	
Solids, Total Suspended	mg/L	Max Max	30.0 100.0	Monthly Average Daily Maximum	Monthly	8-hr FPC	EFF-5	

22. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.21. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-5	HRSG boiler blowdown discharge from Unit 4 but prior to entering the onsite canal or mixing with any other waste stream.

23. Discharge of Hydrazine in Units 4 and 5 HRSG blowdown and in plant lay-up water is authorized without limitation or monitoring requirements.

24. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge Unit 5 Heat Recovery Steam Generator (HRSG) boiler blowdown from I-16B to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max Max	Report Report	Daily Maximum Monthly Average	Monthly	Calculated	EFF-6	
Oil and Grease	mg/L	Max Max	15.0 20.0	Monthly Average Daily Maximum	Monthly	Grab	EFF-6	
Solids, Total Suspended	mg/L	Max Max	30.0 100.0	Monthly Average Daily Maximum	Monthly	8-hr FPC	EFF-6	

25. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.24. and as described below:

PERMITTEE: Florida Power & Light
 FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
 ISSUANCE DATE: June 25, 2010
 EXPIRATION DATE: June 24, 2015

Monitoring Site Number	Description of Monitoring Site
EFF-6	HRSG boiler blowdown discharge from Unit 5 but prior to entering the onsite canal or mixing with any other waste stream.

26. During the period beginning on the issuance date and lasting through the expiration date of this permit, the permittee is authorized to discharge construction dewatering from I-01D to discharge canal to cooling pond. Such discharge shall be limited and monitored by the permittee as specified below and reported in accordance with Permit Condition I.C.3.:

			Effluent Limitations		Monitoring Requirements			
Parameter	Units	Max/Min	Limit	Statistical Basis	Frequency of Analysis	Sample Type	Monitoring Site Number	Notes
Flow	MGD	Max	Report	Daily Maximum	Daily, when discharging	Calculated	EFF-7	
Oil and Grease	mg/L	Max	Report	Daily Maximum	Monthly, when discharging	Grab	EFF-7	
Solids, Total Suspended	mg/L	Max	50.0	Daily Maximum	Monthly, when discharging	Grab	EFF-7	
Turbidity	NTU	Max	Report	Daily Maximum	Monthly, when discharging	Grab	EFF-7	
pH	s.u.	Min Max	6.0 9.0	Daily Minimum Daily Maximum	Monthly, when discharging	Grab	EFF-7	

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

27. Effluent samples shall be taken at the monitoring site locations listed in Permit Condition I.B.26. and as described below:

Monitoring Site Number	Description of Monitoring Site
EFF-7	Construction related dewatering prior to entering the discharge canal or alternatively hydraulic dredge return water discharge prior to entering the on-site intake canals.

C. Other Limitations and Monitoring and Reporting Requirements

- The sample collection, analytical test methods, and method detection limits (MDLs) applicable to this permit shall be conducted using a sufficiently sensitive method to ensure compliance with applicable water quality standards and effluent limitations and shall be in accordance with Rule 62-4.246, Chapters 62-160 and 62-601, F.A.C., and 40 CFR 136, as appropriate. The list of Department established analytical methods, and corresponding MDLs (method detection limits) and PQLs (practical quantitation limits), which is titled "FAC 62-4 MDL/PQL Table (April 26, 2006)" is available at <http://www.dep.state.fl.us/labs/library/index.htm>. The MDLs and PQLs as described in this list shall constitute the minimum acceptable MDL/PQL values and the Department shall not accept results for which the laboratory's MDLs or PQLs are greater than those described above unless alternate MDLs and/or PQLs have been specifically approved by the Department for this permit. Any method included in the list may be used for reporting as long as it meets the following requirements:
 - The laboratory's reported MDL and PQL values for the particular method must be equal or less than the corresponding method values specified in the Department's approved MDL and PQL list;
 - The laboratory reported MDL for the specific parameter is less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Parameters that are listed as "report only" in the permit shall use methods that provide an MDL, which is equal to or less than the applicable water quality criteria stated in 62-302, F.A.C.; and
 - If the MDLs for all methods available in the approved list are above the stated permit limit or applicable water quality criteria for that parameter, then the method with the lowest stated MDL shall be used.

When the analytical results are below method detection or practical quantitation limits, the permittee shall report the actual laboratory MDL and/or PQL values for the analyses that were performed following the instructions on the applicable discharge monitoring report.

Where necessary, the permittee may request approval of alternate methods or for alternative MDLs or PQLs for any approved analytical method. Approval of alternate laboratory MDLs or PQLs are not necessary if the laboratory reported MDLs and PQLs are less than or equal to the permit limit or the applicable water quality criteria, if any, stated in Chapter 62-302, F.A.C. Approval of an analytical method not included in the above-referenced list is not necessary if the analytical method is approved in accordance with 40 CFR 136 or deemed acceptable by the Department. [62-4.246, 62-160]

- The permittee shall provide safe access points for obtaining representative influent and effluent samples which are required by this permit. [62-620.320(6)]
- Monitoring requirements under this permit are effective on the first day of the second month following permit issuance. Until such time, the permittee shall continue to monitor and report in accordance with previously effective permit requirements, if any. During the period of operation authorized by this permit, the permittee shall complete and submit to the Department Discharge Monitoring Reports (DMRs) in accordance with the frequencies specified by the REPORT type (i.e. monthly, toxicity, quarterly, semiannual, annual, etc.) indicated on the DMR forms attached to this permit. Monitoring results for each monitoring period shall be submitted in accordance with the associated DMR due dates below.

REPORT Type on DMR	Monitoring Period	Due Date
Monthly or Toxicity	first day of month - last day of month	28 th day of following month
Quarterly	January 1 - March 31	April 28

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

REPORT Type on DMR	Monitoring Period	Due Date
	April 1 - June 30 July 1 - September 30 October 1 - December 31	July 28 October 28 January 28
Semiannual	January 1 - June 30 July 1 - December 30	July 28 January 28
Annual	January 1 - December 31	January 28

DMRs shall be submitted for each required monitoring period including months of no discharge. The permittee may submit either paper or electronic DMR form(s). If submitting paper DMR form(s), the permittee shall make copies of the attached DMR form(s). If submitting electronic DMR form(s), the permittee shall use a Department-approved electronic DMR system.

The electronic submission of DMR forms shall be accepted only if approved in writing by the Department. For purposes of determining compliance with this permit, data submitted in electronic format is legally equivalent to data submitted on signed and certified paper DMR forms.

The permittee shall submit the completed DMR form(s) to the Department by the twenty-eighth (28th) of the month following the month of operation at the addresses specified below:

Florida Department of Environmental Protection
Wastewater Compliance Evaluation Section, Mail Station 3551
Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

And

Florida Department of Environmental Protection
Southeast District
400 N. Congress Avenue, Suite 200
West Palm Beach, Florida 33401-2913

[62-620.610(18)]

- The permittee shall not submit DMR forms that alter the original format or content of the attached DMR forms without written approval from the Department's Southeast District Office at the address specified above.
- Unless specified otherwise in this permit, all reports and other information required by this permit, including 24-hour notifications, shall be submitted to or reported to, as appropriate, the Department's Southeast District Office at the address specified above.
- All reports and other information shall be signed in accordance with the requirements of Rule 62-620.305, F.A.C. *[62-620.305]*
- If there is no discharge from the facility on a day when the facility would normally sample, the sample shall be collected on the day of the next discharge. *[62-620.320(6)]*
- There shall be no discharge of polychlorinated biphenyl compounds such as those commonly used for transformer fluid. The permittee shall dispose of all known PCB equipment, articles, and wastes in accordance with 40 CFR 761. The permittee shall certify each time that this disposal has been accomplished.
- There shall be no discharge of floating debris, scum, oil, or other matter in such amounts as to form nuisances or produce color, odor, taste, turbidity, or other conditions to such degree as to create a nuisance or otherwise interfere with the beneficial use of the receiving waters in accordance with Rules 62-302.500(1)(a) and 62-

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

302.530(500)(b), F.A.C. Any such discharges to waters of the State shall be reported to the Department when submitting DMR's.

10. Discharge of any product registered under the Federal Insecticide, Fungicide, and Rodenticide Act to any waste stream which ultimately may be discharged to lakes, rivers, or other waters of the State is prohibited unless specifically authorized elsewhere in this permit. This requirement is not applicable to products used for lawn and agricultural purposes or to the use of herbicides if used in accordance with labeled instructions and any applicable State permit. Discharge of chlorine from the use of chlorine gas, sodium hypochlorite, or similar chlorination compounds for treatment of the plant potable and service water systems is authorized.

A permit revision from the Department shall be required prior to the use of any biocide or chemical additive (except chlorine or hydrazine as authorized elsewhere in this permit) used in the cooling system or any other portion of the treatment system which may be toxic to aquatic life. The permit revision request shall include:

- a. Name and general composition of biocide or chemical
- b. Frequencies of use
- c. Quantities to be used
- d. Proposed effluent concentrations
- e. Acute and/or chronic toxicity data (laboratory reports shall be prepared according to Section 12 of EPA document no. EPA/600/4-90/027 entitled, Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters for Freshwater and Marine Organisms, or most current addition.)
- f. Product data sheet
- g. Product label

Herbicides may be used within the cooling pond for the purpose of prevention of over accumulation of aquatic weeds that could inhibit cooling pond water circulation. Use shall be in accordance with labeled instructions. Not later than 90 days after the effective date of this permit, the permittee shall provide the Department with a list of all herbicides used in the previous twelve months. Other products shall not be used without prior approval.

11. Discharge of any waste resulting from the combustion of toxic, hazardous, or metal cleaning wastes to any waste stream which ultimately discharges to waters of the State is prohibited, unless specifically authorized elsewhere in this permit.
12. The permittee shall continue compliance with the facility's manatee protection plan approved by the Department on August 18, 1999.

II. SLUDGE MANAGEMENT REQUIREMENTS

1. The disposal of sludge or other solids generated from the plant's wastewater treatment and containment system shall be reused, reclaimed, or otherwise disposed of in accordance with the requirements of Chapter 62-701, F.A.C.
2. The permittee shall be responsible for proper treatment, management, use, and land application or disposal of its sludges. [62-620.320(6)]
3. Storage, transportation, and disposal of sludge/solids characterized as hazardous waste shall be in accordance with requirements of Chapter 62-730, F.A.C. [62-730]
4. The permittee shall keep records of the amount of sludge or residuals disposed, transported, or incinerated in (Please specify units). If a person other than the permittee is responsible for sludge transporting, disposal, or incineration, the permittee shall also keep the following records:
 - a. Name, address and telephone number of any transporter, and any manifests or bill of lading used;
 - b. Name and location of the site of disposal, treatment or incineration;
 - c. Name, address, and telephone number of the entity responsible for the disposal, treatment, or incineration site.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

III. GROUND WATER REQUIREMENTS

Section III is not applicable to this facility.

IV. ADDITIONAL LAND APPLICATION REQUIREMENTS

Section IV is not applicable to this facility.

V. OPERATION AND MAINTENANCE REQUIREMENTS

1. During the period of operation authorized by this permit, the wastewater facilities shall be operated under the supervision of a person who is qualified by formal training and/or practical experience in the field of water pollution control. *[62-620.320(6)]*
2. The permittee shall maintain the following records and make them available for inspection on the site of the permitted facility.
 - a. Records of all compliance monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, including, if applicable, a copy of the laboratory certification showing the certification number of the laboratory, for at least three years from the date the sample or measurement was taken;
 - b. Copies of all reports required by the permit for at least three years from the date the report was prepared;
 - c. Records of all data, including reports and documents, used to complete the application for the permit for at least three years from the date the application was filed;
 - d. A copy of the current permit;
 - e. A copy of any required record drawings; and
 - f. Copies of the logs and schedules showing plant operations and equipment maintenance for three years from the date of the logs or schedules.

[62-620.350]

VI. SCHEDULES

1. The following improvement actions shall be completed according to the following schedule. The Storm water Pollution Prevention Plan (SWPPP) shall be prepared and implemented in accordance with Part VII of this permit.

Improvement Action	Completion Date
1. Develop and implement SWPPP	18 months from permit issuance.
2. Complete Plan Summary	2 years from permit issuance.
3. Progress/Update Report	3 years, and then annual thereafter.

[62-620.320(6)]

4. If the permittee wishes to continue operation of this wastewater facility after the expiration date of this permit, the permittee shall submit an application for renewal no later than one-hundred and eighty days (180) prior to the expiration date of this permit. Application shall be made using the appropriate forms listed in Rule 62-620.910, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C. *[62-620.335(1) and (2)]*
3. The permittee shall submit a copy of the Manatee Protection Plan, including any amendments, with the permit renewal application to each of the following agencies no later than one-hundred and eighty days (180) prior to the expiration date of this permit:

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

Florida Department of Environmental Protection
Industrial Wastewater Section, Mail Station 3545
Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Florida Fish and Wildlife Conservation Commission
Bureau of Protected Species Management
620 South Meridian Street
OES-BPS
Tallahassee, Florida 32399-1600

And

US Fish and Wildlife Service
Jacksonville Field Office
7915 Baymeadows Way, Suite 200
Jacksonville, Florida 32256-7517

4. Within six months of the effective date of this permit, the permittee shall schedule a meeting with the Department to discuss the contents of the aquatic organism return plan in accordance with Condition I.A.5 and shall submit the plan to the Department within 12 months of the effective date of this permit. The plan shall be implemented within 24 months subsequent to approval by the Department.

VII. STORMWATER POLLUTION PREVENTION PLAN (SWPPP)

1. General Requirements

In accordance with Section 304(e) and 402(a)(2) of the Clean Water Act (CWA) as amended, 33 U.S.C. §§ 1251 et seq., and the Pollution Prevention Act of 1990, 42 U.S.C. §§ 13101-13109, the permittee must develop and implement a plan for utilizing practices incorporating pollution prevention measures. References to be considered in developing the plan are "Criteria and Standards for Best Management Practices Authorized Under Section 304(e) of the Act," found at 40 CFR 122.44 Subpart K and the Storm Water Management Industrial Activities Guidance Manual, EPA/833-R92-002 and other EPA documents relating to Best Management Practice guidance.

a. Definitions

- (1) The term "pollutants" refers to conventional, non-conventional and toxic pollutants.
- (2) Conventional pollutants are: biochemical oxygen demand (BOD), suspended solids, pH, fecal coliform bacteria and oil & grease.
- (3) Non-conventional pollutants are those which are not defined as conventional or toxic.
- (4) Toxic pollutants include, but are not limited to: (a) any toxic substance listed in Section 307(a)(1) of the CWA, any hazardous substance listed in Section 311 of the CWA, or chemical listed in Section 313(c) of the Superfund Amendments and Reauthorization Act of 1986; and (b) any substance (that is not also a conventional or non-conventional pollutant except ammonia) for which EPA has published an acute or chronic toxicity criterion.
- (5) "Significant Materials" is defined as raw materials; fuels; materials such as solvents and detergents; hazardous substances designated under Section 101(14) of CERCLA; and any chemical the facility is required to report pursuant to EPCRA, Section 313; fertilizers; pesticides; and waste products such as ashes, slag and sludge.
- (6) "Pollution prevention" and "waste minimization" refer to the first two categories of EPA's preferred hazardous waste management strategy: first, source reduction and then, recycling.
- (7) "Recycle/Reuse" is defined as the minimization of waste generation by recovering and reprocessing usable products that might otherwise become waste; or the reuse or reprocessing of usable waste products in place of the original stock, or for other purposes such as material recovery, material regeneration or energy production.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

- (8) "Source reduction" means any practice which: (a) reduces the amount of any pollutant entering a waste stream or otherwise released into the environment (including fugitive emissions) prior to recycling, treatment or disposal; and (b) reduces the hazards to public health and the environment associated with the release of such pollutant. The term includes equipment or technology modifications, process or procedure modifications, reformulation or redesign of products, substitution of raw materials, and improvements in housekeeping, maintenance, training, or inventory control. It does not include any practice which alters the physical, chemical, or biological characteristics or the volume of a pollutant through a process or activity which itself is not integral to, or previously considered necessary for, the production of a product or the providing of a service.
- (9) "SWPPP" means a Storm Water Pollution Prevention Plan incorporating the requirements of 40 CFR § 125, Subpart K, plus pollution prevention techniques, except where other existing programs are deemed equivalent by the permittee. The permittee shall certify the equivalency of the other referenced programs.
- (10) The term "material" refers to chemicals or chemical products used in any plant operation (i.e., caustic soda, hydrazine, degreasing agents, paint solvents, etc.). It does not include lumber, boxes, packing materials, etc.

2. Storm Water Pollution Prevention Plan

The permittee shall develop and implement a SWPPP for the facility, which is the source of wastewater and storm water discharges, covered by this permit. The plan shall be directed toward reducing those pollutants of concern which discharge to surface waters and shall be prepared in accordance with good engineering and good housekeeping practices. For the purposes of this permit, pollutants of concern shall be limited to toxic pollutants, as defined above, known to the discharger. The plan shall address all activities which could or do contribute these pollutants to the surface water discharge, including process, treatment, and ancillary activities.

a. Signatory Authority & Management Responsibilities

The SWPPP shall be signed by permittee or their duly authorized representative in accordance with rule 62-620.305(2)(a) and (b). The SWPPP shall be reviewed by plant environmental/engineering staff and plant manager. Where required by Chapter 471-(P.E.) or Chapter 492 (P.G.) Florida Statutes, applicable portions of the SWPPP shall be signed and sealed by the professional(s) who prepared them.

A copy of the plan shall be retained at the facility and shall be made available to the permit issuing authority upon request.

The SWPPP shall contain a written statement from corporate or plant management indicating management's commitment to the goals of the BMP program. Such statements shall be publicized or made known to all facility employees. Management shall also provide training for the individuals responsible for implementing the SWPPP.

b. SWPPP Requirements

- (1) A topographic map extending one-quarter mile beyond the property boundaries of the facility, showing: the facility, surface water bodies, wells (including injection wells), seepage pits, infiltration ponds, and the discharge points where the facility's storm water discharges to a municipal storm drain system or other water body. The requirements of this paragraph may be included on the site map if appropriate.
- (2) A site map showing:
 - (a) The storm water conveyance and discharge structures;
 - (b) An outline of the storm water drainage areas for each storm water discharge point;
 - (c) Paved areas and buildings;
 - (d) Areas used for outdoor manufacturing, storage, or disposal of significant materials, including activities that generate significant quantities of dust or particulates;
 - (e) Location of existing or future storm water structural control measures/practices (dikes, coverings, detention facilities, etc.);
 - (f) Surface water locations and/or municipal storm drain locations;
 - (g) Areas of existing and potential soil erosion;
 - (h) Vehicle service areas;

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

Florida Department of Environmental Protection
Industrial Wastewater Section, Mail Station 3545
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
(850) 245-8589
(850) 245-8669 – Fax

d. Pollution Prevention Committee:

A pollution prevention committee within the plant organization shall be appointed. These members shall be responsible for developing the SWPPP and assisting the plant manager in its implementation, maintenance, and revision.

e. Employee Training

- (1) The permittee shall describe the storm water employee training program for the facility. The description shall include the topics to be covered, such as spill response, good housekeeping and material management practices, and shall identify periodic dates (e.g., every 6 months during the months of July and January) for such training. The permittee shall provide employee training for all employees and contractors that work in areas where industrial materials or activities are exposed to storm water, and for employees that are responsible for implementing activities identified in the SWPPP (e.g., inspectors, maintenance people). The employee training shall inform facility personnel and contractors of the components and goals of the facility SWPPP.
- (2) Each employee and contractor that works in an areas where industrial materials or activities are exposed to storm water, and each employee that is responsible for implementing activities identified in the SWPPP shall undergo training at least once a year. Training records shall include trainee's name, signature, date of training and topics covered. Records shall be retained on-site for a minimum of three years.

f. Plan Development & Implementation

- (1) The SWPPP shall be developed and implemented 18 months after the effective date of this permit, unless any later dates are specified in this permit. Any portion of the SWPPP which is ongoing at the time of development or implementation shall be described in the plan. Any waste reduction practice which is recommended for implementation over a period of time shall be identified in the plan, including a schedule for its implementation.
- (2) The personnel named in the SWPPP shall perform and document a quarterly visual observation of a storm water discharge associated with industrial activity from each outfall. The visual observation shall be made during daylight hours. If no storm event resulted in runoff during daylight hours from the facility during a monitoring quarter, the permittee is excused from the visual observation requirement for that quarter, provided the permittee documents in their records that no runoff occurred. The permittee shall sign and certify the documentation.
- (3) The personnel named in the SWPPP shall conduct visual observations on samples collected as soon as practical, but not to exceed 1 hour of when the runoff begins discharging from the facility. All samples must be collected from a storm event discharge that is greater than 0.1 inch in magnitude and that occurs at least 72 hours from the previously measurable (greater than 0.1 inch rainfall) storm event. The observation shall document: color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution.
- (4) The permittee shall maintain visual observation reports onsite with the SWPPP for a minimum of three years. The report must include the observation date and time, inspection personnel, nature of the discharge (i.e., runoff), visual quality of the storm water discharge (including observations of color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution), and probable sources of any observed storm water contamination.
- (5) At least once a year the personnel named in the SWPPP shall verify that the description of potential pollutant sources required under this permit is accurate; the site map as required in the SWPPP has been updated or otherwise modified to reflect current conditions; and the controls to reduce pollutants

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

in storm water discharges associated with industrial activity identified in the SWPPP are being implemented and are adequate.

g. Submission of Plan Summary & Progress/Update Reports

- (1) Plan Summary: Not later than 2 years after the effective date of the permit, a summary of the SWPPP shall be developed and maintained at the facility and made available to the permit issuing authority upon request. The summary should include the following: a brief description of the plan, its implementation process, schedules for implementing identified waste reduction practices, and a list of all waste reduction practices being employed at the facility. The results of waste minimization assessment studies already completed as well as any scheduled or ongoing WMA studies shall be discussed.
- (2) Progress/Update Reports: Annually thereafter for the duration of the permit progress/update reports documenting implementation of the plan shall be maintained at the facility and made available to the permit issuing authority upon request. The reports shall discuss whether or not implementation schedules were met and revise any schedules, as necessary. The plan shall also be updated as necessary and the attainment or progress made toward specific pollutant reduction targets documented. Results of any ongoing WMA studies as well as any additional schedules for implementation of waste reduction practices shall be included.
- (3) A timetable for the various plan requirements follows:

Timetable for SWPPP Requirements:

<u>REQUIREMENT</u>	<u>TIME FROM EFFECTIVE DATE OF THIS PERMIT</u>
Complete SWPPP	18 months
Complete Plan Summary	2 years
Progress/Update Reports	3 years, and then annually thereafter

The permittee shall maintain the plan and subsequent reports at the facility and shall make the plan available to the Department upon request.

h. Plan Review & Modification

If following review by the Department, the SWPPP is determined insufficient, the permittee will be notified that the SWPPP does not meet one or more of the minimum requirements of this Part. Upon such notification from the Department, the permittee shall amend the plan and shall submit to the Department a written certification that the requested changes have been made. Unless otherwise provided by the Department, the permittee shall have 30 days after such notification to make the changes necessary.

The permittee shall modify the SWPPP whenever there is a change in design, construction, operation, or maintenance, which has a significant effect on the potential for the discharge of pollutants to waters of the State or if the plan proves to be ineffective in achieving the general objectives of reducing pollutants in wastewater or storm water discharges. Modifications to the plan may be reviewed by the Department in the same manner as described above.

The permittee may incorporate applicable portions of plans prepared for other purposes. Plans or portions of plans incorporated into a SWPPP become enforceable requirements of this permit.

VIII. OTHER SPECIFIC CONDITIONS

A. Specific Conditions Applicable to All Permits

1. Where required by Chapter 471 or Chapter 492, F.S., applicable portions of reports that must be submitted under this permit shall be signed and sealed by a professional engineer or a professional geologist, as appropriate. [62-620.310(4)]
2. The permittee shall provide verbal notice to the Department's Central District Office as soon as practical after discovery of a sinkhole or other karst feature within an area for the management or application of wastewater, or wastewater sludges. The permittee shall immediately implement measures appropriate to control the entry of

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

contaminants, and shall detail these measures to the Department's Central District Office in a written report within 7 days of the sinkhole discovery. [62-620.320(6)]

3. Drawings, plans, documents or specifications submitted by the permittee, not attached hereto, but retained on file at the Department's Central District Office, are made a part hereof.
4. This permit satisfies Industrial Wastewater program permitting requirements only and does not authorize operation of this facility prior to obtaining any other permits required by local, state or federal agencies.

B. Specific Conditions Related to Existing Manufacturing, Commercial, Mining, and Silviculture Wastewater Facilities or Activities

1. Existing manufacturing, commercial, mining, and silvicultural wastewater facilities or activities that discharge into surface waters shall notify the Department as soon as they know or have reason to believe:
 - a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following levels;
 - (1) One hundred micrograms per liter,
 - (2) Two hundred micrograms per liter for acrolein and acrylonitrile; five hundred micrograms per liter for 2, 4-dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter for antimony, or
 - (3) Five times the maximum concentration value reported for that pollutant in the permit application; or
 - b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following levels;
 - (1) Five hundred micrograms per liter,
 - (2) One milligram per liter for antimony, or
 - (3) Ten times the maximum concentration value reported for that pollutant in the permit application.

[62-620.625(1)]

C. Duty to Reapply

1. The permittee is not authorized to discharge to waters of the State after the expiration date of this permit, unless:
 - a. the Permittee has applied for renewal of this permit at least 180 days before the expiration date (December 26, 2014) using the appropriate forms listed in Rule 62-620.910, F.A.C., and in the manner established in the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., including submittal of the appropriate processing fee set forth in Rule 62-4.050, F.A.C.; or
 - b. the Permittee has made complete the application for renewal of this permit before the permit expiration date.
2. When publishing Notice of Draft and Notice of Intent in accordance with Rules 62-110.106 and 62-620.550, F.A.C., the permittee shall publish the notice at its expense in a newspaper of general circulation in the county or counties in which the activity is to take place either
 - a. Within thirty days after the permittee has received a notice; or
 - b. Within thirty days after final agency action.

Failure to publish a notice is a violation of this permit.

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

D. Reopener Clauses

1. The permit shall be revised, or alternatively, revoked and reissued in accordance with the provisions contained in Rules 62-620.325 and 62-620.345 F.A.C., if applicable, or to comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), 307(a)(2) and 316 of the Clean Water Act (the Act), as amended, if the effluent standards, limitations, or water quality standards so issued or approved:
 - a. Contains different conditions or is otherwise more stringent than any condition in the permit/or;
 - b. Controls any pollutant not addressed in the permit.The permit as revised or reissued under this paragraph shall contain any other requirements then applicable.
2. The permit may be reopened to adjust effluent limitations or monitoring requirements should future Water Quality Based Effluent Limitation determinations, water quality studies, DEP approved changes in water quality standards, EPA established Total Maximum Daily Loads (TMDLs), or other information show a need for a different limitation or monitoring requirement.
3. The Department or EPA may develop a TMDL during the life of the permit. Once a TMDL has been established and adopted by rule, the Department shall revise this permit to incorporate the final findings of the TMDL.
4. The permit shall be reopened for revision as appropriate to address new information that was not available at the time of this permit issuance or to comply with requirements of new regulations, standards, or judicial decisions relating to CWA 316(b).

IX. GENERAL CONDITIONS

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit are binding and enforceable pursuant to Chapter 403, Florida Statutes. Any permit noncompliance constitutes a violation of Chapter 403, Florida Statutes, and is grounds for enforcement action, permit termination, permit revocation and reissuance, or permit revision. [62-620.610(1)]
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviations from the approved drawings, exhibits, specifications or conditions of this permit constitutes grounds for revocation and enforcement action by the Department. [62-620.610(2)]
3. As provided in Subsection 403.087(6), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor authorize any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit or authorization that may be required for other aspects of the total project which are not addressed in this permit. [62-620.610(3)]
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title. [62-620.610(4)]
5. This permit does not relieve the permittee from liability and penalties for harm or injury to human health or welfare, animal or plant life, or property caused by the construction or operation of this permitted source; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department. The permittee shall take all reasonable steps to minimize or prevent any discharge, reuse of reclaimed water, or residuals use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. It shall not

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. *[62-620.610(5)]*

6. If the permittee wishes to continue an activity regulated by this permit after its expiration date, the permittee shall apply for and obtain a new permit. *[62-620.610(6)]*
7. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control, and related appurtenances, that are installed and used by the permittee to achieve compliance with the conditions of this permit. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to maintain or achieve compliance with the conditions of the permit. *[62-620.610(7)]*
8. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. *[62-620.610(8)]*
9. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, including an authorized representative of the Department and authorized EPA personnel, when applicable, upon presentation of credentials or other documents as may be required by law, and at reasonable times, depending upon the nature of the concern being investigated, to:
 - a. Enter upon the permittee's premises where a regulated facility, system, or activity is located or conducted, or where records shall be kept under the conditions of this permit;
 - b. Have access to and copy any records that shall be kept under the conditions of this permit;
 - c. Inspect the facilities, equipment, practices, or operations regulated or required under this permit; and
 - d. Sample or monitor any substances or parameters at any location necessary to assure compliance with this permit or Department rules.*[62-620.610(9)]*
10. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data, and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except as such use is proscribed by Section 403.111, F.S., or Rule 62-620.302, F.A.C. Such evidence shall only be used to the extent that it is consistent with the Florida Rules of Civil Procedure and applicable evidentiary rules. *[62-620.610(10)]*
11. When requested by the Department, the permittee shall within a reasonable time provide any information required by law which is needed to determine whether there is cause for revising, revoking and reissuing, or terminating this permit, or to determine compliance with the permit. The permittee shall also provide to the Department upon request copies of records required by this permit to be kept. If the permittee becomes aware of relevant facts that were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be promptly submitted or corrections promptly reported to the Department. *[62-620.610(11)]*
12. Unless specifically stated otherwise in Department rules, the permittee, in accepting this permit, agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules. A reasonable time for compliance with a new or amended surface water quality standard, other than those standards addressed in Rule 62-302.500, F.A.C., shall include a reasonable time to obtain or be denied a mixing zone for the new or amended standard. *[62-620.610(12)]*
13. The permittee, in accepting this permit, agrees to pay the applicable regulatory program and surveillance fee in accordance with Rule 62-4.052, F.A.C. *[62-620.610(13)]*

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

14. This permit is transferable only upon Department approval in accordance with Rule 62-620.340, F.A.C. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department. *[62-620.610(14)]*
15. The permittee shall give the Department written notice at least 60 days before inactivation or abandonment of a wastewater facility or activity and shall specify what steps will be taken to safeguard public health and safety during and following inactivation or abandonment. *[62-620.610(15)]*
16. The permittee shall apply for a revision to the Department permit in accordance with Rules 62-620.300, F.A.C., and the Department of Environmental Protection Guide to Permitting Wastewater Facilities or Activities Under Chapter 62-620, F.A.C., at least 90 days before construction of any planned substantial modifications to the permitted facility is to commence or with Rule 62-620.325(2), F.A.C., for minor modifications to the permitted facility. A revised permit shall be obtained before construction begins except as provided in Rule 62-620.300, F.A.C. *[62-620.610(16)]*
17. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The permittee shall be responsible for any and all damages which may result from the changes and may be subject to enforcement action by the Department for penalties or revocation of this permit. The notice shall include the following information:
 - a. A description of the anticipated noncompliance;
 - b. The period of the anticipated noncompliance, including dates and times; and
 - c. Steps being taken to prevent future occurrence of the noncompliance.*[62-620.610(17)]*
18. Sampling and monitoring data shall be collected and analyzed in accordance with Rule 62-4.246 and Chapters 62-160, 62-601, and 62-610, F.A.C., and 40 CFR 136, as appropriate.
 - a. Monitoring results shall be reported at the intervals specified elsewhere in this permit and shall be reported on a Discharge Monitoring Report (DMR), DEP Form 62-620.910(10), or as specified elsewhere in the permit.
 - b. If the permittee monitors any contaminant more frequently than required by the permit, using Department approved test procedures, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.
 - c. Calculations for all limitations which require averaging of measurements shall use an arithmetic mean unless otherwise specified in this permit.
 - d. Except as specifically provided in Rule 62-160.300, F.A.C., any laboratory test required by this permit shall be performed by a laboratory that has been certified by the Department of Health Environmental Laboratory Certification Program (DOH ELCP). Such certification shall be for the matrix, test method and analyte(s) being measured to comply with this permit. For domestic wastewater facilities, testing for parameters listed in Rule 62-160.300(4), F.A.C., shall be conducted under the direction of a certified operator.
 - e. Field activities including on-site tests and sample collection shall follow the applicable standard operating procedures described in DEP-SOP-001/01 adopted by reference in Chapter 62-160, F.A.C.
 - f. Alternate field procedures and laboratory methods may be used where they have been approved in accordance with Rules 62-160.220, and 62-160.330, F.A.C.*[62-620.610(18)]*
19. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule detailed elsewhere in this permit shall be submitted no later than 14 days following each schedule date. *[62-620.610(19)]*

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

20. The permittee shall report to the Department's Tallahassee any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five days of the time the permittee becomes aware of the circumstances. The written submission shall contain: a description of the noncompliance and its cause; the period of noncompliance including exact dates and time, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
- a. The following shall be included as information which must be reported within 24 hours under this condition:
 - (1) Any unanticipated bypass which causes any reclaimed water or effluent to exceed any permit limitation or results in an unpermitted discharge,
 - (2) Any upset which causes any reclaimed water or the effluent to exceed any limitation in the permit,
 - (3) Violation of a maximum daily discharge limitation for any of the pollutants specifically listed in the permit for such notice, and
 - (4) Any unauthorized discharge to surface or ground waters.
 - b. Oral reports as required by this subsection shall be provided as follows:
 - (1) For unauthorized releases or spills of treated or untreated wastewater reported pursuant to subparagraph (a)4. that are in excess of 1,000 gallons per incident, or where information indicates that public health or the environment will be endangered, oral reports shall be provided to the STATE WARNING POINT TOLL FREE NUMBER (800) 320-0519, as soon as practical, but no later than 24 hours from the time the permittee becomes aware of the discharge. The permittee, to the extent known, shall provide the following information to the State Warning Point:
 - (a) Name, address, and telephone number of person reporting;
 - (b) Name, address, and telephone number of permittee or responsible person for the discharge;
 - (c) Date and time of the discharge and status of discharge (ongoing or ceased);
 - (d) Characteristics of the wastewater spilled or released (untreated or treated, industrial or domestic wastewater);
 - (e) Estimated amount of the discharge;
 - (f) Location or address of the discharge;
 - (g) Source and cause of the discharge;
 - (h) Whether the discharge was contained on-site, and cleanup actions taken to date;
 - (i) Description of area affected by the discharge, including name of water body affected, if any; and
 - (j) Other persons or agencies contacted.
 - (2) Oral reports, not otherwise required to be provided pursuant to subparagraph b.1 above, shall be provided to the Department's Tallahassee within 24 hours from the time the permittee becomes aware of the circumstances.
 - c. If the oral report has been received within 24 hours, the noncompliance has been corrected, and the noncompliance did not endanger health or the environment, the Department's Tallahassee shall waive the written report.
- [62-620.610(20)]
21. The permittee shall report all instances of noncompliance not reported under Permit Conditions IX. 17, 18 or 19 of this permit at the time monitoring reports are submitted. This report shall contain the same information required by Permit Condition IX.20 of this permit. [62-620.610(21)]
22. Bypass Provisions.
- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment works.
 - b. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless the permittee affirmatively demonstrates that:
 - (1) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage; and
 - (2) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and

- (3) The permittee submitted notices as required under Permit Condition IX.22.b. of this permit.
- c. If the permittee knows in advance of the need for a bypass, it shall submit prior notice to the Department, if possible at least 10 days before the date of the bypass. The permittee shall submit notice of an unanticipated bypass within 24 hours of learning about the bypass as required in Permit Condition IX. 20. of this permit. A notice shall include a description of the bypass and its cause; the period of the bypass, including exact dates and times; if the bypass has not been corrected, the anticipated time it is expected to continue; and the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- d. The Department shall approve an anticipated bypass, after considering its adverse effect, if the permittee demonstrates that it will meet the three conditions listed in Permit Condition IX. 22. a. 1 through 3 of this permit.
- e. A permittee may allow any bypass to occur which does not cause reclaimed water or effluent limitations to be exceeded if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Permit Condition IX. 22. a. through c. of this permit.

[62-620.610(22)]

23. Upset Provisions.

- a. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based effluent limitations because of factors beyond the reasonable control of the permittee.
- (1) An upset does not include noncompliance caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, careless or improper operation.
- (2) An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of upset provisions of Rule 62-620.610, F.A.C., are met.
- b. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
- (2) The permitted facility was at the time being properly operated;
- (3) The permittee submitted notice of the upset as required in Permit Condition IX.5. of this permit; and
- (4) The permittee complied with any remedial measures required under Permit Condition IX. 5. of this permit.
- c. In any enforcement proceeding, the burden of proof for establishing the occurrence of an upset rests with the permittee.
- d. Before an enforcement proceeding is instituted, no representation made during the Department review of a claim that noncompliance was caused by an upset is final agency action subject to judicial review.


[62-620.610(23)]

PERMITTEE: Florida Power & Light
FACILITY: Lauderdale Power Plant

PERMIT NUMBER: FL0001503-003 (Major)
ISSUANCE DATE: June 25, 2010
EXPIRATION DATE: June 24, 2015

Executed in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT OF
ENVIRONMENTAL PROTECTION

A handwritten signature in black ink, appearing to read "J. G. Llewellyn", is written over a horizontal line.

Janet G. Llewellyn
Director
Division of Water Resource Management
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
(850) 245-8336

Attachment(s):
Discharge Monitoring Report

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER: FL0001503-003-IW1S

LIMIT: Final
CLASS SIZE: MA
MONITORING GROUP NUMBER: D-001
MONITORING GROUP DESCRIPTION: Cooling pond discharge to South Fork New River

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD

From: To:

COUNTY: Broward
OFFICE: Southeast District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 Y Mon. Site No. EFF-3	Permit Requirement		380 (An.Avg.)	MGD						Daily; 24 hours	Calculated
Flow	Sample Measurement										
PARM Code 50050 I Mon. Site No. EFF-3	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Daily; 24 hours	Calculated
Temperature (F), Water (JUN - SEP)	Sample Measurement										
PARM Code 00011 I Mon. Site No. EFF-3	Permit Requirement					99.0 (Mo.Avg.)	Deg F			Continuous	Recorder
Temperature (F), Water (JUN - SEP)	Sample Measurement										
PARM Code 00011 Q Mon. Site No. EFF-3	Permit Requirement					101.1 (Day.Max.)	Deg F			Continuous	Recorder
Temperature (F), Water (OCT - MAY)	Sample Measurement										
PARM Code 00011 R Mon. Site No. EFF-3	Permit Requirement					96.0 (Mo.Avg.)	Deg F			Continuous	Recorder
Temperature (F), Water (OCT - MAY)	Sample Measurement										
PARM Code 00011 S Mon. Site No. EFF-3	Permit Requirement					99.0 (Day.Max.)	Deg F			Continuous	Recorder

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: FPL - Lauderdale Power Plant

MONITORING GROUP D-001

PERMIT NUMBER: FL0001503-003-IW1S

NUMBER:

MONITORING PERIOD From: _____ To: _____

[illegible]

¹ During months that do not require sampling enter "MNR" to indicate that no sampling required for that month.

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue

PERMIT NUMBER:

FL0001503-003-IW1S

Fort Lauderdale, FL 33314-

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:

Final
MA
D-001

REPORT FREQUENCY: Toxicity
PROGRAM: Industrial

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue

Fort Lauderdale, FL 33314-

RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING NOT REQUIRED: ☐
MONITORING PERIOD From:

Cooling pond discharge to South Fork New River

COUNTY: Broward

OFFICE: Southeast District

To:

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
7-DAY CHRONIC STATRE Mysidopsis bahia(Routine)	Sample Measurement										
PARM Code TRP3E P Mon. Site No. EFF-3	Permit Requirement				100 (Min.)			percent		Quarterly	Grab
7-DAY CHRONIC STATRE Mysidopsis bahia(Additional)	Sample Measurement										
PARM Code TRP3E Q Mon. Site No. EFF-3	Permit Requirement				100 (Min.)			percent		As needed	As required by the permit
7-DAY CHRONIC STATRE Mysidopsis bahia(Additional)	Sample Measurement										
PARM Code TRP3E R Mon. Site No. EFF-3	Permit Requirement				100 (Min.)			percent		As needed	As required by the permit
7-DAY CHRONIC STATRE Menidia beryllina(Routine)	Sample Measurement										
PARM Code TRP6B P Mon. Site No. EFF-3	Permit Requirement				100 (Min.)			percent		Quarterly	Grab
7-DAY CHRONIC STATRE Menidia beryllina(Additional)	Sample Measurement										
PARM Code TRP6B Q Mon. Site No. EFF-3	Permit Requirement				100 (Min.)			percent		As needed	As required by the permit
7-DAY CHRONIC STATRE Menidia beryllina(Additional)	Sample Measurement										
PARM Code TRP6B R Mon. Site No. EFF-3	Permit Requirement				100 (Min.)			percent		As needed	As required by the permit

*ENTER "MNR" IN THE RESULTS COLUMN FOR EACH TEST THAT IS NOT REQUIRED.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME:	FPL - Lauderdale Power Plant	PERMIT NUMBER:	FL0001503-003-IW1S	
MAILING ADDRESS:	4300 SW 42nd Avenue Fort Lauderdale, FL 33314-	LIMIT:	Final	REPORT FREQUENCY:
		CLASS SIZE:	MA	Monthly
FACILITY:	FPL - Lauderdale Power Plant	MONITORING GROUP NUMBER:	D-0B1	PROGRAM:
LOCATION:	4300 SW 42nd Avenue Fort Lauderdale, FL 33314-	MONITORING GROUP DESCRIPTION:	Stormwater Runoff From Equipment Area	
		RE-SUBMITTED DMR:	☐	
		NO DISCHARGE FROM SITE:	☐	
COUNTY:	Broward	MONITORING PERIOD	From:	To:
OFFICE:	Southeast District			

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-8	Permit Requirement		Report (Day Max.)	MGD						Weekly, when discharging	Calculated
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-8	Permit Requirement					50.0 (Day Max.)	mg/L			Weekly, when discharging	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-8	Permit Requirement				6.0 (Day Min.)	9.0 (Day Max.)	s.u.			Weekly, when discharging	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER:

FL0001503-003-IW1S

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD

Final
MA
I-012
Demineralizer Regeneration Wastewater

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

COUNTY: Broward
OFFICE: Southeast District

From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-12	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Per batch of process	Calculated
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-12	Permit Requirement				15.0 (Mo.Avg.)	20.0 (Day.Max.)		mg/L		Weekly, when discharging	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-12	Permit Requirement				30 (Mo.Avg.)	100 (Day.Max.)		mg/L		Weekly, when discharging	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-12	Permit Requirement				6.0 (Day.Min.)	9.0 (Day.Max.)		s.u.		Weekly, when discharging	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME:	FPL - Lauderdale Power Plant	PERMIT NUMBER:	FL0001503-003-1W1S	
MAILING ADDRESS:	4300 SW 42nd Avenue Fort Lauderdale, FL 33314-	LIMIT:	Final	REPORT FREQUENCY:
		CLASS SIZE:	MA	Monthly
FACILITY:	FPL - Lauderdale Power Plant	MONITORING GROUP NUMBER:	I-013	PROGRAM:
LOCATION:	4300 SW 42nd Avenue Fort Lauderdale, FL 33314-	MONITORING GROUP DESCRIPTION:	Wastewater Treatment System Effluent	
		RE-SUBMITTED DMR:	☐	
		NO DISCHARGE FROM SITE:	☐	
COUNTY:	Broward	MONITORING PERIOD	From:	To:
OFFICE:	Southeast District			

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-13	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Continuous	Flow Totalizer
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-13	Permit Requirement					15 (Mo.Avg.)	20 (Day.Max.)	mg/L		Bi-monthly; every 2 months ²	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-13	Permit Requirement					30.0 (Mo.Avg.)	100.0 (Day.Max.)	mg/L		Bi-monthly; every 2 months ²	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-13	Permit Requirement					6.0 (Day.Min.)	9.0 (Day.Max.)	s.u.		Monthly	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

² During months that do not require sampling enter "MNR" to indicate that no sampling required for that month.

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

COUNTY: Broward
OFFICE: Southeast District

PERMIT NUMBER: FL0001503-003-IW1S

LIMIT: Final
CLASS SIZE: MA
MONITORING GROUP NUMBER: I-015
MONITORING GROUP DESCRIPTION: Metal Cleaning Wastewater
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: To:

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow, Total Volume	Sample Measurement										
PARM Code 82220 1 Mon. Site No. EFF-14	Permit Requirement	Report (Mo.Total)	Report (Day.Max.)	Mgal						Continuous	Flow Totalizer
Copper, Total Recoverable	Sample Measurement										
PARM Code 01119 1 Mon. Site No. EFF-14	Permit Requirement					1.0 (Day.Max.)	mg/L			Per batch of process	24-hr TPC
Iron, Total Recoverable	Sample Measurement										
PARM Code 00980 1 Mon. Site No. EFF-14	Permit Requirement					1.0 (Day.Max.)	mg/L			Per batch of process	24-hr TPC
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-14	Permit Requirement					15.0 (Day.Max.)	mg/L			Per batch of process	24-hr TPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-14	Permit Requirement					30 (Day.Max.)	mg/L			Per batch of process	24-hr TPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER: FL0001503-003-IW1S

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

LIMIT: Final
CLASS SIZE: MA
MONITORING GROUP NUMBER: I-01D
MONITORING GROUP DESCRIPTION: Construction Dewatering
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

COUNTY: Broward
OFFICE: Southeast District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-7	Permit Requirement		Report (Day.Max.)	MGD						Daily, when discharging	Calculated
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-7	Permit Requirement					Report (Day.Max.)	mg/L			Monthly, when discharging	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-7	Permit Requirement					50.0 (Day.Max.)	mg/L			Monthly, when discharging	Grab
Turbidity	Sample Measurement										
PARM Code 00070 1 Mon. Site No. EFF-7	Permit Requirement					Report (Day.Max.)	NTU			Monthly, when discharging	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-7	Permit Requirement				6.0 (Day.Min.)	9.0 (Day.Max.)	s.u.			Monthly, when discharging	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER:

FL0001503-003-IW1S

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD

Final
MA
I-01E
Reverse Osmosis Reject

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

COUNTY: Broward
OFFICE: Southeast District

From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-11	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Weekly	Calculated
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-11	Permit Requirement				15.0 (Mo.Avg.)	20.0 (Day.Max.)		mg/L		Bi-monthly; every 2 months ³	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 Y Mon. Site No. EFF-11	Permit Requirement				30.0 (An.Avg.)			mg/L		Weekly	8-hr FPC
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-11	Permit Requirement					100.0 (Day.Max.)		mg/L		Weekly	8-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

³ During months that do not require sampling enter "MNR" to indicate that no sampling required for that month.

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER: FL0001503-003-IW1S

LIMIT: Final
CLASS SIZE: MA
MONITORING GROUP NUMBER: I-11A
MONITORING GROUP DESCRIPTION: Unit 4 Once-through Cooling Water
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

COUNTY: Broward
OFFICE: Southeast District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 7 Mon. Site No. INT-1	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Continuous	Flow Totalizer
Temperature (F), Water	Sample Measurement										
PARM Code 00011 1 Mon. Site No. EFF-1	Permit Requirement				Report (Mo.Avg.)	Report (Day.Max.)	Deg F			Continuous	Meter
Temperature (F), Water	Sample Measurement										
PARM Code 00011 Q Mon. Site No. INT-1	Permit Requirement				Report (Mo.Avg.)	Report (Day.Max.)	Deg F			Continuous	Meter
Temp. Diff. between Intake and Discharge	Sample Measurement										
PARM Code 61576 1 Mon. Site No. EFF-1	Permit Requirement				13.2 (Mo.Avg.)	Report (Day.Max.)	Deg F			Daily; 24 hours	Calculated
Oxidants, Total Residual	Sample Measurement										
PARM Code 34044 1 Mon. Site No. EFF-1	Permit Requirement				0.20 (Mo.Avg.)	0.20 (Day.Max.)	mg/L			Weekly	Grab
Chlorination Duration	Sample Measurement										
PARM Code 78739 7 Mon. Site No. INT-3	Permit Requirement					1440 (Day.Max.)	min			Daily; 24 hours	Calculated

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: FPL - Lauderdale Power Plant

MONITORING GROUP

I-11A

PERMIT NUMBER: FL0001503-003-IWIS

NUMBER:

MONITORING PERIOD

From: _____

To: _____

[illegible]

ISSUANCE/REISSUANCE DATE:

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER: FL0001503-003-IW1S

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

LIMIT: Final
CLASS SIZE: MA
MONITORING GROUP NUMBER: I-11B
MONITORING GROUP DESCRIPTION: Unit 5 Once-through Cooling Water

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

COUNTY: Broward
OFFICE: Southeast District

RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 7 Mon. Site No. INT-2	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Continuous	Flow Totalizer
Temperature (F), Water	Sample Measurement										
PARM Code 00011 1 Mon. Site No. EFF-2	Permit Requirement					Report (Mo.Avg.)	Report (Day.Max.)	Deg F		Continuous	Meter
Temperature (F), Water	Sample Measurement										
PARM Code 00011 Q Mon. Site No. INT-2	Permit Requirement					Report (Mo.Avg.)	Report (Day.Max.)	Deg F		Continuous	Meter
Temp. Diff. between Intake and Discharge	Sample Measurement										
PARM Code 61576 1 Mon. Site No. EFF-2	Permit Requirement					13.2 (Mo.Avg.)	Report (Day.Max.)	Deg F		Daily; 24 hours	Calculated
Oxidants, Total Residual	Sample Measurement										
PARM Code 34044 1 Mon. Site No. EFF-2	Permit Requirement					0.20 (Mo.Avg.)	0.20 (Day.Max.)	mg/L		Weekly	Grab
Chlorination Duration	Sample Measurement										
PARM Code 78739 7 Mon. Site No. INT-4	Permit Requirement						1440 (Day.Max.)	min		Daily; 24 hours	Meter

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DISCHARGE MONITORING REPORT - PART A (Continued)

FACILITY: FPL - Lauderdale Power Plant

MONITORING GROUP

I-11B

PERMIT NUMBER: FL0001503-003-IW1S

NUMBER:

MONITORING PERIOD

From: _____ To: _____

To: _____

[illegible]

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME:	FPL - Lauderdale Power Plant	PERMIT NUMBER:	FL0001503-003-IW1S
MAILING ADDRESS:	4300 SW 42nd Avenue Fort Lauderdale, FL 33314-	LIMIT:	Final
		CLASS SIZE:	MA
FACILITY:	FPL - Lauderdale Power Plant	MONITORING GROUP NUMBER:	I-16A
LOCATION:	4300 SW 42nd Avenue Fort Lauderdale, FL 33314-	MONITORING GROUP DESCRIPTION:	Unit 4 Heat Recovery Steam Generator (HRSG) Boiler Blowdown
		RE-SUBMITTED DMR:	☐
		NO DISCHARGE FROM SITE:	☐
COUNTY:	Broward	MONITORING PERIOD	From: _____ To: _____
OFFICE:	Southeast District		

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-5	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Monthly	Calculated
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-5	Permit Requirement					15.0 (Mo.Avg.)	20.0 (Day.Max.)	mg/L		Monthly	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-5	Permit Requirement					30.0 (Mo.Avg.)	100.0 (Day.Max.)	mg/L		Monthly	8-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER:

FL0001503-003-IW1S

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD From: _____ To: _____

Final
MA
I-16B
REPORT FREQUENCY: Monthly
PROGRAM: Industrial
Unit 5 Heat Recovery Steam Generator (HRSG) Boiler Blowdown

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

COUNTY: Broward
OFFICE: Southeast District

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-6	Permit Requirement	Report (Mo.Avg.)	Report (Day.Max.)	MGD						Monthly	Calculated
Oil and Grease	Sample Measurement										
PARM Code 00556 1 Mon. Site No. EFF-6	Permit Requirement				15.0 (Mo.Avg.)	20.0 (Day.Max.)		mg/L		Monthly	Grab
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-6	Permit Requirement				30.0 (Mo.Avg.)	100.0 (Day.Max.)		mg/L		Monthly	8-hr FPC

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER: FL0001503-003-IW1S

LIMIT: Final
CLASS SIZE: MA
MONITORING GROUP NUMBER: I-1B2

REPORT FREQUENCY: Monthly
PROGRAM: Industrial

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

MONITORING GROUP DESCRIPTION: Stormwater Runoff from Equipment Area

RE-SUBMITTED DMR: ☐

NO DISCHARGE FROM SITE: ☐

COUNTY: Broward
OFFICE: Southeast District

MONITORING PERIOD From: _____ To: _____

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement										
PARM Code 50050 1 Mon. Site No. EFF-9	Permit Requirement		Report (Day.Max.)	MGD						Weekly, when discharging	Calculated
Solids, Total Suspended	Sample Measurement										
PARM Code 00530 1 Mon. Site No. EFF-9	Permit Requirement					50.0 (Day.Max.)	mg/L			Weekly, when discharging	Grab
pH	Sample Measurement										
PARM Code 00400 1 Mon. Site No. EFF-9	Permit Requirement				6.0 (Day.Min.)	9.0 (Day.Max.)	s.u.			Weekly, when discharging	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

DEPARTMENT OF ENVIRONMENTAL PROTECTION DISCHARGE MONITORING REPORT - PART A

When Completed mail this report to: Department of Environmental Protection, Wastewater Compliance Evaluation Section, MS 3551, 2600 Blair Stone Road, Tallahassee, FL 32399-2400

PERMITTEE NAME: FPL - Lauderdale Power Plant
MAILING ADDRESS: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

PERMIT NUMBER:

FL0001503-003-IW1S

LIMIT:
CLASS SIZE:
MONITORING GROUP NUMBER:
MONITORING GROUP DESCRIPTION:
RE-SUBMITTED DMR: ☐
NO DISCHARGE FROM SITE: ☐
MONITORING PERIOD

Final
MA
I-1B3
REPORT FREQUENCY: Monthly
PROGRAM: Industrial
Stormwater Runoff from Equipment Area and non-Equipment Area

FACILITY: FPL - Lauderdale Power Plant
LOCATION: 4300 SW 42nd Avenue
Fort Lauderdale, FL 33314-

COUNTY: Broward
OFFICE: Southeast District

From: To:

Parameter		Quantity or Loading	Units	Quality or Concentration	Units	No. Ex.	Frequency of Analysis	Sample Type
Flow	Sample Measurement							
PARM Code 50050 1 Mon. Site No. EFF-10	Permit Requirement		Report (Day.Max.)	MGD			Weekly, when discharging	Calculated
Solids, Total Suspended	Sample Measurement							
PARM Code 00530 1 Mon. Site No. EFF-10	Permit Requirement				50.0 (Day.Max.)	mg/L	Weekly, when discharging	Grab
pH	Sample Measurement							
PARM Code 00400 1 Mon. Site No. EFF-10	Permit Requirement			6.0 (Day.Min.)	9.0 (Day.Max.)	s.u.	Weekly, when discharging	Grab

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO	DATE (mm/dd/yyyy)

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here):

ISSUANCE/REISSUANCE DATE:

DEP Form 62-620.910(10), Effective Nov. 29, 1994

INSTRUCTIONS FOR COMPLETING THE WASTEWATER DISCHARGE MONITORING REPORT

Read these instructions before completing the DMR. Hard copies and/or electronic copies of the required parts of the DMR were provided with the permit. All required information shall be completed in full and typed or printed in ink. A signed, original DMR shall be mailed to the address printed on the DMR by the 28th of the month following the monitoring period. The DMR shall not be submitted before the end of the monitoring period.

The DMR consists of three parts--A, B, and D--all of which may or may not be applicable to every facility. Facilities may have one or more Part A's for reporting effluent or reclaimed water data. All domestic wastewater facilities will have a Part B for reporting daily sample results. Part D is used for reporting ground water monitoring well data.

When results are not available, the following codes should be used on parts A and D of the DMR and an explanation provided where appropriate. Note: Codes used on Part B for raw data are different.

CODE	DESCRIPTION/INSTRUCTIONS
ANC	Analysis not conducted.
DRY	Dry Well
FLD	Flood disaster.
IFS	Insufficient flow for sampling.
LS	Lost sample.
MNR	Monitoring not required this period.

CODE	DESCRIPTION/INSTRUCTIONS
NOD	No discharge from/to site.
OPS	Operations were shutdown so no sample could be taken.
OTH	Other. Please enter an explanation of why monitoring data were not available.
SEF	Sampling equipment failure.

When reporting analytical results that fall below a laboratory's reported method detection limits or practical quantification limits, the following instructions should be used:

1. Results greater than or equal to the PQL shall be reported as the measured quantity.
2. Results less than the PQL and greater than or equal to the MDL shall be reported as the laboratory's MDL value. These values shall be deemed equal to the MDL when necessary to calculate an average for that parameter and when determining compliance with permit limits.
3. Results less than the MDL shall be reported by entering a less than sign ("<") followed by the laboratory's MDL value, e.g. < 0.001. A value of one-half the MDL or one-half the effluent limit, whichever is lower, shall be used for that sample when necessary to calculate an average for that parameter. Values less than the MDL are considered to demonstrate compliance with an effluent limitation.

PART A -DISCHARGE MONITORING REPORT (DMR)

Part A of the DMR is comprised of one or more sections, each having its own header information. Facility information is preprinted in the header as well as the monitoring group number, whether the limits and monitoring requirements are interim or final, and the required submittal frequency (e.g. monthly, annually, quarterly, etc.). Submit Part A based on the required reporting frequency in the header and the instructions shown in the permit. The following should be completed by the permittee or authorized representative:

Resubmitted DMR: Check this box if this DMR is being re-submitted because there was information missing from or information that needed correction on a previously submitted DMR. The information that is being revised should be clearly noted on the re-submitted DMR (e.g. highlight, circle, etc.)

No Discharge From Site: Check this box if no discharge occurs and, as a result, there are no data or codes to be entered for all of the parameters on the DMR for the entire monitoring group number; however, if the monitoring group includes other monitoring locations (e.g., influent sampling), the "NOD" code should be used to individually denote those parameters for which there was no discharge.

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Sample Measurement: Before filling in sample measurements in the table, check to see that the data collected correspond to the limit indicated on the DMR (i.e. interim or final) and that the data correspond to the monitoring group number in the header. Enter the data or calculated results for each parameter on this row in the non-shaded area above the limit. Be sure the result being entered corresponds to the appropriate statistical base code (e.g. annual average, monthly average, single sample maximum, etc.) and units.

No. Ex.: Enter the number of sample measurements during the monitoring period that exceeded the permit limit for each parameter in the non-shaded area. If none, enter zero.

Frequency of Analysis: The shaded areas in this column contain the minimum number of times the measurement is required to be made according to the permit. Enter the actual number of times the measurement was made in the space above the shaded area.

Sample Type: The shaded areas in this column contain the type of sample (e.g. grab, composite, continuous) required by the permit. Enter the actual sample type that was taken in the space above the shaded area.

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comment and Explanation of Any Violations: Use this area to explain any exceedances, any upset or by-pass events, or other items which require explanation. If more space is needed, reference all attachments in this area.

PART B - DAILY SAMPLE RESULTS

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Daily Monitoring Results: Transfer all analytical data from your facility's laboratory or a contract laboratory's data sheets for all day(s) that samples were collected. Record the data in the units indicated. Table 1 in Chapter 62-160, F.A.C., contains a complete list of all the data qualifier codes that your laboratory may use when reporting analytical results. However, when transferring numerical results onto Part B of the DMR, only the following data qualifier codes should be used and an explanation provided where appropriate.

CODE	DESCRIPTION/INSTRUCTIONS
<	The compound was analyzed for but not detected.
A	Value reported is the mean (average) of two or more determinations.
J	Estimated value, value not accurate.
Q	Sample held beyond the actual holding time.
Y	Laboratory analysis was from an unpreserved or improperly preserved sample.

To calculate the monthly average, add each reported value to get a total. For flow, divide this total by the number of days in the month. For all other parameters, divide the total by the number of observations.

Plant Staffing: List the name, certificate number, and class of all state certified operators operating the facility during the monitoring period. Use additional sheets as necessary.

PART D - GROUND WATER MONITORING REPORT

Monitoring Period: Enter the month, day, and year for the first and last day of the monitoring period (i.e. the month, the quarter, the year, etc.) during which the data on this report were collected and analyzed.

Date Sample Obtained: Enter the date the sample was taken. Also, check whether or not the well was purged before sampling.

Time Sample Obtained: Enter the time the sample was taken.

Sample Measurement: Record the results of the analysis. If the result was below the minimum detection limit, indicate that.

Detection Limits: Record the detection limits of the analytical methods used.

Analysis Method: Indicate the analytical method used. Record the method number from Chapter 62-160 or Chapter 62-601, F.A.C., or from other sources.

Sampling Equipment Used: Indicate the procedure used to collect the sample (e.g. airlift, bucket/bailer, centrifugal pump, etc.)

Samples Filtered: Indicate whether the sample obtained was filtered by laboratory (L), filtered in field (F), or unfiltered (N).

Signature: This report must be signed in accordance with Rule 62-620.305, F.A.C. Type or print the name and title of the signing official. Include the telephone number where the official may be reached in the event there are questions concerning this report. Enter the date when the report is signed.

Comments and Explanation: Use this space to make any comments on or explanations of results that are unexpected. If more space is needed, reference all attachments in this area.

SPECIAL INSTRUCTIONS FOR LIMITED WET WEATHER DISCHARGES

Flow (Limited Wet Weather Discharge): Enter the measured average flow rate during the period of discharge or divide gallons discharged by duration of discharge (converted into days). Record in million gallons per day (MGD).

Flow (Upstream): Enter the average flow rate in the receiving stream upstream from the point of discharge for the period of discharge. The average flow rate can be calculated based on two measurements; one made at the start and one made at the end of the discharge period. Measurements are to be made at the upstream gauging station described in the permit.

Actual Stream Dilution Ratio: To calculate the Actual Stream Dilution Ratio, divide the average upstream flow rate by the average discharge flow rate. Enter the Actual Stream Dilution Ratio accurate to the nearest 0.1.

No. of Days the SDF > Stream Dilution Ratio: For each day of discharge, compare the minimum Stream Dilution Factor (SDF) from the permit to the calculated Stream Dilution Ratio. On Part B of the DMR, enter an asterisk (*) if the SDF is greater than the Stream Dilution Ratio on any day of discharge. On Part A of the DMR, add up the days with an "*" and record the total number of days the Stream Dilution Factor was greater than the Stream Dilution Ratio.

CBOD₅: Enter the average CBOD₅ of the reclaimed water discharged during the period shown in duration of discharge.

TKN: Enter the average TKN of the reclaimed water discharged during the period shown in duration of discharge.

Actual Rainfall: Enter the actual rainfall for each day on Part B. Enter the actual cumulative rainfall to date for this calendar year and the actual total monthly rainfall on Part A. The cumulative rainfall to date for this calendar year is the total amount of rain, in inches, that has been recorded since January 1 of the current year through the month for which this DMR contains data.

Rainfall During Average Rainfall Year: On Part A, enter the total monthly rainfall during the average rainfall year and the cumulative rainfall for the average rainfall year. The cumulative rainfall for the average rainfall year is the amount of rain, in inches, which fell during the average rainfall year from January through the month for which this DMR contains data.

No. of Days LWWD Activated During Calendar Year: Enter the cumulative number of days that the limited wet weather discharge was activated since January 1 of the current year.

Reason for Discharge: Attach to the DMR a brief explanation of the factors contributing to the need to activate the limited wet weather discharge.