

21 West Church Street
Jacksonville, Florida 32202-3139

September 20, 2010

DEPARTMENT OF
ENVIRONMENTAL PROTECTION

SEP 24 2010



SITING COORDINATION

Mr. Mike Halpin, P.E.
Siting Coordination Office Administrator
Florida Department of Environmental Protection
Siting Coordination Office
3900 Commonwealth Blvd. MS 48
Tallahassee, Florida 32399

E L E C T R I C

W A T E R

S E W E R

RE: JEA - St. Johns River Power Park (SJRPP)
Conditions of Certification PA 81-13
Request for Modification

Dear Mr. Halpin,

On behalf of JEA and SJRPP, I am pleased to submit, for your internal distribution and review, this request for modification of the St. Johns River Power Park Site Certification PA 81-13, in accordance with Chapter 403.516 Florida Statutes and Chapter 61-17.211 Florida Administrative Code (FAC). Also, pursuant to 62-17.293, F.A.C., please find enclosed a check in the amount of \$10,000 for the modification processing fee.

The SJRPP Conditions state that groundwater monitoring is required to be conducted on a quarterly basis. The following is the excerpt from the Conditions:

F. Monitoring and Reporting

6. Minimum Water Level Restrictions

The water quality analyses shall be performed monthly during the year prior to commercial operation and quarterly thereafter. Results shall be submitted to the Department and the SJRWMD by the fifteenth (15th) day of the month following the month during which such analyses were performed.

Quarterly sampling and analysis have been conducted since initial plant operation. The request proposes a reduction of the quarterly sampling and analysis to semi-annually with a submittal date proposed for the thirtieth (30th) day of the month in lieu of the current fifteenth (15th) day of the month.

The following language is offered for your consideration.


F. Monitoring and Reporting

6. Minimum Water Level Restrictions

The water quality analyses shall be performed monthly during the year prior to commercial operation and semi-annually thereafter. Results shall be submitted to the Department and the SJRWMD by the thirtieth (30th) day of the month following the month during which such analyses were performed.

Please do not hesitate to contact me at (904) 665-8729 if you have any questions or require any additional information.

Sincerely,

A handwritten signature in dark ink, appearing to read "Jay Worley", is written over a large, loopy circular mark.

Jay Worley
Director, Environmental Programs

Enclosure: Check - modification fee



21 W. CHURCH STREET
JACKSONVILLE, FLORIDA 32202
(904) 665-6460
Floor - CC6



CHECK NO.

000692788

VOID 90 DAYS FROM DATE

DATE

9/17/2010

63-2
630

CHECK AMOUNT

\$***10,000.00

PAY EXACTLY *Ten thousand and 00/100 Dollars*

PAY TO
THE ORDER
OF

DEPT OF ENVIRONMENTAL PROTECTION
OFFICE OF SITTING COORDINATION
TWIN TOWERS OFFICE BLDG
2600 BLAIR STONE RD
TALLAHASSEE FL 32399-2400

Wachovia Bank, N.A.
Pensacola

Paul E. McElroy
Vice President of Financial Services

LA DeLeon
JEA Managing Director/CEO

⑈000692788⑈ ⑆063210125⑆ 2079940003086⑈

JEA Financial Management Services

INVOICE #	DATE	VOUCHER #	GROSS AMOUNT	DISCOUNT	RETAINAGE	TAXES	NET AMOUNT
090210	9/02/2010	618694	10,000.00				10,000.00