

Table 1
Orlando - Lakeland 230 kv Transmission Line
Lake Agnes to McIntosh Segment

Summary of Proposed Structure Improvements

Structure No.	Structure Type	Proposed Improvement	
		Structure Modification	Comments
Lake Agnes Sub	Sub		
62B	Stl Pole	Replace with Stl. 1-Pole Structure	
62A	Stl Pole	Replace with Stl. 1-Pole Structure	
62	T	Reframe to T-Mod	
61	T	Reframe to T-Mod	
60	MA		
59	T	Reframe to T-Mod	
58	MA		
57	T (3 Pole Conc)		
56	T (3 Pole Conc)		
55	MA (3 Pole Conc)		
54	T (3 Pole Conc)	Replace with Stl. 2-Pole Structure	This portion of the line is to be reconstructed approximately 45 feet south of it's present location.
53	T	Replace with Stl. 2-Pole Structure	
52	T	Replace with Stl. 2-Pole Structure	
51	T	Replace with Stl. 2-Pole Structure	
50	T	Replace with Stl. 2-Pole Structure	
49	T	Replace with Stl. 2-Pole Structure	
48	T	Replace with Stl. 2-Pole Structure	
47	T	Replace with Stl. 2-Pole Structure	
46	T	Replace with Stl. 2-Pole Structure	
45	T	Replace with Stl. 2-Pole Structure	
44	T	Replace with Stl. 2-Pole Structure	
43	T	Replace with Stl. 2-Pole Structure	
42	T	Replace with Stl. 2-Pole Structure	
41	T	Replace with Stl. 2-Pole Structure	
40	T	Replace with Stl. 2-Pole Structure	
39	SA	Replace with Stl. 3-Pole DE Structure	
38	T	Replace with Stl. 2-Pole Structure	
37	T	Replace with Stl. 2-Pole Structure	
36	T	Replace with Stl. 2-Pole Structure	
35	MA	Replace with Stl. 1-Pole Structure	
34	T	Replace with Stl. 2-Pole Structure	
33	LA	Replace with Stl. 1-Pole Structure	
32	SA	Replace with Stl. 1-Pole Structure	
31	SA	Replace with Stl. 1-Pole Structure	
30	SA	Replace with Stl. 1-Pole Structure	
29	SA	Replace with Stl. 1-Pole Structure	
28	SA	Replace with Stl. 1-Pole Structure	
27	SA	Replace with Stl. 1-Pole Structure	

Table 1
Orlando - Lakeland 230 kv Transmission Line
Lake Agnes to McIntosh Segment

Summary of Proposed Structure Improvements

Structure No.	Structure Type	Proposed Improvement	
		Structure Modification	Comments
26	T	Reframe to T-Mod	
25	HA		
24	T	Replace with Std. 2-Pole Structure	Relocate 100 Ft. South
23	T	Reframe to T-Mod	
22	T	Reframe to T-Mod	
21	T	Reframe to T-Mod	
20	T	Reframe to T-Mod and Raise 7 ft.	
19	MA		
18	T	Reframe to T-Mod	
17	MA		
16	T	Reframe to T-Mod	
15	T	Reframe to T-Mod	
14	T	Reframe to T-Mod	
13	T	Reframe to T-Mod	
12	T	Reframe to T-Mod and Raise 7 ft.	
11	T	Reframe to T-Mod and Raise 7 ft.	
10	T	Reframe to T-Mod and Raise 10 ft.	
9	T	Reframe to T-Mod	
8A	T (3 Pole Conc)		
8	HA		
7	STV	Replace Insulator Assemblies	
6	SDE	Replace Insulator Assemblies	
5	STHV	Replace Insulator Assemblies	
4	STHV	Replace Insulator Assemblies	
3	SFA	Replace Insulator Assemblies	Reframe
2	STHVG	Replace Insulator Assemblies	
McIntosh Sub	Sub		