

FORMER ATTACHMENT D



March 17, 2017

Mr. Pawan Kumar Subramanian, PhD.
Florida Department of Environmental Protection
Division of Air Resource Management
Office of Permitting and Compliance
3900 Commonwealth Blvd., Mail Stop 48
Tallahassee, FL 32399
850-245-2001

RE: Compliance Notification for the Quarry-Sugar 500 kV Transmission line.

Dear Mr. Subramanian,

Attached please find a copy of completed DEP forms meeting the requirements of Chapter 62-814 F.A.C., for the above referenced project. The submittal includes the following:

- EMF Notification cover letter
- Location Map
- Transmission Cross-Section Drawing
- EzEMF Report on Compliance.

The proposed start construction date for the Quarry-Sugar 500 kV transmission line is September 1, 2017.

Sincerely,

Heriberto J. Alvarez, PhD, P.E.
EMF Coordinator

TLSA EXEMPTION NOTIFICATION

Florida Power and Light Co.

Quarry-Sugar 500kV

Name of Transmission Line/Substation

Palm Beach, Broward, Dade

Counties

68.5 mi

Length

500 kV

Voltage

September, 01 2017

Anticipated Construction Start Date

EXEMPTION TYPE:
per ch 403 F.S.

☐

Less than 15 miles [403.524(d)]

☐

One County [403.524(d)]

☐

Existing ROW [403.524(c)]

☐

DRI Binding Letter [403.524(b)]

☐

DRI Dev. Order [403.524(a)]

STRUCTURE PROFILE
ATTACHED

☒

Yes

☐

No

LOCATION MAP ATTACHED

☒

Yes

☐

No

EMF NOTIFICATION:

☐

Previously Submitted

☒

Concurrently Submitted

☐


Other (explain)

Other Notes

Submitted By

Phone


Date



EMF Location Sketch

Quarry-Sugar 500kV

Kori Earnhardt 3/17/17 N.T.S.



EMF Cross Section Index
Quarry-Sugar 500kV
Kori Earnhardt 3/17/17 N.T.S.

Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Report on Compliance with Electric and Magnetic Field (EMF) Standards

Agent/Facility Information

Quarry-Sugar 500kV

Name of Transmission Line/InterestPoint

Florida Power and Light Co.

PO Box 14000, Juno Beach, FL 33408-0420

Name and Address of Facility (Utility) Owner

Heriberto J. Alvarez P.E.

PO Box 14000, Juno Beach, FL 33408-0420

Name and Address of Authorized Agent

September 01, 2017

Date of Proposed Construction

Heriberto J. Alvarez P.E.

PO Box 14000, Juno Beach, FL 33408-0420

Name and Address of Professional Engineer

Signature of Authorized Agent

03/17/2017

Date



Signature and Seal of Professional Engineer

03/17/2017

Date

Field Strength Information

Transmission Lines

Cross Section	Right-of-Way (ROW) Width (ft)	Maximum Calculated Fields and Distance From ROW Left					
		Electric				Magnetic	
		Within ROW		At Edge of ROW		At Edge of ROW	
		(kV/m)	(ft)	(kV/m)	(ft)	(mG)	(ft)
CS 2 Proposed	1500					192.7	0
CS 3 Existing	1036	11.4	533				
CS 3 Proposed	1036			2.9	0		

Substations

Substation Name	Maximum Calculated Fields and Distance from Left ROW			
	Electric	Distance	Magnetic	Distance
	(kV/m)	(ft)	(mG)	(ft)
CS 1 Existing	2.94	0	187.1	0
CS 1 Proposed	2.94	0	190.5	0
CS 7 Proposed	1.83	1100	164.0	1100

Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Details for CrossSection: **CS 3_Proposed- Quarry-Sugar 500kV**

QUASUG

Circuit Name

500 kV

Rated Voltage

NEW CIRCUIT

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
4A1	667.70	34.00	45.00	3	1.38	18.00	550.0	0	4215
4B1	633.70	0.00	45.00	3	1.38	18.00	550.0	120	4215
4C1	599.70	-34.00	45.00	3	1.38	18.00	550.0	240	4215
4G1	661.70	28.00	99.00	1	0.38	0.00	0.0	0	0
4G2	605.70	-28.00	99.00	1	0.47	0.00	0.0	0	0

ANDORG

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	117.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
1B1	83.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
1C1	49.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
1G1	111.70	28.00	90.00	1	0.36	0.00	0.0	0	0
1G2	55.70	-28.00	90.00	1	0.36	0.00	0.0	0	0

ANDMAR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
2A1	392.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
2B1	358.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
2C1	324.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
2G1	386.70	28.00	90.00	1	0.36	0.00	0.0	0	0
2G2	330.70	-28.00	90.00	1	0.47	0.00	0.0	0	0

ANDCOR

Circuit Name

500 kV

Rated Voltage


Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
3A1	530.20	34.00	31.00	3	1.22	18.00	550.0	0	3060
3B1	496.20	0.00	31.00	3	1.22	18.00	550.0	120	3060
3C1	462.20	-34.00	31.00	3	1.22	18.00	550.0	240	3060
3G1	524.20	28.00	90.00	1	0.36	0.00	0.0	0	0
3G2	468.20	-28.00	90.00	1	0.36	0.00	0.0	0	0

Points of Interest

None



Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Details for CrossSection: CS 3_Existing- Quarry-Sugar 500kV

ANDORG

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	117.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
1B1	83.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
1C1	49.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
1G1	111.70	28.00	90.00	1	0.36	0.00	0.0	0	0
1G2	55.70	-28.00	90.00	1	0.36	0.00	0.0	0	0

ANDMAR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
2A1	392.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
2B1	358.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
2C1	324.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
2G1	386.70	28.00	90.00	1	0.36	0.00	0.0	0	0
2G2	330.70	-28.00	90.00	1	0.47	0.00	0.0	0	0

ANDCOR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
3A1	530.20	34.00	31.00	3	1.22	18.00	550.0	0	3060
3B1	496.20	0.00	31.00	3	1.22	18.00	550.0	120	3060
3C1	462.20	-34.00	31.00	3	1.22	18.00	550.0	240	3060
3G1	524.20	28.00	90.00	1	0.36	0.00	0.0	0	0
3G2	468.20	-28.00	90.00	1	0.36	0.00	0.0	0	0

Points of Interest

None

Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400



Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Details for CrossSection: **CS 2_Proposed- Quarry-Sugar 500kV**

QUASUG

Circuit Name

500 kV

Rated Voltage

NEW CIRCUIT

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
3A1	422.00	34.00	40.00	3	1.38	18.00	550.0	0	4215
3B1	388.00	0.00	40.00	3	1.38	18.00	550.0	120	4215
3C1	354.00	-34.00	40.00	3	1.38	18.00	550.0	240	4215
3G1	416.00	28.00	94.00	1	0.38	0.00	0.0	0	0
3G2	360.00	-28.00	94.00	1	0.47	0.00	0.0	0	0

ANDMAR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	120.00	34.00	31.00	3	1.22	18.00	550.0	0	3060
1B1	86.00	0.00	31.00	3	1.22	18.00	550.0	120	3060
1C1	52.00	-34.00	31.00	3	1.22	18.00	550.0	240	3060
1G1	114.00	28.00	90.00	1	0.36	0.00	0.0	0	0
1G2	58.00	-28.00	90.00	1	0.36	0.00	0.0	0	0

ANDCOR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
2A1	284.00	34.00	31.00	3	1.22	18.00	550.0	0	3060
2B1	250.00	0.00	31.00	3	1.22	18.00	550.0	120	3060
2C1	216.00	-34.00	31.00	3	1.22	18.00	550.0	240	3060
2G1	278.00	28.00	90.00	1	0.36	0.00	0.0	0	0
2G2	222.00	-28.00	90.00	1	0.36	0.00	0.0	0	0

Points of Interest

None

Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400



Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Details for CrossSection: CS 2_Existing- Quarry-Sugar 500kV

ANDMAR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	120.00	34.00	31.00	3	1.22	18.00	550.0	0	3060
1B1	86.00	0.00	31.00	3	1.22	18.00	550.0	120	3060
1C1	52.00	-34.00	31.00	3	1.22	18.00	550.0	240	3060
1G1	114.00	28.00	90.00	1	0.36	0.00	0.0	0	0
1G2	58.00	-28.00	90.00	1	0.36	0.00	0.0	0	0

ANDCOR

Circuit Name

500 kV

Rated Voltage


Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
2A1	284.00	34.00	31.00	3	1.22	18.00	550.0	0	3060
2B1	250.00	0.00	31.00	3	1.22	18.00	550.0	120	3060
2C1	216.00	-34.00	31.00	3	1.22	18.00	550.0	240	3060
2G1	278.00	28.00	90.00	1	0.36	0.00	0.0	0	0
2G2	222.00	-28.00	90.00	1	0.36	0.00	0.0	0	0

Points of Interest

None



Details for CrossSection: **CS 4_Proposed- Quarry-Sugar 500kV**

QUASUG
Circuit Name

500 kV
Rated Voltage

NEW CIRCUIT
New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	134.00	34.00	35.00	3	1.38	18.00	550.0	0	4215
1B1	100.00	0.00	35.00	3	1.38	18.00	550.0	120	4215
1C1	66.00	-34.00	35.00	3	1.38	18.00	550.0	240	4215
1G1	128.00	28.00	89.00	1	0.38	0.00	0.0	0	0
1G2	72.00	-28.00	89.00	1	0.47	0.00	0.0	0	0

Points of Interest

None

Phase Configuration

All Measurements in Feet



Details for CrossSection: **CS 5_Proposed- Quarry-Sugar**

QUA-SUG
Circuit Name

500 kV
Rated Voltage

NEW CIRCUIT
New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	184.00	34.00	35.00	3	1.38	18.00	550.0	0	4215
1B1	150.00	0.00	35.00	3	1.38	18.00	550.0	120	4215
1C1	116.00	-34.00	35.00	3	1.38	18.00	550.0	240	4215
1G1	178.00	28.00	89.00	1	0.38	0.00	0.0	0	0
1G2	122.00	-28.00	89.00	1	0.38	0.00	0.0	0	0

Points of Interest

None

Phase Configuration

All Measurements in Feet



Details for CrossSection: **CS 6_Proposed- Quarry-Sugar 500kV**

QUASUG
Circuit Name

500 kV
Rated Voltage

NEW CIRCUIT
New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	134.00	34.00	35.00	3	1.38	18.00	550.0	0	4215
1B1	100.00	0.00	35.00	3	1.38	18.00	550.0	120	4215
1C1	66.00	-34.00	35.00	3	1.38	18.00	550.0	240	4215
1G1	128.00	28.00	89.00	1	0.38	0.00	0.0	0	0
1G2	72.00	-28.00	89.00	1	0.47	0.00	0.0	0	0

Points of Interest

None

Phase Configuration

All Measurements in Feet



Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Details for CrossSection: CS 1_Existing- Sugar Sub

ANDORG

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	117.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
1B1	83.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
1C1	49.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
1G1	111.70	28.00	90.00	1	0.36	0.00	0.0	0	0
1G2	55.70	-28.00	90.00	1	0.36	0.00	0.0	0	0

ANDMAR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
2A1	392.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
2B1	358.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
2C1	324.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
2G1	386.70	28.00	90.00	1	0.36	0.00	0.0	0	0
2G2	330.70	-28.00	90.00	1	0.47	0.00	0.0	0	0

ANDCOR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
3A1	530.20	34.00	31.00	3	1.22	18.00	550.0	0	3060
3B1	496.20	0.00	31.00	3	1.22	18.00	550.0	120	3060
3C1	462.20	-34.00	31.00	3	1.22	18.00	550.0	240	3060
3G1	524.20	28.00	90.00	1	0.36	0.00	0.0	0	0
3G2	468.20	-28.00	90.00	1	0.36	0.00	0.0	0	0

Points of Interest

None

Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400



Florida Department of Environmental Protection

Twin Tower Office Bldg * 2600 Blair Stone Road * Tallahassee, Florida 32399-2400

Details for CrossSection: **CS 1_Proposed- Sugar Sub**

QUASUG

Circuit Name

500 kV

Rated Voltage

NEW CIRCUIT

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
4A1	667.70	34.00	45.00	3	1.38	18.00	550.0	0	4215
4B1	633.70	0.00	45.00	3	1.38	18.00	550.0	120	4215
4C1	599.70	-34.00	45.00	3	1.38	18.00	550.0	240	4215
4G1	661.70	28.00	99.00	1	0.38	0.00	0.0	0	0
4G2	605.70	-28.00	99.00	1	0.47	0.00	0.0	0	0

ANDORG

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	117.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
1B1	83.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
1C1	49.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
1G1	111.70	28.00	90.00	1	0.36	0.00	0.0	0	0
1G2	55.70	-28.00	90.00	1	0.36	0.00	0.0	0	0

ANDMAR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
2A1	392.70	34.00	31.00	3	1.22	18.00	550.0	0	3060
2B1	358.70	0.00	31.00	3	1.22	18.00	550.0	120	3060
2C1	324.70	-34.00	31.00	3	1.22	18.00	550.0	240	3060
2G1	386.70	28.00	90.00	1	0.36	0.00	0.0	0	0
2G2	330.70	-28.00	90.00	1	0.47	0.00	0.0	0	0

ANDCOR

Circuit Name

500 kV

Rated Voltage

Existing Circuit

New/Existing


Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
3A1	530.20	34.00	31.00	3	1.22	18.00	550.0	0	3060
3B1	496.20	0.00	31.00	3	1.22	18.00	550.0	120	3060
3C1	462.20	-34.00	31.00	3	1.22	18.00	550.0	240	3060
3G1	524.20	28.00	90.00	1	0.36	0.00	0.0	0	0
3G2	468.20	-28.00	90.00	1	0.36	0.00	0.0	0	0

Points of Interest

None

Phase Configuration

All Measurements in Feet



Details for CrossSection: **CS 7_Proposed- Quarry Sub**

QUA-SUG
Circuit Name

500 kV
Rated Voltage

NEW CIRCUIT
New/Existing

Id	Dist From Left ROW (ft)	Dist From Circuit CL (ft)	Minimum Height (ft)	SubConductors			Maximum Voltage (kV)	Angle (Degrees)	MCR (Amps)
				# of	Diameter (in)	Spacing (in)			
1A1	966.00	-34.00	35.00	3	1.38	18.00	550.0	0	4215
1B1	1000.00	0.00	35.00	3	1.38	18.00	550.0	120	4215
1C1	1034.00	34.00	35.00	3	1.38	18.00	550.0	240	4215
1G1	1028.00	28.00	89.00	1	0.38	0.00	0.0	0	0
1G2	972.00	-28.00	89.00	1	0.47	0.00	0.0	0	0

Points of Interest

None




TABLE 1
MAXIMUM EMF CAPABLE OF BEING PRODUCED BY THE
TRANSMISSION LINE FOR QUARRY-SUGAR 500KV

Cross-Section Location*		Ampacity of New Line(s) (amps)	Right- of-Way Width (ft)	Electric Field (kV/m)			Magnetic Field (mG)	
				On Right-of- Way	Left Edge† of Right-of- Way	Right Edge† of Right-of- Way	Left Edge† of Right-of- Way	Right Edge† of Right-of- Way
<u>Quarry-Sugar 500-kV</u>								
C1	Sugar Substation property	4,215	2335	11.33	2.94	0	190.48	1.45
C2	State Road 80 to Terrytown	4,215	500	11.37	2.76	0	192.70	2.66
C3	Terrytown to I-75	4,215	660	11.33	2.94	0.05	190.48	17.97
C4	I-75 to Krome Avenue	4,215	200	9.43	1.83	1.83	164.04	164.04
C5	Krome Avenue	4,215	300	9.43	0.55	0.55	73.09	73.09
C6	Krome Avenue to Quarry Substation	4,215	200	9.43	1.83	1.83	164.04	164.04
C7	Quarry Substation property	4,215	1,100	9.43	0	1.83	1.63	164.04
Florida EMF rule limit for new 500-kV lines‡				10.0	2.0	2.0	200	200
Florida EMF rule limit for AND-ORA; AND-MAR, MAR-MID ROWs				10.0	2.0	2.0	250	250
Existing EMF for QUA-SUG ROW				11.4	2.94	2.94	187.1	187.1

Note: mG = milliGauss.

The field levels of the proposed transmission lines shown in this table are based on the highest fields anticipated for the 500/230-kV transmission line configurations, even though structural configurations with lower fields may be employed for some portions of the line routes. The transmission lines will generally operate at a level well under the MCR.

*Locations depicted on Cross Section Index.

†The “left” and “right” designations are as shown in EMF Cross Sections CS-1 through CS7.

‡The field limits are established in Rule 62-814.450(2), F.A.C.

Source: EzEmf software program developed through Florida Electric Power Coordinating Group and accepted by FDEP.

Revised March 17, 2017




NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG

EMF Cross Section #1 (CS 1)
Quarry-Sugar 500kV
T-17431 Phase 1: Sugar-Terrytown
Kori Earnhardt 3/17/17 N.T.S.

EXISTING
ANDYTOWN-MARTIN 500KV
LINE
Tri-Bndl 1127 AAAC 3060
AMPS @75°C
(2) 3/8" OHGW

EXISTING
ANDYTOWN-CORBETT
500KV LINE
Tri-Bndl 1127 AAAC 3060
AMPS @75°C
(2) 3/8" OHGW

PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW



EXISTING 2335.0' WIDE R/W SUGAR SUBSTATION PROPERTY (LOOKING NORTH)




NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG

EMF Cross Section #2 (CS 2)
Quarry-Sugar 500kV
T-17431 Phase 1: Sugar-Terrytown
Kori Earnhardt 3/17/17 N.T.S.

EXISTING
ANDYTOWN-MARTIN 500KV
LINE
Tri-Bndl 1127 AAAC 3060
AMPS @75°C
(2) 3/8" OHGW

EXISTING
ANDYTOWN-CORBETT
500KV LINE
Tri-Bndl 1127 AAAC 3060
AMPS @75°C
(2) 3/8" OHGW

PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW



EXISTING 500' WIDE R/W BETWEEN STATE ROAD 80 AND TERRYTOWN (LOOKING NORTH)



NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG


EMF Cross Section #3 (CS 3)
Quarry-Sugar 500kV
T-17432 Phase 2: Terrytown- I-75
Kori Earnhardt 3/17/17 N.T.S.

EXISTING
ANDYTOWN-
ORANGE RIVER
500KV LINE
Tri-Bndl 1127 AAAC
3060 AMPS @75°C
(2) 3/8" OHGW

EXISTING
ANDYTOWN-
MARTIN 500KV LINE
Tri-Bndl 1127 AAAC
3060 AMPS @75°C
(2) 3/8" OHGW

EXISTING
ANDYTOWN-CORBETT
500KV LINE
Tri-Bndl 1127 AAAC
3060 AMPS @75°C
(2) 3/8" OHGW

PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW




EXISTING 660' WIDE R/W BETWEEN TERRYTOWN AND I-75 (LOOKING NORTH)



NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG

EMF Cross Section #4 (CS 4)
Quarry-Sugar 500kV
T-17433 Phase 3: I-75-Quarry
Kori Earnhardt 3/17/17 N.T.S.

PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW




200' WIDE R/W BETWEEN I-75 AND KROME AVE (LOOKING NORTH)



NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG

PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW

EMF Cross Section #5 (CS 5)
Quarry-Sugar 500kV
T-17433 Phase 3: I-75-Quarry
Kori Earnhardt 3/17/17 N.T.S.




300' WIDE R/W KROME AVE (LOOKING NORTH)

NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG


EMF Cross Section #6 (CS 6)
Quarry-Sugar 500kV
T-17433 Phase 3: I-75-Quarry
Kori Earnhardt 3/17/17 N.T.S.

PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW




200' WIDE R/W BETWEEN KROME AVE AND QUARRY SUB (LOOKING NORTH)

NOTE: ALL HEIGHTS ARE AT MIDSPAN AND CONDUCTOR SHOWN MAXIMUM SAG



PROPOSED
QUARRY-SUGAR 500KV LINE
Tri-Bndl 1272 ACSR/AW
4215 AMPS
(1) 7#8 OHGW
(1) 0.472 OPGW

EMF Cross Section #7 (CS 7)
Quarry-Sugar 500kV
T-17433 Phase 3: I-75-Quarry
Kori Earnhardt 3/17/17 N.T.S.



1100' WIDE R/W QUARRY SUBSTATION PROPERTY (LOOKING WEST)