

BEFORE THE STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

IN RE:)
)
Gainesville Regional Utilities)
Deerhaven Generating Station #2)
Modification of Terms and)
Conditions of Certification)
NO. PA 74-04)
Alachua County, Florida)
)

FINAL ORDER MODIFYING
CONDITIONS OF CERTIFICATION

The Florida Department of Environmental Regulation modifies the conditions of certification for the Gainesville Regional Utilities' Deerhaven Generating Station Unit 2, pursuant to Section 403.516(1), Florida Statutes, and Section VII of the Conditions of Certification, which delegated modifications of monitoring conditions to the Department. The Department states:

1. On June 24, and July 21, 1986, the Gainesville Regional Utilities submitted a letter to the Department requesting modification of the existing Conditions of Certification for its Deerhaven Unit 2 to delete certain conditions relating to ambient air quality monitoring and to modify a condition to allow use of natural gas as fuel for startup and flame stabilization.

2. On September 19, 1986, a Notice of Proposed Agency Action was served on all parties with a provision that a hearing would be held if requested on or before November 5, 1986. No hearing was requested. THEREFORE,

IT IS ORDERED:

The Department grants relief to the Gainesville Regional Utilities by making the following modifications to the Conditions of Certification:

A. Special Conditions I.B.2. and I.B.5. shall be deleted and the remaining conditions rearranged to read as follows:

~~2.-The-permittee-shall-provide-one-additional-ambient-mon-~~
~~itoring-device-for-sulfur-dioxide-in-accordance-with-EPA-reference~~
~~methods-in-40-CFR, Part-53, and one-additional-ambient-monitoring~~
~~device-for-suspended-particulates.--New-and-existing-monitoring~~

~~devices shall be located as designated by the Department, and may be operated by the Alachua County Pollution Control Department. The frequency of operation shall be every six days as specified by the Department.~~

2. 3- The permittee shall maintain a daily log of fuels used and copies of fuel analyses containing information on sulfur content, ash content and heating values to facilitate calculations of emissions.

3. 4- The permittee shall provide sampling ports into the stack and shall provide access to the sampling ports, in accordance with Standard Sampling Techniques and Methods of Analysis for the Determination of Air Pollutants from Point Source, July 1975.

~~5. --The ambient monitoring program may be reviewed annually beginning two years after start-up of Unit No. 2 by the Department and the permittee.~~

5. 6- Emission Control Systems:

B. Special Condition I.D.1. shall be amended to read as follows:

D. Reporting

1. Stack monitoring, fuel usage and fuel analysis data shall be reported to the Department on a quarterly basis in accordance with 40 CFR, Part 60, Section 60.7. Such reporting shall include amounts of number 2 oil and natural gas used for start-up or flame stabilization.


C. Special Condition I.D.2. shall be deleted.

~~2. --Ambient air monitoring data shall be reported to the Department quarterly by the last day of the month following the quarterly reporting period utilizing the SAROAD or other format approved by the Department in writing.~~

Any party to this Order has the right to seek judicial review of the Order pursuant to Section 120.68, Florida Statutes by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date this Order is filed with the clerk of the Department.

DONE AND ORDERED this 27th day of January, 1987, in Tallahassee, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION



DALE TWACHTMANN
SECRETARY

FILING AND ACKNOWLEDGEMENT

FILED on this date pursuant to S120.52
in the Office of the designated Clerk.
The Clerk of which is hereby acknow-
ledged.

Mary L. Wilson 1-27-87
Clerk Date

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
Telephone: (904) 488-4805

CERTIFICATE OF SERVICE

I HEREBY CERTIFY that copies of the foregoing NOTICE OF PROPOSED AGENCY ACTION were furnished by United States Mail to all counsel of record listed on the attached service list, on this 27th day of September, 1987.

Bradford L. Thomas
BRADFORD L. THOMAS
Assistant General Counsel

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL REGULATION

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400
Telephone: (904) 488-9730

Copies furnished:

Mr. Michael Twomey, Esquire
Public Service Commission
Fletcher Building
101 East Gaines Street
Tallahassee, Florida 32301

Mr. C. Laurence Keeseey, Esquire
Department of Community Affairs
Howard Building
2571 Executive Center Circle East
Tallahassee, Florida 32301

Mr. Charles McCoy, Esquire
Attorney for the Department of Natural Resources/
Board of Trustees of the Internal Improvement Fund
3900 Commonwealth Boulevard
Tallahassee, Florida 32301

Mr. Tom W. Brown, Esquire
Suwannee River Water Management District
Post Office Box 1029
Lake City, Florida 32055

Mrs. Helen Hood, Chairperson
Parks and Endangered Lands Committtee
Florida Defenders of the Environment, Inc.
622 North Main Street
Gainesville, Florida 32604

Mr. Robert L. Guyer
Gainesville Regional Utilities
Post Office Box 490
Gainesville, Florida 32602